

## **SRP 6.2.2 CHANGES**

### Review Responsibilities

1. Responsible branch is Probabilistic Safety Assessment Branch (SPSB)

### Areas of Review

2. I.G The Technical Specifications Branch has been changed to the Reactor Operations Branch (IROB)

### Acceptance Criteria

3. II.C.1 Added the word “in”: This is in conformance with the requirements of GDC 38.
4. II.C.2 Changed NPSH guidance to refer to RG 1.82 Revision 4.
5. II.C.2 Detailed discussion of acceptable temperature and pressure is deleted since it is included in the referenced Regulatory Guide 1.82 Revision 4.
6. II.C.6 Replaced the word “core” with “containment”. The core spray system is a BWR system which is included in the BWR ECCS.

### Review Procedures

7. III.2.c Removed the word “to”.
8. III.3 Regulatory Guide reference changed to Regulatory Guide 1.82 Revision 4.
9. III.3 Discussion of requirements is deleted since it is included, in a revised form, in Regulatory Guide 1.82 Revision 4.
10. III.4, III.5, III.6 Deleted since the guidance is contained in Regulatory Guide 1.82 Revision 4.
11. III.11.a.iv Replace “sucked” with “swept”
12. III.11.a.v Specify Regulatory Guide 1.82 Revision 4
13. III.11 Specify that SRP Section 14.3 is “draft” not “proposed”

### Evaluation Findings

14. Evaluation/Findings 1. Delete reference to Regulatory Guide 1.1 and specify Regulatory Guide 1.82 Revision 4

### References

15. References. Delete References 4 and 8