

From: <Terrill.Garland@kidde-fenwal.com>
To: "Jonathan Rivera" <JXR4@nrc.gov>
Date: 4/11/05 10:31AM
Subject: Re: SSD review for new Model No. 7054, Certificate No. NR-668-D-101-E

Jonathan,

I received the following remaining information from our manufacturer in Japan, concerning the JRIA test:

Type: S-1371A
Window Thickness: 100 micro meter (beryllium window)
Sensitivity: Counting Efficiency 24%
Condition: At ordinary room temperature (25C 50% Relative Humidity)

I believe this answers all of the remaining questions you had asked, concerning the SSD review for our Models CPD-7054 and CPD-7054D.

Please let me know if there is any additional info. you need from me to complete this review.

Regards,

Terry Garland
Manager, D&A Project Development
Kidde-Fenwal, Inc.

Tel: (508) 881-2000 Ext. 2364
Fax: (508) 231-2015
e-mail: Terrill.Garland@kidde-fenwal.com

The information contained in this message or any of its attachments may be privileged and confidential and intended for the exclusive use of the addressee. Any views or opinions expressed in this e-mail are those of the individual and not necessarily of Kidde plc. If you are not the intended recipient, any disclosure, reproduction, distribution or other dissemination or use of this communications is strictly prohibited. If you have received this transmission in error, please contact the IT Help Desk on +44 (0) 1753 766380.

CC: "John Jankovich" <JPJ2@nrc.gov>

Mail Envelope Properties (425A8A30.C00 : 1 : 7168)

Subject: Re: SSD review for new Model No. 7054, Certificate No. NR-668-D-101-E
Creation Date: 4/11/05 10:34AM
From: <Terrill.Garland@kidde-fenwal.com>
Created By: Terrill.Garland@kidde-fenwal.com

Recipients

nrc.gov
twf4_po.TWFN_DO
JPJ2 CC (John Jankovich)
JXR4 (Jonathan Rivera)

Post Office

twf4_po.TWFN_DO

Route

nrc.gov

Files

MESSAGE
Mime.822

Size

1227
1901

Date & Time

04/11/05 10:34AM

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard