

May 5, 2005

MEMORANDUM TO: Michael L. Marshall, Jr., Chief, Section 2
Project Directorate II
Division of Licensing Project Management

FROM: Brendan T. Moroney, Project Manager, Section 2 */RA/*
Project Directorate II
Division of Licensing Project Management

SUBJECT: FORTHCOMING MEETING WITH FLORIDA POWER
AND LIGHT COMPANY

DATE & TIME: Wednesday, May 18, 2005
1:00 p.m. - 4:00 p.m.

LOCATION: U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike, Room O-9B4
Rockville, Maryland

PURPOSE: Florida Power and Light Company (FPL) will discuss a proposed increase
in the steam generator tube plugging limit at St. Lucie Unit 2 and related
licensing actions.

CATEGORY 1: * This is a Category 1 Meeting. The public is invited to observe this
meeting and will have one or more opportunities to communicate with the
NRC after the business portion, but before the meeting is adjourned.

PARTICIPANTS: Participants from the NRC include members of the Office of Nuclear
Reactor Regulation (NRR).

<u>NRC</u>	<u>FPL</u>
W. Bateman, NRR	R. Kundalkar
K. Karwoski, NRR	C. Villard
S. Sun, NRR	J. Kabadi
et al.	et al.

Docket No. 50-389

MEETING CONTACTS: Brendan Moroney, NRR Jose Arroyo, NRR
301-415-3974 301-415-2149
btm3@nrc.gov jxa1@nrc.gov

* Commission's Policy Statement on "Enhancing Public Participation in NRC Meetings"
(67 FR 36920), May 28, 2002

Attachment: Agenda

cc w/att: See next page

Florida Power and Light Company

cc:

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

Senior Resident Inspector
St. Lucie Plant
U.S. Nuclear Regulatory Commission
P.O. Box 6090
Jensen Beach, Florida 34957

Craig Fugate, Director
Division of Emergency Preparedness
Department of Community Affairs
2740 Centerview Drive
Tallahassee, Florida 32399-2100

M. S. Ross, Managing Attorney
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Marjan Mashhadi, Senior Attorney
Florida Power & Light Company
801 Pennsylvania Avenue, NW.
Suite 220
Washington, DC 20004

Mr. Douglas Anderson
County Administrator
St. Lucie County
2300 Virginia Avenue
Fort Pierce, Florida 34982

Mr. William A. Passetti, Chief
Department of Health
Bureau of Radiation Control
2020 Capital Circle, SE, Bin #C21
Tallahassee, Florida 32399-1741

ST. LUCIE PLANT

Mr. William Jefferson, Jr.
Site Vice President
St. Lucie Nuclear Plant
6351 South Ocean Drive
Jensen Beach, Florida 34957

Mr. G. L. Johnston
Plant General Manager
St. Lucie Nuclear Plant
6351 South Ocean Drive
Jensen Beach, Florida 34957

Mr. Terry L. Patterson
Licensing Manager
St. Lucie Nuclear Plant
6351 South Ocean Drive
Jensen Beach, Florida 34957

David Moore, Vice President
Nuclear Operations Support
Florida Power and Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Mr. Rajiv S. Kundalkar
Vice President - Nuclear Engineering
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Mr. J. Kammel
Radiological Emergency
Planning Administrator
Department of Public Safety
6000 Southeast Tower Drive
Stuart, Florida 34997

May 5, 2005

MEMORANDUM TO: Michael L. Marshall, Jr., Chief, Section 2
Project Directorate II
Division of Licensing Project Management

FROM: Brendan T. Moroney, Project Manager, Section 2 */RA/*
Project Directorate II
Division of Licensing Project Management

SUBJECT: FORTHCOMING MEETING WITH FLORIDA POWER
AND LIGHT COMPANY

DATE & TIME: Wednesday, May 18, 2005
1:00 p.m. - 4:00 p.m.

LOCATION: U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike, Room O-9B4
Rockville, Maryland

PURPOSE: Florida Power and Light Company (FPL) will discuss a proposed increase in the steam generator tube plugging limit at St. Lucie Unit 2 and related licensing actions.

CATEGORY 1: * This is a Category 1 Meeting. The public is invited to observe this meeting and will have one or more opportunities to communicate with the NRC after the business portion, but before the meeting is adjourned.

PARTICIPANTS: Participants from the NRC include members of the Office of Nuclear Reactor Regulation (NRR).

<u>NRC</u>	<u>FPL</u>
W. Bateman, NRR	R. Kundalkar
K. Karwoski, NRR	C. Villard
S. Sun, NRR	J. Kabadi
et al.	et al.

Docket No. 50-389

MEETING CONTACTS:	Brendan Moroney, NRR	Jose Arroyo, NRR
	301-415-3974	301-415-2149
	btm3@nrc.gov	jxa1@nrc.gov

* Commission's Policy Statement on "Enhancing Public Participation in NRC Meetings," (67 FR 36920), May 28, 2002

Attachment: Agenda

cc w/att: See next page

Distribution: See next page

ADAMS Accession No.: ML051240502

NRC-001

OFFICE	PM:PDII-2	LA:PDII-2	SC:PDII-2
NAME	BMoroney	BClayton	MMarshall
DATE	05/ 05 /05	05/ 05 /05	05/ 05 /05

OFFICIAL RECORD COPY

SUBJECT: FORTHCOMING MEETING WITH FLORIDA POWER AND LIGHT COMPANY

DATE: May 5, 2005

Distribution:

PUBLIC
PDII-2 r/f
BMoroney
JArroyo
BClayton
SSun
JNakoski
MMarshall
EHackett
LMarsh
MMayfield
WBateman
TJKim
KKarwoski
PKlein
LMiller
EMurphy
SBlack
JWermiel
PClifford
MBlumberg
RJasinski
TMensah
JJolicouer
RidsNrrAdpt
OPA Mail
OGC Mail
ACRS
PMNS
Rgn2MailCtr
OWFN/TWFN

Agenda for May 18 Meeting With Florida Power & Light

1. Need for NRC review and approval to increase steam generator tube plugging limit above 30 percent
2. Approach to submittal:
 - a. Consistent with safety evaluation (SE) for Amendment 138 that authorized 30 percent limit
 - b. Safety Analyses (LOCA, non-LOCA, fuel)
 - c. Containment Peak Pressure Analysis
 - d. Evaluation of Radiological Consequences (Consistent with Amendment 138 SE)
3. Proposed changes to the Technical Specifications
4. Identification of NRC emergent issues since Amendment 138 that should be considered in the analytical work supporting the proposed submittal
5. Schedule for St. Lucie submittal and NRC approval
6. Feedback on ways to facilitate NRC review