

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.3.3.1.1 Perform CHANNEL CHECK.	31 days
SR 3.3.3.1.2 Deleted.	
SR 3.3.3.1.3 Perform CHANNEL CALIBRATION.	24 months

Table 3.3.3.1-1 (page 1 of 1)  
Post Accident Monitoring Instrumentation

FUNCTION	REQUIRED CHANNELS	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1
1. Reactor Steam Dome Pressure	2	E
2. Reactor Vessel Water Level-Wide Range	2	E
3. Reactor Vessel Water Level-Fuel Zone	2	E
4. Suppression Pool Water Level	2	E
5. Suppression Pool Sector Water Temperature	2(c)	E
6. Drywell Pressure	2	E
7. Drywell Air Temperature	2	E
8. Primary Containment/Drywell Area Gross Gamma Radiation Monitors	2	F
9. Penetration Flow Path, PCIV Position	2 per penetration flow path (a)(b)	E
10. Deleted		
11. Primary Containment Pressure	2	E
12. Primary Containment Air Temperature	2	E

(a) Not required for isolation valves whose associated penetration flow path is isolated.

(b) Only one position indication channel is required for penetration flow paths with only one installed control room indication channel.

(c) Monitoring each of eight sectors.

# SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.2.4.1	<p>Verify upper containment pool water level is:</p> <p>a. <math>\geq 22</math> ft 9 inches above the reactor pressure vessel (RPV) flange.</p> <p><u>OR</u></p> <p>b. <math>\geq 22</math> ft 5 inches above the RPV flange, and suppression pool water level <math>\geq 17</math> ft 11.7 inches.</p>	24 hours
SR 3.6.2.4.2	Verify upper containment pool water temperature is $\leq 110^{\circ}\text{F}$ .	24 hours
SR 3.6.2.4.3	Verify each SPMU subsystem manual, power operated, and automatic valve that is not locked, sealed, or otherwise secured in position is in the correct position.	31 days
SR 3.6.2.4.4	Verify all required upper containment pool gates are in the stored position or are otherwise removed from the upper containment pool.	31 days
SR 3.6.2.4.5	<p>-----NOTE-----</p> <p>Actual makeup to the suppression pool may be excluded.</p> <p>-----</p> <p>Verify each SPMU subsystem automatic valve actuates to the correct position on an actual or simulated automatic initiation signal.</p>	24 months