

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.3.3.1.1 -----NOTE----- Applicable for each Function in Table 3.3.3.1-1. ----- Perform CHANNEL CHECK.	31 days
SR 3.3.3.1.2 Deleted	
SR 3.3.3.1.3 -----NOTE----- Applicable for each Function in Table 3.3.3.1-1. ----- Perform CHANNEL CALIBRATION.	18 months

Table 3.3.3.1-1 (page 1 of 1)
Post Accident Monitoring Instrumentation

FUNCTION	REQUIRED CHANNELS	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1
1. Reactor Steam Dome Pressure	2	E
2. Reactor Vessel Water Level	2	E
3. Suppression Pool Water Level		
a. High Range	2	E
b. Low Range	2	E
4. Drywell Pressure	2	E
5. Primary Containment Area Radiation	2	F
6. Drywell Area Radiation	2	F
7. Penetration Flow Path, Automatic PCIV Position	2 per penetration flow path ^(a) ^(b)	E
8. Deleted		
9. Primary Containment Pressure		
a. High Range	2	E
b. Low Range	2	E
10. Suppression Pool Water Bulk Average Temperature	2 ^(c)	E

(a) Not required for isolation valves whose associated penetration flow path is isolated.

(b) Only one position indication channel is required for penetration flow paths with only one installed control room indication channel.

(c) Monitoring each quadrant.

3.6.3.1

3.6 CONTAINMENT SYSTEMS

3.6.3.1 Deleted

This page intentionally blank