



Entergy Operations, Inc.
1448 S.R. 333
Russellville, AR 72802
Tel 501 858 5000

2CAN050503

May 2, 2005

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: License Renewal Clarification
TAC No. MB8402
Arkansas Nuclear One – Unit 2
Docket No. 50-368
License No. NPF-6

Dear Sir or Madam:

Section B.1.4 of the Arkansas Nuclear One, Unit 2 (ANO-2) License Renewal Application describes the Buried Piping Inspection Program. With respect to the ANO-2 Buried Piping Inspection Program upon entering the period of extended operation, Entergy will perform an inspection within ten years, unless an opportunistic inspection occurred within this ten-year period.

The new commitment contained in this submittal is summarized in the attachment. Should you have any questions concerning this submittal, please contact Ms. Natalie Mosher at (479) 858-4635.

I declare under penalty of perjury that the foregoing is true and correct. Executed on May 2, 2005.

Sincerely,

A handwritten signature in black ink, appearing to read "Dale E. James", with a long horizontal flourish extending to the right.

Dale E. James
Acting Director, Nuclear Safety Assurance

DEJ/nbm

Attachment

A100

cc: Dr. Bruce S. Mallett
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One
P.O. Box 310
London, AR 72847

U. S. Nuclear Regulatory Commission
Attn: Mr. Drew Holland
Mail Stop 0-7 D1
Washington, DC 20555-0001

U. S. Nuclear Regulatory Commission
Attn: Mr. Greg Suber
Mail Stop 0-11 F1
Washington, DC 20555-0001

Mr. Bernard R. Bevill
Director, Division of Radiation
Control and Emergency Management
Arkansas Department of Health
4815 West Markham Street, Slot 30
Little Rock, AR 72205-3867

Attachment to

2CAN050503

List of Regulatory Commitments

List of Regulatory Commitments

The following table identifies those actions committed to by Entergy in this document. Any other statements in this submittal are provided for information purposes and are not considered to be regulatory commitments.

COMMITMENT	TYPE (Check One)		SCHEDULED COMPLETION DATE (If Required)
	ONE- TIME ACTION	CONTINUING COMPLIANCE	
With respect to the ANO-2 Buried Piping Inspection Program upon entering the period of extended operation, Entergy will perform an inspection within ten years, unless an opportunistic inspection occurred within this ten-year period.		X	Prior to July 17, 2018