

May 19, 2005

Mr. Jeffery Archie
Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88
Jenkinsville, South Carolina 29065

SUBJECT: VIRGIL C. SUMMER - REQUEST FOR ADDITIONAL INFORMATION
REGARDING RELIEF REQUESTS RR II-09 AND RR II-10 (TAC NO. MC5750)

Dear Mr. Archie:

By letters dated September 16 and September 23, 2003, South Carolina Electric and Gas Company (the licensee) submitted Relief Request (RR) Numbers II-9 and II-10 from the requirements of the American Society of Mechanical Engineers (ASME) Code, Section XI. The staff of the Nuclear Regulatory Commission has identified a need for additional information (RAI) as discussed below.

Regarding RR II-9, please provide clarification whether the examinations were performed using procedures and personnel that were qualified in accordance with Appendix VIII of the ASME Code. Address whether the coverage achieved was obtained using qualified procedures in accordance with Appendix VIII and whether the coverage achieved was obtained using your best efforts to obtain the coverage required by the Code. Were any recordable indications detected? Provide a discussion on the impracticality of using radiograph testing to examine the subject welds.

Regarding RR-10, please clarify whether the examinations were performed using Section XI, Appendix III, or another subsection or article of the ASME Code to qualify the procedures and personnel. Were any recordable indications detected?

This RAI was discussed with Mr. Robert Sweet, and others on your staff, on May 5, 2005. Please contact me if you have any questions.

Sincerely,

/RA/

Robert E. Martin, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-395

cc: See next page

May 19, 2005

Mr. Jeffery Archie
Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88
Jenkinsville, South Carolina 29065

SUBJECT: VIRGIL C. SUMMER - REQUEST FOR ADDITIONAL INFORMATION
REGARDING RELIEF REQUESTS RR II-09 AND RR II-10 (TAC NO. MC5750)

Dear Mr. Archie:

By letters dated September 16 and September 23, 2003, South Carolina Electric and Gas Company (the licensee) submitted Relief Request (RR) Numbers II-9 and II-10 from the requirements of the American Society of Mechanical Engineers (ASME) Code, Section XI. The staff of the Nuclear Regulatory Commission has identified a need for additional information (RAI) as discussed below.

Regarding RR II-9, please provide clarification whether the examinations were performed using procedures and personnel that were qualified in accordance with Appendix VIII of the ASME Code. Address whether the coverage achieved was obtained using qualified procedures in accordance with Appendix VIII and whether the coverage achieved was obtained using your best efforts to obtain the coverage required by the Code. Were any recordable indications detected? Provide a discussion on the impracticality of using radiograph testing to examine the subject welds.

Regarding RR-10, please clarify whether the examinations were performed using Section XI, Appendix III, or another subsection or article of the ASME Code to qualify the procedures and personnel. Were any recordable indications detected?

This RAI was discussed with Mr. Robert Sweet, and others on your staff, on May 5, 2005. Please contact me if you have any questions.

Sincerely,
/RA/

Robert E. Martin, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-395

cc: See next page

Distribution: PUBLIC PDII-1 R/F RMartin KCotton BClayton
EMarinos OGC ACRS KLandis DNaujock

ADAMS Accession No.: ML051320083

NRR-088

OFFICE	PDII-1/PM	PDII-1/LA	DE/EMCB	PDII-1/SC
NAME	RMartin	BClayton	DNaujock	EMarinos
DATE	05 / 15 / 05	05 / 13 / 05	05 / 16 / 05	05 / 19 / 05

OFFICIAL RECORD COPY

Mr. Jeffrey B. Archie
South Carolina Electric & Gas Company

VIRGIL C. SUMMER NUCLEAR STATION

cc:

Mr. R. J. White
Nuclear Coordinator
S.C. Public Service Authority
c/o Virgil C. Summer Nuclear Station
Post Office Box 88, Mail Code 802
Jenkinsville, South Carolina 29065

Resident Inspector
Virgil C. Summer Nuclear Station
U.S. Nuclear Regulatory Commission
576 Stairway Road
Jenkinsville, South Carolina 29065

Chairman, Fairfield County Council
Drawer 60
Winnsboro, South Carolina 29180

Mr. Henry Porter, Assistant Director
Division of Waste Management
Bureau of Land & Waste Management
Dept. of Health & Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. Thomas D. Gatlin, General Manager
Nuclear Plant Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88, Mail Code 300
Jenkinsville, South Carolina 29065

Mr. Ronald B. Clary, Manager
Nuclear Licensing
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88, Mail Code 830
Jenkinsville, South Carolina 29065

Ms. Kathryn M. Sutton, Esquire
Winston & Strawn Law Firm
1400 L Street, NW
Washington, DC 20005-3502