

Appendix C	Job Performance Measure Worksheet	Form ES-C-1
------------	--------------------------------------	-------------

Facility: **BVPS Unit 1** Task No.: 0011-014-01-013
0535-006-04-013
Task Title: Raise Reactor Power To 10^{-8} Amps JPM No.: 2005 NRC JPM S1

K/A Reference: 001 A2.11 (4.4/4.7)
001 AA1.05 (4.3/4.2)

Examinee: NRC Examiner:
Facility Evaluator: Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X
Classroom _____ Simulator X Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions: A reactor startup is in progress in accordance with 1OM-50.4.D, Reactor Startup From Mode 3 To Mode 2. The following conditions exist:

- All shutdown bank rods are fully withdrawn.
- Control Bank "D" is at 90 steps.
- The estimated critical position is 110 steps on Control Bank "D".

Task Standard: The reactor is tripped in response to inappropriate continuous control rod motion.

Required Materials: Estimated Critical Position & 1/M Plot

General References: 1OM-50.4.D, Reactor Startup From Mode 3 To Mode 2, Rev. 43
1OM-53C.4.1.1.3, RCCA Control Bank Inappropriate Continuous Movement, Rev. 9

Handouts: 1OM-50.4.D, Reactor Startup From Mode 3 To Mode 2, Rev. 43
Estimated Critical Position & 1/M Plot

Initiating Cue: The Unit Supervisor directs you to withdraw control rods to criticality in accordance with 1OM-50.4.D, Reactor Startup From Mode 3 To Mode 2, beginning at Step IV.D.15.f.

Time Critical Task: NO

Validation Time: 16 minutes

Simulator Setup: Initialize IC-
PW = NJPM
Select **FAST** speed on NR-45.

PERFORMANCE INFORMATION

(Denote Critical Steps with a check mark)

START TIME: _____

Performance Step: 1
(Step IV.D.15.f)

WHEN the Inverse Count Rate Ratio is less than 0.25, Reduce rod withdrawal intervals to 25 step increments.

Standard:

Candidate initiates rod withdrawal at less than 25 step increments.

CUE: The ICRR is less than 0.25. Withdraw control rods to take the reactor critical.

Comment:

Performance Step: 2
(Step IV.D.16.a)

Verify both source ranges HV Manual ON/OFF switches are in the NORMAL position.

Standard:

Candidate locates and verifies both source range HV MANUAL CONTROL switches in NORMAL.

Comment:

Performance Step: 3
(Step IV.D.16.b)

Record Source Range Neutron Level indications:

[NI-NI-31A] _____ CPS

[NI-NI-32A] _____ CPS

Standard:

Candidate locates and records SR counts for N31 and N32.

Comment:

PERFORMANCE INFORMATION

Performance Step: 4 Verify annunciators A4-85 and A4-87 "NIS SOURCE RANGE CH
(Step IV.D.16.c) 1(2) DETECTOR VOLTAGE TROUBLE", are ON.

Standard: Candidate locates and verifies A4-85 and A4-87 in alarm.

Comment:

Performance Step: 5 Select both IR channels to indicate on recorder NR-45.
(Step IV.D.16.d)

Standard: Candidate locates and places NI SYS RECORDER SEL SW
1N45 and 2N45 to record IR channels N35 and N36.

Comment:

√ **Performance Step: 6** BLOCK the source range hi flux trip by placing the Block Source
(Step IV.D.16.e) Range Trip Train A and Train B control switches to BLOCK.

Standard: Candidate locates and places BLOCK SOURCE RANGE TRIP
TRAIN A/TRAIN B control switches in Block.

Comment:

PERFORMANCE INFORMATION

Performance Step: 7

(Step IV.D.16.f)

Verify the Source Range High Voltage is de-energized.

Standard:

Candidate locates and verifies Source Range DETECTOR VOLTS indicate zero.

Comment:**Performance Step: 8**

(Step IV.D.16.g)

Verify annunciators A4-85 AND A4-87, "NIS SOURCE RANGE CH1(2) DETECTOR VOLTAGE TROUBLE", are OFF.

Standard:

Candidate locates and verifies A4-85 AND A4-87 not in alarm.

Comment:**Performance Step: 9**

(Step IV.D.17.a)

If the Source Range High Flux Trip signal is blocked prior to criticality, perform the following: (Otherwise N/A)

Suspend performance of the 1/m plot.

Standard:

Candidate directs suspending the 1/m plot.

CUE: The 1/m Plot is suspended.**Comment:**

PERFORMANCE INFORMATION

- √ **Performance Step: 10** Continue incremental rod withdrawal (at a rate determined by the SM, but not to exceed 25 step increments) until the reactor is critical as indicated by a stable positive startup rate, with no rod motion, on the intermediate range instrumentation once the prompt jump has receded.
(Step IV.D.17.b)

Standard: Candidate continues withdrawing control rods to obtain a stable startup rate.

CUE: If asked, inform Candidate to withdraw rods at no more than 25 step increments to obtain a stable startup rate.

Comment:

NOTE: The following step begins the alternate path portion of the JPM.

Performance Step: 11 Determine that rods are withdrawing with NO demand signal.

Standard: Candidate determines from CONTROL BANK D GROUP 1 and GROUP 2 ROD POSITION indication that rods are withdrawing with **NO** demand signal.

Comment:

PERFORMANCE INFORMATION

- √ **Performance Step: 12** Trip the reactor in response to inappropriate continuous rod motion.
(AOP-1.1.3, Step 1 RNO)

Standard: Candidate trips the reactor in response to inappropriate continuous rod motion.

NOTE: Candidate may refer to AOP-1.1.3 and determine that a reactor trip is required based on Step 1 RNO.

Comment:

Terminating Cue: When the Candidate trips the reactor, the evaluation for this JPM is complete.
--

STOP TIME: _____

VERIFICATION OF COMPLETION

JPM No.: 2005 NRC S1

Examinee's Name:

Examiner's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:Question: _____

_____Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's Signature: _____

Date: _____

INITIAL CONDITIONS:

A reactor startup is in progress in accordance with 1OM-50.4.D, Reactor Startup From Mode 3 To Mode 2. The following conditions exist:

- All shutdown bank rods are fully withdrawn.
- Control Bank "D" is at 90 steps.
- The estimated critical position is 110 steps on Control Bank "D".

INITIATING CUE:

The Unit Supervisor directs you to withdraw control rods to criticality in accordance with 1OM-50.4.D, Reactor Startup From Mode 3 To Mode 2, beginning at Step IV.D.15.f.

Worksheet

Facility: **BVPS Unit 1** Task No.: 0531-005-05-013

Task Title: Perform SI Termination IAW ES-1.1 JPM No.: 2005 NRC JPM S2

K/A Reference: E02 EA1.3 (3.8/4.0)

Examinee: NRC Examiner:

Facility Evaluator: Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X

Classroom _____ Simulator X Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions:

- The reactor was tripped and safety injection was actuated due to low RCS pressure.
- The crew has entered ES-1.1, SI Termination.

Task Standard: High head safety injection is aligned to provide flow to the RCS.

Required Materials: None

General References: 1OM-53A.1.ES-1.1, SI Termination, Issue 1C, Rev. 4

Handouts: 1OM-53A.1.ES-1.1, SI Termination, Issue 1C, Rev. 4

Initiating Cue: The Unit Supervisor directs you to perform the steps to terminate safety injection in accordance with ES-1.1, SI Termination.

Time Critical Task: NO

Validation Time: 20 minutes

Simulator Setup: Initialize IC-192
 PW = NJPM

PERFORMANCE INFORMATION

(Denote Critical Steps with a check mark)

START TIME: _____√ **Performance Step: 1** Reset SI

(Step 1)

Standard: Candidate locates and depresses SI Reset/Override Train A/Train B pushbuttons.

Standard: Candidate verifies Status Light Panel 62-4C is off and 62-4D is on.

Comment:

√ **Performance Step: 2** Reset CIA and CIB

(Step 2)

Standard: Candidate locates and depresses CIA Reset/Override Train A/Train B and CIB Reset Override Train A/Train B switches.

Standard: Candidate verifies A1-72, Containment Isolation Phase B clears.

Comment:

Performance Step: 3 Stop All But One Charging Pump

(Step 3)

Standard: Candidate locates and places 1CH-P-1A or 1B control switch in Stop.

Standard: Candidate verifies white trip light on and red running light off.

Comment:

PERFORMANCE INFORMATION

Performance Step: 4 Check RCS Pressure - STABLE OR RISING

(Step 4)

Standard: Candidate locates RCS pressure indication and verifies stable or rising.

Comment:

Performance Step: 5 Isolate The BIT

(Step 5.a)

Close [MOV-1SI-867A, B]

Standard: Candidate locates MOV-1SI-867A, B control switches and places in Close.

Standard: Candidate verifies green close light on and red open light off for each valve.

Comment:

Performance Step: 6 Isolate the BIT

(Step 5.b)

Close [MOV-1SI-867C, D]

Standard: Candidate locates MOV-1SI-867C, D control switches and places in Close.

Standard: Candidate verifies green close light on and red open light off for each valve.

Comment:

PERFORMANCE INFORMATION

Performance Step: 7 Establish Normal Charging Flow
(Step 6.a) Close [FCV-1CH-122]
Standard: Candidate locates FCV-1CH-122 controller and places in Manual
and closes valve.
Standard: Candidate verifies valve controller indicates 100% (Shut).

Comment:

Performance Step: 8 Establish Normal Charging Flow
(Step 6.b) Open [MOV-1CH-310]
Standard: Candidate locates MOV-1CH-310 control switch and places in
open.
Standard: Candidate verifies red open light on and green close light off.

Comment:

Performance Step: 9 Establish Normal Charging Flow
(Step 6.c) Open [MOV-1CH-289]
Standard: Candidate locates MOV-1CH-289 control switch and places in
open.
Standard: Candidate verifies red open light on and green close light off.

Comment:

PERFORMANCE INFORMATION

Performance Step: 10 Establish Normal Charging Flow
(Step 6.d) Adjust [FCV-1CH-122] to maintain required PRZR level
Standard: Candidate locates FCV-1CH-122 controller and opens valve to
re-establish charging flow.

Comment:

Performance Step: 11 Control Charging Flow to Maintain PRZR Level
(Step 7)
Standard: Candidate observes PRZR level indication and adjusts charging
flow, as necessary to maintain PRZR level greater than 18%.

Comment:

Performance Step: 12 Energize Stub Busses
(Step 8.a) Check 4160V stub busses - ENERGIZED
Standard: Candidate locates and verifies ACB-1E5, 1AE stub bus red
closed light on and white trip light off.

Comment:

PERFORMANCE INFORMATION

Performance Step: 13 Energize Stub Busses

(Step 8.a)

Check 4160V stub busses - ENERGIZED

Standard:

Candidate locates and verifies ACB-1F5, 1DF stub bus red closed light on and white trip light off.

Comment:**Performance Step: 14** Energize Stub Busses

(Step 8.b)

Check 480V stub busses - ENERGIZED

Standard:

Candidate locates and verifies either boric acid transfer pumps or containment vacuum pumps indicating lights are lit.

Comment:**Performance Step: 15** Verify CNMT Instrument Air - AVAILABLE

(Step 9.a)

Check Station Instrument Air Header Pressure - GREATER THAN 100 PSIG

Standard:

Candidate locates and verifies PI-11A-106 pressure indicates greater than 100 psig.

Comment:

PERFORMANCE INFORMATION

Performance Step: 16 Verify CNMT Instrument Air - AVAILABLE
(Step 9.b) Verify [TV-11A-400] - OPEN
Standard: Candidate locates TV-11A-400 and verifies red open light on and green closed light off.

Comment:

Performance Step: 17 Verify CNMT Instrument Air - AVAILABLE
(Step 9.c) Check CNMT instrument air header pressure - GREATER THAN 85 PSIG
Standard: Candidate locates and verifies PI-11A-106A indicates greater than 85 psig.

Comment:

Performance Step: 18 Check If LHSI Pumps Should Be Stopped:
(Step 10.a) LHSI pumps - ANY RUNNING WITH SUCTION ALIGNED TO RWST
Standard: Candidate locates and verifies 1SI-P-1A and 1B running.
Standard: Candidate verifies red running light on for each pump.
Standard: Candidate locates and verifies MOV-1SI-862A/B open.
Standard: Candidate verifies red open light on and green closed light off for each valve.

Comment:

PERFORMANCE INFORMATION

Performance Step: 19 Check If LHSI Pumps Should Be Stopped:
(Step 10.b) Stop LHSI pumps and place in AUTO
Standard: Candidate locates and places 1SI-P-1A and 1B control switches in Stop.
Standard: Candidate verifies white trip light on and red running light off for each pump.

Comment:

Performance Step: 20 Reset SI Auto Recirc Changeover
(Step 11)
Standard: Candidate locates and depresses SIS Auto Recirc Reset Train A/Train B pushbuttons.

Comment:

Performance Step: 21 Verify SI Flow Not Required
(Step 12.a) RCS subcooling based on core exit TCs - GREATER THAN 46°F [54°F ADVERSE CNMT]
Standard: Candidate locates ICCM display and verifies subcooling greater than 46°F.

Comment:

PERFORMANCE INFORMATION

Performance Step: 22 Verify SI Flow Not Required
(Step 12.b) PRZR level - GREATER THAN 18% [37% ADVERSE CNMT]
Standard: Candidate locates and verifies PRZR level indicates less than 18%.
Standard: Candidate determines that PRZR level is dropping and refers to RNO column step 12.b.

Comment:

NOTE: The following step begins the alternate path portion of the JPM.

√ **Performance Step: 23** Adjust charging flow to restore PRZR level.
(Step 12.b RNO)
Standard: Candidate locates and adjusts FCV-1CH-122 to restore PRZR level.

Comment:

√ **Performance Step: 24** IF PRZR level can NOT be restored, THEN manually start SI pumps and align valves as necessary.
(Step 12.b RNO)
Standard: Candidate manually starts SI pumps and aligns valves, as necessary.

NOTE: Candidate may choose to manually re-initiate SI based on SI Reinitiation Criteria on Foldout Page.

Comment:

Terminating Cue: When the Candidate starts the SI pumps manually or re-initiates SI, the evaluation for this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

JPM No.: 2005 NRC S2

Examinee's Name:

Examiner's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:Question: _____

_____Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's Signature: _____

Date: _____

INITIAL CONDITIONS:

- The reactor was tripped and safety injection was actuated due to low RCS pressure.
- The crew has entered ES-1.1, SI Termination.

INITIATING CUE:

The Unit Supervisor directs you to perform the steps to terminate safety injection in accordance with ES-1.1, SI Termination.

Facility: **BVPS Unit 1** Task No.: 0111-011-01-013

Task Title: Isolate SI Accumulators During a LOCA JPM No.: 2005 NRC JPM S3

K/A Reference: 009 EA1.13 (4.4/4.4)

Examinee: _____ NRC Examiner: _____

Facility Evaluator: _____ Date: _____

Method of testing:

Simulated Performance: _____ Actual Performance: X

Classroom _____ Simulator X Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions: A LOCA has occurred. The crew is performing ES-1.2, Post LOCA Cooldown and Depressurization.

Task Standard: SI Accumulators A and B are isolated. SI Accumulator C is vented.

Required Materials: Shorting Bars (3)

General References: 1OM-53.A.1.ES-1.2, Post LOCA Cooldown and Depressurization, Issue 1C, Rev. 5
1OM-11.4.H, Venting Safety Injection Accumulator [1SI-TK-1A (1B) (1C)]

Handouts: 1OM-53A.1.ES-1.2, Post LOCA Cooldown and Depressurization, Issue 1C, Rev. 5
1OM-11.4.H, Venting Safety Injection Accumulator [1SI-TK-1A (1B) (1C)]
1OM-53A.1.6-A, 0 F Plus Subcooling Based on Core Exit TCs, Issue 1C, Rev. 0

Initiating Cue: The Unit Supervisor directs you to isolate the SI accumulators in accordance with ES-1.2, Post LOCA Cooldown and Depressurization, Step 25.

Time Critical Task: NO

Validation Time: 12 minutes

Simulator Setup: Initialize IC-196
PW = NJPM

PERFORMANCE INFORMATION

(Denote Critical Steps with a check mark)

START TIME: _____

Performance Step: 1 RCS subcooling based on core exit TCs - GREATER THAN
(Step 25.a) SUBCOOLING LISTED ON ATTACHMENT 6-A

Standard: Candidate locates ICCM display and verifies RCS subcooling
based on core exit TCs is greater than subcooling listed on
Attachment 6-A.

CUE: **Provide Candidate with a copy of Attachment 6-A.**

Comment:

Performance Step: 2 PRZR level - GREATER THAN 18% [37% ADVERSE CNMT].
(Step 25.b)

Standard: Candidate locates and verifies PRZR level indication is greater
than 18%.

Comment:

Performance Step: 3 Power to [MOV-1SI-865A, B, C] - AVAILABLE.
(Step 25.c)

Standard: Candidate locates and verifies power available to
MOV-1SI-865A, B and C.

Standard: Candidate verifies red open light on for each valve.

Comment:

PERFORMANCE INFORMATION

- √ **Performance Step: 4** Insert shorting bars into jacks for [MOV-1SI-865A, B, and C]
(Step 25.d)

Standard: Candidate locates and inserts shorting bars into jacks for MOV-1SI-865A, B, and C.

CUE: Provide Candidate with shorting bars as needed.

Comment:

- √ **Performance Step: 5** Close [MOV-1SI-865A, B, C].
(Step 25.e)

Standard: Candidate locates MOV-1SI-865A and B control switches and places in Close.

Standard: Candidate verifies green close light on and red open light off for each valve.

Comment:

- √ **Performance Step: 6** Close [MOV-1SI-865A, B, C].
(Step 25.e)

Standard: Candidate locates MOV-1SI-865C control switch and places in Close.

Standard: Candidate verifies red open light remains on indicating valve **NOT** closed.

NOTE: Valve is overridden in the Open position.

Comment:

PERFORMANCE INFORMATION

NOTE: The following step begins the alternate path portion of the JPM.

Performance Step: 7

(Step 25.e.1 RNO)

Verify at least one station air compressor or the diesel air compressor is RUNNING.

Standard:

Candidate locates and verifies 1SA-C-1A or 1B running.

Standard:

Candidate verifies red running light on for at least one station air compressor.

Comment:**Performance Step: 8**

(Step 25.e.2 RNO)

Verify [TV-11A-400] OPEN.

Standard:

Candidate locates and verifies TV-11A-400 is open.

Standard:

Candidate verifies red open light on and green closed light off.

Comment:**Performance Step: 9**

(Step 25.e.3 RNO)

Check CNMT instrument air header pressure - GREATER THAN 85 PSIG.

Standard:

Candidate locates PI-11A-106A and verifies containment instrument air header pressure indicates greater than 85 psig.

Comment:

PERFORMANCE INFORMATION

Performance Step: 10

(Step 25.e.4 RNO)

Vent any unisolated accumulators to atmospheric pressure. Refer to 10M-11.4.H, "Venting Safety Injection Accumulators [1SI-TK-1A(B) (C)]".

Standard:

Candidate refers to 10M-11.4.H to vent 1SI-TK-1C.

CUE: Provide Candidate with a copy of 10M-11.4.H.

Comment:**Performance Step: 11**

(Step IV.1)

Check [HIC-1SI-936] SI ACC N₂ Vent to Atm control, output is adjusted to "Zero" percent. (BB-A)

Standard:

Candidate checks HIC-1SI-936 output is adjusted to zero percent.

Standard:

Candidate locates and verifies HIC-1SI-936 indicates zero percent.

CUE: If asked, inform Candidate that Radiation Protection does not require a nitrogen gas sample.

Comment:

PERFORMANCE INFORMATION

Performance Step: 12 Close [1SI-69], Nitrogen Supply to S.I. Accumulators (Aux Bldg, 768" near B.A Batch Tank).
(Step IV.2.a)

Standard: Candidate dispatches local operator to direct closing 1SI-69.

CUE: Local operator reports that 1SI-69 is closed.

Comment:

Performance Step: 13 If desired by the SM/US, Close [1SI-437], Nitrogen Supply to Overpressure Protection System, (CNMT, At 1C SI ACC-692').
(Step IV.2.b)

Standard: No action required.

CUE: As Unit Supervisor, inform Candidate it is NOT desired to close 1SI-437.

Comment:

√ **Performance Step: 14** Open [MOV-1SI-853C], (1C) SI Acc N₂ Sup Isol Vlv. (BB-A)
(Step IV.3)

Standard: Candidate locates and opens MOV-1SI-853C.

Standard: Candidate verifies red open light on and green closed light off.

Comment:

PERFORMANCE INFORMATION

- √ **Performance Step: 15** Open [TV-1SI-101-1], SI Acc N₂ Sup Isol Vlv. (BB-A)
(Step IV.4)
Standard: Candidate locates and opens TV-1SI-101-1.
Standard: Candidate verifies red open light on and green closed light off.

Comment:
- √ **Performance Step: 16** Open [TV-1SI-101-2], SI Acc N₂ Sup Isol Vlv. (BB-A)
(Step IV.5)
Standard: Candidate locates and opens TV-1SI-101-2.
Standard: Candidate verifies red open light on and green closed light off.

Comment:
- √ **Performance Step: 17** Operate [HIC-1SI-936] (BB-A) to lower accumulator to the desired
(Step IV.6) pressure as indicated on [PI-1SI-921 & 923 (925 & 927) (929 & 931)]. (VB-A)
Standard: Candidate locates and operates HIC-1SI-936 to lower accumulator pressure.
Standard: Candidate verifies PI-1SI-929 & 931 indicate accumulator pressure is lowering.

Comment:

Terminating Cue: When the Candidate verifies that accumulator pressure is lowering, the evaluation for this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

JPM No.: 2005 JPM S3

Examinee's Name:

Examiner's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:Question: _____

_____Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's Signature: _____ Date: _____

INITIAL CONDITIONS:

A LOCA has occurred. The crew is performing ES-1.2, Post LOCA Cooldown and Depressurization.

INITIATING CUE:

The Unit Supervisor directs you to isolate the SI accumulators in accordance with ES-1.2, Post LOCA Cooldown and Depressurization, Step 25.

Facility: **BVPS Unit 1** Task No.: 0211-012-01-013
0531-009-05-011
Task Title: Initiate Natural Circulation Cooldown JPM No.: 2005 NRC JPM S4
K/A Reference: 002 A4.02 (4.3/4.5)
E09 EA1.1 (3.5/3.5)

Examinee: NRC Examiner:

Facility Evaluator: Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X
Classroom _____ Simulator X Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions:

- A reactor trip has occurred and all RCP's were tripped.
- The crew has transitioned to ES-0.2, Natural Circulation Cooldown.
- The plant is stable with condenser steam dumps in automatic in the steam pressure mode.

Task Standard: RCS cooldown in progress using residual heat release valve.

Required Materials: None

General References: 1OM-53A.1.ES-0.2, Natural Circulation Cooldown, Issue 1.C, Rev 4
1OM-53A.1.5-C, CRDM Fans Running - Natural Circulation Cooldown
Subcooling Requirements

Handouts: 1OM-53A.1.ES-0.2, Natural Circulation Cooldown, Issue 1.C, Rev 4
1OM-53A.1.5-C, CRDM Fans Running - Natural Circulation Cooldown
Subcooling Requirements

Initiating Cue: The Unit Supervisor directs you to initiate an RCS cooldown in accordance with ES-0.2, Natural Circulation Cooldown, beginning at Step 5.

Time Critical Task: NO

Validation Time: 15 minutes

Simulator Setup:	Initialize IC-194 PW = NJPM Setup IPC RCS cold leg temperature trend
-------------------------	--

PERFORMANCE INFORMATION

(Denote Critical Steps with a check mark)

START TIME: _____

Performance Step: 1 Maintain cooldown rate in RCS cold legs - LESS THAN 25°F/HR
(Step 5.a)

Standard: No action required.

Comment:

Performance Step: 2 Initiate a trend of RCS cold leg temperature and pressure
(Step 5.a.1)

Standard: Candidate initiates a trend of RCS cold leg temperature and pressure.

CUE: **Inform Candidate that an IPC trend has been setup to trend RCS temperature and pressure.**

Comment:

Performance Step: 3 Initial every half hour
(Step 5.a.2)

Standard: Candidate notes trending frequency requirement.

NOTE: **Inform Candidate that another operator will be responsible for trending and initialing.**

Comment:

PERFORMANCE INFORMATION

Performance Step: 4 Maintain RCS temperature and pressure - WITHIN LIMITS OF
(Step 5.a.3) ATTACHMENT 5-C IF ANY CRDM FAN RUNNING -OR- WITHIN
LIMITS OF ATTACHMENT 5-B IF NO CRDM FAN RUNNING

Standard: Candidate locates and verifies at least 1 CRDM fan running.

Standard: Candidate verifies red running light on and white trip light off.

Standard: Candidate refers to Attachment 5-C for temperature/pressure limits.

CUE: Provide Candidate with a copy of Attachment 5-C.

Comment:

Performance Step: 5 Maintain SG narrow range level - BETWEEN 30% - 50%
(Step 5.b)

Standard: No action required.

CUE: Inform Candidate that another operator will be responsible for controlling SG levels.

Comment:

Performance Step: 6 Check MSIVs - AT LEAST ONE OPEN
(Step 5.c.1)

Standard: Candidate locates and verifies at least one MSIV open.

Standard: Candidate verifies red open light on and green closed light off.

Comment:

PERFORMANCE INFORMATION

Performance Step: 7 Check condenser available

(Step 5.c.2)

Standard: Candidate locates and checks status light C-12, "COND AVAIL" (Panel 622) is on.

Comment:

√ **Performance Step: 8** Place condenser steam dump controller in MANUAL.

(Step 5.c.3)

Standard: Candidate locates and places AM-1MS-464B, COOLDOWN VLVS CONTROL in Manual.

Standard: Candidate verifies red light on.

Comment:

Performance Step: 9 Verify demand - ZERO

(Step 5.c.4)

Standard: Candidate locates and verifies AM-1MS-464B demand indicates zero.

Comment:

PERFORMANCE INFORMATION

Performance Step: 10 Place steam dumps in STM PRESS Mode.

(Step 5.c.5)

Standard: No action required per JPM Initial Conditions.

Comment:

Performance Step: 11 Check Tavg - GREATER THAN 541°F

(Step 5.c.6)

Standard: Candidate locates and checks status light D-11, "2/3 Lo-Lo Tavg" (Panel 622) is **NOT** on.

Comment:

✓ **Performance Step: 12** Gradually raise steam dump rate.

(Step 5.c.7)

Standard: Candidate locates AM-1MS-464B controller and depresses raise pushbutton to open steam dump valves.

Standard: Candidate determines that steam dump valves do **NOT** open.

NOTE: Candidate may attempt to open steam dump valves in AUTO. If so, valves will NOT open.

NOTE: Steam dump controller is overridden to prevent dump valves from opening.

CUE: As the Unit Supervisor, acknowledge steam dump failure and direct Candidate to use HCV-1MS-104 to dump steam.

Comment:

PERFORMANCE INFORMATION

NOTE: The following step begins the alternate path portion of the JPM.

√ **Performance Step: 13** Manually or locally dump steam using:

(Step 5.c RNO)

SG Atm Dump Vlvs -OR-

Residual Heat Release Control Valve

Standard:

Candidate locates HCV-1MS-104, Residual Heat Release Valve and opens to manually dump steam.

Standard:

Candidate verifies valve open indication.

CUE: As the Unit Supervisor, direct the Candidate to use the RHR valve to continue the cooldown.

Comment:

Terminating Cue: When the Candidate initiates a cooldown using the RHR valve, the evaluation for this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

JPM No.: 2005 JPM S4

Examinee's Name:

Examiner's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:Question: _____

_____Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's Signature: _____

Date: _____

INITIAL CONDITIONS:

- A reactor trip has occurred.
- All RCP's are tripped.
- The crew has transitioned to ES-0.2, Natural Circulation Cooldown.
- The plant is stable with condenser steam dumps in automatic in the steam pressure mode.

INITIATING CUE:

The Unit Supervisor directs you to initiate an RCS cooldown in accordance with ES-0.2, Natural Circulation Cooldown, beginning at Step 5.

Facility:	BVPS Unit 1	Task No.:	0011-006-01-013
Task Title:	<u>Manually Actuate CIB</u>	JPM No.:	<u>2005 NRC JPM S5</u>
K/A Reference:	026 A3.01 (4.3/4.5)	026 A4.01 (4.5/4.3)	

Examinee: _____ NRC Examiner: _____

Facility Evaluator: _____ Date: _____

Method of testing:

Simulated Performance: _____ Actual Performance: X
Classroom _____ Simulator X Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions:

- A reactor trip and safety injection have occurred due to a large break LOCA.
- The actions of E-0 are being performed.

Task Standard: Manually initiate CIB, start 1QS-P-1A and stop the RCP's.

Required Materials: None

General References: 1OM-53A.1.1-K, Verification Of Automatic Actions, Issue 1C, Rev. 2
1OM-53A.1.1-E, Containment Isolation Phase B Checklist, Issue 1C, Rev. 2

Handouts: 1OM-53A.1.1-K, Verification Of Automatic Actions, Issue 1C, Revision 2
1OM-53A.1.1-E, Containment Isolation Phase B Checklist, Issue 1C, Rev. 2

Initiating Cue: The Unit Supervisor directs you to perform Attachment 1-K, Verification Of Automatic Actions, Step 8 to check CIB and Containment Spray status.

Time Critical Task: NO

Validation Time: 10 minutes

Simulator Setup: Initialize IC-195
PW = NJPM

(Denote Critical Steps with a check mark)

START TIME: _____

Performance Step: 1 Check CIB and Containment Spray Status
(Step 8) Containment pressure - HAS REMAINED LESS THAN 8 PSIG
Standard: Candidate locates PI-1LM-100A and 100B, Containment Pressure Indicators, or PR-1LM-100A, Containment Pressure Recorder.
Standard: Candidate determines that containment pressure has **NOT** remained less than 8 psig.

NOTE: Containment pressure is > 8 psig.

Comment:

NOTE: The following step begins the alternate path portion of the JPM.

Performance Step: 2 Verify CIB initiated:
(Step 8.a RNO) Check BLUE CIB marks - LIT
Standard: Candidate checks components properly aligned and determines CIB components not positioned as required and CIB **NOT** actuated.

Comment:

- ✓ **Performance Step: 3** Verify CIB initiated:
(Step 8.a RNO) IF NOT, THEN manually initiate CIB (both pushbuttons for both trains). Check BLUE CIB marks - LIT
- Standard:** Candidate locates and depresses both pushbuttons for Train "A" CIB.
- Standard:** Candidate locates and depresses both pushbuttons for Train "B" CIB.
- NOTE:** Candidate may actuate either train first followed by the opposite train.
- Comment:**

- ✓ **Performance Step: 4** Verify CIB initiated:
(Step 8.a RNO) IF CIB NOT actuated, THEN manually align equipment. If necessary, refer to Attachment 1-E, "Containment Isolation Phase B Checklist".
- NOTE:** If requested, provide Candidate with a copy of Attachment 1-E.
- Standard:** Candidate checks all indicating lights with BLUE CIB marks LIT.
- Standard:** Candidate identifies 1QS-P-1A, Quench Spray Pump **failed** to start.
- Standard:** Candidate locates 1QS-P-1A control switch and places in Start.
- Standard:** Candidate verifies red running light on and white trip light off.
- Standard:** Candidate locates and verifies discharge pressure and motor amps for each pump.
- NOTE:** Candidate should recognize time delays for 1-RS-P1A and 1-RS-P2A, Recirc Spray Pumps following CIB actuation.
- Comment:**

- √ **Performance Step: 5** Verify CIB initiated:
(Step 8.b RNO) Stop all RCP's.
- Standard:** Candidate determines that all RCP's are running.
- Standard:** Candidate locates and places control switches for 1RC-P-1A, 1B and 1C in Stop.
- Standard:** Candidate verifies white trip light on and red running light off for each pump.

NOTE: **Candidate may choose to place control switches in Pull-To-Lock after stopping pumps.**

Comment:

- Performance Step: 6** Request BV-2 operator verify CREVS equipment actuation.
(Step 8.c RNO)
- Standard:** Candidate contacts Unit 2 to verify proper CREVS equipment operation.

CUE: **Inform Candidate as Unit 2 Operator that all CREVS equipment is functioning properly.**

Comment:

Terminating Cue: When the Candidate stops the RCP's, the evaluation for this JPM is complete.

STOP TIME: _____

JPM No.: 2005 JPM S5

Examinee's Name:

Examiner's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:Question: _____

_____Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's Signature: _____

Date: _____

INITIAL CONDITIONS:

- A reactor trip and safety injection have occurred due to a large break LOCA.
- The actions of E-0 are being performed.

INITIATING CUE:

The Unit Supervisor directs you to perform Attachment 1-K, Verification Of Automatic Actions, Step 8 to check CIB and Containment Spray status.

Facility: **BVPS Unit 1** Task No.: 0362-005-06-013

Task Title: Synchronize and Load EDG No. 2 JPM No.: 2005 NRC JPM S6

K/A Reference: 064 A4.06 (3.9/3.9)

Examinee:

NRC Examiner:

Facility Evaluator:

Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X

Classroom _____ Simulator X Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions: The plant is operating at power. 1OST-36.2, Diesel Generator No. 2 Monthly Test is in progress.

Task Standard: No. 2 diesel generator synchronized and running at minimum load.

Required Materials: None

General References: 1OST-36.2, Diesel Generator No. 2 Monthly Test, Rev 43

Handouts: 1OST-36.2, Diesel Generator No. 2 Monthly Test, Rev 43

Initiating Cue: The Unit Supervisor directs you to synchronize and load Diesel Generator No. 2 in accordance with 1OST-36.2, Diesel Generator No. 2 Monthly Test, Steps 27 - 31. All of the preceding procedure steps have been completed.

Time Critical Task: NO

Validation Time: 12 minutes

Simulator Setup: Initialize IC- PW = NJPM

PERFORMANCE INFORMATION

(Denote Critical Steps with a check mark)

START TIME: _____

- √ **Performance Step: 1** Position the No. 2 Diesel Generator Synchroscope Selector
(Step V.27) Switch to the 1F9 position to compare the diesel generator
frequency to the frequency on bus 1DF. (Generator Section of
the Benchboard)
- Standard:** Candidate locates and places EMERG GEN 2 SYNCHRONIZING
SELECTOR SW in the 1F9 position.
- Standard:** Candidate locates and compares diesel generator frequency to
bus 1DF frequency.
- Comment:**
-
- Performance Step: 2** Verify A9-16, "ACB 1F7 OR 1F9 IN SYNCHRONIZING MODE"
(Step V.27.a) alarms when the Synchroscope Selector Switch is moved from
the OFF position.
- Standard:** Candidate verifies A9-16 in alarm.
- Comment:**
-
- √ **Performance Step: 3** Using the No. 2 diesel Generator Governor Control Switch,
(Step V.28) adjust generator speed until the synchroscope needle is rotating
very slowly in the FAST direction. (Generator Section of the
Benchboard)
- Standard:** Candidate locates and adjusts EMERG GEN 2 GOVERNOR
control switch.
- Standard:** Candidate verifies synchroscope needle is rotating slowly in the
fast direction.
- Comment:**

PERFORMANCE INFORMATION

- √ **Performance Step: 4** Using the No. 2 Diesel Generator Voltage control Switch, match generator voltage (Incoming) with the voltage on bus 1DF (Running).
(Step V.29)
- Standard:** Candidate locates and adjusts EMERG GEN 2 VOLT ADJUST control switch to match voltages.
- Standard:** Candidate verifies incoming and running voltages indicate approximately 120 - 122 volts.
- Comment:**
-
- √ **Performance Step: 5** Close the Motor Operated Ground Switch by positioning the No. 2 Diesel Generator Motor Operated Ground Switch control to CLOSE. (Generator Section of the Benchboard).
(Step V.30)
- Standard:** Candidate locates and closes EMERG GEN 2 MOTOR OPERATED GND SW DS2.
- Standard:** Candidate verifies red close light on and green open light off.
- Comment:**
-
- Performance Step: 6** Verify that ANN. A9-10, "DIESEL GENERATOR NO. 2 M.O. GROUND SWITCH NOT FULLY OPEN" is ON.
(Step V.30.a)
- Standard:** Candidate verifies A9-10 in alarm.
- Comment:**

PERFORMANCE INFORMATION

- √ **Performance Step: 7** When both synchronizing lights are completely dark AND the
(Step V.31) synchroscope needle is at the 12 o'clock position, place the No. 2 Diesel Generator Breaker control to CLOSE. (Red light)
(Generator Section of the Benchboard)
- Standard:** Candidate locates and places EMERG GEN 2 CIRCUIT BREAKER ACB 1E9 in Close at 12 o'clock position.
- Standard:** Candidate verifies red close light on and green open light off.
- Comment:**
-
- √ **Performance Step: 8** Pick up a small amount of load by moving the No. 2 Diesel
(Step V.31.a) Generator Governor Control Switch, intermittently, to the RAISE position.
- Standard:** Candidate locates EMERG GEN 2 GOVERNOR control switch and places in the Raise position.
- Standard:** Candidate verifies EMERG GEN 2 WATTS indicates increasing load.
- Comment:**
-
- Performance Step: 9** Turn synchroscope selector switch to OFF.
(Step V.31.b)
- Standard:** Candidate locates and places EMERG GEN 2 SYNCHRONIZING SELECTOR SW in Off.
- Comment:**
-
- Terminating Cue:** When the Candidate turns the synchroscope selector switch off, the evaluation for this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

JPM No.: 2005 JPM S6

Examinee's Name:

Examiner's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:Question: _____

_____Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's Signature: _____

Date: _____

INITIAL CONDITIONS:

The plant is operating at power. 1OST-36.2, Diesel Generator No. 2 Monthly Test is in progress.

INITIATING CUE:

The Unit Supervisor directs you to synchronize and load Diesel Generator No. 2 in accordance with 1OST-36.2, Diesel Generator No. 2 Monthly Test, Steps 27 - 31. All of the preceding procedure steps have been completed.

Facility: **BVPS Unit 1** Task No.: 0021-004-01-013

Task Title: Remove Power Range Instrument From Service JPM No.: 2005 NRC JPM S7

K/A Reference: 015 A3.03 (3.9/3.9)
015 A4.03 (3.8/3.9)

Examinee: NRC Examiner:

Facility Evaluator: Date:

Method of testing:

Simulated Performance: _____ Actual Performance: X
Classroom _____ Simulator X Plant _____

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

- Initial Conditions:
- The plant is operating at power.
 - All systems are normal with the exception of one Power Range Nuclear Instrument which has failed.
 - The required actions to stabilize the plant have been taken. Reactor, turbine power and T_{AVG} are stable. T_{AVG} is within one degree of T_{REF} .
 - Control Rods are in Manual.

Task Standard: The failed nuclear channel is bypassed in accordance with AOP-1.2.1C.

Required Materials: None

General References: 1OM-53C.4.1.2.1C, Power Range Channel Malfunction, Issue 3A, Rev. 7

Handouts: 1OM-53C.4.1.2.1C, Power Range Channel Malfunction, Issue 3A, Rev. 7

Initiating Cue: The Unit Supervisor directs you to bypass the failed power range channel using AOP-1.2.1C and report when complete.

Time Critical Task: NO

Validation Time: 10 Minutes

Simulator Setup: Initialize IC-182
PW = NJPM
IMF NIS03A 0

PERFORMANCE INFORMATION

(Denote Critical Steps with a check mark)

START TIME: _____

Performance Step: 1 Check If Malfunction Of One Power Range Channel (N-41, N-42, N-43, N-44) Has Occurred.
(Step 1)

Standard: Candidate locates and determines that 2NMP-NI41B and/or NIS Rack N41, drawer A indicates channel has failed.

Standard: Candidate verifies that no other power range channel has failed.

NOTE: Power Range channels read as follows:

N-41: 0%

N-42: 48%

N-43: 48%

N-44: 48%

Comment:

Performance Step: 2 IF Power Range Channel 4 (N-44) fails, THEN perform the following:
(Step 1.b.1)

Place Control Rod Group Selector switch in MAN.

Standard: No action required.

NOTE: Candidate may choose to verify that Control Rod Group Selector switch is in Manual.

Comment:

PERFORMANCE INFORMATION

Performance Step: 3

(Step 1.b.2)

IF Power Range Channel 4 (N-44) fails, THEN perform the following:

Place [2FWS*FCV479, 489, 499], 21A (B) (C) SG Feedwater Bypass Control Vlvs in MANUAL.

Standard:

No action required.

NOTE: Candidate may choose to verify that 2FWS*FCV479, 489, 499 are in Manual.

Comment:√ **Performance Step: 4**

(Step 1.c)

At NIS Rack N50, "Detector Current Comparator," turn Rod Stop Bypass Switch to BYPASS on the failed channel.

Standard:

Candidate locates and places rod stop bypass switch in Bypass PR N-41 position.

Comment:**Performance Step: 5**

(Step 1.c.1)

Verify appropriate Status Light, "Overpwr Rod Stop Bypass" (Status Light Panel 308, A-14, B-14, C-14, D-14) - LIT FOR FAILED CHANNEL

Standard:

Candidate locates and verifies A-14 status light on.

Comment:

PERFORMANCE INFORMATION

Performance Step: 6

Check reactor power - GREATER THAN 50%.

(Step 1.d)

Standard:

Candidate locates and verifies reactor power indicates less than 50%.

Comment:√ **Performance Step: 7**

At NIS Rack N37/N46, "Comparator and Rate", turn Comparator Channel Defeat Switch to failed channel.

(Step 1.g)

Standard:

Candidate locates and places comparator channel defeat switch in N41 position.

Comment:**Performance Step: 8**

Ensure vertical board recorders are selected to monitor only operable detectors.

(Step 1.g)

Standard:

Candidate locates and places NIS RECORDER SELECTOR UPPER 1N45 or LOWER 2N45 in N42, N43, or N44 position.

NOTE: Normally, only 1 recorder is set to monitor power range indication.**Comment:**

PERFORMANCE INFORMATION

Performance Step: 9 Report task complete to the Unit Supervisor.

Standard: Candidate reports Power Range Channel N-41 is bypassed.

NOTE: As Unit Supervisor, acknowledge report that channel is bypassed.

Comment:

Terminating Cue: When the Candidate selects an operable recorder to the detector, the evaluation for this JPM is complete.

STOP TIME: _____

VERIFICATION OF COMPLETION

JPM No.: 2005 JPM S7

Examinee's Name:

Examiner's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:Question: _____

_____Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's Signature: _____

Date: _____

INITIAL CONDITIONS:

- The plant is operating at power.
- All systems are normal with the exception of one Power Range Nuclear Instrument which has failed.
- The required actions to stabilize the plant have been taken. Reactor, turbine power and T_{AVG} are stable. T_{AVG} is within one degree of T_{REF} .
- Control Rods are in Manual.

INITIATING CUE:

The Unit Supervisor directs you to bypass the failed power range channel using AOP-1.2.1C and report when complete.

Facility: **BVPS Unit 1** Task No.: 0071-025-01-013

Task Title: Perform Manual Makeup to the VCT JPM No.: 2005 NRC JPM S8

K/A Reference: 004A4.01 (3.8/3.9) 004A4.07 (3.9/3.7)
004A4.04 (3.2/3.6)

Examinee: NRC Examiner:

Facility Evaluator: Date:

Method of testing:

Simulated Performance: X Actual Performance:
Classroom Simulator X Plant

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions:

- The plant is at 100% power.
- Core burnup is 500 MWD/MTU.
- RCS boron concentration is 1550 ppm.
- The inservice Boric Acid Tank concentration is 7380 ppm.
- VCT level is 24%.

Task Standard: Makeup flow initiated at 100 gpm through the blender.

Required Materials: CB-29

General References: 1OM-7.4.P, Blender Manual Makeup Operation, Rev. 5

Handouts: 1OM-7.4.P, Blender Manual Makeup Operation, Rev. 5

Initiating Cue: The Unit Supervisor directs you to raise VCT level to 40% at 100 gpm by performing a manual makeup in accordance with 1OM-7.4.P, Blender Manual Makeup Operation. All Initial Conditions are met. The addition is to be batched, therefore the total volume change does not need to be calculated.

Time Critical Task: No

Validation Time: 13 minutes

Simulator Setup: Initialize IC-10
PW = NJPM
Ramp ACVCVCTW, 7000, 20, 0 to set VCT level to 24%.
Update blender setpoint to 1550 ppm.
Update inservice BAT placard to 7380 ppm.
Do not enter setpoint data.
Reset Boric Acid and Total Flow Totalizers to ZERO.

(Denote Critical Steps with a check mark)

START TIME: _____

Performance Step: 1

(Step IV.A.1)

Obtain the existing RCS boron concentration obtained from Chemist's sample.

Standard:

No action required per JPM Initial Conditions.

CUE: If asked, inform Candidate that current RCS boron is 1550 ppm.

Comment:

Performance Step: 2

(Step IV.A.2)

If the plant is operating at power, Obtain the B-10 Correction Factor from Curve Book 29, Otherwise Contact Reactor Engineering to obtain a B-10 Correction Factor.

Standard:

Candidate locates and determines a correction factor from CB-29 of 0.977.

CUE: Provide Candidate with a copy of CB-29 (attached).

Comment:

Performance Step: 3

(Step IV.A.3)

Calculate Corrected Boron Concentration AND record in the Daily Journal.

Standard:

Candidate calculates a corrected boron concentration of 1514 ppm. $1550 \times 0.977 = 1514$

CUE: If asked, inform the Candidate that another operator will make the Daily Journal log entry.

Comment:

Performance Step: 4
(Step IV.A.4)

Obtain the inservice Boric Acid Tank boron concentration obtained from Chemist's sample.

Standard:

No action required per JPM Initial Conditions.

CUE: If asked, inform Candidate that current BAT boron is 7380 ppm.

Comment:**Performance Step: 5**
(Step IV.A.5)

Determine the desired boric acid flow controller setpoint as follows AND record in the Daily Journal.

Standard:

Candidate calculates the required boric acid flow as:

$$\frac{1514 \text{ ppm} \times 100 \text{ gpm}}{7380} = 20.5 \text{ gpm}$$

CUE: If asked, inform the Candidate that another operator will make the Daily Journal log entry.

Comment:√ **Performance Step: 6**
(Step IV.A.6)

Place 1MU to STOP for greater than 1 second to allow the blender to unarm.

Standard:

Candidate locates and places 1MU switch in Stop for greater than 1 second.

Standard:

Candidate verifies makeup control green light is on.

Comment:

- √ **Performance Step: 7** Adjust Boric Acid to Blender FCV [FCV-1CH-113A] controller
(Step IV.A.7) (BB-A) to the calculated desired boric acid flow setpoint.
Standard: Candidate locates and sets FCV-1CH-113 for the desired flow:
 $20.5 \text{ gpm} \times 25 \text{ units/gpm} = 513 \text{ units} \pm 2 \text{ units}$

Comment:

- √ **Performance Step: 8** Set [YIC-1CH-113], Boric Acid Integrator, for desire quantity
(Step IV.A.8.a) (BB-A).
Reset [YIC-1CH-113], Boric Acid Integrator
Standard: Candidate locates and sets YIC-1CH-113 to the desired value.

NOTE: Batch amounts are at the operator's discretion.
Total volume change is approximately 225 gallons
including approximately 46 gallons of boric acid.

Comment:

- √ **Performance Step: 9** Adjust Primary Water to Blender FCV [FCV-1CH-114A] controller
(Step IV.A.9) (BB-A) to the desired blender total flow.
Standard: Candidate locates and sets FCV-1CH-114A for the desired total
flow setpoint: $100 \text{ gpm} = 625 \text{ units}$.

Comment:

- √ **Performance Step: 10** Set [YIC-1CH-168A], Blender Output Integrator, for desired
(Step IV.A.10.a) quantity (BB-A).
Reset [YIC-1CH-168A], Blender Output Integrator
- Standard:** Candidate locates and sets YIC-1CH-168A to the desired value.

**NOTE: Batch amounts are at the operator's discretion.
Total volume change is approximately 225 gallons.**

Comment:

- Performance Step: 11** Log the flow totalizer indication and add to it the number of
(Step IV.A.11) gallons set into the batch integrator for [YIC-1CH-113], Boric
Acid Integrator AND [YIC-1CH-168A], Blender Output Integrator.
- Standard:** Candidate sums the totalizer and integrator values, then records
the summed values.

Comment:

- Performance Step: 12** Prior to the start of AND at least once every hour during a
(Step IV.A.12) reduction in the RCS boron concentration: (Tech. Spec. 4.1.1.3,
4.9.8.1.b) (N/A if raising or maintaining RCS boron
concentration)
- Standard:** No action required. Step is N/A.

Comment:

Performance Step: 13 If in Mode 4, 5 or 6, align PG water to the blender by unlocking
(Step IV.A.13) and opening either of the following valves: (Blender Room)
Standard: No action required. Plant is in Mode 1.

Comment:

√ **Performance Step: 14** Place 43/MU to MAN. (BB-A)
(Step IV.A.14)
Standard: Candidate locates and places 43/MU switch in Manual.

Comment:

√ **Performance Step: 15** Place 1MU to START. (BB-A)
(Step IV.A.15)
Standard: Candidate locates and places 1MU switch in Start.
Standard: Candidate verifies makeup control red light is on and inservice
boric acid pump Fast light is on.

Comment:

- √ **Performance Step: 16** Place Blender Outlet to Chg Pumps FCV [FCV-1CH-113B]
(Step IV.A.16) control switch to OPEN. (BB-A)
- Standard:** Candidate locates and places FCV-1CH-113B switch in open.
- Standard:** Candidate verifies red open light is on and green closed light is off.

Comment:

- Performance Step: 17** Verify boric acid to Blender flow on [FR-1CH-113], Boric Acid
(Step IV.A.16.a) Flow. (VB-A)
- Standard:** Candidate locates and verifies FR-1CH-113 indicates boric acid flow.

Comment:

- Performance Step: 18** Verify PG Water to Blender flow on [FR-1CH-113], Boric Acid
(Step IV.A.16.b) Flow. (VB-A)
- Standard:** Candidate locates and verifies FR-1CH-113 indicates PG water flow.

Comment:

Terminating Cue: When the Candidate verifies flow to the blender, the evaluation for this JPM is complete.

STOP TIME: _____

JPM No.: 2005 NRC S8

Examinee's Name:

Examiner's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

_____Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's Signature: _____

Date: _____

INITIAL CONDITIONS:

- The plant is at 100% power.
- Core burnup is 500 MWD/MTU.
- RCS boron concentration is 1550 ppm.
- The inservice Boric Acid Tank concentration is 7380 ppm.
- VCT level is 24%.

INITIATING CUE:

The Unit Supervisor directs you to raise VCT level to 40% at 100 gpm by performing a manual makeup in accordance with 1OM-7.4.P, Blender Manual Makeup Operation. All Initial Conditions are met. The addition is to be batched, therefore the total volume change does not need to be calculated.

Facility: **BVPS Unit 1**

Task No.: 0461-012-01-012

Task Title: Locally Startup a Containment Hydrogen AnalyzerJPM No.: 2005 NRC JPM P1K/A Reference: 028 A1.01 (3.4/3.8)
028 A4.01 (4.0/4.0)

Examinee:

NRC Examiner:

Facility Evaluator:

Date:

Method of testing:Simulated Performance: X Actual Performance:
Classroom Simulator Plant X **READ TO THE EXAMINEE**

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions: A reactor trip and safety injection occurred 10 minutes ago due to a LOCA. A wide range hydrogen analyzer is to be placed in service. The 120VAC and 125VDC electrical distribution systems are operable.

Task Standard: The containment hydrogen analyzer is in service and a containment hydrogen concentration is calculated.

Required Materials: Fluke Thermometer (Simulated)

General References: 1OM-46.4.G, Placing Wide Range Containment Hydrogen Monitoring System in Operation, Rev. 3

Handouts: 1OM-46.4.G, Placing Wide Range Containment Hydrogen Monitoring System in Operation, Rev. 3

Initiating Cue: The Unit Supervisor directs you to place the Train "B" wide range hydrogen analyzer in service and obtain a containment hydrogen sample using 1OM-46.4.G. Steps 1 - 3 of the procedure are complete. Report your results when completed.

Time Critical Task: Yes

Validation Time: 15 minutes

(Denote Critical Steps with a check mark)

START TIME: _____

Performance Step: 1 Open [PNL-H2-101B,], Wide Range Hydrogen Analyzer cabinet.
(Step IV.A.4.a)
Standard: Candidate locates [PNL-H2-101B] and opens the cabinet door.
(Service Building West Wall 713')

Comment:

Performance Step: 2 Verify the STANDBY/OFF switch in the STANDBY position.
(Step IV.A.4.b)
Standard: Candidate locates and verifies or places the STANDBY/OFF switch is in STANDBY.

CUE: The STANDBY/OFF switch is in STANDBY.

Comment:

√ **Performance Step: 3** Place the ON/OFF switch in the ON position.
(Step IV.A.4.c)
Standard: Candidate locates and places the ON/OFF switch in ON.

CUE: The ON/OFF switch is in ON.

NOTE: If the ON/OFF Switch is not placed to ON within 25 minutes, then the UFSAR assumption has not been met and the JPM is UNSAT.

Comment:

Performance Step: 4
(Step IV.A.4.d)

Verify the amber STANDBY indicator is On.

Standard:

Candidate locates and verifies the STANDBY indicator is ON.

CUE: STANDBY indicator is On.**Comment:****Performance Step: 5**
(Step IV.A.4.e.1)

Verify the following:

Blue READY indicator is On.

Standard:

Candidate locates and verifies the Blue READY indicator is On.

CUE: Blue READY indicator is On.**Comment:****Performance Step: 6**
(Step IV.A.4.e.2)

Verify the following:

Green ON indicator is On.

Standard:

Candidate locates and verifies Green indicator is On.

CUE: Green ON indicator is On.**Comment:**

Performance Step: 7
(Step IV.A.4.f. 1 - 9)

Within four minutes after the green ON indicator comes On,
Verify the following:

Standard:

- Red H2 indicator is OFF.

CUE: H2 indicator is OFF.

Standard:

- Yellow CAUTION indicator is OFF.

CUE: CAUTION indicator is OFF.

Standard:

- Red HI indicator is OFF.

CUE: HI indicator is OFF.

Standard:

- Green SAFE indicator is ON.

CUE: SAFE indicator is ON.

Standard:

- Percent hydrogen meter is <1% (dependent on plant conditions).

CUE: Meter reading is 1.6%.

Standard:

- PRESS ALARM indicator is OFF.

CUE: PRESS ALARM indicator is OFF.

Standard:

- FLOW ALARM indicator is OFF.

CUE: FLOW ALARM indicator is OFF.

Standard:

- TEMP ALARM indicator is OFF.

CUE: TEMP ALARM indicator is OFF.

Standard:

- SYSTEM STATUS ALARM is OFF.

CUE: SYSTEM STATUS ALARM is OFF.

Comment:

Performance Step: 8
(Step IV.B.1.a)**Standard:**

Obtain local temperature of the applicable Cable Vault (735') using a calibrated Fluke Thermometer (or equivalent).

Candidate obtains local temperature of the Cable Vault (735').

CUE: 4 minutes have elapsed. (Refer to Note prior to step IV.B.1)

CUE: The Cable Vault temperature is 87°F (simulated reading from Fluke Thermometer).

Comment:

Performance Step: 9
(Step IV.B.1.b)**Standard:**

Observe the indicated hydrogen concentration.

Candidate observes hydrogen concentration.

CUE: Hydrogen concentration is 1.6%.

Comment:

- √ **Performance Step: 10** Subtract the appropriate correction factor as determined from Figure 1.
(Step IV.B.1.c)

Standard: Candidate calculates actual hydrogen concentration by subtracting the correction factor found on Figure 1 from the indicated hydrogen concentration.

CUE: Containment pressure is 10 psia.

Standard: Candidate reports hydrogen concentration is 1% (+/- 0.2%)

NOTE: $1.6\% - 0.6\% = 1.0\%$
(Indicated - Correction = Actual)

Comment:

Terminating Cue: When the Candidate reports the hydrogen concentration, the evaluation for this JPM is complete.

STOP TIME: _____

JPM No.: 2005 NRC P1

Examinee's Name:

Examiner's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

_____Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's Signature: _____

Date: _____

INITIAL CONDITIONS:

A reactor trip and safety injection occurred 10 minutes ago due to a LOCA. A wide range hydrogen analyzer is to be placed in service. The 120VAC and 125VDC electrical distribution systems are operable.

INITIATING CUE:

The Unit Supervisor directs you to place the Train "B" wide range hydrogen analyzer in service and obtain a containment hydrogen sample using 1OM-46.4.G. Steps 1 - 3 of the procedure are complete. Report your results when completed.

Facility: **BVPS UNIT 1**

Task No: 0241-024-01-043

Task Title: Reset TDAFW Pump Trip Throttle ValveJPM No: 2005 NRC JPM P2K/A Reference: 061 A2.04 (3.4/3.8)
2.1.30 (3.9/3.4)

Examinee: _____

NRC Examiner: N/A

Facility Evaluator: _____

Date: _____

Method of Testing:Simulated Performance: X

Actual Performance _____

Classroom: _____

Simulator: _____

Plant: X**READ TO THE EXAMINEE**

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions: The Unit is at 50% power.

1FW-P-2, Steam Driven Auxiliary Feedwater Pump has tripped on overspeed. The Turbine Bldg. Operator has verified that the trip throttle valve is closed and no start signals exist for the pump.

TV-1MS-105A and TV-1MS-105B are closed. MOV-1MS-105 is open.

Task Standard: TDAFW pump trip throttle valve is reset IAW 1OM-24.4.V.

Required Materials: None

General References: 1OM-24.4.V, [1FW-P-2] Trip Throttle Valve Resetting, Rev. 4

Handouts: 1OM-24.4.V, [1FW-P-2] Trip Throttle Valve Resetting, Rev. 4

Initiating Cue: The Unit Supervisor directs you to reset the Turbine Driven AFW Pump trip throttle valve in accordance with 1OM-24.4.V.

Time Critical Task: NO

Validation Time: 15 minutes

JOB PERFORMANCE MEASURE

2005 NRC P2

(Denote Critical Steps with a check mark)

START TIME: _____

Performance Step: 1 Close or Verify Closed [TV-1MS-105A], Turb Steam Sup A Trm
(Step IV.A.1.a) Trip Vlv.

Standard: No action required. (Valve is closed per the Initial Conditions.)

Comments:

Performance Step: 2 Close or Verify Closed [TV-1MS-105B], Turb Steam Sup B Trm Trip
(Step IV.A.1.b) Vlv.

Standard: No action required per the JPM Initial Conditions.

Comments:

Performance Step: 3 Open or Verify Open [MOV-1MS-105], AFW Turb Steam Isol Vlv.
(Step IV.A.1.c)

Standard: No action required per the JPM Initial Conditions.

Comments:

PERFORMANCE INFORMATION

2005 NRC P2

- √ **Performance Step: 4** Press the Manual Emergency Trip Lever to verify that the Overspeed
(Step IV.A. 2) Trip Mechanism is tripped.

Standard: Candidate locates the trip mechanism and indicates it is in the tripped position.

CUE: The overspeed trip mechanism is tripped.

Comments:

Evaluator Note: Figure 1 depicts the overspeed trip device mechanism and may be referred to by the Candidate to assist in explaining the actions in the following steps.

- Performance Step: 5** Verify that [1MS-465], 1FW-T-2 Inlet Stm Isol, is unlatched.
(Step IV.A.3)

Standard: Candidate indicates that the valve is unlatched.

CUE: 1MS-465 is unlatched.

Comments:

- √ **Performance Step: 6** Turn [1MS-465], 1FW-T-2 Inlet Stm Isol, handwheel in the clockwise
(Step IV.A.4) direction until the sliding nut and trip lever rise to the upper limit of travel.

Standard: Candidate simulates turning 1MS-465 in the clockwise direction until the sliding nut and trip lever reach the upper limit.

CUE: The sliding nut and trip lever are at their upper limit.

Comments:

PERFORMANCE INFORMATION

2005 NRC P2

- √ **Performance Step: 7** Reset the Overspeed Trip Mechanism by performing the following:
(Step IV.A.5)

Standard:

Candidate simulates the following steps to reset the trip mechanism:

- Hold the overspeed trip connecting rod to the left.
- Verify the overspeed tappet washer flat side directly faces the overspeed trip lever.
- Release the connecting rod and allow the spring tension to maintain the reset condition.
- Verify the flat side of the washer is flush against the vertical side of the overspeed trip lever.
- Verify the trip lever is engaged with the trip hook.

CUE: The overspeed trip mechanism is reset.**Comments:**

- √ **Performance Step: 8** Slowly Open [1MS-465], 1FW-T-2 Inlet Stm Isol, by turning the
(Step IV.A.6) handwheel counterclockwise.

Standard:

Candidate simulates turning the handwheel counterclockwise.

CUE: 1MS-465 is open.**Comments:**

PERFORMANCE INFORMATION

2005 NRC P2

Performance Step: 9 Verify that the pump does **NOT** accelerate in an uncontrolled manner.
(Step IV.A.6)

Standard: Candidate indicates that the pump is not accelerating uncontrollably.

NOTE: The Candidate may explain that the pump will accelerate due to residual steam pressure in the steam supply line when 1MS-465 is opened.

Comments:

Performance Step: 10 WHEN Open, THEN adjust [1MS-465], 1FW-T-2 Inlet Stm Isol,
(Step IV.A.7) 1/4 turn off of the backseat.

Standard: Candidate simulates turning 1MS-465 until 1/4 of a turn off the backseat.

CUE: 1MS-465 is 1/4 of a turn off its backseat.

NOTE: If requested, inform the Candidate that another Operator will perform a concurrent verification of the valve position.

Comments:

Performance Step: 11 Notify the Unit 1 Control Room Operator that [1FW-P-2], Steam
(Step IV.A.8) Driven Auxiliary Feedwater Pump, is available.

Standard: Candidate informs the Control Room of the pump status.

CUE: As Control Room Operator, acknowledge report that the TD AFW pump is available.

Comments:

Terminating Cue:	When the Candidate notifies the Control Room that 1FW-P-2 is available, the evaluation for this JPM is complete.
-------------------------	--

STOP TIME: _____

VERIFICATION OF COMPLETION

2005 NRC P2

JPM No.: 2005 NRC P2

Examinee's Name:

Examiner's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

_____Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature: _____

Date: _____

INITIAL CONDITIONS:

The Unit is at 50% power.

1FW-P-2, Steam Driven Auxiliary Feedwater Pump has tripped on overspeed. The Turbine Bldg. Operator has verified that the trip throttle valve is closed and no start signals exist for the pump.

TV-1MS-105A and TV-1MS-105B are closed. MOV-1MS-105 is open.

INITIATING CUE:

The Unit Supervisor directs you to reset the Turbine Driven AFW Pump trip throttle valve in accordance with 1OM-24.4.V.

Facility: **BVPS Unit 1**

Task No: 0361-019-01-013

Task Title: BV-1 Actions To Establish Station
Blackout Cross-tie to Unit 2JPM No: 2005 NRC JPM P3K/A Reference: 055 EA1.06 (4.1/4.5) 055 EA2.03 (3.9/4.7)
055 G2.1.30 (3.9/3.4)

Examinee: _____

NRC Examiner: _____

Facility Evaluator: N/A

Date: _____

Method of Testing:Simulated Performance: X

Actual Performance: _____

Classroom: _____

Simulator: _____

Plant: X **READ TO THE EXAMINEE**

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions: A tornado strike has caused a partial loss of the switchyard. Unit 2 is without normal and emergency AC power. The Unit 2 Control Room has requested Unit 1 to establish a station blackout cross-tie from 4KV Bus 1DF.

Task Standard: Station cross-tie has been established in accordance with EOP Attachment A-1.14.

Required Materials: Cubicle Pictures

General References: 1OM-53A.1.A-1.14, BV-1 Actions To Establish Station Blackout Cross-tie To BV-2, Issue 1C, Rev. 2

Handouts: 1OM-53A.1.A-1.14, BV-1 Actions To Establish Station Blackout Cross-tie To BV-2, Issue 1C, Rev. 2

Tools: Racking Tool and Gear (Simulated)
Key No. 30 (Simulated)

Initiating Cue: The Unit Supervisor directs you to perform EOP Attachment A-1.14, Steps 11 and 12 to establish a station blackout cross-tie to Unit 2.

Time Critical Task: NO

Validation Time: 20 minutes

JOB PERFORMANCE MEASURE

2005 NRC P3

(Denote Critical Steps with a check mark)

START TIME: _____

NOTE: Remind Candidate to simulate all actions and NOT to reach inside any switchgear or relay panel cabinets.
--

NOTE: Relay Panels and Bus UV cubicles are NOT to be opened. Provide Candidates with a picture of cabinet internals as appropriate.

√ **Performance Step: 1** To Defeat Diesel Generator Trips, perform the following:
(Step 11.a) Open Knife Switch 3-771 (Loss of Field) on left inside [PNL-REL-21],
(Relay Room)

Standard: Candidate locates Relay Room Panel 21 [PNL-REL-21].

Standard: Candidate locates and opens Knife Switch 3-771 (Loss of Field).

CUE: Knife Switch 3-771 is open.

NOTE: Refer to attached picture.

Comments:

√ **Performance Step: 2** To Defeat Diesel Generator Trips, perform the following:
(Step 11.a) Open Knife Switch 2-688 (Rev Pwr) on left inside [PNL-REL-22],
(Relay Room)

Standard: Candidate locates Relay Room Panel 22 [PNL-REL-22].

Standard: Candidate locates and opens Knife Switch 2-688 (Reverse Power).

CUE: Knife Switch 2-688 is open.

NOTE: Refer to attached picture.

Comments:

PERFORMANCE INFORMATION

2005 NRC P3

-
- √ **Performance Step: 3** To defeat 4KV emergency bus undervoltage trip, open 125 VDC
(Step 11.b) control breaker in Cubicle F8A (1DF bus).

Standard: Candidate locates 4KV Bus 1DF, Cubicle F8A.

Standard: Candidate locates and opens 125VDC control power breaker.

CUE: 125VDC control power breaker is open.

Comments:

- √ **Performance Step: 4** To defeat 480V emergency bus undervoltage trip, open 125 VDC
(Step 11.c) circuit breaker "Bus U/V DC" (1P bus)

Standard: Candidate locates 480V Bus 1P.

Standard: Candidate locates and opens 125 VDC circuit breaker "Bus U/V DC".

CUE: 125VDC circuit breaker is open.

Comments:

- √ **Performance Step 5:** Open [ACB-1D3] 480V Substation 1-2 Bus 1D And 480V Substation
(Step 12.a) 1-4 Bus 1H Breaker.

Standard: Candidate locates and opens ACB-1D3 using the control switch.

CUE: ACB-1D3 is open.

Comments:

PERFORMANCE INFORMATION

2005 NRC P3

Performance Step: 6 Open [ACB-1D13], Air Conditioning Chilled Water Unit [1VS-E-3C].
(Step 12.b)

Standard: Candidate locates and opens ACB-1D13 using the control switch or local pushbutton.

CUE: ACB-1D13 is open.

Comments:

NOTE: Prior to racking in breaker, Candidate may verbalize donning flash suit and 4KV switching gloves. Candidate may open ACB-1A8 cubicle door to demonstrate actions to be taken or provide the Candidate with a 4KV breaker diagram (attached).

✓ **Performance Step: 7** With Key 30, [1D5] SBO Bkr, remove padlock from [ACB-1D5], Unit 1
(Step 12.c.1) To Bus 1D Cross-tie.

Standard: Candidate obtains Key No. 30.

CUE: Use of the key is simulated.

Standard: Candidate locates ACB-1D5 and removes padlock using Key 30.

CUE: Padlock is removed.

Comments:

PERFORMANCE INFORMATION2005 NRC P3

- √ **Performance Step: 8** Verify DC Control Power - OFF
(Step 12.c.2)

Standard: Candidate locates and opens DC control power breaker.

CUE: Control power breaker is off.

Comments:

- √ **Performance Step: 9** Verify charging springs are discharged by pulling the manual close
(Step 12.c.3, 4 & 5) lever.

Standard: Candidate locates and then holds down the manual trip button.

Standard: Candidate locates and pulls the manual close lever.

Standard: Candidate releases the manual trip button.

CUE: Charging springs are discharged.

Comments:

- Performance Step: 10** Verify that the breaker mechanical indicator is in the OPEN position.
(Step 12.c.6)

Standard: Candidate locates and verifies the mechanical flag indicates open.

CUE: Mechanical flag is in the open position.

Comments:

PERFORMANCE INFORMATION2005 NRC P3

- √ **Performance Step: 11** Rack the breaker to the CONNECT position.
(Step 12.c.7)

Standard: Candidate turns the lock release lever to the left, inserts racking tool and turns clockwise until reaching the connect position.

CUE: Breaker is in the connect position.

Comments:

- Performance Step: 12** Verify charging spring motor disconnect toggle switch - ON.
(Step 12.c.8)

Standard: Candidate locates and verifies the charging spring motor disconnect switch is on.

CUE: Charging spring motor disconnect switch is on.

Comments:

- √ **Performance Step: 13** Close DC control power breaker.
(Step 12.c.9)

Standard: Candidate locates and closes the DC control power breaker.

CUE: DC control power breaker is closed and the closing springs are charged.

Comments:

PERFORMANCE INFORMATION

2005 NRC P3

- √ **Performance Step: 14** Manually close [ACB-1D5], Unit 2 To Bus 1D Cross-tie using
(Step 12.c.10) breaker control switch.

Standard: Candidate locates and closes ACB-1D5 using the control switch.

Standard: Candidate verifies red light is on.

CUE: Breaker is closed.

NOTE: Ensure the breaker door is shut and fastened.

Comments:

Terminating Cue: When the Candidate completes the actions to close breaker ACB-1D5, the evaluation for this JPM is complete.

STOP TIME: _____

PERFORMANCE INFORMATION

2005 NRC P3

JPM No.: 2005 NRC P3

Examinee's Name:

Examiner's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

_____Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature: _____

Date: _____

INITIAL CONDITIONS:

A tornado strike has caused a partial loss of the switchyard.

Unit 2 is without normal and emergency AC power. The Unit 2 Control Room has requested Unit 1 to establish a station blackout cross-tie from 4KV Bus 1DF.

INITIATING CUE:

The Unit Supervisor directs you to perform EOP Attachment A-1.14, Steps 11 and 12 to establish a station blackout cross-tie to Unit 2.