
### **ENCLOSURE 1**

Edwin I. Hatch Nuclear Plant Annual Radiological Environmental Operating Report for 2004

## EDWIN I. HATCH NUCLEAR PLANT ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT FOR 2004





Energy to Serve Your World"

### TABLE OF CONTENTS

Title and/or Section	Subsection	Page
List of Figures		ii
List of Tables		iii
List of Acronyms		iv
1.0 Introduction		1-1
2.0 REMP Description		2-1
3.0 Results Summary		3-1
4.0 Discussion of Results		4-1
	4.1 Land Use Census and River Survey	4-5
	4.2 Airborne	4-7
	4.3 Direct Radiation	4-12
	4.4 Milk	4-18
	4.5 Vegetation	4-22
	4.6 River Water	4-25
	4.7 Fish	4-28
	4.8 Sediment	4-32
5.0 Interlaboratory		
Comparison Program (ICP)		5-1
6.0 Conclusions		6-1

### **LIST OF FIGURES**

Figure Number	Title	Page
Figure 2-1	REMP Stations Near the Plant	2-7
Figure 2-2	REMP Stations Beyond Six Miles from the Plant	2-8
Figure 4.2-1	Average Weekly Gross Beta Air Concentration	4-7
Figure 4.2-2	Average Annual Cs-137 Concentration in Air	4-9
Figure 4.3-1	Average Quarterly Exposure from Direct Radiation	4-13
Figure 4.3-2	Average Quarterly Exposure from Direct Radiation at	
	Special Interest Areas	4-15
Figure 4.4-1	Average Annual Cs-137 Concentration in Milk	4-18
Figure 4.4-2	Average Annual I-131 Concentration in Milk	4-20
Figure 4.5-1	Average Annual Cs-137 Concentration in Vegetation	4-23
Figure 4.6-1	Average Annual H-3 Concentration in River Water	4-26
Figure 4.7-1	Average Annual Cs-137 Concentration in Fish	4-28
Figure 4.7-2	Average Annual Cs-134 Concentration in Fish	4-30
Figure 4.8-1	Average Annual Co-60 Concentration in Sediment	4-32
Figure 4.8-2	Average Annual Cs-137 Concentration in Sediment	4-34
Figure 4.8-3	Average Annual Indicator Station Concentrations	
	of Select Nuclides in Sediment	4-36

### **LIST OF TABLES**

Table Number	Title	Page
Table 2-1	Summary Description of Radiological Environmental	
	Monitoring Program	2-2
Table 2-2	Radiological Environmental Sampling Locations	2-5
Table 3-1	Radiological Environmental Monitoring Program	
	Annual Summary	3-2
Table 4-1	Minimum Detectable Concentrations (MDC)	4-1
Table 4-2	Reporting Levels (RL)	4-2
Table 4-3	Deviations from Radiological Environmental	
	Monitoring Program	4-4
Table 4.1-1	Land Use Census Results	4-5
Table 4.2-1	Average Weekly Gross Beta Air Concentration	4-8
Table 4.2-2	Average Annual Cs-137 Concentration in Air	4-10
Table 4.3-1	Average Quarterly Exposure from Direct Radiation	4-14
Table 4.3-2	Average Quarterly Exposure from Direct Radiation at	
	Special Interest Areas	4-16
Table 4.4-1	Average Annual Cs-137 Concentration in Milk	4-19
Table 4.4-2	Average Annual I-131 Concentration in Milk	4-21
Table 4.5-1	Average Annual Cs-137 Concentration in Vegetation	4-24
Table 4.6-1	Average Annual H-3 Concentration in River Water	4-27
Table 4.7-1	Average Annual Cs-137 Concentration in Fish	4-29
Table 4.7-2	Average Annual Cs-134 Concentration in Fish	4-31
Table 4.8-1	Average Annual Co-60 Concentration in Sediment	4-33
Table 4.8-2	Average Annual Cs-137 Concentration in Sediment	4-35
Table 4.8-3	Sediment Nuclide Concentrations Other Than Co-60 &	
	Cs-137	4-37
Table 5-1	Interlaboratory Comparison Results	5-3

### **LIST OF ACRONYMS**

Acronyms presented in alphabetical order.

Acronym	Definition
ASTM	American Society for Testing and Materials
CL	Confidence Level
EL	Georgia Power Company Environmental Laboratory
EPA	Environmental Protection Agency
GPC	Georgia Power Company
HNP	Edwin I. Hatch Nuclear Plant
ICP	Interlaboratory Comparison Program
MDC	Minimum Detectable Concentration
MDD	Minimum Detectable Difference
NA	Not Applicable
NDM	No Detectable Measurement(s)
NRC	Nuclear Regulatory Commission
ODCM	Offsite Dose Calculation Manual
Po	Preoperation
REMP	Radiological Environmental Monitoring Program
RL	Reporting Level
TLD	Thermoluminescent Dosimeter
TS	Technical Specification

### 1.0 INTRODUCTION

The Radiological Environmental Monitoring Program (REMP) is conducted in accordance with Chapter 4 of the Offsite Dose Calculation Manual (ODCM). REMP activities for 2004 are reported herein in accordance with Technical Specification (TS) 5.6.2 and ODCM 7.1.

The objectives of the REMP are to:

- 1) Determine the levels of radiation and the concentrations of radioactivity in the environs and;
- 2) Assess the radiological impact (if any) to the environment due to the operation of the Edwin I. Hatch Nuclear Plant (HNP).

The assessments include comparisons between the results of analyses of samples obtained at locations where radiological levels are not expected to be affected by plant operation (control stations) and at locations where radiological levels are more likely to be affected by plant operation (indicator stations), as well as comparisons between preoperational and operational sample results.

The pre-operational stage of the REMP began with the establishment and activation of the environmental monitoring stations in January of 1972. The operational stage of the REMP began on September 12, 1974 with Unit 1 initial criticality.

A description of the REMP is provided in Section 2 of this report. An annual summary of the results of the analyses of REMP samples is provided in Section 3. A discussion of the results, including assessments of any radiological impacts upon the environment, and the results of the land use census and the river survey, are provided in Section 4. The results of the Interlaboratory Comparison Program (ICP) are provided in Section 5. Conclusions are provided in Section 6.

### 2.0 REMP DESCRIPTION

A summary description of the REMP is provided in Table 2-1. This table summarizes the program as it meets the requirements outlined in ODCM Table 4-1. It details the sample types to be collected and the analyses to be performed in order to monitor the airborne, direct radiation, waterborne and ingestion pathways, and also delineates the collection and analysis frequencies. The sampling locations (stations) specified by ODCM 4.2 are depicted on maps in Figures 2-1 and 2-2. These maps are keyed to Table 2-2 which delineates the direction and distance of each station from the main stack.

REMP samples are collected by Georgia Power Company's (GPC) Environmental Laboratory (EL) personnel. The same lab performs all the laboratory analyses at their headquarters in Smyrna, Georgia.

### **TABLE 2-1 (SHEET 1 of 3)**

### SUMMARY DESCRIPTION OF RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

Exposure Pathway and/or Sample	Approximate Number of Sample Locations	Sampling and Collection Frequency	Type of Analysis and Frequency
Airborne     Radioiodine and     Particulates	6	Continuous operation of the sampler with sample collection weekly.	Radioiodine canister: I-131 analysis, weekly.  Particulate sampler: analyze for gross beta radioactivity not less than 24 hours following filter change, weekly; perform gamma isotopic analysis on affected sample when gross beta activity is 10 times the yearly mean of control samples; and composite (by location) for gamma isotopic analysis, quarterly.
2. Direct Radiation	37	Quarterly	Gamma dose, quarterly.
3. Ingestion			
Milk (a)	1	Biweekly	Gamma isotopic and I-131 analysis, biweekly.
Fish or Clams (b)	2	Semiannually	Gamma isotopic analysis on edible portions, semiannually.
Grass or Leafy Vegetation	3	Monthly during growing season.	Gamma isotopic analysis, monthly. (c)
4. Waterborne	<u> </u>		
Surface	2	Composite sample collected monthly. (d)	Gamma isotopic analysis, monthly. Composite (by location) for tritium analysis, quarterly.
Sediment	2	Semiannually.	Gamma isotopic analysis, semiannually.

### TABLE 2-1 (SHEET 2 of 3)

### SUMMARY DESCRIPTION OF RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

Exposure Pathway and/or Sample	Approximate Number of Sample Locations	Sampling and Collection Frequency	Type of Analysis and Frequency
Drinking Water (e & f)	One sample of river water near the intake and one sample of finished water from each of one to three of the nearest water supplies which could be affected by HNP discharges.	River water collected near the intake will be a composite sample; the finished water will be a grab sample. These samples will be collected monthly unless the calculated dose due to consumption of the water is greater than 1 mrem/year; then the collection will be biweekly. The collections may revert to monthly should the calculated doses become less than 1 mrem/year.	I-131 analysis on each sample when biweekly collections are required. Gross beta and gamma isotopic analysis on each sample; composite (by location) for tritium analysis, quarterly.

### **TABLE 2-1 (SHEET 3 of 3)**

#### SUMMARY DESCRIPTION OF RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

#### Notes:

- a. Up to three sampling locations within 5 miles and in different sectors will be used as available. In addition, one or more control locations beyond 10 miles will be used.
- b. Commercially or recreationally important fish may be sampled. Clams may be sampled if difficulties are encountered in obtaining sufficient fish samples.
- c. If gamma isotopic analysis is not sensitive enough to meet the Minimum Detectable Concentration (MDC), a separate analysis for I-131 may be performed.
- d. The composite samples shall be composed of a series of aliquots collected at intervals not exceeding a few hours.
- e. If it is found that river water downstream of the plant is used for drinking, drinking water samples will be collected and analyzed as specified herein.
- f. A survey shall be conducted annually at least 50 river miles downstream of the plant to identify those who use water from the Altamaha River for drinking.

### **TABLE 2-2 (SHEET 1 of 2)**

### RADIOLOGICAL ENVIRONMENTAL SAMPLING LOCATIONS

Station	Station	Descriptive Location	Direction	Distance (a)	Sample Type
Number	Type Other	Roadside Park	(a) WNW	(miles) 0.8	Direct Rad
064					
101	Indicator Indicator	Inner Ring	N NNE	1.9	Direct Rad Direct Rad
102	Indicator	Inner Ring	NE NE	1.8	Airborne Rad
103	Indicator	Inner Ring	NE	1.8	Direct Rad
104	Indicator	Inner Ring	ENE	1.6	Direct Rad
105	Indicator	Inner Ring	E	3.7	Direct Rad
106	Indicator	Inner Ring	ESE	1.1	Direct Rad
100	Hidicator	Inner King	LOE	1.1	Vegetation
107	Indicator	Inner Ring	SE	1.2	Airborne Rad
107	naicator	I milet King	) SL	1.2	Direct Rad
108	Indicator	Inner Ring	SSE	1.6	Direct Rad
109	Indicator	Inner Ring	S	0.9	Direct Rad
110	Indicator	Inner Ring	SSW	1.0	Direct Rad
111	Indicator	Inner Ring	SW	0.9	Direct Rad
112	Indicator	Inner Ring	WSW	1.0	Airborne Rad
Į.					Direct Rad
				l	Vegetation
113	Indicator	Inner Ring	W	1.1	Direct Rad
114	Indicator	Inner Ring	WNW	1.2	Direct Rad
115	Indicator	Inner Ring	NW_	1.1	Direct Rad
116	Indicator	Inner Ring	NNW	1.6	Airborne Rad
					Direct Rad
170	Control	Upstream	WNW	(c)	River (b)
172	Indicator	Downstream	E	(c)	River (b)
201	Other	Outer Ring	N	5.0	Direct Rad
202	Other	Outer Ring	NNE	4.9	Direct Rad
203	Other	Outer Ring	NE	5.0	Direct Rad
204	Other	Outer Ring	ENE	5.0	Direct Rad
205	Other	Outer Ring	E	7.2	Direct Rad
206	Other	Outer Ring	ESE	4.8	Direct Rad
207	Other	Outer Ring	SE	4.3	Direct Rad
208	Other	Outer Ring	SSE	4.8	Direct Rad
209	Other	Outer Ring	S	4.4	Direct Rad
210	Other	Outer Ring	SSW	4.3	Direct Rad
211	Other	Outer Ring	SW	4.7	Direct Rad
212	Other	Outer Ring	WSW	4.4	Direct Rad
213 214	Other	Outer Ring	WNW	4.3	Direct Rad
214	Other	Outer Ring	NW NW	5.4	Direct Rad
215	Other Other	Outer Ring Outer Ring	NNW	4.4	Direct Rad Direct Rad
301	Other	Toombs Central School	NNW	8.0	Direct Rad Direct Rad
304	Control	State Prison	ENE	11.2	Airborne Rad
304	Connoi	State FIISUII	ENE	11.4	Direct Rad
304	Control	State Prison	ENE	10.3	Milk
309	Control	Baxley	S	10.0	Airborne Rad
309	Collubi	Substation	١٥	10.0	Direct Rad
416	Control	Emergency News	NNW	21.0	Direct Rad
410	Control	Center	1414 44	21.0	Vegetation Vegetation
		Collei	L	<u> </u>	vegetation

### **TABLE 2-2 (SHEET 2 of 2)**


#### RADIOLOGICAL ENVIRONMENTAL SAMPLING LOCATIONS


#### Notes:

- a. Direction and distance are determined from the main stack.
- b. River (fish or clams, shoreline sediment, and surface water)
- c. Station 170 is located approximately 0.6 river miles upstream of the intake structure for river water, 1.1 river miles for sediment and clams, and 1.5 river miles for fish.

Station 172 is located approximately 3.0 river miles downstream of the discharge structure for river water, sediment and clams, and 1.7 river miles for fish.

The locations from which river water and sediment may be taken can be sharply defined. However, the sampling locations for clams often have to be extended over a wide area to obtain a sufficient quantity. High water adds to the difficulty in obtaining clam samples and may also make an otherwise suitable location for sediment sampling unavailable. A stretch of the river of a few miles or so is generally needed to obtain adequate fish samples. The mile locations given above represent approximations of the locations where samples are collected.





### 3.0 RESULTS SUMMARY

In accordance with ODCM 7.1.2.1, the summarized and tabulated results for all of the regular samples collected for the year at the designated indicator and control stations are presented in Table 3-1. The format of Table 3-1 is similar to Table 3 of the Nuclear Regulatory Commission (NRC) Branch Technical Position, "An Acceptable Radiological Environmental Monitoring Program", Revision 1, November 1979. Since no naturally occurring radionuclides were found in the plant's effluent releases, only man-made radionuclides are reported as permitted by ODCM 7.1.2.1. Results for samples collected at locations other than control or indicator stations are discussed in Section 4 under the particular sample type.

### **TABLE 3-1 (SHEET 1 of 4)**

### RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY

Edwin I. Hatch Nuclear Plant, Docket Nos. 50-321 and 50-366 Appling County, Georgia

Medium or Pathway Sampled (Unit of Measurement)	Type and Total Number of Analyses Performed	Minimum Detectable Concentration (MDC) (a)	Indicator Locations Mean (b), Range (Fraction)	Annual I Name Distance	· · · · · · · · · · · · · · · · · · ·		Control Locations Mean (b), Range (Fraction)
Airborne Particulates (fCi/m3)	Gross Beta 309 Gamma Isotopic 24	10	21.4 6.3-43.1 (206/206)	No. 112 Indicator 1.0 mile, WSW	22.8 10.2-43.1 (50/50)	NA	21.2 7.2-38.6 (103/103)
	Cs-134 Cs-137	50 60	NDM (c) NDM		NDM NDM		NDM NDM
Airborne Radioiodine (fCi/m3)	I-131 309	70	NDM		NDM	NA	NDM
Direct Radiation (mR/91 days)	Gamma Dose 146	NA (d)	12.2 9.4-16.9 (63/63)	No. 214(e) Outer Ring 5.4 miles, WNW	15.6 14.2-16.7 (4/4)	12.2 8.7-16.7 (71/71)	12.4 9.7-14.5 (12/12)
Milk (pCi/l)	Gamma Isotopic 26 Cs-134 Cs-137 Ba-140 La-140 I-131 26	15 18 60 15	NA NA NA NA NA		NDM NDM NDM NDM NDM	NA	NDM NDM NDM NDM NDM

### **TABLE 3-1 (SHEET 2 of 4)**

### RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY

Edwin I. Hatch Nuclear Plant, Docket Nos. 50-321 and 50-366 Appling County, Georgia

Medium or	Type and	Minimum	Indicator		h the Highest	Control
Pathway	Total Number	Detectable	Locations	Annual Mean		Locations
Sampled	of Analyses	Concentration	Mean (b),		3.5 (1)	Mean (b),
(Unit of	Performed	(MDC) (a)	Range	Name Distance	Mean (b),	Range
Measurement)			(Fraction)	& Direction	Range (Fraction)	(Fraction)
Vegetation	Gamma					
(pCi/kg-wet)	Isotopic					
	36	1				
	I-131	60	NDM		NDM	NDM
	Cs-134	60	NDM		NDM	NDM
i	Cs-137	80	41.6	Station 106	50.4	43.5
			14.4-98.9	Inner Ring	29.2-98.9	30.0-62.9
!			(14/24)	1.1 miles; ESE	(7/12)	(5/12)
River Water	Gamma					
(pCi/l)	Isotopic					
	24					
	Mn-54	15	NDM		NDM	NDM
	Fe-59	30	NDM		NDM	NDM
i	Co-58	15	NDM		NDM	NDM
	Co-60	15	NDM		NDM	NDM
	Zn-65	30	NDM		NDM	NDM
	Zr-95	30	NDM		NDM	NDM
	Nb-95	15	NDM		NDM	NDM
	I-131	15 (f)	NDM		NDM	NDM
1	Cs-134	15	NDM		NDM	NDM
	Cs-137	18	NDM		NDM	NDM
	Ba-140	60	NDM		NDM	NDM
	La-140	15	NDM		NDM	NDM
	Tritium	3000 (g)	206	No. 170	302	302
	8		206-206	0.6 miles	302-302	302-302
			(1/4)	Upstream	(1/4)	(1/4)

### **TABLE 3-1 (SHEET 3 of 4)**

### RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY

Edwin I. Hatch Nuclear Plant, Docket Nos. 50-321 and 50-366 Appling County, Georgia

Medium or Pathway Sampled (Unit of Measurement)	Type and Total Number of Analyses Performed	Minimum Detectable Concentration (MDC) (a)	Indicator Locations Mean (b), Range (Fraction)	Location with the Highest Annual Mean  Name Distance Mean (b), & Direction Range (Fraction)		Control Locations Mean (b), Range (Fraction)
Fish (pCi/kg-wet)	Gamma Isotopic 6 Mn-54 Fe-59 Co-58 Co-60 Zn-65 Cs-134 Cs-137	130 260 130 130 260 130 150	NDM NDM NDM NDM NDM NDM 11.6 9.0-13.3 (3/3)	No. 170 1.5 miles Upstream	NDM NDM NDM NDM NDM NDM 11.6 9.0-13.3 (3/3)	NDM NDM NDM NDM NDM NDM 18.8 15.2-22.3 (2/3)
Sediment (pCi/kg-dry)	Gamma Isotopic 4 Cs-134 Cs-137	150 180	NDM 59.5 43.9-75.0 (2/2)	No. 172 3.0 miles Downstream	NDM 59.5 43.9-75.0 (2/2)	NDM 57.1 27.1-87.2 (2/2)

### **TABLE 3-1 (SHEET 4 of 4)**

# RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM ANNUAL SUMMARY Edwin I. Hatch Nuclear Plant, Docket Nos. 50-321 and 50-366 Appling County, Georgia

#### **NOTATIONS**

- a. The MDC is defined in ODCM 10.1. Except as noted otherwise, the values listed in this column are the detection capabilities required by ODCM Table 4-3. The values listed in this column are a priori (before the fact) MDCs. In practice, the a posteriori (after the fact) MDCs are generally lower than the values listed. Any a posteriori MDC greater than the value listed in this column is discussed in Section 4.
- b. Mean and range are based upon detectable measurements only. The fraction of all measurements at specified locations that are detectable is placed in parenthesis.
- c. No Detectable Measurement(s).
- d. Not Applicable.
- e. This station is in the outer ring and is one of eighteen "other (h)" stations.
- f. If a drinking water pathway were to exist, a MDC of 1 pCi/l would have been used (see Table 4-1 of this report).
- g. If a drinking water pathway were to exist, a MDC of 2000 pCi/l would have been used (see Table 4-1 of this report).
- h. "Other" stations, identified in the "station type" column of Table 2-2, include community and special stations.

### 4.0 DISCUSSION OF RESULTS

Included in this section are evaluations of the laboratory results for the various sample types. Comparisons were made between the difference in mean values for pairs of station groups (e.g., indicator and control stations) and the calculated Minimum Detectable Difference (MDD) between these pairs at the 99% Confidence Level (CL). The MDD was determined using the standard Student's t-test. A difference in the mean values which was less than the MDD was considered to be statistically indiscernible.

The 2004 results were compared with past results, including those obtained during pre-operation. As appropriate, results were compared with their Minimum Detectable Concentrations (MDC) and Reporting Levels (RL) which are listed in Tables 4-1 and 4-2 of this report, respectively. The required MDCs were achieved during laboratory sample analyses. Any anomalous results are explained within this report.

Results of interest are graphed to show historical trends. The data points are tabulated and included in this report. The points plotted and provided in the tables represent mean values of only detectable results. Periods for which no detectable measurements (NDM) were observed or periods for which values were not applicable (e.g., milk indicator, etc.) are plotted as and listed in the tables as 0's.

Table 4-1

Minimum Detectable Concentrations (MDC)

Analysis	Water (pCi/l)	Airborne Particulate or Gases (fCi/m3)	Fish (pCi/kg- wet)	Milk (pCi/l)	Grass or Leafy Vegetation (pCi/kg-wet)	Sediment (pCi/kg- dry)
Gross Beta	4	10				
H-3	2000 (a)					
Mn-54	15		130			
Fe-59	30		260			
Co-58	15		130	<u> </u>		
Co-60	15		130		T	
Zn-65	30		260			
Zr-95	30					
Nb-95	15					
I-131	1 (b)	70		1	60	
Cs-134	15	50	130	15	60	150
Cs-137	18	60	150	18	80	180
Ba-140	60		<del>_</del>	60		l
La-140	15			15		

<sup>(</sup>a) If no drinking water pathway exists, a value of 3000 pCi/l may be used.

<sup>(</sup>b) If no drinking water pathway exists, a value of 15 pCi/l may be used.

Table 4-2
Reporting Levels (RL)

Analysis	Water (pCi/l)	Airborne Particulate or Gases (fCi/m3)	Fish (pCi/kg-wet)	Milk (pCi/l)	Grass or Leafy Vegetation (pCi/kg-wet)
H-3	20,000 (a)				
Mn-54	1000		30,000		
Fe-59	400		10,000		
Co-58	1000		30,000		
Co-60	300		10,000	<u>-</u>	
Zn-65	300		20,000		
Zr-95	400				
Nb-95	700				
I-131	2 (b)	900		3	100
Cs-134	30	10,000	1000	60	1000
Cs-137	50	20,000	2000	70	2000
Ba-140	200			300	
La-140	100			400	

<sup>(</sup>a) This is the 40 CFR 141 value for drinking water samples. If no drinking water pathway exists, a value of 30,000 may be used.

<sup>(</sup>b) If no drinking water pathway exists, a value of 20 pCi/l may be used.

Atmospheric nuclear weapons tests from the mid 1940s through 1980 distributed man-made nuclides around the world. The most recent atmospheric tests in the 1970s and in 1980 had a significant impact upon the radiological concentrations found in the environment prior to and during preoperation, and the earlier years of operation. Some long lived radionuclides, such as Cs-137, continue to be detectable.

Significant upward trends also followed the Chernobyl incident which began on April 26, 1986.

In accordance with ODCM 4.1.1.2.1, deviations from the required sampling schedule are permitted, if samples are unobtainable due to hazardous conditions, unavailability, inclement weather, equipment malfunction or other just reasons. Deviations from conducting the REMP as described in Table 2-1 are summarized in Table 4-3 along with their causes and resolutions.

All results were tested for conformance to Chauvenet's criterion (G. D. Chase and J. L. Rabinowitz, <u>Principles of Radioisotope Methodology</u>, Burgess Publishing Company, 1962, pages 87-90) to identify values which differed from the mean of a set by a statistically significant amount. Identified outliers were investigated to determine the reason(s) for the difference. If equipment malfunction or other valid physical reasons were identified as causing the variation, the anomalous result was excluded from the data set as non-representative. No data were excluded exclusively for failing Chauvenet's criterion. Data exclusions are discussed in this section under the appropriate sample type.

TABLE 4-3
DEVIATIONS FROM RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

COLLECTION PERIOD	AFFECTED SAMPLES	DEVIATION	CAUSE	RESOLUTION
01/20/04-01/26/04	Air sampling station 107	Heavy particulates on filter.	Controlled burn by Land Department.	Contacted Land Dept. and asked that GPC be notified prior to controlled burns.
1 <sup>st</sup> Quarter 2004	TLD station 110	Direct radiation exposure results for the first half of the first quarter were not obtained.	TLDs were destroyed by controlled burn.	Contacted Land Dept. and asked that GPC be notified prior to controlled burns.
03/01/04-03/08/04	Air sampling station 304	Non-representative sample of airborne particulates.	Filter not aligned correctly. Windy weather conditions may have caused the filter to move as the filter head was being replaced.	Ensure filter aligned correctly in filter housing. Use extra precautions during adverse weather conditions.
04/26/04-05/03/04	Air sampling station 112	Non-representative sample of airborne particulates.	Air sampling not performed for approximately 10 hours. Lightning hit the supplying substation.	Power restored to air sampling station.
2 <sup>nd</sup> Quarter 2004	TLD station 203	Direct radiation exposure results for the first half of the second quarter were not obtained.	TLD packet was missing at the mid- quarter inspection.	The TLDs were replaced at mid-quarter.
08/30/04-09/07/04	Air sampling station 112	Non-representative sample of airborne particulates.	Air sampling not performed for approximately 24 hours. No power to air station. Trees fell on electrical lines during Hurricane Frances.	Power was restored to air sampling station on 9/13/04.
09/07/04-09/13/04	Air sampling station 112	Non-representative sample of airborne particulates.	Air sampling not performed during the week. No power to air station. Trees fell on electrical lines during Hurricane Frances.	Power was restored to air sampling station on 9/13/04.

### 4.1 Land Use Census and River Survey

In accordance with ODCM 4.1.2, a land use census was conducted on November 8 and 9, 2004, to determine the locations of the nearest permanent residence and milk animal in each of the 16 compass sectors within a distance of 5 miles, and the locations of all milk animals within a distance of 3 miles. A milk animal is defined as a cow or goat producing milk for human consumption. The locations of beef cattle and of gardens greater than 500 square feet producing broad leaf vegetation were also included in the census. The census results are tabulated in the Table 4.1-1.

Table 4.1-1

LAND USE CENSUS RESULTS

#### Distance in Miles to Nearest Location in Each Sector

SECTOR	RESIDENCE	MILK ANIMAL	BEEF CATTLE	GARDEN
N	2.1	None	None	3.8
NNE	2.9	None	None	2.9
NE	3.3	None	None	None
ENE	4.2	None	4.1	None
E	3.0	None	None	None
ESE	3.8	None	None	None
SE	1.8	None	2.3	3.3
SSE	2.0	None	2.2	2.1
S	1.0	None	2.3	2.3
SSW	1.1	None	2.0	2.7
SW	1.1	None	2.3	1.6
WSW	1.0	None	1.6	1.7
W	1.1	None	2.8	1.3
WNW	1.1	None	None	None
NW	3.6	None	4.6	4.3
NNW	1.8	None	4.5	3.0

ODCM 4.1.2.2.1 requires a new controlling receptor to be identified if the land use census identifies a location that yields a calculated receptor dose greater than the one in current use. No change in the controlling receptor was required as a result of the 2004 land use census. The current controlling receptor as described in ODCM Table 3-7 is a child in the WSW Sector at 1.2 miles

ODCM 4.1.2.2.2 requires that whenever the land use census identifies a location which would yield a calculated dose (via the same ingestion pathway) 20% greater than that of a current indicator station, the new location must become a REMP station (if samples are available). The 2004 land use census did not identify a garden which yielded a calculated dose 20% greater than that for any of the current indicator stations for vegetation. The results of the census were corroborated by inquiries to the county extension agents in the 5 counties in the vicinity of the plant.


As required by Note f of Table 2-1, the annual survey of the Altamaha River for 50 miles downstream of the plant was conducted on September 20, 2004 to identify any withdrawal of river water for drinking purposes. No sources of withdrawal for drinking water were identified. Information obtained from the Georgia Department of Natural Resources on October 1, 2004 indicated that no surface water withdrawal permit for drinking purposes or irrigation had been issued for this stretch of the Altamaha River between the 2003 survey and the 2004 survey. Should it be determined that river water downstream of the plant is being used for drinking, the sampling and analysis requirements for drinking water found in Table 2-1 would be implemented.

### 4.2 Airborne

As indicated in Table 2-2 and Figures 2-1 and 2-2, airborne particulates and airborne radioiodine are collected at 4 indicator stations (Nos. 103, 107, 112 and 116) which encircle the plant near the site periphery and at 2 control stations (Nos. 304 and 309) which are located approximately 10 miles from the main stack. At each location, air is continuously drawn through a glass fiber filter and a charcoal canister placed in series to collect airborne particulates and radioiodine. The filters and canisters are collected weekly and analyzed for gross beta and I-131, respectively. A gamma isotopic analysis is performed quarterly on a composite of the filters for each station.

The 2004 annual average weekly gross beta concentration of 21.37 fCi/m³ for the indicator stations was 0.12 fCi/m³ greater than that for the control stations (21.25 fCi/m³. This difference is not statistically discernible, since it is less than the calculated MDD of 1.95 fCi/m³. Figure 4.2-1 and Table 4.2-1 provide the historical trending of the average weekly gross beta concentrations in air. In general, there is close agreement between the results for the indicator and control stations. This close agreement supports the position that the plant is not contributing significantly to the gross beta concentration in air.

**Figure 4.2-1** 



C-03


Table 4.2-1

Average Weekly Gross Beta Air Concentration

Year	Indicator (fCi/m3)	Control (fCi/m3)
Pre-op	140	140
1974	87	90
1975	85	90
1976	135	139
1977	239	247
1978	130	137
1979	38	39
1980	49	48
1981	191	203
1982	33	34
1983	31	30
1984	26	28
1985	22	21
1986	36	38
1987	23	22
1988	22.6	21.7
1989	18.4	17.8
1990	19.3	18.7
1991	18.1	18
1992	18.5	18.4
1993	20.4	20.7
1994	19.5	19.7
1995	21.7	21.7
1996	21.3	21.4
1997	20.3	20.7
1998	20.0	20.5
1999	21.3	21.3
2000	23.6	23.9
2001	21.5	21.0
2002	19.3	19.2
2003	18.8	18.2
2004	21,4	21.3

During 2004, no man-made radionuclides were detected from the gamma isotopic analysis of the quarterly composites of the particulate air filters. During preoperation and during operation through 1986, a number of fission products and activation products were detected. These were generally attributed to the nuclear weapons tests and to the Chernobyl incident. On only one occasion since 1986, has a man-made radionuclide been detected in a quarterly composite. A small amount of Cs-137 (1.7 fCi/m3) was identified in the first quarter of 1991 at Station 304. The MDC and RL for Cs-137 in air are 60 and 20,000 fCi/m3, respectively. The historical trending of the average annual concentrations of detectable Cs-137 from quarterly air filter composites is provided in Figure 4.2-2 and Table 4.2-2.

**Figure 4.2-2** 



C-OH

Table 4.2-2

Average Annual Cs-137 Concentration In Air

Year	Indicator (fCi/m3)	Control (fCi/m3)
Pre-op	0	2.0
1974	1.5	2.0
1975	1.4	1.4
1976	0.6	0.7
1977	1.5	1.4
1978	2.3	2.6
1979	0.8	0.8
1980	0.4	0.6
1981	1.8	1.7
1982	0.5	0.6
1983	0.7	0
1984	0	0
1985	0.7	0
1986	8.1	9.6
1987	0	0
1988	0	0
1989	0	0
1990	0	0
1991	0	1.7
1992	0	0
1993	0	0
1994	0	0
1995	0	0
1996	0	0
1997	0	0
1998	0	0_
1999	0	0
2000	0	0
2001	0	0
2002	0	0
2003	0	0
2004	0	0

No airborne I-131 was detected in the charcoal canisters in 2003. During 1976, 1977, and 1978, positive levels of I-131 were found in nearly all of the samples collected for a period of a few weeks following atmospheric nuclear weapons tests. Some of the concentrations were on the order of 70 fCi/m³. In 1986, the same phenomenon occurred following the Chernobyl incident. The highest airborne I-131 concentration found to date in an individual charcoal canister was 217 fCi/m³ in 1977. The MDC and RL for airborne I-131 are 70 fCi/m³ and 900 fCi/m³, respectively.

Table 4-3 lists REMP deviations that occurred in 2004. Five deviations involved air sampling. Three of the five deviations resulted in excluded data. They are listed below.

For the period 3/1-3/8 at Station 304, the air filter was misaligned in the filter housing. The sample results failed Chauvenet's Criterion and were excluded from the data base.

For the period 4/26-5/3 at Station 112, a power loss to the air sampling station resulted from lightning striking the supplying substation. The air sample run time was short 10 hours. The sample results failed Chauvenet's Criterion and were excluded from the data base.

For the period 9/7-9/13 at Station 112, no air monitoring was done. Power was lost to the air sampling station during Hurricane Frances and not restored until 9/13/04.

### 4.3 Direct Radiation

Direct (external) radiation is measured with thermoluminescent dosimeters (TLDs). Two Panasonic UD-814 TLD badges are placed at each station. Each badge contains three phosphors composed of calcium sulfate crystals (with thulium impurity). The gamma dose at each station is based upon the average readings of the phosphors from the two badges. The badges for each station are placed in thin plastic bags for protection from moisture while in the field. The badges are nominally exposed for periods of a quarter of a year (91 days). An inspection is performed near mid-quarter to assure that all badges are on-station and to replace any missing or damaged badges.

Two TLD stations are established in each of the 16 compass sectors around the plant to form 2 concentric rings, as seen in Figures 2-1 and 2-2. The two ring configuration of stations was established in 1980, in accordance with NRC Branch Technical Position "An Acceptable Radiological Environmental Monitoring Program", Revision 1, 1979. With the exception of the East sector, the inner ring stations (Nos. 101 through 116) are located near the site boundary and the outer ring stations (Nos. 201 through 216) are located at distances of 4 to 5 miles from the plant. The stations in the East sector are a few miles farther out than the other stations in their respective rings due to large swamps making normal access extremely difficult. The 16 stations forming the inner ring are designated as the indicator stations. The 3 control stations (Nos. 304, 309 and 416) are located 10 miles or more from the plant. Stations 064 and 301 monitor special interest areas. Station 064 is located at the onsite roadside park, while Station 301 is located near the Toombs Central School. Station 210, in the outer ring, is located near the Altamaha School (the only other nearby school).

As provided in Table 3-1, the average quarterly exposure measured at the indicator stations (inner ring) during 2004 was 12.22 mR. At the control stations, the average quarterly exposure was 12.38 mR. This difference is not statistically discernible since it is less than the MDD of 1.19 mR.

The quarterly exposures acquired at the outer ring stations during 2004 ranged from 8.7 to 16.7 mR, with an average of 12.16 mR. The average for the outer ring stations was 0.22 mR less than the average for the control stations. Since the results for the outer ring stations and the control stations differ by less than the MDD of 1.37 mR, there is no discernible difference between outer ring and control station results for 2004.

The historical trending of the average quarterly exposures for the indicator inner ring, outer ring, and the control stations are plotted in Figure 4.3-1 and listed in Table 4.3-1. The decrease between 1991 and 1992 values is attributed to a change in TLDs from Teledyne to Panasonic. It should be noted however that the differences between indicator and control and outer ring values did not change. The close agreement between the station groups supports the position that the plant is not contributing significantly to direct radiation in the environment.

**Figure 4.3-1** 






Table 4.3-1

Average Quarterly Exposure from Direct Radiation

Year	Indicator (mR)	Control (mR)	Outer Ring (mR)
Pre-op	22.3	23	0
1974	23.2	25.6	0
1975	10.0	10.5	0
1976	8.18	6.9	0
1977	7.31	6.52	0
1978	6.67	6.01	0
1979	5.16	6.77	0
1980	4.44	5.04	4.42
1981	5.9	5.7	5.7
1982	12.3	12	11.3
1983	11.4	11.3	10.6
1984	13.3	12.9	11.9
1985	14.7	14.7	13.7
1986	15	14	14.5
1987	14.9	14.6	15.3
1988	15.0	14.7	15.2
1989	16.4	18.0	16.5
1990	14.9	13.9	14.7
1991	15.1	13.7	15.6
1992	11.9	10.9	12.3
1993	11.6	10.7	11.5
1994	11	10.7	11.2
1995	11.5	10.8	11.3
1996	11.6	11.3	11.6
1997	12.3	11.8	12.3
1998	12.1	12.3	12.3
1999	12.8	13.2	13.0
2000	13.6	13.3	13.3
2001	12.0	12.1	11.8
2002	11.7	11.7	11.5
2003	11.4	11.4	11.4
2004	12.2	12.4	12.2

The historical trending of the average quarterly exposures at the special interest areas for the past 18 years is provided in Figure 4.3-2 and listed in Table 4.3-2. These exposures are within the range of those acquired at the other stations. They too, show that the plant is not contributing significantly to direct radiation at the special interest areas.

**Figure 4.3-2** 






Table 4.3-2

Average Quarterly Exposure from Direct Radiation at Special Interest Areas

Period	Station 064 (mR)	Station 301 (mR)
1986	14.6	15.1
1987	14.2	15.0
1988	14.9	15.3
1989	16.1	16.6
1990	15.1	14.4
1991	14.4	15.2
1992	11.1	11.5
1993	11.2	10.8
1994	10.4	10.7
1995	11.0	10.5
1996	11.7	11.0
1997	12.6	11.4
1998	12.4	11.8
1999	12.5	12.4
2000	13.3	12.6
2001	11.8	11.3
2002	11.4	11.4
2003	11.2	11.1
2004	11.9	12.3

As seen in Table 4-3, there were two deviations involving direct radiation measurements in 2004. Both deviations led to the loss of direct radiation data. The TLDs at Station 110 were destroyed in a controlled burn and replace at mid-quarter of the first quarter. At Station 203, the TLDs were missing at mid-quarter of the second quarter and replacement TLDs were used to obtain data for the second half of the quarter. The results of the replacement TLDs at both stations failed Chauvenet's Criterion and were excluded from the direct radiation data base.

The standard deviation for the quarterly result for each badge was subjected to a self imposed limit of 1.4. This limit is based upon the standard deviations obtained with the Panasonic UD-814 badges during 1992 and is calculated using a method developed by the American Society of Testing and Materials (ASTM Special Technical Publication 15D, <u>ASTM Manual on Presentation of Data and Control Chart Analysis</u>, Fourth Revision, Philadelphia, PA, October 1976).

The limit serves as a flag to initiate an investigation. To be conservative, readings with a standard deviation greater than 1.4 are excluded from the data set since the high standard deviation is interpreted as an indication of unacceptable variation in TLD response. In 2004, the following TLD results were excluded from the data set because their standard deviations were greater than 1.4:

First Quarter 101B, 104B, and 214B
Second Quarter 109A
Third Quarter 215B
Fourth Quarter None

For these stations, the reading of the companion badge at each location was used to determine the quarterly exposure.


During 2004, no direct radiation station experienced both badges having standard deviations above the self-imposed limit of 1.4. For those instances in which one badge at a station exhibited a standard deviation greater than 1.4, the other badge of the two-badge set was available to give a valid reading for the particular location.

### 4.4 Milk

Milk samples are obtained biweekly from Station 304 (the state prison dairy) which is a control station located more than 10 miles from the plant. Gamma isotopic and I-131 analyses are performed on each sample as specified in Tables 2-1 and 2-2. Since 1989, efforts to locate a reliable milk sample source within 5 miles of the plant have been unsuccessful.

During 2004, as in the previous 13 years, no man-made radionuclides were detected from the gamma isotopic analysis of the milk samples. Except for 1987, Cs-137 was found in some of the samples each year from 1978 (when this analysis became a requirement) through 1989. No other man-made radionuclides have been detected by this analysis.

The MDC and RL for Cs-137 in milk are 18 and 70 pCi/l, respectively. The historical trending of the average annual detectable Cs-137 concentration in milk is provided in Figure 4.4-1 and Table 4.4-1.



**Figure 4.4-1** 

C-07

Table 4.4-1

Average Annual Cs-137 Concentration in Milk

Year	Indicator (pCi/l)	Control (pCi/l)
Pre-op	19.9	19.4
1974	0	0
1975	0	0
1976	0	0
1977	0	0
1978	12.1	18.3
1979	16.1	13
1980	14.7	15.4
1981	12.57	10.2
1982	11.8	11
1983	12	7.2
1984	9.6	10.2
1985	9.14	5.35
1986	9.8	10
1987	0	0
1988	10.9	0
1989	8.6	7.9
1990	0	0
1991	0	0
1992	0	0
1993	0	0
1994	0	0
1995	0	0
1996	0	0
1997	0	0
1998	0	0
1999	0	0
2000	0	0
2001	0	0
2002	0	0
2003	0	0
2004	0	0

During 2004 as in the previous 14 years, I-131 was not detected in any of the milk samples. During preoperation, all readings were less than 2 pCi/l which was the allowed MDC at that time. Figure 4.4-2 and Table 4.4-2 provide the historical trending of the average annual detectable concentration of I-131 in milk. In 1988, a single reading of 0.32 pCi/l, which was believed to have resulted from a procedural deficiency, was reported. The MDC and RL for I-131 in milk are 1 and 3 pCi/l, respectively.

All the detectable results for Cs-137 and I-131 are attributed to fallout from the nuclear weapons tests and the Chernobyl incident.

**Figure 4.4-2** 






Table 4.4-2

Average Annual I-131 Concentration in Milk

Year	Indicator (pCi/l)	Control (pCi/l)
Pre-op	0	0
1974	0.98	2.6
1975	0.3	0
1976	12.23	9.1
1977	14.61	4.08
1978	2.72	4.18
1979	0	0
1980	1.26	0.69
1981	0	0
1982	0	0
1983	0	0
1984	0	0
1985	0	0
1986	8.9	7.6
1987	0	0
1988	0	0.32
1989	0	0
1990	0	0
1991	0	0
1992	0	0
1993	0	0
1994	0	0
1995	0	0
1996	0	0
1997	0	0
1998	0	0
1999	0	0
2000	0	0
2001	0	0
2002	0	0
2003	0	0 '
2004	0	0

# 4.5 Vegetation


In accordance with Tables 2-1 and 2-2, grass samples are collected monthly from two indicator stations near the site boundary (Nos. 106 and 112) and at one control station located about 21 miles from the plant (No. 416). Gamma isotopic analyses are performed on each sample. Gamma isotopic analysis on vegetation samples began in 1978 when the analysis became a TS requirement.

The results presented in Table 3-1 show that Cs-137 was the only man-made radionuclide detected in vegetation samples during 2004. Cs-137 was detected in fourteen samples collected at the indicator stations at an average value of 41.6 pCi/kg-wet; five samples collected at the control station had detectable Cs-137 at 43.5 pCi/kg-wet. The difference of 1.9 pCi/kg/wet between the control and the indicator averages is not statistically discernible since it is less than the MDD of 26.8 pCi/kg-wet.

Since 1986, Cs-137 has been the only man-made radionuclide found in vegetation samples. The MDC and RL for Cs-137 in vegetation samples are 80 pCi/kg-wet and 2000 pCi/kg-wet, respectively. The occasional presence of Cs-137 in vegetation samples is attributed primarily to fallout from nuclear weapons tests and the Chernobyl incident.

Figure 4.5-1 and Table 4.5-1 provide the historical trending of the average annual detectable Cs-137 concentration found in vegetation. Since 1978, the Cs-137 concentration has been on a decline, and since about 1989, generally occurring below the required MDC and very close to levels of detectability.

**Figure 4.5-1** 



C-09

Table 4.5-1

Average Annual Cs-137 Concentration in Vegetation

Year	Indicator (pCi/kg-wet)	Control (pCi/kg-wet)
Pre-op	55	30
1974	0	0
1975	0	0
1976	0	0
1977	0	0
1978	112 .	1089
1979	59	695
1980	208	916
1981	182	152
1982	65	99
1983	95	211
1984	149	388
1985	60.9	113.3
1986	80	215
1987	60	428
1988	40.1	228.8
1989	37	0
1990	66.7	34.5
1991	34.1	36.1
1992	35.2 41.	
1993	1993 24.7	
1994	32.2	46.6
1995	49.8	47.6
1996	47.2	41.1
1997	48.4	54.9
1998	81.4	44.1
1999	26.9	0
2000	0	0
2001	0	0
2002	33.7	41.1
2003	61.0	62.8
2004	41.6	43.5

#### 4.6 River Water

Surface water from the Altamaha River is obtained at an upstream location (Station 170) and at a downstream location (Station 172) using automatic samplers. Small quantities are drawn at intervals not exceeding a few hours. The samples drawn are collected monthly and quarterly composites are produced from the monthly collections.

As specified in Table 2-1, a gamma isotopic analysis is conducted on each monthly sample. No man-made radionuclides were detected during 2004. The only man-made radionuclides previously detected are presented in the table below.

Year	Quarter	Station	Radionuclide	Level (pCi/l)
1975	4th	172	Ce-141	78.2
1986	2nd	170	La-140	18.0
1986	2nd	172	Cs-137	12.0
1988	2nd	170	Cs-137	6.8

A tritium analysis is performed on the quarterly composite. Prior to 1986, positive results were usually found in each quarterly composite at levels generally ranging from 200 and 400 pCi/l. Subsequently, the number of positive results and their concentrations have diminished. In the 15 years since 1988, tritium has been detected in only about 18% of the samples.

In 2004, tritium was detected in one sample at the upstream (control) location, and in one sample at the downstream (indicator) location. The indicator sample was 206 pCi/l and the control sample was 302 pCi/l. The MDC and RL for tritium in river water are 3000 and 30,000 pCi/l, respectively. Figure 4.6-1 and Table 4.6-1 provide the historical trending of the annual average detectable tritium concentration in river water.

The annual 50 mile downstream survey of the Altamaha River to determine if river water is being withdrawn for drinking purposes is discussed in Section 4.1.

**Figure 4.6-1** 






Table 4.6-1

Average Annual H-3 Concentration in River Water


Year	Indicator (pCi/l)	Control (pCi/l)
Pre-op	210	191
1974	230	205
1975	205	238
1976	165	153
1977	189	170
1978	224	193
1979	210	180
1980	358	218
1981	220	135
1982	165	220
1983	265	328
1984	437	327
1985	288	220
1986	242	206
1987	241	204
1988	220	0
1989	0	0
1990	139	0
1991	0	0
1992	0 0	
1993	0	0
1994	0	0
1995	200	0
1996	144	147
1997	0	0
1998	0	0
1999	0	0
2000	209	0
2001	0	0
2002	0	0
2003	0	261
2004	206	302

#### **4.7** Fish

Gamma isotopic analyses were performed on the edible portion of the fish samples collected at the river stations on April 12 and on October 25, 2004. The control station (No. 170) is located upstream of the plant while the indicator station (No. 172) is located downstream.

As shown in Table 3-1, Cs-137 was the only man-made radionuclide detected in fish during 2004. The average concentration of 11.6 pCi/kg-wet at the indicator station was 7.2 pCi/kg-wet less than the average concentration found at the control station (18.8 pCi/kg-wet). This difference is not statistically discernible since it is less than the calculated MDD of 14.4 pCi/kg-wet. Cs-137 in fish samples is attributed primarily to weapons testing and the Chernobyl incident. The MDC and RL for Cs-137 in fish are 150 and 2000 pCi/kg-wet, respectively.

The historical trending of the average annual detectable Cs-137 concentration in fish is provided in Figure 4.7-1 and Table 4.7-1. Figure 4.7-1 indicates, in general, a decline in the Cs-137 levels after 1983. (Note: From 1979 through 1982, clams were collected rather than fish.)



**Figure 4.7-1** 

011


Table 4.7-1

Average Annual Cs-137 Concentration in Fish

Year	Indicator (pCi/kg-wet)	Control (pCi/kg-wet)
Pre-op	90	115
1974	134	61
1975	80.6	89.4
1976	73	88
1977	76	91
1978	88	47
1979	0	0
1980	0	0
1981	0	0
1982	0	0
1983	138.6	67.5
1984	84	53
1985	117	63.3
1986	79	44
1987	62	52
1988	77.8	33.3
1989	34.3	28.9
1990	26.7	24.2
1991	32.9	26.9
1992	41.6	28.8
1993	38.0	25.9
1994	23.8	20.7
1995	25.0	27.9
1996	20.4	18.0
1997	29.4	15.1
1998	26.1	17.7
1999	22.3	13.5
2000	17.9	25.3
2001	20.8	10.2
2002	18.2	13.0
2003	13.1	7.1
2004	11.6	18.8

In the past, the only other man-made radionuclides detected in fish samples were Co-60 and Cs-134. During preoperation, Co-60 was detected in one fish sample at a very low concentration. During the period of 1983 through 1988, Cs-134 was found in about half of the samples at concentrations of the same order of magnitude as those found for Cs-137. The Co-60 and Cs-134 levels found in these samples are attributed to the nuclear weapons tests and the Chernobyl incident. Figure 4.7-2 and Table 4.7-2 show the historical trending of the annual average detectable concentration of Cs-134 in fish.

**Figure 4.7-2** 



0-12

Table 4.7-2

Average Annual Cs-134 Concentration in Fish


Year	Indicator (pCi/kg-wet)	Control (pCi/kg-wet)
Pre-op	0	0
1974	0	0
1975	0	0
1976	0	0
1977	0	0
1978	0	0
1979	0	0
1980	0	0
1981	0	0
1982	0	0
1983	101.8	0
1984	35.8	26.3
1985	46.7	21.1
1986	29	0
1987	69	15
1988	21.7	6.9
1989	0	0
1990	0	0
1991	0	0
1992	0	0
1993	0 0	
1994	0	0
1995	0	0
1996	0	0
1997	0	0
1998	0	0
1999	0	0
2000	0	0
2001	0	0
2002	0	0
2003	0	0
2004	0	0

#### 4.8 Sediment

Sediment was collected along the shoreline of the Altamaha River on May 3 and November 1, 2004, at the upstream control station (No. 170) and the downstream indicator station (No. 172). A gamma isotopic analysis was performed on each sample.

Co-60 was not found in sediment samples in 2004. With the exception of five years, Co-60 has been found at either the indicator or the control station every year since 1986. There is no RL or MDC assigned to Co-60 in sediment in ODCM Tables 4-2 and 4-3 (Tables 4-2 and 4-1 of this report). The MDC assigned by the EL for Co-60 in sediment is 70 pCi/kg-dry. The historical trending of the average annual detectable Co-60 concentration in sediment is provided in Figure 4.8-1 and Table 4.8-1.

**Figure 4.8-1** 



0-13

Table 4.8-1


Average Annual Co-60 Concentration in Sediment

Year	Indicator (pCi/kg-dry)	Control (pCi/kg-dry)
Pre-op	0	0
1974	0	0
1975	0	0
1976	0	0
1977	0	0
1978	0	0
1979	0	0
1980	0	0
1981	0	0
1982	0	0
1983	0	0
1984	0	0
1985	0	0
1986	108	33
1987	0	0
1988	67.8	0
1989	0	31
1990	33	19
1991	123.6	0
1992	81.4	0
1993	70.7	0
1994	218	0
1995	0	0
1996	118.5	0
1997	0	0
1998	79.4	0
1999	107.7	0
2000	70.0	0
2001	58.1	0
2002	0	0
2003	0	31.5
2004	0	0

Co-60 was not detected in sediment samples near the plant until 1986, the year of the Chernobyl incident. However, because Co-60 has been detected in indicator station samples more often than in control station samples in recent years, some contribution from plant effluents cannot be ruled out.

In 2004, Cs-137 was detected in both indicator and control station sediment samples. It has been found in over 95% of all of the sediment samples collected back through preoperation, and is generally attributed to the atmospheric nuclear weapons tests or to the Chernobyl incident. As shown in Table 3-1, the average at the indicator station was 59.5 pCi/kg-dry and at the control station the average was 57.1 pCi/kg-dry. However, the difference (2.4 pCi/kg-dry) between the stations is not statistically discernible since it is less than the MDD of 236 pCi/kg-dry. The MDC for Cs-137 in sediment is 180 pCi/kg-dry. The historical trending of the average annual detectable Cs-137 concentration in sediment is provided in Figure 4.8-2 and Table 4.8-2.

**Figure 4.8-2** 




(-14

Table 4.8-2
Average Annual Cs-137 Concentration in Sediment

Indicator	Control (pCi/kg-dry)
	270
	57
	615
<del></del>	300
	200
	260
	310
	0
	110
141	285
384	365
500	260
76.5	269
238	190
59	39
903	114
56	62
130.5	66
43.1	54.5
151	198.5
113	115
127	104
52.3	80.6
	110
	137
	101.4
<del></del>	111.8
<del></del>	114.5
	69.6
	62.8
	106
<del></del>	57.1
	(pCi/kg-dry)  170  218  330  211  364  330  0  240  590  141  384  500  76.5  238  59  903  56  130.5  43.1  151

Other man-made nuclides, besides Co-60 and Cs-137, were occasionally found in past years. Their presence was generally attributed to the nuclear weapons tests or to the Chernobyl incident, although plant releases were not ruled out. Mn-54, Co-58, and Zn-65, which have relatively short half-lives, are most likely a result of plant releases and have been plotted in Figure 4.8-3 along with their MDCs. All the man-made nuclides detected in sediment except for Co-60 and Cs-137 have been listed in Table 4.8-3. The Cs-134 MDC (150 pCi/kg-dry) is defined in ODCM Table 4-3 (Table 4-1 of this report). The MDCs for Mn-54 (42 pCi/kg-dry) and Zn-65 (129 pCi/kg-dry) were determined by the EL since no values are provided in ODCM Table 4-3.

**Figure 4.8-3** 



0-15

Table 4.8-3
Sediment Nuclide Concentrations Other Than Co-60 & Cs-137

Nuclide	YEAR	Indicator (pCi/kg-dry)	Control (pCi/kg-dry)
Ce-141	1976	340	254
	1977	141	
Ce-144	Preop		720
	1974	363	
	1975	342	389
	1978	700	
	1981	1290	
Co-58	1994	22.2	
Cs-134	Preop		40
	1981	280	
	1984	130	40
	1986	132	
	1988	505	
	1990	31	
Mn-54	1975	36.1	
	1986	28	26
	1991	57.2	
	1996	77.7	
Ru-103	1974	81	
	1976	158	
	1977	195	
	1981	220	
Zn-65	1986	175	
	1988	136	
	1991	250.5	
	1992	83	
	1993	39.9	
	1994	332	
Zr-95	Preop		180
	1974	138	
	1976	427	170
	1977	349	294
	1978	220	230
	1981	860	280

# 5.0 INTERLABORATORY COMPARISON PROGRAM

In accordance with ODCM 4.1.3, the EL participates in an ICP that satisfies the requirements of Regulatory Guide 4.15, Revision 1, "Quality Assurance for Radiological Monitoring Programs (Normal Operations) - Effluent Streams and the Environment", February 1979. The guide indicates the ICP is to be conducted with the Environmental Protection Agency (EPA) Environmental Radioactivity Laboratory Intercomparison Studies (Cross-check) Program or an equivalent program, and the ICP should include all of the determinations (sample medium/radionuclide combinations) that are offered by the EPA and included in the REMP.

The ICP is conducted by Analytics, Inc. of Atlanta, Georgia. Analytics has a documented Quality Assurance (QA) program and the capability to prepare Quality Control (QC) materials traceable to the National Institute of Standards and Technology. The ICP is a third party blind testing program which provides a means to ensure independent checks are performed on the accuracy and precision of the measurements of radioactive materials in environmental sample matrices. Analytics supplies the crosscheck samples to the EL which performs the laboratory analyses in a normal manner. Each of the specified analyses is performed three times. The results are then sent to Analytics who performs an evaluation which may be helpful to the EL in the identification of instrument or procedural problems.

The samples offered by Analytics and included in the EL analyses are gross beta and gamma isotopic analyses of an air filter; gamma isotopic analyses of milk samples; and gross beta, tritium and gamma isotopic analyses of water samples.

The accuracy of each result is measured by the normalized deviation, which is the ratio of the reported average less the known value to the total error. The total error is the square root of the sum of the squares of the uncertainties of the known value and of the reported average. The uncertainty of the known value includes all analytical uncertainties as reported by Analytics. The uncertainty of the reported average is the propagated error of the values in the reported average by the EL. The precision of each result is measured by the coefficient of variation, which is defined as the standard deviation of the reported result divided by the reported average. An investigation is undertaken whenever the absolute value of the normalized deviation is greater than three or whenever the coefficient of variation is greater than 15% for all radionuclides other than Cr-51 and Fe-59. For Cr-51 and Fe-59, an investigation is undertaken when the coefficient of variation exceeds the values shown as follows:

Nuclide	Concentration *	Total Sample Activity (pCi)	Percent Coefficient of Variation
Cr-51	<300	NA	25
Cr-51	NA	>1000	25
Cr-51	>300	<1000	15
Fe-59	<80	NA	25
Fe-59	>80	NA	15

<sup>\*</sup> For air filters, concentration units are pCi/filter. For all other media, concentration units are pCi/liter (pCi/l).

As required by ODCM 4.1.3.3 and 7.1.2.3, a summary of the results of the EL's participation in the ICP is provided in Table 5-1 for: the gross beta and gamma isotopic analyses of an air filter; gamma isotopic analyses of milk samples; and gross beta, tritium and gamma isotopic analyses of water samples. Delineated in this table for each of the media/analysis combinations, are: the specific radionuclides; Analytics' preparation dates; the known values with their uncertainties supplied by Analytics; the reported averages with their standard deviations; and the resultant normalized deviations and coefficients of variation expressed as a percentage.

It may be seen from Table 5-1 that all 2004 results were acceptable for precision and accuracy. The activity for Fe-59 was trending with a positive bias. The analysis is performed by gamma spectroscopy and will be investigated in 2005.

#### **TABLE 5-1 (SHEET 1 of 3)**

#### INTERLABORATORY COMPARISON PROGRAM RESULTS

#### GROSS BETA ANALYSIS OF AN AIR FILTER (pCi/filter)

Analysis or Radionuclide	Date Prepared	Reported Average	Known Value	Standard Deviation EL	Uncertainty Analytics (3S)	Percent Coef of Variation	Normalized Deviation
Gross Beta	09/16/04	55	53.6	2.64	0.90	9.00	0.22

#### GAMMA ISOTOPIC ANALYSIS OF AN AIR FILTER (pCi/filter)

Analysis or Radionuclide	Date Prepared	Reported Average	Known Value	Standard Deviation EL	Uncertainty Analytics (3S)	Percent Coef of Variation	Normalized Deviation
Ce-141	09/16/04	180	190	2.97	2.11	3.70	-1.53
Co-58	09/16/04	69	71.9	1.85	0.80	5.60	-0.74
Co-60	09/16/04	90.2	95.2	2.19	1.06	4.58	-1.20
Cr-51	09/16/04	190.5	170	11.59	1.89	13.20	0.81
Cs-134	09/16/04	65.4	73.3	3.88	0.81	7.40	-1.63
Cs-137	09/16/04	165.5	163	2.53	1.81	3.96	0.38
Fe-59	09/16/04	76.9	69.5	0.69	0.77	6.42	1.50
Mn-54	09/16/04	142.1	138	2.49	1.53	4.20	0.69
Zn-65	09/16/04	142.7	136	5.22	1.51	6.28	0.75

#### GAMMA ISOTOPIC ANALYSIS OF A MILK SAMPLE (pCi/liter)

Analysis or Radionuclide	Date Prepared	Reported Average	Known Value	Standard Deviation EL	Uncertainty Analytics (3S)	Percent Coef of Variation	Normalized Deviation
Ce-141	06/17/04	160	157	7.1	1.74	4.44	0.40
Co-58	06/17/04	48	46.2	4.52	0.51	9.41	0.39
Co-60	06/17/04	172	172	6.64	1.91	3.86	0.00
Cr-51	06/17/04	247	228	37.01	2.53	14.98	0.51
Cs-134	06/17/04	102	101	4.01	1.12	3.93	0.23
Cs-137	06/17/04	158	156	7.89	1.73	4.99	0.24

#### TABLE 5-1 (SHEET 2 of 3)

#### INTERLABORATORY COMPARISON PROGRAM RESULTS

#### GAMMA ISOTOPIC ANALYSIS OF A MILK SAMPLE (pCi/liter)

Analysis or Radionuclide	Date Prepared	Reported Average	Known Value	Standard Deviation EL	Uncertainty Analytics (3S)	Percent Coef of Variation	Normalized Deviation
Fe-59	06/17/04	60	44.5	9.17	0.49	15.28	1.69
I-131	06/17/04	61	58.2	5.48	0.65	8.98	0.50
Mn-54	06/17/04	75	70.5	5.86	0.78	7.81	0.75
Zn-65	06/17/04	105	99.3	10.2	1.10	9.72	0.55

#### GROSS BETA ANALYSIS OF WATER SAMPLE (pCi/liter)

Analysis or Radionuclide	Date Prepared	Reported Average	Known Value	Standard Deviation EL	Uncertainty Analytics (3S)	Percent Coef of Variation	Normalized Deviation
Gross Beta	03/25/04	296	276	9.17	3.00	3.00	1.89
	06/17/04	299	286	13.94	3.18	10.00	0.45

#### GAMMA ISOTOPIC ANALYSIS OF WATER SAMPLES (pCi/liter)

Analysis or Radionuclide	Date Prepared	Reported Average	Known Value	Standard Deviation EL	Uncertainty Analytics (3S)	Percent Coef of Variation	Normalized Deviation
Ce-141	03/25/04	83	85	6.2	1.00	7.47	-0.31
Co-58	03/25/04	116	112	6.72	1.33	5.79	0.57
Co-60	03/25/04	148	153	5.94	1.67	4.01	-0.78
Cr-51	03/25/04	369	326	37.5	3.67	9.47	1.85
Cs-134	03/25/04	92	90	4.2	1.00	4.57	0.45

#### **TABLE 5-1 (SHEET 3 of 3)**

#### INTERLABORATORY COMPARISON PROGRAM RESULTS

#### GAMMA ISOTOPIC ANALYSIS OF WATER SAMPLES (pCi/liter)

Analysis or Radionuclide	Date Prepared	Reported Average	Known Value	Standard Deviation EL	Uncertainty Analytics (3S)	Percent Coef of Variation	Normalized Deviation
Cs-137	03/25/04	193	185	8.75	2.00	4.53	0.86
Fe-59	03/25/04	74	57	7.84	0.67	10.59	2.10
I-131	03/25/04	90	90	5.74	1.00	6.38	0.00
Mn-54	03/25/04	119	114	7.14	1.33	6.00	0.67
Zn-65	03/25/04	146	143	12.78	1.67	8.75	0.23

#### TRITIUM ANALYSIS OF WATER SAMPLES (pCi/liter)

Analysis or Radionuclide	Date Prepared	Reported Average	Known Value	Standard Deviation EL	Uncertainty Analytics (3S)	Percent Coef of Variation	Normalized Deviation
H-3	03/25/04	4452	4700	140.32	100.00	6.00	-0.92
	06/17/04	11871	11900	168.96	133.33	1.00	-0.13

# 6.0 CONCLUSIONS

This report confirms the licensee's conformance with the requirements of Chapter 4 of the ODCM during 2004. It provides a summary and discussion of the results of the laboratory analyses for each type of sample.

All of the radiological levels were low and are generally trending downward.

In 2004, there were no instances in which the indicator station readings were statistically discernible from the control station readings.

No discernible radiological impact upon the environment or the public as a consequence of plant discharges to the atmosphere or to the river was established for any REMP samples for 2004.