Sim JPM's.

JOB PERFORMANCE MEASURE APPROVAL SHEET

I JPM Title:

Manual Makeup to the VCT

ID Number:

JPM-S1

Revision: 0 Provide examinee with OP 2304C only

II. Initiated:

Daniel A. Pantalone Developer

1/21/2005 Date

III. Reviewed:

R. Ashey

Technical Reviewer

1/26/05

Date

IV. Approved:

JA User Department Supervisor

Date

Nuclear Training Supervisor

Date

JOB PERFORMANCE MEASURE WORKSHEET

Facility: MP-2	Examinee:	<u></u>
JPM Number:	JPM-S1	Rev0
Task Title: Manual M	lakeup to the VCT	
System: <u>CVCS</u>		
Time Critical Task: Yes	No X	
Validated Time (minutes)	10	
Task No.(s): <u>NUTIMS</u> #	004-01-194	
Applicable To: SR	RO X RO X PE	0
K/A No. 004-A2.	06 K/A Rating <u>4.2/4.3</u>	
<u>Method of Testing:</u> Simulated Performance: Location:	Actual Perform	ance: X
Classroom:	Simulator: X	In-Plant:
Task_Standards:	At the completion of this JPM, th Manual blended make up to the	e examinee has completed a VCT.
Required Materials (procedures, equipment):	OP 2304C, and 2208 Attachmen	nt 4
General References:	OP 2304C Rev 021-10, Section	4.9

**** READ TO THE EXAMINEE ****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.



JOB PERFORMANCE MEASURE WORKSHEET

JPM Number:	JPM-S1	Rev0
Initiating Cues:	 The Unit Supervisor has directed yo the VCT and raise VCT level by 2% flow controllers in the "AUTO" mode step 4.9.2. 	bu to perform a manual blended makeup to while maintaining the PMW and Boric Acid of operation. Use OP 2304C starting with
	- When makeup is completed, return	the system lineup to normal.
	- The examiner will act as the US.	
Initial Conditions:	 RCS boron concentration is 573 In-service Boric Acid Storage Ta No manual leak rate is in progret 	ank concentration is 5,943 ppm ss.
<u>Simulator Requirements</u> :	 Initialize at any IC with charging available. Verify RCS boron (Cb) = 573 or Verify "A" BAST pp selected to Verify "A" BAST concentration = Verify VCT level ≤ 82% Set the PMW and BA Controller 	g, letdown, and makeup to the VCT n the simulator. 'lead' (C-O2) = 5943 ppm rs 210Y and 210X setpoint to zero.

**** NOTES TO EXAMINER ****

1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.

2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".

3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").

JPM ID NUMBER: JF	<u>PM-S1</u>		TIT	LE: Manual Makeup to the V	<u>CT</u>
START TIME:		-			
STEP 1		Performance S	teps:	Ensure PMW is available a charging pump operating.	and at least one
GRADE		Standards:	Examinee - PMW - and ch	e observes red indicating light oumps parging pumps.	's lit on C-02 for
	C	ue			
Comments:		~~~~~~~	.~~~~~~~~		
STEP 2	<u>_X</u>	Performance S	teps:	Determine the required rat flow to PMW_flow.	io of Boric Acid
GRADE	<u> X </u>	Standards:	Examinee the ratio or gallons, re	uses either OP 2208 or PPC ^f Boric Acid to PMW flow is 1 spectively.	to determine that gallon to 9.2 to 9.5
	C(:	ue			
Comments:	PMW hand.	value does not	have to be o	alculated to the decimal point	ts if done by
STEP 3		Performance Si	eps:	Ensure the following are clo - Makeup valve stop, CH-5 - VCT makeup bypass, CH - RWST isolation, CH-192	sed: 512 (C-04) 1-196 (C-02) (C-02)

JPM ID NUMBER: J	<u>PM-S1</u>		TI	TLE: Manual Makeup to the VCT
GRADE		Standards:	Examine on C-04,	e observes the green lights 'only' lit for CH-512 Ch-196 and CH-192 on C-02
	-	Cue		
Comments:				
		~~~~~~~	~~~~~~	~~~~~
STEP 4		Performance S	Steps:	Determine the desired VCT level change in % level and total gallons required.
GRADE	_	Standards:	Examine 34 gal/%	ee states that a 2% level rise is required and using 5, a total of 68 gallons is required.
	(	Cue If not stat	ed, solicit in	formation.
Comments:	VCI	⁻ %/gal. is listed	on the VCT	Label on C-02.

____

-----

PM ID NUMBER: <u>JPM</u>	<u>I-S1</u>	TITLE: Manual Makeup to the VCT
STEP 5	X Performance St	eps: Reset PMW and BA controllers (FC-210X & FC-210Y), to zero.
GRADE - -	Standards: X X X	<ul> <li>For each controller, examinee checks:</li> <li>"L" indicated,</li> <li>presses and holds "SEL" button until "TOTAL RST" is displayed.</li> <li>Presses "R/L" button to shift controller to "R" (resets totalizer), then back to "L".</li> <li>Presses "SEL" to display controller number.</li> </ul>
Comments:	Cue : Manual Leak Rate De	etermination is not in progress (Step 4.9.7.b is N/A)
STEP 6	Performance St	eps: Start PPC trend of VCT level (L226).
GRADE	Standards:	Examinee starts PPC trend and displays it on PPC monitor.
	Cue	
Comments:		
	~~~~~~~~~~	~~~~~~

JPM ID NUMBER: <u>J</u>	PM-S1		TITLE: Manual Makeup to the VCT
STEP 7	<u>X</u> Perforr	nance Steps:	Adjust automatic setpoints of PMW and Boric Acid controllers (FC-210X / FC-210Y), and ensure in automatic.
GRADE	<u>X</u> Standa	ards: For ea - ", ne ga	nch controller, examinee ensures: AM" is lit and adjusts controller setpoint as ecessary to obtain a ratio of 1 gal. BA to 9.2 to 9.5 al. PMW.
	Cue :		
Comments:	Any ratio of 10 gals. BA	approximately 1 <u>c</u> to 92-95 gals. PM	gal. BA to 9.2 to 9.5 gal. PMW is acceptable (i .e. IW, etc.). Controllers are normally in "AM" mode.
STEP 8	<u>X</u> Perforr	nance Steps:	Place "Makeup Mode Selector Switch" in "MANUAL".
GRADE	<u>X</u> Standa	ards: Exami "MANI	nee places the "Makeup Mode Selector Switch" in JAL" position on C-04.
	Cue		
Comments:	~~~~~		
STEP 9	<u>X</u> Perform	nance Steps:	Start one boric acid pump.
GRADE	<u>X</u> Standa <u>X</u> Cue	ards: Exami "A" B.A - p - c - a 98	nee starts the selected (by indicated switch position) A. pump by: lacing its hand switch to the "START" position, checks red light lit, nd checks indicated discharge pressure is at least B psig.
	•		

Comments: The selected BA pump must be from the BAST used to determine VCT

ana -

JPM ID NUMBER: <u>J</u>	PM-S1 TITLE: Manual Makeup to the VCT
	blend. (The "A" is the selected pump and should be used)
STEP 10	<u>X</u> Performance Steps: Open Makeup Stop Valve, CH-512.
GRADE	X Standards: Examinee places CH-512 switch to "OPEN" on C-04 and ensures red light only is lit.
Comments:	Cue Examinee may check that the "M" of "AM" extinguishes on the makeup controllers.
STEP 11	Performance Steps: Ensure flows have stabilized at setpoints of the flow controllers.
GRADE	 Standards : Examinee watches flow controllers on C-04 to ensure flow begins and then stabilizes at the calculated setpoints.
Comments	Cue
Commenta.	
STEP 12	Performance Steps: Monitor VCT level and pressure as indicated on PI-225 and LI-226.
GRADE	Standards: Examinee observes indications on C-02 or PPC. Cue
Comments:	

JPM ID NUMBER: JPM-S1			TITLE: Manual Makeup to the VCT			
STEP 13	<u>_x</u>	Performance Step	ps: When desired VCT level is reached Close "Makeup Vlv Stop" CH-512, on C-04			
GRADE	X	Standards: Cue	 Examinee observes that: 2% level has been added to the VCT and closes CH-512. Observes green light lit for value and flow stops. 			
Comments:		~~~~~~~~~~				
STEP 14	<u>_X</u>	Performance Step	os: Stop "Boric Acid" pump, P-19A or B.			
GRADE	_ <u>X</u>	Standards:	 Examinee takes the "A" Boric Acid Pump hand switch on C-O2 to stop verifies the green light is lit and the red light is out verifies discharge pressure is zero with no flow. 			
Comments:	:	~~~~~~~~				
STEP 15	<u>_X</u>	Performance Step	es: Places the "Make Up Mode Select" switch in "Dilute" on C-04.			
GRADE	<u>_X</u>	Standards:	Examinee takes handswitch and turns it from the "Manual" to "Dilute" position.			
	(:					

JPM ID NUMBER: JPM-S1

TITLE: Manual Makeup to the VCT

Comments: After this step is completed, the JPM is considered complete.

STOP TIME:

VERIFICATION OF JPM COMPLETION

Job Performance Measure No.	JPM-S1	Rev.	0
Date Performed:			
Operator:			
Evaluator(s):			
For examinee to achiev	ve a satisfactory grade, <u>ALL</u> critic	al steps m	ust be completed correctly.
Time Critical Task? Yes	NoX		
Validated Time (minutes) [,]			
	10		
Actual Time to Complete (minut	10 es):		

Areas for Improvement:

EXAMINEE HANDOUT

JPM ID Number: <u>S1</u>

- Initiating Cues: The Unit Supervisor has directed you to perform a manual blended makeup to the VCT and raise VCT level by 2%while maintaining the PMW and Boric Acid flow controllers in the "AUTO" mode of operation. Use OP 2304C starting with step 4.9.2.
 - When makeup is completed, return the system lineup to normal.
 - The examiner will act as the US.
 - No manual leak rate is in progress.

Initial Conditions:

- RCS boron concentration is 573 ppm
- In-service Boric Acid Storage Tank concentration is 5,943 ppm

JOB PERFORMANCE MEASURE APPROVAL SHEET

I. Filling #1 Safety Injection Tank JPM Title:

ID Number:

JPM-S2

Revision: 0

Provide exeminue with OP 23060 only.

11. Initiated:

R. J. Ashey

Developer

1/24/05

Date

III. Reviewed:

Ince hiçal Reviewer

Date

IV. Approved:

User Department Supervisor

Date

Nuclear Training Supervisor

1/27/05

Date

SUMMARY OF CHANGES

A/I & Date	DESCRIPTION	REV/CHANGE
01/18/2005	Develop new JPM using 2306O.	0

JOB PERFORMANCE MEASURE WORKSHEET

Facility:	MP-2	Examinee:
JPM Number:		JPM-S2 Rev. 0
Task Title:	Fill #1 Sa	fety Injection Tank
System: Sat	fety Injectio	n
Time Critical Ta	ask: Yes	NoX
Validated Time	(minutes):	25
Task No.(s):	NUTIMS #	006-02-017
Applicable To:	SRC	X RO X PEO
K/A No.:	006-A1.1	3 K/A Rating: <u>3.5/3.7</u>
Method of Testir	ng:	
Simulated Per	formance:	Actual Performance: X
Location:		
Classroom:		Simulator: X In-Plant:
Task Standards	<u>s:</u>	The examinee will start filling the #1 SIT using the "A" HPSI Pump. The "A" HPSI Pump will trip on overload. The examinee will align the "B" HPSI Pump to Facility 1 and complete filling the #1 SIT using the "B" HPSI Pump.
Required Mater (procedures,eq	rials uipment):	SP 2606O OP 2343 OP 2308 ARP 2590A-001
<u>General Refere</u>	ences:	SP 2606O, Section 4.1 OP 2343, Section 4.7 OP 2308, Section 4.1 ARP 2590A-001

**** READ TO THE EXAMINEE ****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

JOB PERFORMANCE MEASURE WORKSHEET

JPM Number:	JPM-S2	Rev.	0
Initiating Cues:	 You are the PPO. The Unit Supervisor has directed the "A" HPSI Pump per OP-2306 RCS > 1750 psia". The examiner will act as the Unit 	you to fill 1 O, "Safety Superviso	the #1 SIT using Injection Tanks, r and/or PEO.
Initial Conditions:	 The plant is at 100% power, NOI No equipment is out of service. Bus 24E is aligned to Bus 24C. A PEO is available at the "A" HP The "A" HPSI has been checked 	P/NOT. SI Pump. and is rea	idy to start.
<u>Simulator Requirements</u> :	 Initialize at a normal 100% power low level alarm, above 200 psig, a SI04A on BT 48 ("A" HPSI Pur Trip I/O on Annunciator C-01 A-1 (" Overload/Trip) on C-01 on BT amps) IDT SIMT39(1) set to 7.3e4 (# Pressurize #1 SIT to approximate 	(IC-93) wi and enter t np >20 am A" HPSI P 49 ("A" HP 1 SIT at 55 ly 218 psig	th #1 SIT at the he following: ps) "A" HPSI Pp ump SI Pump >2 5.2%) J.

**** NOTES TO EXAMINER ****

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM (in-plant only).

JPM ID NUMBER: JPM-S2 TITLE: Fill #1 Safety Injection Tank

START TIME:		
STEP 1	Performance S	 bteps: DETERMINE desired SIT(s) level using one of the following criteria: IF sampling is required, do not fill greater than 59.6% (PPC high alarm 59.7%), the following alarms are excepted (C-01): SAFETY INJECTION TANK 1 LEVEL HI" (A-10) SAFETY INJECTION TANK 2 LEVEL HI" (A-11) SAFETY INJECTION TANK 3 LEVEL HI" (A-12) SAFETY INJECTION TANK 4 LEVEL HI" (A-13) IF sampling is not required, do not fill greater than the following: 59.6% (PPC high alarm 59.7%) for SIT 1 58.8% (alarm C-01 59%) for SITs 2, 3, and 4
GRADE	Standards:	Per precaution 3.1, the examinee should know that a sample is not required because the SIT is being filled from the RWST, > 1720 ppm; therefore, he/she determines that the desired level is NOT greater than 59.6%
	Cue: If asked required	l, as the US inform the examinee that a sample is NOT d.
Comments:	~~~~~~~	~~~~~~
STEP 2 _	Performance S	 teps: WHEN HPSI pump is started, CHECK the following (C-01): Motor amperage 20 to 30 amps Nominal discharge pressure 1250 to 1300 psig
GRADE	Standards:	The examinee states he/she will check motor amps between 20 and 30 amps and discharge pressure of the "A" HPSI Pump between 1250 and 1300 psig on C-01.
	Cue:	
Comments:	~~~~~~	~~~~~

JPM ID NUMBER:	<u>JPM-S2</u> TITL	E: <u>Fill #1 Safety Injection Tank</u>
STEP 3 <u>X</u>	Performance Steps: I	 Filling SIT 1, PERFORM the following (C-01): a. VERIFY open "SI-611, FILL & DRN." b. IF required, START one of the following HPSI pumps: "P-41A, HPSI PP A" "P-41B, HPSI PP B" "P-41C, HPSI PP C"
GRADE	Standards: The e. • Or re • Pla - - - • Re arr • Ma co • Ini 00 • Re • Char • C	 xaminee performs the following: a C-01, opens SI-611, Fill and Drain, and observes the d light is lit. aces the "A" HPSI Pump. handswitch on C-01 to start. Observes that the pump trips. Observes no pump amps or pressure. Observes an amber light above the pump handswitch. Observes Annunciator C-01,A1 "HPSI PUMP A OVERLOAD/TRIP" eports to the US that the "A" HPSI has tripped and munciator A-1 on C-01 is lit. ay ask the PEO at the pump to report any abnormal nditions. tiates Annunciator Response Procedure, ARP 2590A-01. ecommend placing the "B" HPSI in service on Facility 1. oses SI-611 to place the plant in a known stable ndition.
C	Cue: • As the US, i annunciato • When asked Response F • As the PEO immediately abnormal n • If required, concur. • As the US, o	respond that the "A" HPSI Pp. tripped and r C-01, A1, Is lit. d, provide the examinee with Annunciator Procedure, ARP 2590A-001. , report that the pump started then stopped y. There are no signs of any damage and no oises were heard. ask the examinee for a recommendation and call maintenance and generate a CR.

Comments: The examinee should state that the "A" HPSI Pump is inoperable.

- - -----

_

~

JPM ID NUMBER: JPM-S2 TIT	LE: Fill #1 Safety Injection Tank
STEP 4 Performance Steps:	 Refer to the following LCOs and determine applicability: TRM 3.1.2.1 Tech Spec 3.5.2 Tech Spec 3.5.3
GRADE Standards: The of T	examinee informs the US to determine applicability RM 3.1.2.1 and TS 3.5.2 and 3.5.3
Cue: Report as the	US that you will check the TS applicability.
Comments: This action is directed in AR	P 2590A-001 "HPSI Pp. 'A' Overload/Trip"
STEP 5 Performance Steps:	 Refer to OP 2308, High Pressure Safety Injection System, and place "B" HPSI Pp. on Facility 1. Determine the cause of the pump trip and submit a trouble report.
GRADE Standards: •	The examinee refers to OP 2308, High Pressure Safety Injection System, Section 4.1. The examinee requests the US to have a CR/TR written and have the cause of the trip determined.
Cue: • The US a • When as Pressure	acknowledges the request. sked, provide the examinee with OP 2308, High e Safety Injection System, Section 4.1
Comments:	

JPM ID NUMBER:	<u>JPM-S2</u> TI	TLE: <u>Fill #1 Safety Injection Tank</u>
STEP 6 <u>X</u>	Performance Steps:	 If shifting from "A" pump to "B" pump, perform the following: Verify "B" HPSI aligned to Facility 1 per OP 2343. Enter TSAS 3.5.2 Place P41A, "HPSI PP A," in PTL Remove P41B, "HPSI PP B," from PTL. Exit TSAS 3.5.2
GRADE	Standards: •	The examinee references OP 2343 to determine if the "B" HPSI is aligned to Facility 1 <u>or</u> he/she determines that "B" HPSI is aligned to Facility 1 because Bus 24E is aligned to Bus 24C.
X X	•	 Per OP 2308, the examinee will: Inform the US to log into TSAS 3.5.2 On C-01, place the "A" HPSI Pump handswitch in Pull-To-Lock. On C-01, remove the "B" HPSI Pump from Pull- To Lock. Inform the US to log out of TSAS 3.5.2.
C	Cue: If asked, Electrical If the exa HPSI to F HPSI is al If examin- that the p	provide the examinee with OP 2343, 4160 Volt System. minee begins to verify all the steps to align the 'B' acility 1, as the US inform the examinee the 'B' ligned and the steps in 2343 are complete. ee asks for a PEO to check "B" HPSI Pump, report ump is ready to start.

Comments: The above guidance is in 2308 step 4.1

Page 8 of 13

JPM ID NUMBER: <u>JPM-S2</u>	TITLE: Fill #1 Safety Injection Tank
STEP 7 Performance	 Steps: WHEN HPSI pump is started, CHECK the following (C-01): Motor amperage 20 to 30 amps Nominal discharge pressure 1250 to 1300 psig
GRADE Standards:	The examinee states he/she will check motor amps between 20 and 30 amps and discharge pressure of the "B" HPSI Pp between 1250 and 1300 psig on C-01.
Cue:	
Comments: This step may or may I	NOT be repeated by the examinee.
STEP 8 <u>X</u> Performance S	 Steps: IF filling SIT 1, PERFORM the following (C-01): a. VERIFY open "SI-611, FILL & DRN." b. IF required, START one of the following HPSI pumps: "P-41A, HPSI PP A" "P-41B, HPSI PP B" "P-41C, HPSI PP C"
GRADE Standards: X	 The examinee performs the following: On C-01, examinee opens (or ensures open) SI-611, Fill and Drain, and observes the red light is lit. Places the "B" HPSI Pump. handswitch on C-01 to start and observes the proper indications on the "B" HPSI Pump.
Cue: If reque NO abr	ested, as the PEO, report that the pump is running with normal indications.

Comments: The examinee must realize that she/he must return to 2306O and commence with step 4.1.3.

~~~~~~~~~~~~

-----

| JPM ID NUMBER: | JPM-S2 TI          | TLE: Fill #1 Safety Injection Tank                                                                                                                                                                                                                                                               |
|----------------|--------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| STEP 9 X       | Performance Steps: | Throttle open SI-618, Hdr –1A Ck Vlv Lkg Drn Stop,<br>not to exceed 300 psig, as indicated in Recirc Hdr<br>Press, PI-305.                                                                                                                                                                       |
| GRADE <u>X</u> | Standards: •       | While observing Recirc Header Pressure indicator,<br>PI-305, the examinee throttles open SI-618, Hdr –1A<br>Ck Vlv Lkg Drn Stop, to a pressure less than 300<br>psig, but greater than #1 SIT pressure.<br>Examinee observes rise in #1 SIT level.                                               |
|                | Cue:               |                                                                                                                                                                                                                                                                                                  |
| Comments:      | ~~~~~~             | ~~~~~~~~~~~                                                                                                                                                                                                                                                                                      |
| STEP 10 X      | Performance Steps: | <ul> <li>Close SI-618 when any of the following occur:</li> <li>SI TK1 LVL, L311 is at the desired level (PPC)</li> <li>SI TK 1 PRESS, P311, is at 225 psig (PPC)</li> <li>SI TK 1 PRESS, P-311, is at 225 psig (C-01)</li> <li>#1 SIT High Pressure alarm is annunciated on the PPC.</li> </ul> |
| GRADE <u>X</u> | Standards: Wh      | en any of the following occur, the examinee will close SI-618:<br>SI TK1 LVL, L311 is at the desired level of 59.6% (PPC)<br>SI TK 1 PRESS, P311, is at 225 psig (PPC)<br>SI TK 1 PRESS, P-311, is at 225 psig (C-01)<br>#1 SIT High Level alarm is annunciated on the PPC at 59.8%.             |
| (              | Cue:               |                                                                                                                                                                                                                                                                                                  |

Comments: SIT pressure of 225 psig should be the most limiting parameter. Depending on the flow rate, this could take 5 to 10 minutes.

- ----

JPM ID NUMBER: JPM-S2 TITLE: Fill #1 Safety Injection Tank

STEP 11 \_\_\_\_X\_ Performance Steps: When filling is complete, Stop the "B" HPSI Pump.

GRADE <u>X</u> Standards: Examinee stops the "B" HPSI Pump.

Cue:

Comments: This JPM is complete when the examinee stops the "B" HPSI Pump. The examinee does NOT have to wait for Safety Injection to Loop 1A and 2B to lower to between 225 and 275 psig.

STOP TIME:

#### VERIFICATION OF JPM COMPLETION

...

| Job Performance Measure No.                                                           | JPM-S2                                                                         | Rev0                                                        |
|---------------------------------------------------------------------------------------|--------------------------------------------------------------------------------|-------------------------------------------------------------|
| Date Performed:                                                                       |                                                                                |                                                             |
| Operator:                                                                             |                                                                                |                                                             |
| Evaluator(s):                                                                         |                                                                                |                                                             |
| For examinee to achieve a satisfactor<br>Time Critical, it <u>MUST</u> be completed w | y grade, <u>ALL</u> critical steps must<br>vithin the specified time to achiev | be completed correctly. If task is ve a satisfactory grade. |
| Time Critical Task? Yes                                                               | No                                                                             |                                                             |
| Validated Time (minutes):                                                             | 25                                                                             |                                                             |
| Actual Time to Complete (minute                                                       | s):                                                                            |                                                             |
| Result of JPM: (Denote                                                                | e by an <u>S</u> for satisfactory or a                                         | a <u>U</u> for unsatisfactory)                              |
| Areas for Improvement:                                                                |                                                                                |                                                             |

### EXAMINEE HANDOUT

.

| JPM Number:         | JPM-S2                                                                                 | Rev.                                              | 0                                    |
|---------------------|----------------------------------------------------------------------------------------|---------------------------------------------------|--------------------------------------|
| Initiating Cues:    | <ul> <li>You are the PPO.</li> </ul>                                                   |                                                   |                                      |
|                     | <ul> <li>The Unit Supervisor<br/>the "A" HPSI Pump<br/>RCS &gt; 1750 psia".</li> </ul> | has directed you to fill<br>per OP-2306O, "Safety | the #1 SIT using<br>Injection Tanks, |
|                     | • The examiner will ac                                                                 | t as the Unit Superviso                           | r and/or PEO.                        |
|                     |                                                                                        |                                                   |                                      |
| Initial Conditions: |                                                                                        |                                                   |                                      |

- The plant is at 100% power, NOP/NOT.
- No equipment is out of service.
- Bus 24E is aligned to Bus 24C.
- A PEO is available at the "A" HPSI Pump.
- The "A" HPSI has been checked and is ready to start.

# JOB PERFORMANCE MEASURE APPROVAL SHEET

I. JPM Title: Start 4<sup>th</sup> RCP

ID Number:

JPM-S3

Revision: 0

Privide exeminee with op2301C only.

II. Initiated:

Daniel A. Pantalone Developer

01/18/05 Date

III. Reviewed:

Duffy Ashey

**Technical Reviewer** 

1/26/05 Date

IV Approved:

User Department Supervisor

Date

Nuclear Training Supervisor

Date

### SUMMARY OF CHANGES

| A/I & Date | DESCRIPTION            | REV/CHANGE |
|------------|------------------------|------------|
| 10/27/2005 | Developed this new JPM | 0          |
| (DAP)      |                        |            |
|            |                        |            |
|            |                        |            |
|            |                        |            |
|            |                        |            |

#### JOB PERFORMANCE MEASURE WORKSHEET

| Facility: MP-2                                | Examinee:                                                                               |                                                             |
|-----------------------------------------------|-----------------------------------------------------------------------------------------|-------------------------------------------------------------|
| JPM Number:                                   | JPM-S3                                                                                  | Rev0                                                        |
| Task Title: Start a Re                        | eactor Coolant Pump                                                                     |                                                             |
| System: Reactor Coola                         | nt Pump                                                                                 |                                                             |
| Time Critical Task: Yes                       | NoX                                                                                     |                                                             |
| Validated Time (minutes):                     | 15 min                                                                                  |                                                             |
| Task No.(s): <u>NUTIMS</u> #                  | 003 01 031                                                                              |                                                             |
| Applicable To: SRC                            | X RO X PEO                                                                              |                                                             |
| K/A No.: 003 A2.                              | 03 K/A Rating: 2.7/3.1                                                                  |                                                             |
| Method of Testing:                            |                                                                                         |                                                             |
| Simulated Performance:                        | Actual Performance                                                                      | x                                                           |
| Location:                                     |                                                                                         |                                                             |
| Classroom:                                    | Simulator: X                                                                            | In-Plant:                                                   |
| <u>Task Standards:</u>                        | The examinee will start the RCP, mo<br>including alarms and secure the RC<br>2590B-083. | onitor critical RCP parameters<br>P per OP 2301C and/or ARP |
| Required Materials<br>(procedures,equipment): | OP 2301C, Reactor Coolant Pumps<br>Annunciator Response Procedure, A                    | ARP 2509B-083, C-03, BA-19                                  |

General References:

# \*\*\*\* READ TO THE EXAMINEE \*\*\*\*

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

#### JOB PERFORMANCE MEASURE WORKSHEET

| JPM Number:                     | _JPM-S3                                                                                                                                                                                                                                                                                 | Rev. 0                                                                                                                 |
|---------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------|
| Initiating Cues:                | The US has directed you to start the 'A' 2301C, Reactor Coolant Pumps, section                                                                                                                                                                                                          | RCP in accordance with OP<br>4.1.                                                                                      |
| Initial Conditions:             | <ul> <li>A plant heat-up is in progress following maintenance.</li> <li>The RCS is at normal pressure and 7</li> <li>Three RCPs are running.</li> <li>All parameters for the 'A' RCP are not opperative opperation.</li> <li>OP-2301C, section 4.1 is complete to a section.</li> </ul> | an outage for unplanned<br>$\Gamma c \text{ is } > 500^{\circ} F.$<br>normal for this condition.<br>up to step 4.1.10. |
| <u>Simulator Requirements</u> : | Initialize at zero power, ARI. (IC-93<br>- 'A' RCP is secured.<br>- RCS is at ~ 505 °F.<br>- Plant is stable.<br>A malfunction to lower the level in th<br>inserted after the "A" RCP is started                                                                                        | i) then trip rods.<br>ne Upper Oil Reservoir will be<br>d.                                                             |

#### \*\*\*\* NOTES TO EXAMINER \*\*\*\*

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM (in-plant only).

| JPM ID NUMBER: JPM-S3 TITLE: Start 4 <sup>th</sup> RCP                                                                       |
|------------------------------------------------------------------------------------------------------------------------------|
|                                                                                                                              |
| STEP 1 Performance Steps: Observe controlled bleedoff flow on PPC or PR-150A (C-04R) between 0.75 and 2.0 gpm.               |
| GRADE Standards: Examinee displays and monitors "A" RCP bleedoff flow on the PPC, or on C-04R.                               |
| Cue:                                                                                                                         |
| Comments:                                                                                                                    |
| ~~~~~~~                                                                                                                      |
| STEP 2 X Performance Steps: Place "RCP-A LIFT PPS" switch to "START" (C-03)                                                  |
| GRADE <u>X</u> Standards: Examinee places the 'A' RCP Lift Pump switch to start<br>and observes the red light lit.           |
| Cue: When the examinee indicates that the lift pump must run for 2 minutes, inform the examinee that 2 minutes have elapsed. |
| Comments: Annunciator AB-18 on C-02/3, RCP A ANTIREV ROT FLOW LO, will reset.                                                |
| ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~                                                                                      |

| JPM ID NUMBER: JPM-S3                     | TITLE: Start 4 <sup>th</sup> RCP                                                                                                              |
|-------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------|
| STEP 3 <u>X</u> Performance               | Steps: Place the "RCP-A, P-40A" switch to START.                                                                                              |
| GRADE <u>X</u> Standards:                 | Examinee places the 'A' RCP switch on C-03 to the start<br>position and observes:<br>- Red light lit<br>- The ammeter peg high and decay off. |
| Cue: <u>Booth I</u><br>"A" RC<br>level to | nstructor – RC12A (20%) When the examinee starts the P, insert a malfunction to cause the upper oil reservoir lower.                          |
| Comments:                                 |                                                                                                                                               |
| ~~~~~~                                    | ~~~~~                                                                                                                                         |
| STEP 4 X Performance                      | Steps: Place the "RCP-A LIFT PPS" to "AUTO"                                                                                                   |
| GRADE <u>X</u> Standards:                 | When annunciator C-04 AA-4 is not lit, examinee places the 'A' RCP Lift Pp. switch on C-03 to AUTO.                                           |
| Cue:                                      |                                                                                                                                               |
| Comments:                                 |                                                                                                                                               |

\_\_\_\_\_

| JPM ID NUMBER: JPM-S3                                                                            | TITLE: Start 4 <sup>th</sup> RCP                                                                                                                                                                                               |  |  |  |
|--------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|--|
| STEP 5 <u>X</u> Performance Ste                                                                  | ps: Observe annunciator BA19 on C-02/3, RCP A UPPER<br>OIL RSVR LEVEL LO.                                                                                                                                                      |  |  |  |
| GRADE <u>X</u> Standards:                                                                        | <ul> <li>Examinee observes annunciator BA19 on C-02/3, RCP<br/>A UPPER OIL RSVR LEVEL LO, and informs the US.</li> <li>Examinee refers to ARP 2590B-083 or recommends<br/>that the associated ARP be referenced.</li> </ul>    |  |  |  |
| Cue: Acknowledge the recommendation and direct the examinee to<br>implement the recommended ARP. |                                                                                                                                                                                                                                |  |  |  |
| Comments:                                                                                        |                                                                                                                                                                                                                                |  |  |  |
| ~~~~~~~~                                                                                         | ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~                                                                                                                                                                                        |  |  |  |
| STEP 6 X Performance Ste                                                                         | ps: Check 'A' RCP upper reservoir oil level indication and<br>determine rate of level decrease.                                                                                                                                |  |  |  |
| GRADE <u>X</u> Standards: E                                                                      | Examinee<br>displays the "RCP A Motor Data" display on the PPC<br>monitors "L156" (Upper Reservoir Level).<br>calculates the rate of level decrease<br>or<br>monitors "L156" on C-04R<br>calculates the rate of level decrease |  |  |  |
| Cue:                                                                                             |                                                                                                                                                                                                                                |  |  |  |

Comments:

~~~~~~~

| JPM ID NUMBER: JPM-S3 TITLE: Start 4 th RCP |
|---|
| STEP 7 Performance Steps: Monitor "A" RCP bearing temperatures and oil levels (C-04R or PPC) |
| GRADE Standards: The examinee monitors "A" RCP bearing temperatures
and oil level by:
- displaying the "RCP A Motor Data" display on the PPC
or
- monitoring parameters on C-04R |
| Cue: |
| Comments: |
| ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~ |
| STEP 8 X Performance Steps: If oil level is rapidly lowering,
- trip the Rx and Turbine
- stop the "A" RCP
- refer to EOP 2525, Standard Post Trip Actions |
| GRADE <u>X</u> Standards: Examinee secures the "A" RCP.
Examinee reports that tripping the Reactor and Turbine is
NOT applicable in this condition. |
| Cue: If required, ask the examinee for a recommendation.
Acknowledge the recommendation and direct the examinee
to perform the required actions. If the examinee recommends turning off the "A" Lift Pump,
inform the examinee that it will be turned off after the RCP
coasts down. |
| Comments: Turning off the "A" Lift Pump is NOT a required action, but may be recommended to limit the loss of oil in the upper reservoir. |
| ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~ |
| Comments: After this step is completed, the JPM is considered complete. |
| STOP TIME: |

VERIFICATION OF JPM COMPLETION

Γ

- -----

| Job Performance Measure No. | JPM-S3 | Rev. | <u>0</u> | |
|--|--|--|---------------------|--------|
| Date Performed: | | | | |
| Operator: | <u></u> | | | |
| Evaluator(s): | | | | |
| For examinee to achieve a satisfactory
Time Critical, it <u>MUST</u> be completed w | / grade, <u>ALL</u> critical
vithin the specified t | steps must be complete
sime to achieve a satisfac | ed correctly. If ta | ask is |
| Time Critical Task? Yes | No | | | |
| Validated Time (minutes): | 15 | | | |
| Actual Time to Complete (minutes | s): | | | |
| Result of JPM: (Denote | e by an <u>S</u> for satis | factory or a <u>U</u> for unsa | atisfactory) | |
| Areas for Improvement: | | | | |
EXAMINEE HANDOUT

JPM ID Number: JPM-S3

Initiating Cues: The US has directed you to start the 'A' RCP in accordance with OP 2301C, Reactor Coolant Pumps, section 4.1.

Initial Conditions: A plant heat-up is in progress following an outage for unplanned maintenance.

- The RCS is at normal pressure and Tc is $> 500^{\circ}$ F.
- Three RCPs are running.
- All parameters for the 'A' RCP are normal for this condition.
- OP-2301C, section 4.1 is complete up to step 4.1.10.

JOB PERFORMANCE MEASURE APPROVAL SHEET

Perform TDAFP Operability Test I. JPM Title: Revision: 0 JPM-S4 ID Number: Provide all handouts at the start of the JPM II. Initiated: 01/24/05 Dame antalone Date Developer

III. Reviewed:

J. Ashey

1/26/05 Date

Technical Reviewer

IV. Approved:

User Department Supervisor

Date

Nuclear Training Supervisor

127/05

Date

SUMMARY OF CHANGES

- -

| A/I & Date | DESCRIPTION | REV/CHANGE |
|---------------------|---|------------|
| 01/13/2005
(DAP) | Developed new JPM | 0 |
| 02/24/2005
(DAP) | Verified that the TDAFP minimum speed on the simulator is > 1500 rpm. Changed some of the steps in the JPM from critical to not critical per NRC feedback. Deleted steps 19 and 20 from the JPM per NRC feedback. | 0 |

JOB PERFORMANCE MEASURE WORKSHEET

| Facility: MP-2 | Examinee: | | |
|--|---|--|---|
| JPM Number: | JPM-S4 | Rev | 0 |
| Task Title: Align TDA | FP for Service | | |
| System: Aux Feedwate | <u>r</u> | | |
| Time Critical Task: Yes | NoX | | |
| Validated Time (minutes): | 20 | | |
| Task No.(s): NUTIMS # | 061-01-076 | | |
| Applicable To: SRC | X RO X | PEO | |
| K/A No.: 061 A2.0 | 4 K/A Rating: 3.4 | 4/3.8 | |
| Method of Testing: | | | |
| Simulated Performance: | Actual Perfo | ormance: X | |
| Location: | | | |
| Classroom: | Simulator: X | In-Plant: | |
| Task Standards: | Examinee completes the as determines that the TDAFP pump. | signed section of SF
is not operable, and | 2610B,
shuts down the |
| Required Materials
(procedures, equipment):SP-2610BO, Rev 000-00, TDAFP Tests, Operating
SP 2610BO-002, Rev. 000-00, "TDAFP and Recirculation Check
Valve IST"
OP 2322, Rev 025-02, Auxiliary Feedwater System
SP 2610BO-002, Rev. 000-00, "TDAFP and Recirculation Check
Valve IST" | | | ing
circulation Check
em
circulation Check |
| General References: | SP 2610BO Rev 000-00, TE | OAFP Tests, Operatin | ng |

**** READ TO THE EXAMINEE ****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

JOB PERFORMANCE MEASURE WORKSHEET

| JPM Number: | JPM-S4 | Rev. | 0 |
|---------------------------------|---|---|--|
| Initiating Cues: | The US has directed you to complete S
RECIRCULATION CHECK VALVE IST
maintenance. You are to start at step 4.2.10 of SI The completed steps of the proced | SP 2610BC
," for a ret
P 2610BO,
ure are ma | D, "TDAFP AND
est after minor
Rev. 000-00.
Irked. |
| Initial Conditions: | The TDAFP Trip Test does NOT need to be Vibration Data does NOT need to be The Terry Turbine Minimum Flow Fig. 33, does NOT need to be verified for A PEO is stationed at the TDAFP The US entered LCO 3.7.1.2 per statem B, per step 4.2.5. Turbine AFP Discharge Isolation, 2 No S/G Tube leaks exist. Aux Feed Pump Suction Header X-Aux Feed Pump Suction Header Statem TDAFP is ready to start. OP 23 TDAFW for Service," is complete. The examiner will act as the US, PE person. | eed to be p
be taken.
Recirc Discl
ull open.
ep 4.1.3 ar
-FW-9C, is
Tie, 2-CN-2
322, section
EO, and an | erformed.
harge Check, 2-FW-
nd TRMAS 7.1.15,
closed.
28, is open.
27A, is open.
n 4.2 "Aligning
ay other support |
| <u>Simulator Requirements</u> : | IC-24 or any mode IC with AFW se pressure >800 psig. FW30C @ 48%, Degraded TDAFP Check that you can find a comp PPC Trend Search Screen. If not, close the MMI Viewers and the second s | cured and
outer point
nd restart ti | steam supply
like F201 on the
he Viewers. |

**** NOTES TO EXAMINER ****

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM (in-plant only).

| JPM ID NUM | BER: <u>JPM-S4</u> | TITLE: Perform TDAFP Operability Test |
|----------------------|--------------------------|--|
| START TI ME : | | |
| STEP 1 | <u>X</u> Performance Ste | eps: Refer To OP 2322, Auxiliary Feedwater System," and START
TDAFP from Control Room. |
| GRADE | <u>X</u> Standards: | Examinee obtains OP 2322, Auxiliary Feedwater, section 4.3. |
| | Cue: | |
| Comments: | | |
| | ~~~~~~~~ | ~~~~~~ |
| STEP 2 | Performance Ste | eps: - Refer To Section 4.2, and ENSURE TDAFP and stem leakoff drains are aligned for service. |
| GRADE | Standards: | Examinee states that Section 4.2 is complete. |
| | Cue: | |
| Comments: | Per the Initial Conditio | ons, Section 4.2 has been performed. |

....

_

5

| JPM ID NUM | BER: <u>JPM-S4</u> | TITLE: Perform TDAFP Operability Test |
|---------------|-------------------------|---|
| STEP 3 | Performance St | eps: If SG tube leaks are known to exist and it is
necessary to operate TDAFP, as necessary, Record
pump operating times in SM Log Book. |
| GRADE | Standards: | Examinee states that NO tube leaks exist. |
| | Cue: | |
| Comments: | Per Initial Conditions, | NO tube leakage exists. |
| | ~~~~~~~ | ~~~~~ |
| STEP 4 | Performance St | eps: Ensure one or both of the following are open (C-05):
- No. 1 TDAFP Sply Vlv, MS-201
- No. 2 TDAFP Slpy Vlv, MS-202 |
| GRADE | Standards: | Examinee verifies that the following values have red open lights lit. (C-05): No. 1 TDAFP SPLY VLV, MS-201 No. 2 TDAFP SPLY VLV, MS-202 |
| | Cue: | |
| Comments: | | |

~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~

\_\_\_\_\_

-----

JPM ID NUMBER: JPM-S4 TITLE: Perform TDAFP Operability Test
STEP 5 Performance Steps: If at any time, No. 1 TDAFP Sply VIv, MS-201, or No. 2 TDAFP Slpy VIv, MS-202, are to remain closed for greater than 8 hours, Refer To Section 4.18 and Initiate necessary actions.
GRADE Standards: Examinee states that No. 1 TDAFP Sply VIv, MS-201, or No. 2 TDAFP Slpy VIv, MS-202, will NOT be closed for greater than 8 hours
Cue: If asked, as the US state that the steam supply valves will NOT
Comments:
STEP 6 Performance Steps: Ensure the TDAFP is NOT rotating. (Local)
GRADE Standards: Examinee determines the TDAFP is NOT rotating by asking the PEO to check for rotation.
Cue: When asked, report as the PEO that the TDAFP is NOT rotating.
Comments:
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
STEP 7 X Performance Steps: Using TDAFP Stm VIv Sel Sw, SV-4188, slowly Open terry turbine auxiliary feed pump steam supply, 2-MS-464 (SV-4199) (C-05).
 GRADE X Standards: Examinee places SV-4188 in the open position and observes: Both green lights go out. TDAFP Speed on C-05 increases to approximately 1500 rpm.
Cue:
Comments:

\_

JPM ID NUM	IBER: <u>JPM-S4</u>	TITLE:	Perform TDAFP Operability Test
STEP 8	<u>X</u> Performance St	eps: To TD, 2 m	warm turbine and lubricate bearings, OPERATE AFP at a minimum speed of 1,500 rpm for at least inutes.
GRADE	<u>X</u> Standards:	Exami	nee waits for 2 minutes.
	Cue: When app The TDAF	propriate, P is warn	inform the examinee that 2 minutes has past. n.
Comments:	~~~~~~~~		~~~~~
STEP 9	<u>X</u> Performance St	eps: Wh "SP - -	en at least 2 minutes has elapsed, adjust the D CNTL" switch to maintain the following: Turbine speed between 1500 to 4200 rpm. Discharge pressure \geq 1080 psig.
GRADE	<u>X</u> Standards:	When 2 I SPD "CN 05 or the - Turbi - Pump 1,080	minutes has elapsed, the examinee adjusts the ITL to maintain the following as monitored on C- PPC: ne speed between 1,500 and 4,200 rpm o discharge pressure greater than or equal to 0 psig
	Cue:		
Comments:	~~~~~~~	.~~~~~	~~~~~~~~~~
STEP 10	Performance Ste	eps: If me quar	chanical seal leakage of TDAFP is greater than 1 t per minute, Notify system engineer.
GRADE	Standards:	Examinee mechanic	e asks PEO to determine magnitude of al seal leakage.
	Cue: When ask normal (le	ed as the ss than 1	PEO, report that mechanical seal leakage is quart per minute).
Comments:	The examinee should	now retur	n to SP 2610BO.

JPM ID NUMBER	R: <u>JPM-S4</u>	TITLE:	Perform TDAFP Operability Test
STEP 11	_ Performance S	teps: Oper minu	rate TDAFP at 1,500 to 1,600 for greater than two tes.
GRADE	Standards:	Examine 1500 rpn	e states that the TDAFP has already been run at n for 2 minutes in OP 2322.
	Cue:		
Comments:			
	~~~~~~~	~~~~~	~~~~~~~~~~~~
STEP 12 _>	C Performance S	teps: Wł mir and	nen TDAFP has operated for greater than two nutes, adjust TDAFP "SPD CNTL" switch (C-05) d establish 4,200 rpm (4,150 to 4,250 rpm).
GRADEX	<u>(</u> Standards:	Examine as read	e adjusts the SPD "CNTL to establish 4,200 rpm on C-05.
	Cue:		
Comments:			
	~~~~~~~~	~~~~~~	~~~~~
STEP 13	_ Performance St	teps: IF me one c	echanical seal leakage of TDAFP is greater than quart per minute, NOTIFY System Engineer.
GRADE	_ Standards:	The exar already b	ninee states that mechanical seal leakage has een verified at less than one quart per minute.
	Cue: If request less than	ted, as PE one quar	O, report that mechanical seal leakoff is still t per minute.
Comments:			
	~~~~~~~	~~~~~~	~~~~~

\_

-----

STEP <b>14</b> Performance Steps: If any TDAFP parameter is NOT normal, Notify SM or US.
GRADE Standards: The examinee states that all TDAFP parameters appear normal.
Cue: If requested, as PEO, report that all local conditions are normal.
Comments:
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
STEP 15 <u>X</u> Performance Steps: WHEN system conditions have been as stable as the system permits for at least two minutes, VERIFY TDAFP speed is 4,150 to 4,250 rpm from hand held tachometer (local).
GRADE <u>X</u> Standards: Examinee requests TDAFP speed from the PEO using the hand held tachometer.
Cue: As the PEO, report the TDAFP speed in 4190 rpm.
Comments:
~~~~~~~
STEP 16 Performance Steps: WHEN TDAFP has operated at 4,150 to 4,250 rpm with stable system conditions for at least two minutes, REQUEST qualified vibration monitoring personnel MEASURE TDAFP vibration level at points specified in SP 2610BO-002.
GRADE Standards: Examinee should indicate vibration monitoring is NOT required per the initial conditions of this JPM.
Cue: If necessary, remind the examinee that vibration monitoring is NOT necessary.
Comments:

JPM ID NUMBER:	<u>JPM-S4</u> TI	TLE:	Perform TDAFP Operability Test
STEP <b>17</b>	Performance Steps:	Refe	r To SP 2610BO-002 and PERFORM the
		follov	wing:
<u>    X   </u>		a.	RECORD TDAFP speed from hand held
v		h	achometer and DOCUMENT results.
		<b>D</b>	flowmeter at EP-9863 and DOCUMENT results
Х		c	RECORD TDAEP discharge pressure (PPC
		0.	P5284)
Х		d.	RECORD TDAFP suction pressure (PI-5401,
			local).
_ <u>X</u> _		е.	CALCULATE $\Delta P$ corrected to rated speed.
<u></u>		f.	RECORD TDAFP $\Delta P$ corrected to rated speed
		:	and DOCUMENT results.
CRADE	Standarda: Eva	mino	a requests the required information from the
GRADE		n and	requests the following in SP 2610BO-002
		o unu	
<u> </u>	-	4190	) rpm in 4.2.18.a, "Hand held Tach"
<u> </u>	-	60 g	pm in 4.2.18.b, "Recirc Flow"
$ \frac{\lambda}{X}$	-	1110 16 n	o psig in 4.2.18.c, Discharge Press sig in 4.2.18 d. "Suction Press"
	-	Mark	(s UNSAT on SP 2610BO-002 for "Acceptable"
<u> </u>		and	"Normal"

#### Cue: Report as PEO that TDAFP speed is still 4190 rpm. Report as PEO that TDAFP Recirc flow is 60 gpm. Report as PEO that TDAFP suction pressure is 16 psig.

Comments: The following is a guideline for determining TDAFP corrected discharge pressure. The actual data may be <u>slightly</u> different.

TC TC TC	TDAFP discharge pressure, (PPC point P5284) = <u>1110 psig</u> TDAFP suction pressure, (PI_5401) = <u>16 psig</u> TDAFP Speed Handheld tachometer = <u>4190 rpm</u>					
1.	4200 ÷ 4190 Recorded \$	) =	1.0023	38 n Ratio		
2.	1.00238	(squared)	= 1.0	048		
5	Speed Correction Rat	tio	Speed Co	orrection Factor	-	
3.	1110	- 11	6 =	1094		
	<b>TDAFP Disch Press</b>	TDAFW Si	ict Press	Uncorrected	D/P	
4.	1094 x	1.00	48	=	1099	
	Uncorrected D/P	Speed Correc	tion Factor	D/P Correct	ed to Rated Pump Spe	ed (Note 3)

11

~~~~~~~~

| JPM ID NUN | IBER: <u>JPM-S4</u> | TITLE: Perform TDAFP Operability Test |
|------------|---|---|
| STEP 18 | <u>X</u> Performance | Steps: IF any Data Section data NOT within "Acceptable"
limits, Refer To Attachment 1 and PERFORM
applicable actions. |
| GRADE | Standards:
X

Cue: As the M
Attachm | The examinee: Determines that the data is NOT within "Acceptable" limits and refers to Attachment 1. Notifies the US that the pump failed the surveillance. Advises the US to carry out the steps in Attachment 1. |
| Comments: | After this step is c | ompleted, the JPM is considered complete. |
| STOP TIME | : | |

12

·

VERIFICATION OF JPM COMPLETION

| Job Performance Measure No. | JPM-S4 | Rev. | <u>0</u> |
|--|---|-------------------------------|--|
| Date Performed: | | | |
| Operator: | | | |
| Evaluator(s): | | | |
| For examinee to achieve a satisfact
If task is Time Critical, it <u>MUST</u> be
grade. | ctory grade, <u>ALL</u> critical steps
completed within the specifie | s must be co
ed time to ac | mpleted correctly.
hieve a satisfactory |
| | | | |
| Time Critical Task? Yes | No | | |
| Validated Time (minutes): | 20 | | |
| Actual Time to Complete (minutes | s):
 | | |
| Result of JPM: (Denote | e by an <u>S</u> for satisfactory or a | <u>U</u> for unsati | sfactory) |
| Areas for Improvement: | | | |

1.00

EXAMINEE HANDOUT

.

| JPM Number: | JPM-S4 | Rev. | 0 |
|---------------------|---|---|---|
| Initiating Cues: | The US has directed you RECIRCULATION CHEC maintenance. You are to start at ste The completed steps | to complete SP 2610B0
K VALVE IST," for a ret
p 4.2.10 of SP 2610BO
of the procedure are ma | D, "TDAFP AND
est after minor
, Rev. 000-00.
arked. |
| Initial Conditions: | The TDAFP Trip Test Vibration Data does N The operation of the T
Discharge Check, 2-F A PEO is stationed at The US entered LCO
Item B, per step 4.2.5 Turbine AFP Discharg No S/G Tube leaks ex Aux Feed Pump Sucti Aux Feed Pump Sucti The TDAFP is ready t
TDAFW for Service," if The examiner will act
person. | does NOT need to be p
IOT need to be taken.
Ferry Turbine Minimum I
W-33, does NOT need
the TDAFP
3.7.1.2 per step 4.1.3 a
ge Isolation, 2-FW-9C, is
dist.
fon Header X-Tie, 2-CN-2
to start. OP 2322, section
is complete.
as the US, PEO, and ar | performed.
Flow Recirc
to be verified.
nd TRMAS 7.1.15,
s closed.
-28, is open.
27A, is open.
in 4.2 "Aligning
ny other support |

JOB PERFORMANCE MEASURE APPROVAL SHEET

1. JPM Title: <u>"A" DG Operability Test (Alternate Path)</u>

ID Number:

JPM-S5

Revision: 0

II. Initiated:

Pantalone Developer

Provide all handouts at the start of the JPM.

1/18/05 Date

III. Reviewed:

Technical Reviewer

1/27/05 Date

IV. Approved:

User Department Supervisor

Date

Nuclear Tra ning Supervisor

Date

SUMMARY OF CHANGES

_

| A/I & Date | DESCRIPTION | REV/CHANGE |
|------------|---|------------|
| 01/18/2005 | Modified JPM 223 Rev1 by using a different malfunction to develop this JPM. | 0 |
| (DAP) | | |
| | | |
| | | |
| | | |
| | | |

JOB PERFORMANCE MEASURE WORKSHEET

| Facility: MP-2 | Examinee: | |
|---|--|--|
| JPM Number: | JPM-S5 | Rev0 |
| Task Title: Conduct | a Facility 1 or 2 D/G operabi | lity test. |
| System: Diesel Gener | ator | |
| Time Critical Task: Yes | NoX | |
| Validated Time (minutes) | : 20 min | |
| Task No.(s): NUTIMS | # 064-02-015 | |
| Applicable To: SR | 0 <u>X</u> RO <u>X</u> | PEO |
| K/A No.: 064 A4 | .01 K/A Rating: 4.0 |)/4.3 |
| Method of Testing: | | |
| Simulated Performance: | Actual Perfo | ormance: X |
| Location: | | |
| Classroom: | Simulator: X | In-Plant: |
| <u>Task Standards:</u> | Examinee performs the Fac
SP 2613A, on the 'A' D/G, re
annunciator. Upon requesti
diesel room, the examinee r | ility 1 Diesel Generator Operability Test,
ecognizes the "D/G 12U Trouble"
ing information from the PEO in the
recommends, or trips, the 'A' D/G. |
| <u>Required Materials</u>
(procedures, equipment): | Stop watch
Authorized OPS Form 2613
SP 2613A, Diesel Generato
04, completed through step | A-001, Rev. 020-01
r Operability Tests, Facility 1, Rev. 021-
4.1.20. |
| <u>General References:</u> | SP 2613A, Diesel Generato
04 | r Operability Tests, Facility 1, Rev. 021- |

**** READ TO THE EXAMINEE ****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

JOB PERFORMANCE MEASURE WORKSHEET

| JPM Number: | JPM-S5 | Rev | 0 |
|---------------------------------|--|---|---|
| Initiating Cues: | The US has directed you to perform
Operability Test (Fast Start, Loade
beginning at step 4.1.21 Review step 4.1.2 and 4.1.4 prior to
surveillance. I will act as the US, PEO, etc. | n the Period
d Run) per
c commenc | dic 'A' D/G
SP 2613A,
ing the |
| Initial Conditions: | All plant conditions are normal. NO other surveillances are being p 2613A. SP 2613A-001 has been authorized. There are NO Ozone alerts in affect. Valve Alignment Check, OPS Form performed two weeks ago. NO maintenance has been perform last two weeks. The 'A' D/G pre-start check list, 234 completed. Steps 4.1.1 through 4.1.18 were performed two had to leave due to a A PEO has been briefed and is star gage board. He will complete the D 004. The applicable portions of SP 2619 Inoperability, were completed 5 mir A chart recorder is installed for autor. | erformed th
d for release
t.
2613A-002
ned on the "
46A-002, ha
erformed by
family eme
nding by at
/G Data Sh
0G, AC Elec
nutes ago.
5 triggering | at interfere with
e.
2 was
A" DG in the
as been
another
ergency.
the 'A' D/G
beet, 2346A-
strical Sources
at the 'A' D/G. |
| <u>Simulator Requirements</u> : | Initialize at a normal 100% power Ensure the 'B' D/G is operable with the powered from the Ensure 24C is powered from the Ensure Z1 SW total flow is ≥ 20 Ensure no surveillances will interest I/O A-36, panel CO-8 'ON' for B | er IC or a L
with its brea
e NSST or I
00 GPM.
erfere with 2
T37 | ow Power IC.
Iker open.
RSST.
2613A. |

**** NOTES TO EXAMINER ****

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. This JPM may be performed in conjunction with JPM-220 and JPM 221.

| JPM ID NUME | BER: <u>JPM-S5</u> | TITLE: | "A" DG Operability Test | |
|-------------|---|--|--|-----------|
| START TIME: | | | | |
| | ~~~~~~~~ | ~~~~~~ | ~~~~~~ | |
| STEP 1 | Performance St | teps: If D/C
not s
the D | G prelube time exceeds 12 minutes and D/G
started, then perform applicable steps to rota
D/G with air. | is
ite |
| GRADE | Standards: | Examinee
exceed 12 | e states that the prelube time should NOT
2 minutes. | |
| | Cue: | | | |
| Comments: | | | | |
| | ~~~~~~~ | | | |
| STEP 2 | X Performance Ste | eps: Place
prelu | e Prelube Pump switch in START and start be timing. | |
| GRADE | <u>X</u> Standards: | Exami
positio Exami
minute | inee places Prelube Pump switch in the STA
on and starts the stop watch.
inee stops the stop watch when 9.5 to 12
es has elapsed. | RT |
| | Cue: At the disc
minutes h
(Booth Op
<u>Trouble" a</u>
When ask
alarm on t | cretion of
as elapsed
<u>perator - E</u>
alarm on C
ked the op
the EDG al | the examiner, inform the examinee that 9
d.
<u>GR16 'Norm' [This resets the "12U DG</u>
<u>:O-8])</u>
erator may request the PEO to reset the
larm panel. | |
| Comments: | The 9 minute mark all | lows the ex | caminee time to review the next set of steps. | |

5

~~~~~~~

-

| JPM ID NUM | BER: <u>JPM-S5</u>       | TITLE: "A" DG Operability Test                                                                                                                                                                                              |
|------------|--------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| STEP 3     | <u>X</u> Performance     | <ul> <li>Steps: When 9½ to 12 minutes has elapsed, perform the following:</li> <li>Start the chart recorder</li> <li>Simultaneously place the "A" DG Manual Start-Stop switch in START and start the stop watch.</li> </ul> |
| GRADE      | <u>X</u> Standards:      | <ul> <li>When 9½ to 12 minutes has elapsed, examinee informs the PEO to start the chart recorder</li> <li>Examinee simultaneously places the "A" DG Manual Start-Stop switch in START and starts the stop watch.</li> </ul> |
|            | Cue: Inform e            | examinee that the chart recorder is running.                                                                                                                                                                                |
| Comments:  |                          |                                                                                                                                                                                                                             |
|            | ~~~~~~~                  | ~~~~~                                                                                                                                                                                                                       |
| STEP 4     | X Performance S          | Steps: When diesel Ready To Load alarm is lit, stop the stop watch.                                                                                                                                                         |
| GRADE      | <u>X</u> Standards:      | After approximately 8 seconds, the examinee observes<br>the "Ready To Load" annunciator (A-34, C-08) and stops<br>the stop watch.                                                                                           |
|            | Cue:                     |                                                                                                                                                                                                                             |
| Comments:  | The Ready to Load        | alarm will be annunciated in less than 15 seconds.                                                                                                                                                                          |
| STEP 5     | Performance S            | Steps: ENSURE "PRESSS DELAY CIRCUIT ENERGIZED"<br>light is lit after 25 seconds.                                                                                                                                            |
| GRADE      | Standards:               | The examinee asks the PEO at the 'A' D/G to report when the "PRESS DELAY CIRCUIT ENERGIZED" light is lit and monitors clock.                                                                                                |
|            | Cue: Wait app<br>CIRCUIT | roximately 25 seconds and report the "PRESS DELAY<br>ENERGIZED" light is lit.                                                                                                                                               |

Comments:

....

—

| JPM ID NUMBER: JPM-S5 TITLE: "A" DG Operability Test                                                                                                                                                                                                                                                                                                           |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| STEP 6 X Performance Steps: Place Prelube Pump switch in STOP.                                                                                                                                                                                                                                                                                                 |
| GRADE <u>X</u> Standards: Examinee places the Prelube Pump switch in STOP.                                                                                                                                                                                                                                                                                     |
| Cue:                                                                                                                                                                                                                                                                                                                                                           |
| Comments:                                                                                                                                                                                                                                                                                                                                                      |
| ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~                                                                                                                                                                                                                                                                                                                        |
| STEP 7 Performance Steps: Record stop watch diesel start time on OPS Form 2346A-004, "A" DG Data Sheet.                                                                                                                                                                                                                                                        |
| GRADE Standards: Examinee directs the PEO to enter the time from the stop watch on OPS Form 2346A-004, "A" DG Data Sheet.                                                                                                                                                                                                                                      |
| Cue: The time has been entered on the form.                                                                                                                                                                                                                                                                                                                    |
| Comments: The start time must be less than or equal to 15 seconds.                                                                                                                                                                                                                                                                                             |
| STEP 8 Performance Steps: Record the appropriate information on SP 2613A-001.                                                                                                                                                                                                                                                                                  |
| <ul> <li>GRADE Standards: Examinee records the following on SP 2613A-001</li> <li>Stopwatch diesel start time, if &lt; 15 sec. Initial the form.</li> <li>'A' D/G voltage, if between 3740 to 4580 volts, initial the form.</li> <li>'A' D/G frequency, if between 58.8 and 61.2 Hz, initial the form.</li> <li>Initial for adequate pre-lube time.</li> </ul> |
| Cue:                                                                                                                                                                                                                                                                                                                                                           |

Comments: The start time must be less than 15 sec.

| PERFORMANCE INFORMATION                  |                                |                                                                                                              |                   |
|------------------------------------------|--------------------------------|--------------------------------------------------------------------------------------------------------------|-------------------|
| JPM ID NUMBER: JPM-                      | <u>35</u> TIT                  | LE: "A" DG Operability Test                                                                                  |                   |
| STEP 9 Perform                           | nance Steps:                   | Adjust "A" DG Load Cntl Governor Cntl swite obtain at least 60 Hz.                                           | sh to             |
| GRADE Standa                             | ards: The<br>swite             | examinee adjusts "A" DG Load Cntl Governo<br>ch to obtain at least 60 Hz.                                    | or Cntl           |
| Cue:                                     |                                |                                                                                                              |                   |
| Comments:                                |                                |                                                                                                              |                   |
| ~~~~                                     | ~~~~~~                         | ~~~~~~                                                                                                       |                   |
|                                          |                                |                                                                                                              |                   |
| STEP 10 <u>X</u> Perforn                 | nance Steps:                   | Place Syn Switch, 15G-12U-2, to ON.                                                                          |                   |
| GRADE <u>X</u> Standa                    | nds: The<br>hole<br>the C      | examinee obtains the hand switch, places it i<br>for Syn Switch, 15G-12U-2, and turns the sw<br>DN position. | n the<br>vitch to |
| Cue:                                     |                                |                                                                                                              |                   |
| Comments: After approxi<br>This is an ex | mately 1 minu<br>pected alarm. | te, the SYNC SWITCH ON alarm will annunc                                                                     | siate.            |

| JPM ID NUMBER: JPM-S5 TITLE: "A" DG Operability Test                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |                                                                                                                                                                                                                                                                               |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| STEP 11 <u>X</u> Performance Steps: Adjust "A" DG Voltage Cntl Reg Auto<br>match generator voltage with bus volt                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               | Cntl switch to age.                                                                                                                                                                                                                                                           |
| GRADE <u>X</u> Standards: The examinee will place the "A" DG Voltag<br>Auto Cntl switch in either RAISE or LOWE<br>Incoming voltage with the Running voltage                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | e Cntl Reg<br>R to match the                                                                                                                                                                                                                                                  |
| Cue: The second se                                                                                                                                                                                                                                             |                                                                                                                                                                                                                                                                               |
| Comments:                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |                                                                                                                                                                                                                                                                               |
| ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |                                                                                                                                                                                                                                                                               |
| STEP <b>12</b> <u>X</u> Performance Steps: Turn "A" DG Volt Cntl Trans Sw to MA                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | N.                                                                                                                                                                                                                                                                            |
| GRADE <u>X</u> Standards: The examinee places the "A" DG Volt Cntl MAN.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        | Trans Sw in                                                                                                                                                                                                                                                                   |
| Cue: president and the state state of the st |                                                                                                                                                                                                                                                                               |
| Comments:                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |                                                                                                                                                                                                                                                                               |
| ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |                                                                                                                                                                                                                                                                               |
| STEP <b>13</b> <u>X</u> Performance Steps: Adjust "A" DG Voltage Cntl Reg Man (<br>match generator voltage with bus volta                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      | Cntl switch to<br>age.                                                                                                                                                                                                                                                        |
| GRADE <u>X</u> Standards: The examinee place the "A" DG Voltage CI<br>Cntl switch in either RAISE or LOWER to n<br>Incoming voltage with the Running voltage.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | ntl Reg Man<br>natch the                                                                                                                                                                                                                                                      |
| Cue: 1975 And 1985 And 1985 And 1986 And 1997 An | an 1917 - San Angela, an San Angela, an<br>San Angela, ang San Angela, ang<br>San Angela, ang San Angela, ang |
| Comments:                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |                                                                                                                                                                                                                                                                               |

۰.

. ....

ميور - 1

| JPM ID NUMBER:   | <u>JPM-S5</u>  | TITLE: "A" DG Operability Test                                                                                                                                                                       |
|------------------|----------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| STEP 14 _X_      | Performance St | teps: Turn "A" DG Volt Cntl Trans Sw to AUTO.                                                                                                                                                        |
| GRADE <u>X</u>   | Standards:     | The examinee places the "A" DG Volt Cntl Trans Sw in AUTO.                                                                                                                                           |
| (                | Cue:           |                                                                                                                                                                                                      |
| Comments:        |                |                                                                                                                                                                                                      |
|                  | ~~~~~~~~       | ~~~~~~                                                                                                                                                                                               |
| STEP 15 <u>X</u> | Performance St | teps: Turn Unit Parallel Sel Sw/12U to UNIT PARALLEL<br>and observe Unit Parallel white light lit.                                                                                                   |
| GRADE <u>X</u>   | Standards:     | The examinee will place the Unit Parallel Sel Sw/12U to<br>the UNIT PARALLEL position and observe Unit Parallel<br>white light is lit.                                                               |
| C                | Cue:           |                                                                                                                                                                                                      |
| Comments:        |                |                                                                                                                                                                                                      |
|                  | ~~~~~~         | ~~~~~                                                                                                                                                                                                |
| STEP 16          | Performance St | eps: To ensure slow rotation (0.5 to 1 rpm) of sychroscope<br>in fast direction, adjust "A" SG Load Cntl Governor<br>Cntl switch to raise or lower engine speed.                                     |
| GRADE            | Standards:     | The examinee will place the "A" SG Load Cntl Governor<br>Cntl switch in the RAISE or LOWER position to ensure<br>the syncroscope is rotating at approximately 0.5 to 1 rpm<br>in the fast direction. |
| С                | Cue:           |                                                                                                                                                                                                      |
| Comments:        |                |                                                                                                                                                                                                      |
|                  | ~~~~~~~        | ~~~~~~                                                                                                                                                                                               |

| JPM ID NUM     | IBER: <u>JPM-S5</u>                                                          | TITLE: "A" DG Operability Test                                                                                                                                                                                                                                                                                                                                    |
|----------------|------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| STEP 17        | X Performance S                                                              | teps: When synchroscope needle passes "11 o'clock"<br>position, simultaneously close DG A Fdr Bkr, 15G-<br>12U-2 (A312)                                                                                                                                                                                                                                           |
| GRADE          | <u>X</u> Standards:                                                          | When synchroscope needle passes "11 o'clock" position,<br>The examinee will simultaneously close the "A" DG<br>Output Breaker, 15G-12U-2 (A312).                                                                                                                                                                                                                  |
|                | Cue:                                                                         |                                                                                                                                                                                                                                                                                                                                                                   |
| Comments:      | Due to the operating<br>may NOT close or m<br>The examinee may b<br>breaker. | characteristics of the simulator, the "A" DG Output Breaker<br>hay trip. This does NOT constitute a failure of the JPM.<br>be given additional opportunities to reset and close the                                                                                                                                                                               |
|                |                                                                              |                                                                                                                                                                                                                                                                                                                                                                   |
| STEP <b>18</b> | X Performance S                                                              | <ul> <li>Adjust "A" DG Load CNTL Governor Cntl switch to<br/>load the "A" DG to between 1,350 and 1,450 kW<br/>at a rate of 250 to 300 kW per minute.</li> <li>While raising "A" DG load, Adjust "A" DG Voltage<br/>Cntl Reg Auto Cntl to maintain a kvar loading at<br/>approximately 50% of the kW loading.</li> </ul>                                          |
| GRADE          | <u>X</u> Standards:                                                          | <ul> <li>The examinee will use the "A" DG Load Cntl<br/>Governor Cntl switch to load the "A" DG to between<br/>1,350 and 1,450 kW at a rate of 250 to 300 kW per<br/>minute.</li> <li>While raising "A" DG load, the examinee will adjust "A"<br/>DG Voltage Cntl Reg Auto Cntl to maintain a kvar<br/>loading at approximately 50% of the kW loading.</li> </ul> |
|                | Cue                                                                          |                                                                                                                                                                                                                                                                                                                                                                   |
| Comments:      | Annunciator (A-36, C<br>annunciated when lo<br>NOT notice the annu           | -08) "DIESEL GENERATOR 12U TROUBLE", will be<br>ad is raised to approximately 500 kW. The examinee may<br>nciator until load is raised to the directed range.                                                                                                                                                                                                     |

11

| JPM ID NUM                                                                              | IBER: JPM-S5                                                                   | TITLE: "A" DG Operability Test                                                                                                                                    |  |  |
|-----------------------------------------------------------------------------------------|--------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|
| STEP <b>19</b>                                                                          | <u>X</u> Performance Step                                                      | os: Observe Annunciator (A-36, C-08) "DIESEL<br>GENERATOR 12U TROUBLE"                                                                                            |  |  |
| GRADE                                                                                   | <u>X</u> Standards: 7<br>"I                                                    | he examinee will observe and annunciator (A-36, C-08)<br>DIESEL GENERATOR 12U TROUBLE".                                                                           |  |  |
|                                                                                         | Cue:                                                                           |                                                                                                                                                                   |  |  |
| Comments:                                                                               |                                                                                |                                                                                                                                                                   |  |  |
|                                                                                         | ~~~~~~~                                                                        | ~~~~~                                                                                                                                                             |  |  |
|                                                                                         |                                                                                |                                                                                                                                                                   |  |  |
| STEP <b>20</b>                                                                          | <u>X</u> Performance Step                                                      | es: Send an operator to the 'A' D/G panel C-38 to determine cause of the annunciator.                                                                             |  |  |
| GRADE                                                                                   | <u>X</u> Standards: T                                                          | he examinee directs the PEO in the 'A' D/G room to eport the cause of the annunciator.                                                                            |  |  |
| Cue: As the PEO, report that annunciator (B-1, C-38) "LUBE OIL<br>PRESSURE LOW" is lit. |                                                                                |                                                                                                                                                                   |  |  |
|                                                                                         | If the exami<br>D/G Lube O                                                     | nee requests a report of lube oil pressure, report 'A'<br>il pressure = 19 psig and decreasing slowly.                                                            |  |  |
|                                                                                         | If requested is missing.                                                       | I the PEO reports that the ARP for alarm B-1 on C-38                                                                                                              |  |  |
| Comments:                                                                               | Due to the seriousness<br>report on lube oil press<br>Oil Pressure" before (re | of the annunciator, the examinee may NOT wait for a<br>ure or for referring to the ARP for (B1, C-38) "Low Lube<br>ecommend) tripping the "A" DG. (See next step) |  |  |

~~~~~~~~~~

JPM ID NUMBER: JPM-S5	TITLE: "A" DG Operability Test
STEP 21 <u>X</u> Performa	nce Steps: Refer to ARP 2591A (B-1, C-38) "LUBE OIL PRESSURE LOW". - Setpoint = 20 psig decreasing - Auto Function, diesel trips.
GRADE <u>X</u> Standard	ls: The examinee refers to ARP 2591A "Lube Oil Pressure Low", and directs the PEO in the 'A' D/G Room to report lube oil pressure.
	 Upon receiving a report of 19 psig and slowly dropping, the examinee will either: Recommend tripping the 'A' D/G or will immediately trip the 'A' D/G by one, or a combination of, the following. Simultaneously push both emergency trip buttons. Place the "A" DG Man Start-Stop switch in the STOP position. Trip the "A" DG Output breaker, then place the "A" DG Man Start-Stop switch in the STOP position.
Cue: As t psiç	he PEO in the 'A' D/G Room report lube oil pressure = 19 g and dropping slowly.
Comments: While ARP 259 D/G should hav	91A (B-1) does not direct the D/G be tripped, it clearly stated the ve tripped. The examinee should recommend or trip the 'A' D/G.
STEP 22 <u>X</u> Performan	nce Steps: Trip the "A" EDG by pushing both Emergency Trip push buttons (CO-8 vertical section), and observing the breaker tripping open and the EDG frequency lowering.
GRADE <u>X</u> Standard	s: The examinee trips the "A" EDG by simultaneously pushing the Emergency Trip pushbuttons. The examinee observes the EDG breaker trip open and the frequency lowering.
Cue:	

Comments:

-

JPM ID NUMBER: JPM-S5 TITLE: "A" DG Operability Test

Comments: After this step is completed, the JPM is considered complete.

STOP TIME: _____

.

VERIFICATION OF JPM COMPLETION

Job Performance Measure No.	JPM-S5	Rev.	<u>0</u>
Date Performed:			
Operator:			
Evaluator(s):		<u></u>	
For examinee to achieve a satisfactory Time Critical, it <u>MUST</u> be completed w	grade, <u>ALL</u> critical steps must t ithin the specified time to achiev	be completed e a satisfacto	correctly. If task is ry grade.
Time Critical Task? Yes	No <u>X</u>		
Validated Time (minutes):20	minutes		
Actual Time to Complete (minutes):		
Result of JPM: (Denote	by an <u>S</u> for satisfactory or a	<u>U</u> for unsati	sfactory)

Areas for Improvement:

<u>IC-93</u> Low Power JPMs

	<u>A</u>	<u>B</u>	<u>C</u>	<u>D</u>
ASI Upper	4.73	4.69	4.70	4.70
ASI Lower	4.73 ¹¹	4.70	4.72	4.69
Nuclear Power	ð 99	4.87	4.89	4.87
<u>∆T Power</u>	3.90	4.09	3.93	4.06
Tcold Cal.	4.80	4.61	4.90	4.90

EXAMINEE HANDOUT

JPM ID Number: JPM-S5

Initiating Cues:

- The US has directed you to perform the Periodic 'A' D/G Operability Test (Fast Start, Loaded Run) per SP 2613A, beginning at step 4.1.21
- Review step 4.1.2 and 4.1.4 prior to commencing the surveillance.
- I will act as the US, PEO, etc.

Initial Conditions:

- All plant conditions are normal.
- NO other surveillances are being performed that interfere with 2613A.
- SP 2613A-001 has been authorized for release.
- There are NO Ozone alerts in affect.
- Valve Alignment Check, OPS Form 2613A-002 was performed two weeks ago
- NO maintenance has been performed on the "A" DG in the last two weeks.
- The 'A' D/G pre-start check list, 2346A-002, has been completed.
- Steps 4.1.1 through 4.1.18 were performed by another operator who had to leave due to a family emergency.
- A PEO has been briefed and is standing by at the 'A' D/G gage board. He will complete the D/G Data Sheet, 2346A-004.
- The applicable portions of SP 2619G, AC Electrical Sources Inoperability, were completed 5 minutes ago.
- A chart recorder is installed for auto triggering at the 'A' D/G.
- "B" D/G is OPERABLE.

JOB PERFORMANCE MEASURE APPROVAL SHEET

Power Range Safety Channel and Delta T Power Channel Calibration 1. JPM Title:

ID Number:

JPM-S6

Initiated: 11.

lily R. J. Ashey

Developer

Provide all handouts at the start of the JPM

1/10/05

Date

Revision: 0

III. Reviewed:

Technical Reviewer

IV. Approved:

User Department Supervisor

Nuclear Training Supervisor

Date

Date

SUMMARY OF CHANGES

A/I & Date	DESCRIPTION	REV/CHANGE	
	·······		

JOB PERFORMANCE MEASURE WORKSHEET

Facility: MP-2	Examin	ee:				
JPM Number:	JPM-S6		Rev	0		
Task Title: Power Ra	Task Title: Power Range Safety Channel and Delta T Power Channel Calibration					
System: Instrumentatio	n					
Time Critical Task: Yes No _X						
Validated Time (minutes):	10 minutes					
Task No.(s): <u>NUTIMS</u> #	015-02-002			<u></u>		
Applicable To: SRC	X RO X	PEO				
K/A No.: 012 A2.0	K/A Rating: _	3.1/3.2				
Method of Testing:						
Simulated Performance:	Actual	Performance: _	X			
Location:						
Classroom:	Simulator:	<u>x</u>	In-Plant:			
Task Standards:During the performance of SP 2601D, Power Range Safety Channel and Delta T Power Channel Calibration, the examinee determines that the -10 Volt power Supply voltage is not in the acceptable range and bypasses the channel.						
Required Materials (procedures,equipment):	 SP 2601D, Power F Channel Calibration Authorized copy of Range Safety Chan Calculator 	Range Safety Cl i surveillance for inel and Delta T	hannel ai m SP 26 ⁻ Power (nd Delta T Power 01D-001, Power Channel Calibration		
General References:	SP 2601D, Power Rang Channel Calibration	ge Safety Chan	nel and [Delta T Power		
	* * * * READ TO THE EX	(AMINEE * * * *				

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

JOB PERFORMANCE MEASURE WORKSHEET

JPM Number:	JPM-S6	Rev	0			
Initiating Cues:	 You are the PPO An I&C Technician has just complete calibration on RPS Channel "C". 	PPO nician has just completed the incore/excore detector RPS Channel "C".				
	 The US has directed you to perforr Power Range Safety Channel and Calibration, for RPS Channel "C" o 	n surveillan Delta T Pov <u>nly</u> .	ce SP 2601D, wer Channel			
Initial Conditions:	 The plant is at 100% power All systems are in a normal alignme SP 2601D-001 has been authorized 	ent d				
<u>Simulator Requirements</u> :	Any 100% power, stable IC. (e.g., I Insert malfunction RP30C at 4% to supply on Channel "C" to read –9.9	C-24) cause the - 96 Volts.	–10 Volt power			

**** NOTES TO EXAMINER ****

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM (in-plant only).
| JPM ID NUMBER: <u>JPM-S6</u> | TITLE: Power Range Safety Channel and Delt
Power Channel Calibration | а Т |
|------------------------------|---|-------------|
| START TIME: | | |
| STEP 1 X Performance Ste | eps: Place Meter Input switch to "METER INPUT. | ** |
| GRADE <u>X</u> Standards: | Examinee places RPS Channel "C" Meter Inpu
"METER INPUT" position. | t switch to |
| Cue: The | | |
| Comments: | | |
| ~~~~~~~ | .~~~~~~ | |
| STEP 2 X Performance Ste | eps: Press and hold the "ZERO" test button. | |
| GRADE <u>X</u> Standards: | Examinee presses and holds the "ZERO" test but RPS Channel "C". | ton on |
| Cue: | | |
| Comments: | | |
| ~~~~~~~ | ~~~~~~ | |
| STEP 3 X Performance Ste | eps: When voltage is observed, release test butto record respective voltage on applicable form | n and |
| GRADE <u>X</u> Standards: | Examinee observes a voltage of 0.000 <u>+</u> 0.003 volt releases the test button, and records this value or 2601D-001, page 2, step 4.1.1c for Channel "C" | s,
1 SP |
| Cue: | | |
| Comments: | | |
| ~~~~~~~~ | ~~~~~ | |

JPM ID NUMBER:	<u>JPM-\$6</u>	TITLE: Power Range Safety Channel and Delta T Power Channel Calibration
STEP 4 X	Performance St	teps: Press and hold the "+10V" test button.
GRADE <u>X</u>	Standards:	Examinee presses and holds the "+10V" test button on RPS Channel "C".
Cu	le:	
Comments:	~~~~~~~	~~~~~~
STEP 5 X	Performance St	teps: When voltage is observed, release test button and record respective voltage on applicable form.
GRADE <u>X</u>	Standards:	Examinee observes a voltage of +10.000 <u>+</u> 0.003 volts, releases the test button, and records this value on SP 2601D-001, page 2, step 4.1.1c for Channel "C"
Cı	le:	
Comments:		
STEP 6 X	Performance St	teps: Press and hold the "-10V" test button.
GRADE X	Standards:	Examinee presses and holds the "-10V" test button on RPS Channel "C".
Cu	ie:	
Comments:		
	~~~~~~~	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
STEP 7 <u>X</u> F	Performance St	eps: When voltage is observed, release test button and record respective voltage on applicable form.
GRADE <u>X</u>	Standards:	Examinee observes a voltage of –9.996 volts, releases the test button, and records this value on SP 2601D-001, page 2, step 4.1.1c.for Channel "C"
Cu	Ie:	
Comments:	~~~~~~~~~	

· ---- •

.

JPM ID NUM	BER:	JPM-S6	TITLE:	Power Range Safety Channel and Delta T Power Channel Calibration
STEP 8	<u>X</u>	Performance S	teps: Con "Aco	npare each channel's voltage values within ceptance Criteria" range on applicable form.
GRADE	<u>x</u>	Standards:	Examine volts exc 10.003 v Channel Examine step 4.1.	e determines that the voltage reading of –9.996 eeds the acceptance criteria of –9.997 to – olts on SP 2601D-001, page 2, step 4.1.1c for "C" e checks "UNSAT" on SP 2601D-001, page 2, 2, for Channel "C"
	C	Cue:		
Comments:				
		~~~~~~	~~~~~	~~~~~
STEP 9	<u>X</u>	Performance S	teps: If ar perf • I • I • I • I	ny values are outside of acceptance criteria, orm the following: Refer to Technical Specification LCO 3.3.1.1 and berform applicable actions to declare applicable RPS channel inoperable. Perform applicable actions to place the RPS channel's trips in a bypassed condition. Submit Priority 1 Trouble Report to I&C Department to repair or calibrate voltmeter.
GRADE	<u>×</u>	Standards:	Examined and perfo Inform and ru Tech Place on Ch Recou to the Chan States accor restor	e determines that RPS Channel "C" is inoperable orms the following: ins the US that RPS Channel "C" is inoperable ecommends logging into the action statement for Spec LCO 3.3.1.1. is the bypass key lock switches for all trip units nannel "C" in the "trip" position. mmends submitting a Priority 1 Trouble Report I&C Department for repair or calibrate the RPS nel "C" –10 volt power supply. is that the remainder of the calibration cannot be inplished until the –10 volt power supply is red.
	C	ue: If the exa ask him/I	minee doo ner what ro	es NOT make the recommendations listed, ecommendations he/she would make.
Comments:	Afte	r this step is co	mpleted, t	the JPM is considered complete.
		~~~~~~~	~~~~~	~~~~~~~~~
STOP TIME:		an a		

## VERIFICATION OF JPM COMPLETION

Job Performance Measure No.	JPM-S6	Rev.	<u>0</u>	
Date Performed:	-			
Operator:				
Evaluator(s):				
For examinee to achieve a satisfactor Time Critical, it <b>MUST</b> be completed	ry grade, <u>ALL</u> criti within the specifie	ical steps must be comple d time to achieve a satisfa	ted correctly. I actory grade.	f task is
Time Critical Task? Yes	X			
Validated Time (minutes): 10	) minutes			
Actual Time to Complete (minute	es): 			
Result of JPM: (Denot	te by an <u>S</u> for sa	ntisfactory or a <u>U</u> for uns	satisfactory)	
Areas for Improvement:				

#### **EXAMINEE HANDOUT**

JPM ID Number: JPM-S6

Initiating Cues:

- You are the PPO
- An I&C Technician has just completed the incore/excore detector calibration on RPS Channel "C".
- The US has directed you to perform surveillance SP 2601D, Power Range Safety Channel and Delta T Power Channel Calibration, for RPS Channel "C" <u>only</u>.

Initial Conditions:

- The plant is at 100% power
- All systems are in a normal alignment
- SP 2601D-001 has been authorized

# JOB PERFORMANCE MEASURE APPROVAL SHEET

JPM Title: Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger

ID Number:

JPM-S7

Revision: 0

II. Initiated:

1.

R. J. Ashey

Developer

Provide all handouts at the start of the JPM

1/18/05 Date

III. Reviewed:

Daniel. alone.

**Technical Reviewer** 

Dáte

IV. Approved:

User Department Supervisor

Date

Date

Nuclear Training Supervisor

#### SUMMARY OF CHANGES

· · · · · · ·

A/I & Date	DESCRIPTION	REV/CHANGE

_

#### JOB PERFORMANCE MEASURE WORKSHEET

Facility:	MP-2	Examinee:	
JPM Number:	JPM-	-\$7	Rev0
Task Title:	Placing "B" RI "A" RBCCW P	BCCW Pump and Heat Exc ump and Heat Exchanger	hanger in Service and Removing
System: Pla	ant Service – Rea	actor Building Closed Coolin	g Water
Time Critical T	ask: Yes	NoX	
Validated Time	e (minutes):	30 minutes	
Task No.(s):	NUTIMS # 076-	-01-043	
Applicable To:	SRO	X RO X PEC	)
K/A No.:	008 A4.01	K/A Rating:3.3/3.1	. <u></u>
Method of Testi	ng:		
Simulated Pe	rformance:	Actual Performa	nce: X
Location:			
Classroom:		Simulator: X	In-Plant:
Task Standard	<u>s:</u> The serv	examinee places "B" RBCC vice in place of "A" RBCCW	W Pump and Heat Exchanger in Pump and Heat Exchanger.
Required Mate (procedures,eq	<u>rials</u> OP juipment):OP	2330A, RBCCW System, Se 2326A, Service Water Syste	ections 4.1, 4.2 and 4.16. m, Sections 4.9 and 4.11
General Refere	ences:		

#### **** READ TO THE EXAMINEE ****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

#### JOB PERFORMANCE MEASURE WORKSHEET

JPM Number:	JPM-S7	Rev. 0
Initiating Cues:	<ul> <li>You are the SPO.</li> <li>Preventive Maintenance is schedu Exchanger and Pump.</li> <li>The US directs you to place the "B RBCCW HX in service and to rem "A" RBCCW HX from service per 0 first) and OP 2326A section 4.9.</li> <li>I will act as the US/PEO as needed</li> </ul>	aled on the "A" RBCCW Heat 3" RBCCW pump and "B" ove the "A" RBCCW pump and OP 2330A, sections 4.2 (Pump d
Initial Conditions:	<ul> <li>"A" &amp; "C" RBCCW Pumps and Heat</li> <li>Bus 24E is aligned to Bus 24C.</li> <li>"B RBCCW Pump breaker (A504)</li> <li>The SIAS/LNP Actuation Signal Has BLOCK position.</li> <li>The "B" RBCCW HX is presently b "A" Service Water header.</li> <li>Injection temperature is 44°F.</li> <li>All other plant conditions are norm</li> </ul>	at Exchangers are in service racked up. S 6119D (A504) is in the being used for minimum flow for al.
Simulator Requirements:	<ul> <li>Initialize to any IC with:</li> <li>A normal RBCCW lineup ("A" &amp; exchangers in service; "B RBC minimum flow for "A" Service V</li> <li>Bus 24E aligned to Bus 24C.</li> <li>SIAS/LNP Actuation Signal HS position.</li> <li>Insert a malfunction to cause foulir Exchanger after it is placed in serv 47, ramp in at 10 sec.)</li> </ul>	& "C" pumps and heat CW Heat Exchanger used for Vater header) 6 6119D (A504) in the BLOCK ng of the "B RBCW Heat vice. (SW03B @ 100% on BT-

#### **** NOTES TO EXAMINER ****

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM (in-plant only).

_____

-

JPM ID NUMI	BER: <u>JPM-S7</u>	TITLE:	Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger
START TIME:			
STEP 1	Performance S	steps:	<ul> <li>Verify the following:</li> <li>"B" RBCCW Pump switch is in Pull-To-Lock. (C-06)</li> <li>"RBCCW PP B HDR B SUCT, RB-211D," is closed and "RBCCW PP B HDR A SUCT, RB-211C," is open (C-06)</li> <li>"HDR B HX-B OUT, RB-4.1D," is closed (C-06)</li> </ul>
GRADE	Standards:	Exami • Th To • Th RE • Th 21 • Th is I	nee observes: e "B" RBCCW pump handswitch is in the Pull- -Lock position. e green light for "RBCCW PP B HDR B SUCT, 3-211D," is lit. e red light for "RBCCW PP B HDR A SUCT, RB- 1C," is lit. e green light for "HDR B HX-B OUT, RB-4.1D," it.
	Cue:		
Comments:	The examinee may o	dispatch a l	PEO to locally monitor the pump swap.
STEP 2	<u>X</u> Performance S	teps: Verify	open PP DIS HDR A/B X-TIE, RB-251A. (C-06).
GRADE	<u>X</u> Standards:	Examinee TIE, RB-2 light lit.	e places the handswitch for PP DIS HDR A/B X- 251A, in the open position and observes the red
	Cue:		
Comments:	PP DIS HDR A/B X- is initially open, the e	TIE, RB-25 examinee w	1A, may be open or closed initially. If the valve ill only observe the red light lit.

5

JPM ID NUMBER: <u>JPM-S7</u>	TITLE: Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger
STEP 3 Performance S	teps: Log into TS 3.7.3.1
GRADE Standards:	Examinee informs the US of the need to log into TSAS 3.7.3.1.
Cue: US ackno	owledges the need to enter TSAS 3.7.3.1
Comments:	
~~~~~~~	~~~~~~
STEP 4 X Performance S	teps: Start "RBCCW PP B." (C-06)
GRADE <u>X</u> Standards:	Examinee momentarily places the "B" RBCCW Pump handswitch in the Start position and observes the red light for the "B" RBCCW Pump is lit.
Cue: If asked,	report as the PEO that the pump is running normally.
Comments:	
~~~~~~~	~~~~~~
STEP 5 Performance S	teps: Check alarm RBCCW PUMP B SIAS/LNP START MANUALLY BLOCKED" (AA-20, C-06/07) lit.
GRADE Standards:	Examinee observes alarm RBCCW PUMP B SIAS/LNP START MANUALLY BLOCKED" (AA-20, C-06/07) is lit.
Cue:	
Comments:	
~~~~~~~	~~~~~

6

~...

JPM ID NUMBER: <u>JPM-S7</u> TITLE: Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger
 STEP 6 Performance Steps: Check the following for the "B" RBCCW Pump: Normal running amps (36 to 44 amps) Pump discharge pressure (105 to135 psig)
GRADE Standards: Examinee observes the following indications on C-06 for the "B" RBCCW Pump: • Normal running amps of 36 to 44 amps • Pump discharge pressure of105 to 135 psig
Cue: If the examinee reports low amperage or high discharge pressure, inform him/her that this is normal for two pumps running together.
Comments:
STEP 7 Performance Steps: Close "A" RBCCW Pump Discharge Stop, 2-RB-3A
GRADE Standards: Examinee directs a PEO to close "A" RBCCW Pump Discharge Stop, 2-RB-3A.
Cue: <u>Booth Operator – Set CCR06 to 0%.</u> When directed as the PEO, report that "A" RBCCW Pump Discharge Stop, 2-RB-3A is closed.
Comments: It would normally take 1-2 minutes to close "A" RBCCW Pump Discharge Stop, 2-RB-3A.
STEP 8 X Performance Steps: Stop "A" RBCCW PP A" and place switch in Pull-To-
Lock. (C06) GRADE X Standards: Examinee places the "A" RBCCW Pump handswitch in
the Pull-To-Lock position and observes pump amps lower to "0" and the green light is lit.
Cue:
Comments:

JPM ID NUMBER: <u>JPM-S7</u>	TITLE: Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger
STEP 9 <u>X</u> Performance S	Steps: Place "SIAS/LNP Actuation Signal HS 6119D" (A504) is in the NORMAL position.
GRADE <u>X</u> Standards:	 Examinee directs a PEO to place SIAS/LNP Actuation Signal HS 6119D (A504) is in the NORMAL position and observes the following: "RBCCW PUMP B SIAS/LNP START MANUALLY BLOCKED" annunciator clears. RBCCW HDR A FLOW HI annunciator is NOT lit.
Cue: <u>Booth O</u> PEO, rep (A504) is	<u>perator – CCR40 set to Normal.</u> When directed, as the port that the "SIAS/LNP Actuation Signal HS 6119D" s in the NORMAL position.
Comments:	
STEP 10 Performance S	Steps: Exit Tech Spec 3.7.3.1
GRADE Standards:	<i>Examinee informs the US of the need to exit TSAS</i> 3.7.3.1.
Cue: US ackn	owledges the need to exit TSAS 3.7.3.1
Comments:	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
STEP 11 Performance S	Steps: Open "A" RBCCW Pump Discharge Stop, 2-RB-3A.
GRADE Standards:	Examinee directs a PEO to open "A" RBCCW Pump Discharge Stop, 2-RB-3A.
Cue: <u>Booth O</u> PEO, rep open.	perator – Set CCR06 to 100%. When directed, as the bort that "A" RBCCW Pump Discharge Stop, 2-RB-3A is
Comments:	

.__.

- - -

JPM ID NUM	BER: <u>JPM-S7</u> TITLE: Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger
STEP 12	Performance Steps: Verify "A" RBCCW header flow on FI-6035 greater than or equal to 6,000 gpm and less than 8,000 gpm.
GRADE	Standards: Examinee observes FI-6035 and determines that "A" RBCCW header flow is greater than or equal to 6,000 gpm and less than 8,000 gpm. (Approximately 6300 gpm)
	Cue:
Comments:	Closing PP DIS HDR A/B X-TIE, RB-251A, is NOT required. The "B" RBCCW Heat Exchanger is NOT in service.
STEP 13	 Performance Steps: Perform the following to ensure correct flow through RM-6038: Throttle "B" RBCCW Pump RE Flow Stop, 2-RB-41, as required to set flow indicated on FI-6313 to greater than or equal to one gpm. Throttle "C" RBCCW Pump RE Flow Stop, 2-RB-39, as required to set flow indicated on FI-6314 to greater than or equal to one gpm. Verify flow indicated on FI-6038 is between 2.0 and 4.5 gpm.
GRADE	 Standards: Examinee directs a PEO to: Throttle "B" RBCCW Pump RE Flow Stop, 2-RB-41, as required to set flow indicated on FI-6313 to greater than or equal to one gpm. Throttle "C" RBCCW Pump RE Flow Stop, 2-RB-39, as required to set flow indicated on FI-6314 to greater than or equal to one gpm. Verify flow indicated on FI-6038 is between 2.0 and 4.5 gpm. Cue: When directed, as the PEO report that radiation monitor flows have been set as requested.
Comments:	

-

_

JPM ID NUMBER: <u>JPM-S7</u>	TITLE: Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger
STEP 14 Performance	Steps: Refer to OP 2326A, "Service water System", and establish Service water flow through the "B" RBCCW Heat Exchanger.
GRADE Standards:	Examinee obtains OP 2326A, "Service water System", and selects section 4.9, Placing "B" RBCCW Heat Exchanger in Service and Removing "A RBCCW Heat Exchanger From Service".
Cue: Provide	OP 2326A, Service Water, when requested.
Comments:	
~~~~~~~	~~~~~
STEP <b>15</b> Performance	<ul> <li>Steps: Ensure the following are closed:</li> <li>"B" Service Water Header to "B" RBCCW Heat Exchanger, 2-SW-7A</li> <li>"B" RBCCW Heat Exchanger to "B" Discharge Header, 2-SW-10A.</li> </ul>
GRADE Standards:	<ul> <li>Direct a PEO to verify the following valves are closed:</li> <li>"B" Service Water Header to "B" RBCCW Heat Exchanger, 2-SW-7A</li> <li>"B" RBCCW Heat Exchanger to "B" RBCCW Discharge Header, 2-SW-10A.</li> </ul>
Cue: As the F	PEO, report that 2-SW-7A and 2-SW-10A are closed.
Comments:	
~~~~~~	~~~~~

JPM ID NUMBER: <u>JPM-S7</u> TITLE: Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger	
 STEP 16 Performance Steps: Open the following: "A" Service Water Header to "B" RBCCW Heat Exchanger, 2-SW-7B "B" RBCCW Heat Exchanger to "A" Discharge Header, 2-SW-10B. 	
 GRADE Standards: Direct a PEO to verify the following values are open: "A" Service Water Header to "B" RBCCW Heat Exchanger, 2-SW-7B "B" RBCCW Heat Exchanger to "A" RBCCW Discharge Header, 2-SW-10B. 	
Cue: As the PEO, report that 2-SW-7B and 2-SW-10B are open.	
Comments:	
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	
<ul> <li>STEP 17 Performance Steps: At "B" RBCCW Heat Exchanger temperature controller, TIC-6307, ensure the following:</li> <li>Mode switch in "A" (inside controller)</li> <li>Temperature control knob set greater than 200</li> </ul>	°F.
<ul> <li>GRADE Standards: Direct a PEO to perform the following:</li> <li>Ensure the mode switch is in "A" (inside controller)</li> <li>Set the temperature control knob to greater than 200°F.</li> </ul>	
Cue: <u>Booth Instructor – Set CCR03 to 95.</u> As the PEO, inform the examinee that the temperature controller is in automatic and s to 200°F.	et
Comments:	
STEP 18 Performance Steps: Ensure "B" RBCCW Heat Exchanger temperature control valve is in either "Summer Valve, 2-SW-8.1 or "Winter Valve, 2-SW-246".	B"
GRADE Standards: Examinee directs the PEO to ensure the "B" RBCCW temperature control valve is in the "Winter" mode.	
Cue: Booth Operator – Ensure SWR09 is set to Winter. Report that the temperature control valve is in the Winter Mode.	
Comments:	
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	

.....

_--- ---

.....

JPM ID NUMBER: <u>JPM-S7</u> 1	ITLE: Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger
STEP 19 Performance Steps	s: Log into TS Action Statement 3.7.4.1
GRADE Standards: Ex 3.	caminee informs the US of the need to enter TSAS 7.4.1.
Cue: Acknowledg	e the need to enter TSAS 3.7.4.1.
Comments:	
STEP 20 X Performance Steps	s: Open "B" RBCCW Heat Exchanger SW Outlet, 2-SW- 9B.
GRADEX_Standards: Ex	caminee directs the PEO to open "B" RBCCW Heat cchanger SW Outlet, 2-SW-9B.
Cue: <u>Booth Opera</u> PEO, report 9B is open.	tor – SWR24 set to 100%. When directed, as the that "B" RBCCW Heat Exchanger SW Outlet, 2-SW-
Comments:	
~~~~~~~~~	~~~~~~
STEP 21 X Performance Steps	Slowly lower "B" RBCCW Heat Exchanger temperature control knob to setting specified by the Control Room.
GRADE <u>X</u> Standards: Ex	aminee directs the PEO to slowly lower the "B" BCCW Heat Exchanger TCV to 75°F.
Cue: Booth Instru examinee that	<u>ctor – Set CCR03 to 75.</u> As the PEO, inform the at the temperature controller has been set to 75°F.
Comments:	
~~~~~~~~~	~~~~~~

_

JPM ID NUMBER: <u>JPM-S7</u> TITLE: Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger
STEP 22 Performance Steps: Refer to OP 2330A, Reactor Building Closed Cooling Water System," and shift RBCCW loads from "A" RBCCW Heat Exchanger to "B" RBCCW Heat Exchanger.
GRADE Standards: Examinee obtains OP 2330A, Reactor Building Closed Cooling Water System," and refers to Section 4.16
Cue:
Comments:
 STEP 23 Performance Steps: If "A" RBCCW Pump is operating, perform the following: Verify HDR BHX-B OUT, RB-4.1D is closed. Open PP DIS HDR A/B X-TIE, RB-251A.
GRADE Standards: • Examinee states that "A" RBCCW Pump is NOT in operation; therefore, this step is NOT applicable.
Cue:
Comments: This step is not applicable. "A" RBCCW Pump is NOT in operation.
STEP 24 X Performance Steps: Open HDR A HX-B OUT, RB-4.1C
GRADE <u>X</u> Standards: Examinee opens HDR A HX-B OUT, RB-4.1C, and observes the associated red light is lit.
Cue:
Comments:

JPM ID NUM	BER: <u>JPM-S7</u> TITLE: Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger
STEP 25	Performance Steps: Monitor header "A" flow on FI-6035 to ensure it remains stable.
GRADE	Standards: Examinee monitors flow on FI-6035 and observes stable flow at approximately 6300 gpm.
	Cue:
Comments:	
	~~~~~~
STEP 26	X Performance Steps: Close HDR A HX-A OUT, RB-4.1A.
GRADE	<u>X</u> Standards: Examinee closes HDR A HX-A OUT, RB-4.1A and observes the associated green light is lit.
Comments:	When RB-4.1A is closed, the malfunction to foul the "B" RBCCW Heat Exchanger will be inserted.
STEP <b>27</b>	Performance Steps: If required, Refer to OP 2326A, Service Water System, and isolate service water flow to "A" RBCCW Heat Exchanger.
GRADE	<b> Standards:</b> Examinee determines that the "A" RBCCW Heat Exchanger should NOT be isolated at this time.
	Cue: If the examinee asks the US whether to isolate the "A" RBCCW Heat Exchanger at this time, inform him/her that the heat exchanger will be isolated later by the work control group.
Comments:	
	~~~~~~

JPM ID NUM	BER: <u>JPM-S7</u>	TITLE: Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger
STEP 28	<u>X</u> Performance S	teps: When rising temperature on "A" header RBCCW or lowering Service Water flow through "B" RBCCW Heat Exchanger is observed, inform the US.
GRADE	<u>X</u> Standards:	 Examinee observes rising "A" RBCCW header temperature and/or lowering Service Water flow through the "B" RBCCW Heat Exchanger and informs the US. Examinee will recommend swapping back to the "A" RBCCW Heat Exchanger.
	Cue: If ask Heat When heade RBCC alread When to the proce	ed, as the PEO, report 60 psid across the "A" RBCCW Exchanger. A examinee reports a rising temperature in "A" RBCCW er or lowering Service Water flow through the "B" CW Heat Exchanger, ask for a recommendation, if NOT dy provided. A examinee provides the recommendation to swap back a "A" RBCCW Heat Exchanger, direct the examinee to red.
Comments:	The examinee may f annunciator alarms.	NOT notice the malfunction until the RBCCW HX TEMP HI This does NOT constitute a failure.
STEP 29	<u>X</u> Performance S	teps: Open HDR A HX-A OUT, RB-4.1A.
GRADE	X Standards:	Examinee opens HDR A HX-A OUT, RB-4.1A, and observes the associated red light is lit.
Comments:	Cue:	
STEP 30	X Performance SI	teps: Open HDR A HX-A OUT, RB-4.1A.
GRADE	<u>X</u> Standards:	Examinee opens HDR A HX-A OUT, RB-4.1A, and observes the associated red light is lit.
	Cue:	$(2\pi)^{-1} = \frac{1}{2} \left[\frac{1}{2} $
Comments:	~~~~~~~~	~~~~~~

15

.

JPM ID NUMBER: JPM-S7	TITLE: Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger
STEP 31 X Performance S	steps: Open HDR A HX-A OUT, RB-4.1A.
GRADE <u>X</u> Standards:	Examinee opens HDR A HX-A OUT, RB-4.1A, and observes the associated red light is lit.
Cue:	
Comments:	
~~~~~~~~	~~~~~~
STEP 32 X Performance S	teps: Open HDR A HX-A OUT, RB-4.1A.
GRADE <u>X</u> Standards:	Examinee opens HDR A HX-A OUT, RB-4.1A, and observes the associated red light is lit.
Cue:	
Comments:	
~~~~~~~	~~~~~~
STEP 33 X Performance St	teps: Open HDR A HX-A OUT, RB-4.1A.
GRADE <u>X</u> Standards:	Examinee opens HDR A HX-A OUT, RB-4.1A, and observes the associated red light is lit.
Cue:	
Comments:	
~~~~~~~~	~~~~~~
STEP 34 Performance St	teps: Monitor header "A" flow on FI-6035 to ensure it remains stable.
GRADE Standards:	Examinee monitors flow on FI-6035 and observes stable flow at approximately 6300 gpm.
	en. 1997 - Andrea Standard, and an anna an a
Comments:	
~~~~~~~~~	~~~~~

JPM ID NUN	MBER: <u>JF</u>	<u>PM-S7</u>	TITLE:	Placing "B" RBCCW Pump and Heat Exchanger in Service and Removing "A" RBCCW Pump and Heat Exchanger
STEP 35	X Per	formance Ste	ps: Clos	e HDR A HX-B OUT, RB-4.1C
GRADE	<u>X</u> Sta	ndards:	Examinee observes	e closes HDR A HX-B OUT, RB-4.1C, and the associated red light is lit.
	Cue:			
Comments:				
	~	~~~~~~~~	~~~~~~	~~~~~~
Comments:	After this	step is com	pleted, tl	ne JPM is considered complete.

STOP TIME:

VERIFICATION OF JPM COMPLETION

Job Performance Measure No.	JPM-S7	Re	v. <u>0</u>	
Date Performed:				
Operator:				
Evaluator(s):				
For examinee to achieve a satisfactory Time Critical, it <u>MUST</u> be completed w	y grade, <u>ALL</u> cr vithin the specif	itical steps must be co led time to achieve a s	mpleted correctly atisfactory grade.	. If task is
Time Critical Task? Yes	No X			
Validated Time (minutes):	30			
Actual Time to Complete (minutes	5):			
Result of JPM: (Denote	e by an <u>S</u> for s	atisfactory or a <u>U</u> fo	r unsatisfactory))
Areas for Improvement:				

EXAMINEE HANDOUT

JPM ID Number: JPM-S7

Initiating Cues:

- You are the SPO.
- Preventive Maintenance is scheduled on the "A" RBCCW Pump and Heat Exchanger.
- The US directs you to place the "B" RBCCW pump and "B" RBCCW HX in service and to remove the "A" RBCCW pump and "A" RBCCW HX from service per OP 2330A, sections 4.2 (Pump first) and OP 2326A section 4.9.
- I will act as the US/PEO as needed

Initial Conditions:

- "A" & "C" RBCCW Pumps and Heat Exchangers are in service
- Bus 24E is aligned to Bus 24C.
- "B RBCCW Pump breaker (A504) racked up.
- The SIAS/LNP Actuation Signal HS 6119D (A504) is in the BLOCK position.
- The "B" RBCCW HX is presently being used for minimum flow for "A" Service Water header.
- All other plant conditions are normal.

JOB PERFORMANCE MEASURE APPROVAL SHEET

1. JPM Title: Change the Alarm Setpoint of the SJAE RM 5099

ID Number:

JPM-S8

Revision: 0 Privi de all handouts at the start of the JPM

01/24/05

Date

III. Reviewed:

Initiated:

11.

Duffy Ashey

Technical Reviewer

Daniel A. Pantalone Developer

1/26/05

Date

IV. Approved:

User Department Supervisor

Date

Nuclear Train g Supervisor

Date

SUMMARY OF CHANGES

A/I & Date	DESCRIPTION	REV/CHANGE
01/19/2005 (DAP)	Developed new JPM.	0

_

JOB PERFORMANCE MEASURE WORKSHEET

Facility: MP-2	Examinee:
JPM Number:	JPM-S8 Rev0
Task Title: Operate t	he SJAE RM. (RM-5099)
System: <u>Radmonitor</u>	
Time Critical Task: Yes	No <u>X</u>
Validated Time (minutes):	20
Task No.(s): NUTIMS #	073-01-050
Applicable To: SRC	X RO X PEO
K/A No.: 071 A4.:	25K/A Rating:3.2/3.2
Method of Testing:	
Simulated Performance:	Actual Performance: X
Location:	
Classroom:	Simulator: X In-Plant:
Task Standards:	The examinee will adjust the setpoint of the Steam Jet Air Ejector Radmonitor as specified on the attached SP2833-007.
Required Materials (procedures, equipment):	 SP2833-007 "SJAE Radmonitor MR 5099 & PPC Alarm Setpoint Change Request. OP2383C Rev.012-02 "Radiation Monitor Alarm Setpoint Control.
General References:	

**** READ TO THE EXAMINEE ****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

JOB PERFORMANCE MEASURE WORKSHEET

JPM Number:	JPM-	S8	Rev.	0
Initiating Cues:	The U Radm Monit	S has assigned you to change the onitor (RM5099) in accordance v or Alarm Setpoint Control", secti	setpoint ovith OP 22 on 4.1.	of the SJAE 383C, "Radiation
Initial Conditions:	The la results reques - Ch Ch - Th an set - Th	test RCS samples have indicated b. Due to this rise in fission producted a change to the SJAE RM (R memistry has provided an approve hange Request, SP-2833-007. The Radiation Monitor System Eng d verified that the new setpoint de point. The S/G Blowdown Radmonitor (F	a rise in I uct gasses M 5099) d "SJAE ineer has bes not ex M-4262)	RCS gaseous isotopic , chemistry has setpoint. Radmonitor Setpoint referenced EN-21235 acceed the maximum is in service.
<u>Simulator Requirements</u> :	-	Any IC in Mode 1 or 2 with the s in service. Ensure the S/G Blowdown Rad Insert Remote Function, RMR3 the alarm setpoint of RM-5099	Steam Je monitor is 37A (RI50 from RC-	t Air Ejector System in service. 99)to allow changing 14.

**** NOTES TO EXAMINER ****

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM (in-plant only).

_

.....

JPM ID NUM	BER: <u>JPM-S8</u>	TITLE:	Change the Setpoint of the SJAE RM 5099	
START TIME				
STEP 1	<u>X</u> Performance S	Steps: OBT, - R - R R	AIN keys for the following (Operations key locke RI-5099 "NORM/SUPV." switch on RC-14D. RADMONITOR BYPASS, HS 5099E" switch on RC-14A.	er):
GRADE	X_ Standards:	The ex by C-2	xaminee retrieves the two keys from the key loc 21 and takes them around to RC-14.	:ker
	Cue:	1. 1. 1. 1. 1.		
Comments:				
	~~~~~~~	~~~~~~~	~~~~~	
STEP 2	<u>X</u> Performance S	Steps: As ap 5099	ppropriate, PLACE "RADMONITOR BYPASS, H E" switch to "RM 5099 OUT" or "BOTH OUT."	łS
GRADE	X_ Standards:	The exan HS5099E	ninee inserts the key into HS5099E, and places E switch on RC-14A_to "RM 5099 OUT" position	; 7.
	Cue:			
Comments:	~~~~~~~		~~~~~	
STEP 3	Performance S	Steps: IF "R. "BOT DETE	ADMONITOR BYPASS, HS 5099E" switch is in "H OUT," Refer To REMODCM IV.C.1 and ERMINE applicability.	I
GRADE	Standards:	HS 50991 The REM	E is not in "BOTH OUT" per the previous step. 10DCM IV.C.1 does not have to be referenced.	
	Cue:			
Comments:	This step is not appl	licable.		
	~~~~~~~	.~~~~~~	~~~~~	
STEP 4	<u>X</u> Performance S	Steps: PLAC	CE RI-5099 "NORM/SUPV." switch to "SUPV."	
GRADE	<u>X</u> Standards:	The exan switch, se MODE lig	ninee inserts the key into the "NORM/SUPV." elects "SUPV", and observes the red SUPV ght is lit.	
	Cue:	n an	$\frac{W_{\rm eff}}{W_{\rm eff}} = \frac{1}{2} \left(\frac{1}{2} - \frac{1}{2} \right)^{-1} \left(\frac{1}{2$	

Comments:

JPM ID NUN	IBER: <u>JPM-S</u>	<u>58</u> TITLE:	Change the Setpoint of the SJAE RM 5099	
	~~~~	~~~~~~~~~~~~		
STEP 5	<u>X</u> Perform	nance Steps: Usin 5099 ENT a. P b. P c. P d. E e. P f. Pl	g SP 2833-007, "SJAE Radiation Monitor RM & PPC Alarm Setpoint Change Request," ER new alarm setpoint. RESS "CH 1." RESS "0," "0," "9." RESS "ITEM." Inter new value using scientific notation. RESS "ENTER" RESS "ENTER"	
GRADE	<u>X</u> Standa <u>X</u> X_ X	rds: At RC-14 the RM-5 - PRE5 - PRE5	AD, the examinee performs the following steps on 5099 insert. SS "CH 1." SS 099 and observes 009 on the display.	
	<u>_X</u>	lit wh relea - Press	en pressed and light goes out when button is sed. s 412+02 and observes 4.12 E2 on the display.	
	X	- PRES - PRES readi	SS "ENTER" and observe 4.12 E ⁺ 2 SS "CH1 and observe present radiation monitor ng of 9.80 E ⁺ 1.	
Cue: - Provide the examinee with SP 2833-07, "SJAE Radiation Monitor RM 5099 & PPC Alarm Setpoint Change Request."				
Comments:	If an error is a CLEAR butto	made while enterin n may be used to	ng information into the RM-5099 Insert, the start over.	
STEP 6	<u>X</u> Perform	ance Steps: PRE	SS C/S" button and VERIFY button is lit.	
GRADE	Standar <u>X</u> ——	rds: The exam - pres - verif.	ninee: ses the C/S button ies the button lights.	
Comments:	~~~~	~~~~~~~~~~~	~~~~~	

JPM ID NUMBER: JPM-S8	TITLE: Change the Setpoint of the SJAE RM 5099
STEP 7 <u>X</u> Performance Step	<ul> <li>s: WHEN 1 minute has elapsed, VERIFY the following:</li> <li>C/S" light is not lit</li> <li>LED channel activity resumes</li> <li>CH 1" light is lit</li> <li>IF "CH 1" light is not lit and "ERROR" light is lit, NOTIFY I&amp;C Department.</li> </ul>
GRADE X Standards: -	Examinee waits one minute and observes the C/S light go out. Examinee observes normal operation of the RM-5099 Insert. Examinee verifies the CH 1 light is lit.
Cue: Magnetic	
Comments:	
~~~~~~~~~	~~~~~
STEP 8 <u>X</u> Performance Steps	 s: IF desired to display alarm setpoint, PERFORM the following: a. PRESS CH 1." b. ENTER item number 0," 0," 9." c. PRESS ITEM." d. PRESS CH. 1."
GRADE X At X - X - X - X - X - X - X - X -	 RC-14D, the examinee performs the following steps on e RM-5099 insert. Press CH 1 and observes no change. Press 009 and observe 009 on the display. Press the ITEM button and observe the button is lit when pressed and light goes out when button is released. Observe display change to current alarm setpoint of 4.12 E+2. Press CH1 and observe current radiation monitor reading of 9.80 E+1.
Cue: It is desired.	
Comments:	

JPM ID NUME	BER: <u>JPM-S8</u>	TITLE: Change the Setpoint of the SJAE RM 5099
STEP 9	<u>X</u> Performance St	eps: PLACE RI-5099 NORM/SUPV." switch to NORM."
GRADE	<u>X</u> Standards:	The examinee places RI-5099 Normal/Supv. Key switch in the NORMAL position and observes the red SUPV MODE light go out.
	Cue:	
Comments:		
	~~~~~~~	~~~~~
STEP 10	<u>X</u> Performance St	eps: As appropriate, PLACE RADMONITOR BYPASS, HS 5099E" switch to RM 4262 OUT" or NORMAL."
GRADE	<u>X</u> Standards:	The examinee locates HS 5099E key switch, and places it in the NORMAL position.
	Cue:	
Comments:		
	~~~~~~~	
STEP 11	Performance St	eps: RETURN keys (Operations key locker).
GRADE	Standards:	The examinee returns the two keys to the Ops Key Locker.
	Cue:	
	~~~~~~~	

JPM ID NUMBER:	<u>JPM-S8</u>	TITLE:	Change the Setpoint of the SJAE RM 5099
STEP 12 <u>X</u>	Performance	Steps: Usin 5099 ENT a b c. d. e. f.	g SP 2833-007, "SJAE Radiation Monitor RM & PPC Alarm Setpoint Change Request," ER new values into PPC as follows: OPEN PPC screen N16 - CHEM. ENTER value for steam jet air ejector instrument background. ENTER value for SJAE DP. ENTER value for RCS total gas activity. ENTER value for RM 5099 response factor. EXIT application.
GRADEX_	Standards:	Using SI PPC Ala performs	P 2833-007, "SJAE Radiation Monitor RM 5099 & rm Setpoint Change Request," the examinee s the following
<u> </u>		a. C F	Dens PPC screen N16-CHEM on any available PPC Console.
<u> </u>		b. E	Enters the instrument background value of 124
		c. E d. E u	Inters SJAE DP value of 0.35 Inches of Water. Inters the Total Gaseous Activity value of 1.113 Ci/CC.
<u> </u>		e. E 7	nters the RM-5099 Response Factor value of
<u>X</u>		f. E a	ixits the application by pressing the ENTER key nd closing the present PPC page.
C			

Comments: When the appropriate data has been entered into the PPC, the JPM is complete. Exiting the application is NOT a requirement for completion of this JPM.

Comments: After this step is completed, the JPM is considered complete.

STOP TIME:

# VERIFICATION OF JPM COMPLETION

Job Performance Measure No.	JPM-S8	Rev.	<u>0</u>	
Date Performed:				
Operator:				
Evaluator(s):				
For examinee to achieve a satisfactory	/ grade, <u>ALL</u> critical steps must	t be comp	leted correctly.	If task is
Time Critical, it MUSI be completed w	vithin the specified time to achie	eve a satis	stactory grade.	
Time Critical Task? Yes	No			
Validated Time (minutes):				
Actual Time to Complete (minutes	s):			
Result of JPM: (Denote	e by an <u>S</u> for satisfactory or a	a <u>U</u> for u	nsatisfactory)	
Areas for Improvement:				

# EXAMINEE HANDOUT

.

JPM Number:	JPM-S8	Rev.	0	
Initiating Cues:	The US has assigned ye Radmonitor (RM5099) Monitor Alarm Setpoir	ou to change the setpoint ) in accordance with OP 2 nt Control", section 4.1.	of the SJAE 383C, "Radiation	
Initial Conditions:	<ul> <li>The latest RCS samples have indicated a rise in RCS gaseous isotop results. Due to this rise in fission product gasses, chemistry has requested a change to the SJAE RM (RM 5099) setpoint.</li> <li>Chemistry has provided an approved "SJAE Radmonitor Setpoin Change Request, SP-2833-007.</li> <li>The Radiation Monitor System Engineer has referenced EN-2122 and verified that the new setpoint does not exceed the maximum setpoint.</li> <li>The S/G Blowdown Radmonitor (RM-4262) is in service.</li> </ul>			

11

· • • • •

ff 3/14/05

PLANT JP.VIS.

-
# JOB PERFORMANCE MEASURE APPROVAL SHEET

I. JPM Title: Removing Section 201B-2, of Battery Charger 201B, From Service

ID Number:

JPM-P1

Revision: 0

II. Initiated:

Narie Daniel A. Pantalone Developer

03-03-05 Date

III. Reviewed:

R. J. Ashey Technical Reviewer

1/05 Date

IV. Approved:

NA

User Department Supervisor

Nuclear Training Supervisor

Date

Date

# SUMMARY OF CHANGES

A/I & Date	DESCRIPTION	REV/CHANGE
10/15/2004	Developed new JPM.	0
(DAP)	Changed to use Charger 2018-1 instead of 2018-1 2018-1 has too many obstructions in the	l
(DAP)	plant. 201B-1 has no physical obstructions.	Ŭ

____

-----

JOB	PERFC	RMANCE	MEASURE	WORKSHEET
and the second se				

~~~~

| Facility: MP-2 | Examinee: |
|---|--|
| JPM Number: | IPM- P-1 Rev. 0 |
| Task Title: Removing | Section 201B-2, of Battery Charger 201B, From Service |
| System: 125 Volt Vital | DC |
| Time Critical Task: Yes | NoX |
| Validated Time (minutes): | 12 |
| Task No.(s): <u>NUTIMS</u> # | 063-01-093 (MP2 063-11-01-04) |
| Applicable To: SRC | X RO X PEO X |
| K/A No.: 063 K1.0 | 03 K/A Rating: 2.9/3.5 |
| Method of Testing: | |
| Simulated Performance: | X Actual Performance: |
| Location: | |
| Classroom: | Simulator: In-Plant:X |
| Task Standards: | At the completion of this JPM, battery charger section 201B-2 will be removed from service in accordance with 2345C section 4.14 |
| Required Materials
(procedures,equipment): | OP-2345C section 4.14 |
| General References: | OP-2345C |

\*\*\*\* READ TO THE EXAMINEE \*\*\*\*

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

| JPM Number: | JPM- P-1 | Rev | 0 |
|-------------------------|---|----------------------------|-----------------------------|
| Initiating Cues: | The US has directed you to remove bat
from service, in preparation for prevent | tery charge
ive mainten | er section 201B-2
lance. |
| Initial Conditions: | Battery Charger 201B is operating with | both sectio | ons in service. |
| Simulator Requirements: | N/A | | |

\*\*\*\* NOTES TO EXAMINER \*\*\*\*

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM (in-plant only).

| JPM ID NUMBER: <u>JPM- P-1</u> | TITLE: | Removing Section 201B-2, of Battery
Charger 201B, From Service |
|--------------------------------|--|---|
| START TIME: | | |
| STEP 1 Performance | e Steps: | ENSURE total charger "DC OUTPUT" current less than 400 amps. |
| GRADE Standards: | Examı
Termi | nee observes "DC OUTPUT" ammeter on the nation Cabinet. |
| Cue: Ampe | rage is < 40(| amps. |
| Comments: | | |
| ~~~~~~~ | ~~~~~~ | ~~~~~~ |
| STEP 2 Performance | e Steps: PLA | CE "MODE SEL." Switch in "DIS. B" |
| GRADE Standards: | - E.
"7
-
- | xaminee indicates the following on the
Fermination Cabinet":
the "MODE SEL." switch is being turned to the
"DIS B." position.
the "BATTERY CHARGER 201B-2 ALARMS
DISABLED" red light lights
the "CURRENT SHARING DISABLED" red
light lights. |
| Cue: -
- | "MODE SEL
"BATTERY (
light is lit.
"CURRENT (| " Switch is in the "DIS B." position
CHARGER 201B-2 ALARMS DISABLED" red
SHARING DISABLED" red light is lit |

Comments:

\_\_\_\_

| JPM ID NUME | 3ER: <u>JPM-P-1</u> | TITLE: | Removing Section 201B-2, of Battery
Charger 201B, From Service |
|-------------|------------------------|------------------------------------|---|
| | ~~~~~~~ | | ~~~~~~ |
| STEP 3 | <u>X</u> Performance S | iteps: PLA
CHA | CE breaker "201B AC INPUT TO BATTERY
ARGER 201B-2" in OFF. |
| GRADE | <u>X</u> Standards: | Examine
Cabinet a | e locates the correct breaker on the Termination
and simulates pulling down on the breaker. |
| | Cue: Breaker i | s in "OFF" | |
| Comments: | | | |
| | ~~~~~~ | ~~~~~~ | ~~~~~ |
| STEP 4 | <u>X</u> Performance S | teps: PLA
BUS | CE breaker "201B-2 DC OUTPUT TO BATTERY
BREAKER D0202" in OFF. |
| GRADE | <u>X</u> Standards: | Examinee
Cabinet a | e locates the correct breaker on the Termination
and simulates pulling down on the breaker. |
| | Cue: Breaker is | s in "OFF" | |
| Comments: | | | |
| | ~~~~~~~~ | ~~~~~~ | ~~~~~~~~~~~ |
| STEP 5 | X Performance S | teps: PLA
INPU | CE breaker "BATTERY CHARGER 201B-2 AC
JT" in OFF. |
| GRADE | <u>X</u> Standards: | Examinee
Charger 2
the break | e locates the correct breaker on the "Battery
201B-2" cabinet and simulates pulling down on
er. |
| | Cue: Breaker is | s in "OFF" | |

Comments:

-

| JPM ID NUMBER: JPM- P-1 TITLE: Removing Section 201B-2, of Battery
Charger 201B, From Service |
|---|
| ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~ |
| STEP 6 <u>X</u> Performance Steps: PLACE breaker "BATTERY CHARGER 201B-2 DC OUTPUT" in OFF. |
| GRADE <u>X</u> Standards: Examinee locates the correct breaker on the "Battery Charger 201B-2" cabinet and indicates pulling down on the breaker. |
| Cue: Breaker is in the OFF Position |
| Comments: |
| ~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~ |
| STEP 7 Performance Steps: ENSURE total charger "DC OUTPUT" current less than 400 amps. |
| GRADE Standards: Examinee locates the "D.C. OUTPUT – DC AMPERES" meter on either the 201B-2 panel or the Termination Cabinet. |
| Cue: DC Amps is < 120 |
| Comments: After this step is completed, the JPM is considered complete. |

STOP TIME:

.

VERIFICATION OF JPM COMPLETION

......

| Job Performance Measure No. | JPM-P-1 | Rev. | <u>0</u> |
|--|---|---------------------|-------------------------------------|
| Date Performed: | | | |
| Operator: | | | |
| Evaluator(s): | | | |
| For examinee to achieve a satisfactory
Time Critical, it <u>MUST</u> be completed w | grade, <u>ALL</u> critical steps must
ithin the specified time to achiev | be completed | correctly. If task is
bry grade. |
| | | | |
| Time Critical Task? Yes | No <u>X</u> | | |
| Validated Time (minutes): | 12 | | |
| Actual Time to Complete (minutes |): | | |
| Result of JPM: (Denote | by an <u>S</u> for satisfactory or a | <u>U</u> for unsati | sfactory) |

Areas for Improvement:

EXAMINEE HANDOUT

JPM ID Number: JPM-P1

| Initiating Cues: | The US has directed you to remove battery charger section 201B-2 from service, in preparation for preventive maintenance. |
|------------------|---|
| | |

Initial Conditions: Battery Charger 201B is operating with both sections in service.

SPH21

JOB PERFORMANCE MEASURE APPROVAL SHEET

I. Loss of SDC / Vent the 'A' LPSI Pp. JPM Title:

ID Number:

JPM-P2

Revision: 0

Initiated: 11.

Pantatone Daniel A Developer

01/25/05 Date

III. Reviewed:

Duffy Ashey

Technical Reviewer

1/26/05

Date

IV. Approved:

NA

User Department Supervisor

Nuclear Training Supervisor

Date

127/05

Date

SUMMARY OF CHANGES

| A/I & Date | DESCRIPTION | REV/CHANGE |
|---------------------|-------------------|------------|
| 01/18/2005
(DAP) | Developed new JPM | 0 |
| | | |
| | | |

| Facility: MP-2 | Examinee: |
|---|---|
| JPM Number: | JPM- P2 Rev0 |
| Task Title: Loss of S | DC / Vent the 'A' LPSI Pp. |
| System: ECCS | |
| Time Critical Task: Yes | NoX |
| Validated Time (minutes): | 13 |
| Task No.(s): <u>NUTIMS</u> # | 000-14-021 (000-016-04-04) |
| Applicable To: SRC | X RO X PEO X |
| K/A No.:005 A2.0 | 03K/A Rating:2.9/3.1 |
| Method of Testing: | |
| Simulated Performance: | X Actual Performance: |
| Location: | |
| Classroom: | Simulator: In-Plant: X |
| Task Standards: | At the completion of this JPM, the examinee will have simulated venting the "A" LPSI Pp. per AOP 2572, "Loss of SDC". |
| <u>Required Materials</u>
(procedures, equipment): | AOP 2572 "Loss of SDC", step 4.15 |
| General References: | AOP 2572 |

\*\*\*\* READ TO THE EXAMINEE \*\*\*\*

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

| JPM Number: | JPM-P2 | Rev | 0 |
|---------------------|--|--|--|
| Initiating Cues: | The US has directed you to vent th 2572 "Loss of Shutdown Cooling", s | e 'A' LPS
step 4.15. | I Pump per AOP |
| Initial Conditions: | The plant is at the center line of the seal. The 'A' LPSI Pp started to sho The 'A' LPSI Pp is secured. RCS level has been raised at evacuated. The pump is placed in a safe vent. RCS temperature is approximation. | hot leg to
bw indicat
nd the SD
condition
nately 85° | o replace an RCP
ions of air binding.
OC suction piping
and is ready to
F. |

Simulator Requirements: N/A

\*\*\*\* NOTES TO EXAMINER \*\*\*\*

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM (in-plant only).

·

.....

| JPM ID NUN | IBER: <u>JPM-P2</u> | TITLE: Loss of SDC / Vent the 'A' LPSI Pp. |
|------------|---|---|
| START TIME | E: | |
| STEP 1 | X Performance Step | s: CONNECT vent hose to SI-21A, ("A" LPSI
Pp. vent). |
| GRADE | Standards:
X
X
X
X
X
X
Cue: 3. see com
5. pipe cap
6. vent fitti
7. see com
8. Tygon h
If the fitting
examinee sig
fitting, tell th | Examinee does the following: Locates SI-21A on the "A" LPSI Pp. casing Verifies SI-21A is closed. Locates the "vent pipe fitting" in the vent rig box, located at the base of the LPSI Pp. Locates the "pipe wrench" in the vent rig box, located at the base of the LPSI Pp. Simulates removing the "pipe cap" at the end of the extension pipe of SI-21A. Simulates installing the "female Camlock vent pipe fitting" on the extension pipe of SI-21A Simulate connecting the Tygon Hose to the "vent pipe fitting". Simulate running and securing the Tygon Hose to a floor drain. |
| Comments: | There may be several ve
Visually determine that t
fitting on the end of the | ent fittings in the box at the base of the LPSI Pump.
the fitting selected by the examinee will couple up to the
Tygon tube. |
| | The examinee should th | en find the correct fitting. |

~~~~~~~~~~~~~~~~~~~~~~~

-----

JPM ID NUMBER: JPM-P2 TITLE: Loss of SDC / Vent the 'A' LPSI Pp.
STEP 2 X Performance Steps: Slowly open SI-21A ("A" LPSI Pp vent)
GRADE <u>X</u> Standards: Examinee simulates cracking open SI-21A.
Cue: Inform the examinee that large air bubbles are visible in the water.
<ul> <li>Comments: - The examinee should indicate that s/he would continue to vent until air free water is observed.</li> <li>- The note in the procedure defines air-free as bubbles the size of bubbles in carbonated water or soda.</li> </ul>
STEP <b>3</b> <u>X</u> Performance Steps: Close SI-21A when air-free water is observed.
GRADE <u>X</u> Standards: The examinee simulates closing SI-21A when soda water like bubbles are observed.
Cue: Soda water like bubbles are observed.
Comments: Ensure the examinee understands the information given in the note. This may be done when the examinee asks if the bubbles are like those in soda water. If the examinee gives no indication, ask the examinee to describe the conditions that would indicate the pump is properly vented.
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
Comments: After this step is completed, the JPM is considered complete.
STOP TIME:

VERIFICATION OF JPM COMPLETION

Job Performance Measure No.	<u>JPM- P2</u>	Rev.	<u>0</u>
Date Performed:			
Operator:			
Evaluator(s):			
For examinee to achieve a satisfactor Time Critical, it <u>MUST</u> be completed v	y grade, <u>ALL</u> critical steps must vithin the specified time to achiev	be completed /e a satisfacto	correctly. If task is bry grade.
Time Critical Task? Yes	No <u>X</u>		
Validated Time (minutes):	13		
Actual Time to Complete (minute	s):		
Result of JPM: (Denote	e by an <u>S</u> for satisfactory or a	<u>U</u> for unsati	sfactory)
Areas for Improvement:			

7

EXAMINEE HANDOUT

JPM Number:	JPM-P2	Rev.	0
Initiating Cues:	The US has directed y 2572 "Loss of Shutdow	vou to vent the 'A' LF vn Cooling", step 4.1	PSI Pump per AOP 5.
Initial Conditions:	The plant is at the cent seal. The 'A' LPSI Pp - The 'A' LPSI Pp - RCS level has b evacuated. - The pump is pla vent. - RCS temperatur	ter line of the hot leg started to show indic is secured. been raised and the s iced in a safe conditi re is approximately 8	to replace an RCP cations of air binding. SDC suction piping on and is ready to 5°F.

JOB PERFORMANCE MEASURE APPROVAL SHEET

I. JPM Title: Cross-Tie Station Air With Unit 3 to Supply Unit 2 Instrument Air

ID Number:

JPM-P3

Revision: 0

II. Initiated:

lio R. J. Ashey Developer

10/25/04 Date

III. Reviewed:

Technical Reviewer

IV. Approved:

User Department Supervisor

Date

Nuclear raining Supervisor

Date

SUMMARY OF CHANGES

A/I & Date	DESCRIPTION	REV/CHANGE
10/25/2004	Developed new JPM.	0

+

.

Facility: MP-2	Examinee:
JPM Number:	JPM-P3 Rev. 0
Task Title: Cross-Tie	Station Air With Unit 3 to Supply Unit 2 Instrument Air
System: Instrument Air	
Time Critical Task: Yes	NoX
Validated Time (minutes):	10
Task No.(s): <u>NUTIMS #</u>	079-01-030
Applicable To: SRC	X RO X PEO X
K/A No.:079 A2.0	1 K/A Rating:2.9/3.2
Method of Testing:	
Simulated Performance:	X Actual Performance:
Location:	
Classroom:	Simulator: In-Plant:X
<u>Task Standards:</u>	The examinee has successfully performed the alignment to allow Unit 3 to supply Unit 2 with Station Air and to permit Station Air to supply Instrument Air.
Required Materials (procedures, equipment):	EOP 2525, Standard Post Trip Actions, Rev. 20, Contingency Action 19.1
General References:	EOP 2525, Standard Post Trip Actions, Rev. 20, Contingency Action 19.1

* * * * READ TO THE EXAMINEE * * * *

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

JPM Number:	JPM-P3	Rev	0
Initiating Cues:	The Unit Supervisor ha Unit 3 to allow Station / EOP 2525, Contingend	is directed you to cross-ti Air to supply Instrument A cy Action step 19.1.	e Station Air from Air in accordance with
Initial Conditions:	 Unit has tripped fro The RSST failed re Both Emergency Di Instrument Air head Unit 3 has informed supply Station Air to SA-10.1, Station Air 	m 100% power. sulting in a loss of off site iesels have energized the ler pressure is reading 85 I the Unit Supervisor that o Unit 2. r to Instrument Air Cross-	e power. Sir respective buses. 5 psig and lowering. they are able to -Tie, is open.

Simulator Requirements: N/A

**** NOTES TO EXAMINER ****

- 1. Critical steps for this JPM are indicated with an "X". For the examinee to achieve a satisfactory grade, <u>ALL</u> critical steps must be completed correctly.
- 2. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".
- 3. If necessary, question examinee for details of simulated actions / observations (i.e. "What are you looking at?" or "What are you observing?").
- 4. Under <u>NO</u> circumstances must the examinee be allowed to manipulate any devices during the performance of this JPM (in-plant only).

JPM ID NUMB	Ber: <u>JPM-P3</u> Title	Cross-Tie Station Air With Unit 3 to Supply Unit 2 Instrument Air
START TIME:		
STEP 1	Performance Steps:	Ensure SA-26, SA-11.1 Outlet Bypass, is open.
GRADE	Standards: Exal atter cloc.	minee checks SA-26, SA-11.1 Outlet Bypass, open mpting to rotate the valve handwheel in the counter kwise direction.
	Cue: SA-26 is open.	
Comments:	SA-26 is located on the 14'6' Instrument Air Dryer.	elevation of the Turbine Building near the
STEP 2	<u>X</u> Performance Steps: Op	oen SA-12, SA-11.1 Inlet Bypass.
GRADE	<u>X</u> Standards: Examin the value	ee opens SA-12, SA-11.1 Inlet Bypass, by rotating we handwheel in the counter clockwise direction.
	Cue: SA-12 is open wh	en the examinee simulates opening the valve.
Comments:	SA-12 is located on the 14'6' Instrument Air Dryer.	elevation of the Turbine Building near the

JPM ID NUM	BER: <u>JPM-P3</u> 1	Cross-Tie Station Air With Unit 3 to Supply Unit 2 Instrument Air	
STEP 3	<u>X</u> Performance Step	s: Open SAS-379, Bypass Valve for SAS-EFV-20	
GRADE	X Standards: Ex 20 cle	xaminee opens SAS-379, Bypass Valve for SAS-EFV-), by rotating the valve handwheel in the counter ockwise direction.	
	Cue: SAS-379 is c valve.	open when the examinee simulates opening the	
Comments:	SAS-379 is located on the stairway by the "C" Instr	he 14'6" elevation of the Turbine Building, on the ument Air Compressor.	
	~~~~~~~	.~~~~~~~~~~~	
STEP 4	<u>X</u> Performance Steps	s: Open SAS-6, Station Air Cross-Tie to Unit 3.	
GRADE	<u>X</u> Standards: Ex by div	caminee opens SAS-6, Station Air Cross-Tie to Unit 3, rotating the valve handwheel in the counter clockwise rection.	
Cue: SAS-6 is open when the examinee simulates opening the valve.			
Comments:	SAS-6 is located in the (	CFP Building Truck Bay.	

___

____

-----

JPM ID NUM	IBER: <u>JPM-P3</u>	TITLE:	Cross-Tie Station Air With Unit 3 to Supply Unit 2 Instrument Air
STEP 5	<u>X</u> Performance	Steps: Req V90	uest Unit 3 Operations to slowly open 3-SAS- 0, Service air Cross-Tie to Unit 2.
GRADE	<u>X</u> Standards:	Examine Control F the Unit 3 a Unit 3 d	e will either simulate contacting the Unit 3 Room or have the Unit 2 Control Room contact 3 Control Room, to have 3-SAS-V900 opened by operator.
	Cue: Unit 3 ro V900.	eports that	an operator is on his way to open 3-SAS-
Comments:	The JPM is comple by a Unit 3 operato	te when the r.	examinee requests 3-SAS-V900 to be opened

STOP TIME:

 $\sim 10^{-1}$ 

#### VERIFICATION OF JPM COMPLETION

Job Performance Measure No.	JPM-P3	Rev.	<u>0</u>
Date Performed:	-		
Operator:			
Evaluator(s):			
For examinee to achieve a satisfactor Time Critical, it <b>MUST</b> be completed	y grade, <u>ALL</u> critical step within the specified time t	os must be completed o achieve a satisfact	d correctly. If task is ory grade.
Time Critical Task? Yes	No <u>X</u>		
Validated Time (minutes):	10		
Actual Time to Complete (minute	es):		
Result of JPM: (Denot	e by an <u>S</u> for satisfacto	ory or a <u>U</u> for unsat	tisfactory)

Areas for Improvement:

# JOB PERFORMANCE MEASURE APPROVAL SHEET

JPM Title: Local Manual Operation of the "A" Atmospheric Dump Valve

ID Number:

JPM-093

Revision: 9

II. Initiated:

R. J. Ashey Developer

1/18/05 Date

III. Reviewed:

Reviewer Teefinical

Date

IV. Approved:

-

NA

User Department Supervisor

ining Supervisor Nuclear Tra

Date

Date

Facility: MP-2	Examinee:			
JPM Number:	JPM-093	Rev. 9		
Task Title: _ <u>Local Ma</u>	anual Operation of the "A" Atmos	pheric Dump Valve		
System: Main Steam				
Time Critical Task: Yes	s No _X			
Validated Time (minutes)	: <u>15</u>			
Task No.(s): <u>NUTIMS#</u>	035-01-029			
Applicable To: SF	RO X RO X PEC	<u>    x    </u>		
K/A No. 041 A2	.03 K/A Rating 2.8/3.1			
Method of Testing: Simulated Performance: XActual Performance:				
Classroom:	Simulator:	In-Plant: X		
Task Standards:	Examinee has taken local manual placed in to 25% open per EOP 2 Operation.	control of the "A" ADV and 541, Appendix 36, ADV Local		
Required Materials (procedures, equipment):	EOP 2541, Appendix 36, ADV Loo	cal Operation		
General References:	EOP 2541, Appendix 36, ADV Loc	cal Operation		
	* * * * <u>READ TO THE EX</u>	AMINEE * * * *		

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgments, and log entries as if the evolution was actually being performed.

-	<u>Ini</u>	tiating Cues:	-	The US directs you to take local manual control of the "A" Atmospheric Dump Valve and open the valve to 25% in accordance with EOP 2541 Appendix 36.	
	Init	tial Conditions:	-	A loss of I.A. has occurred in the plant. The plant has tripped and the decision has been made to use the "A"	
				Atmospheric Dump Valve to remove decay heat.	
	<u>Sir</u>	mulator Requirement	<u>ts</u> :	N/A	
-				* * * * NOTES TO EXAMINER * * * *	
	1			Man indicated with an "V" For the overside to polyious a polyiofectory and	
	7.	ALL critical steps for the	is JP nust l	M are indicated with an "X". For the examinee to achieve a satisfactory grade, be completed correctly.	
	2.	. When examinee states what his/her simulated action/observation would be, read the appropriate "Cue".			
	2. It is a subscription of the details of simulated estimated and include the subscriptions				

- If necessary, question examinee for details of simulated actions / observations 3. (i.e. "What are you looking at?" or "What are you observing?").
- Under NO circumstances must the examinee be allowed to manipulate any devices during the 4. performance of this JPM.

JPM ID NUMBER: JPM	<u>-093</u> TITLE: <u>L</u>	ocal Manual Operation of the "A" Atmospheric Dump Valve
START TIME:		
STEP <u>1</u>	Performance Steps:	Check local ambient air temperatures less than 120°F.
GRADE	Standards: Exan 38'6" is les	ninee observes local thermometer (TI-8130C) in the East penetration room to determine ambient air temperature s than 120°F.
	TI- 8	130C is located just inside the inner door to the right.
	Cue: If as con Roc	sked, as Health Physics, state that radiological ditions are normal. om temperature is as indicated.
Comments:		
	~~~~~~~~~~	~~~~~~
STEP <u>2</u>	Performance Steps:	If local operation of the ADV is desired, refer to Attachment 36-A, Establishing Local ADV Control.
GRADE	Standards: Exan Conti	ninee obtains Attachment 36-A, Establishing Local ADV rol.
	Cue: If re Esta	quested, provide a copy of Attachment 36-A ablishing Local ADV Control.
Comments:		
	~~~~~~~~~~	

_

____

JPM I	d nume	BER	JPM-	<u>093</u> T	ITLE: <u>Loc</u>	al Manual Operation of the "A" Atmospheric Dump Valve
	STEP	3		Performance St	eps:	Establish communications with the Control Room.
	GRADE			Standards:	Examin extensio into ma H.X. an	ee states that he would obtain a headset and on, goes to the blowdown room (East 38'6";AB), plugs intenance jack on the stanchion next to the blowdown d gets in contact with the control room.
	C			Cue	Comm	unications are established.
I	Comme	nts:		~~~~~~	~~~~~	
:	STEP _	4		Performance St	eps: I	Ensure ADV Manual isolation valve, MS-3A is open.
(	GRADE			Standards:	Examin isolatior by statir counter	ee climbs to the ADV platform and observes ADV o valves, MS-3A,is fully open by stem indication and/or ng he/she would attempt to turn the handwheel in the clockwise direction.
1922 - P				Сце	MS-34	is full open
				oue		
(	Commer	nts:				
				~~~~~~~	~~~~~	~~~~~~~~~~~
S	STEP _	5	<u>X</u>	Performance St	eps: F	Remove the "Vent Valve" assembly from the nstrument rack located below the ADV.
(GRADE		<u> X </u>	Standards:	Examine quick dis	ee obtains the 'Vent Valve" assembly by operating the sconnect fitting.
					"Vent Va board ai	alve" assembly is located below the valve on a gauge and is labeled "Vent Valve".
				Cue		
C	Commer	nts:				

-

JPN		R: <u>JPM-(</u>	<u></u>	ITLE: Loo	ocal Manual Operation of the "A" Atmospheric Dump Val	ve
	STEP <u>6</u>		Performance St	eps:	Ensure the "Vent Valve" assembly is closed.	
	GRADE _		Standards:	Examii turning	inee verifies the vent valve is in the closed position by g the handwheel in the clockwise direction until it stops.	
			Cue			
	Comments	:				
			~~~~~~	~~~~~	~~~~~	
	STEP <u>7</u>	<u> </u>	Performance St	eps:	Close the instrument air isolation valve to the ADV.	
	GRADE _	<u>     X</u>	Standards:	Examir the Ctr close it directio	inee locates the I.A. isolation for 2-MS-190A (located on mt wall behind the ADV) and states that he/she would it position by turning the handwheel in the clockwise ion until it stops.	1
14.200 -			Cue	: - A to ti - I.	Ask examinee how s/he would reach the air supply to MS-190A. The examinee should use the ladder that is chained to the cat walk. .A. isolation to 2-MS-190A is closed.	
	Comments	Ċ	~~~~~~~	~~~~~	~~~~~~	
	step <u>8</u>	<u> </u>	Performance St	eps:	Remove the vent cap from the quick disconnect at the top of the ADV operator diaphragm.	
	GRADE	<u> </u>	Standards:	Examir quick o	inee states that he/she would remove the cap from the disconnect at the top of the valve operator diaphragm.	
			Cue	The v	vent cap is removed.	
	Comments	:				
			~~~~~~~	~~~~~	~~~~~	

-

ل.	IPM ID NUMBER: JPM-093 TITLE: Local Manual Operation of the "A" Atmospheric Dump Valv
	STEP <u>9</u> <u>X</u> Performance Steps: Insert the "Vent Valve" assembly into the quick disconnect.
	GRADE <u>X</u> Standards: Examinee inserts the "Vent Valve" assembly into the quick disconnect on top of the ADV operator diaphragm.
	Cue: The vent valve is inserted.
	Comments:
	STEP <u>10 X</u> Performance Steps: Open the vent valve assembly to ensure air has been vented off the ADV operator.
	GRADE <u>X</u> Standards: To vent off the air from the ADV operator, the examinee opens the vent valve on the Vent Valve assembly by turning the handwheel in the clockwise direction until it stops.
	Cue: The air from the operator has been vented off.
	Comments:
	STEP <u>11</u> Performance Steps: Ensure that the ADV is closed.
	GRADE Standards: Examinee observes ADV position indicator and determines that the ADV is closed.
	Cue: The ADV is closed.
	Comments:

JPM ID NUMBER: JPM-093 TITLE: Local Manual Operation of the "A" Atmospheric Dump Valve
STEP <u>12</u> X Performance Steps: Remove the handwheel restraining device.
GRADE <u>X</u> Standards: Examinee states that he would remove the restraining device
Cue: Restraining device is removed.
Comments:
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
STEP <u>13</u> <u>X</u> Performance Steps: Position the ADV as directed by the Control Room.
GRADE <u>X</u> Standards: Examinee states that he/she would rotate the handwheel in the <b>clockwise</b> direction to position the valve to 25% open by the local stem position indication.
Cue: The ADV is 25% open.
Comments:
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
Comments: When it has been simulated that manual control has been taken and the valve is 25% open, then this JPM is complete.
STOP TIME:

VERIFICATION OF JPM COMPLETION

Job Performance Measure No.	<u>JPM -093</u>	Rev.	<u>9</u>
Date Performed:			
Operator:			
Evaluator(s):			
For examinee to achieve	e a satisfactory grade, <u>ALL</u> critic IST be completed within the spec	al steps m	ust be completed correctly.
			to dome ve a satisfactory grade.
Time Critical Task? Yes	NoX		
Validated Time (minutes):	15		
Actual Time to Complete (minute	es):		
Result of JPM: (Denc	ote by an <u>S</u> for satisfactory or a <u>L</u>	<u>l</u> for unsat	isfactory)

Areas for Improvement:

EXAMINEE HANDOUT

JPM ID Number: 093

Initiating Cues:	-	The US directs you to take local manual control of the "A" Atmospheric Dump
		Valve and open the valve to 25% in accordance with EOP 2541 Appendix 36.

Initial Conditions: - A loss of I.A. has occurred in the plant.

- The plant has tripped and the decision has been made to use the "A" Atmospheric Dump Valve to remove decay heat.