

Category	INEEL	Licensee	Subcommittee
"Y"	SSFF	SSFF	SSFF
"W"	SSFF	SSFF	Likely not
"X"	SSFF	Not	Likely SSFF
"Z"	SSFF	Not	Likely not
"L"	Not	SSFF	Likely not
"M"	Not	SSFF	SSFF
"UR"	SSFF	Cannot determine	Cannot determine

Disposition	W	X	Z	L	M
Fire/Helb/seismic – not SSFF	23 – do not assume additional failures	0	50 – hot shorts, AppR, or helb - assume additional failures	11 – do not assume additional failures	-
Creacus –	1 – met GDC	2 – did not meet GDC	20 – GDC met	0	3 - did not meet GDC
OOS –	0	24 – other train unavailable	34 – other train available	1 – other train available	2 – other train unavailable
Design or operability	4 – function not lost	15 – function really lost	62 – function not lost	4 – function not lost	11 – function really lost
Other	0	0	3 retracted LER	5 – n/a	37 – not specified, just obviously SSFF
TOTAL	28	41	169	21	53