

| Category | INEEL | Licensee | Subcommittee |
|----------|-------|------------------|------------------|
| "Y" | SSFF | SSFF | SSFF |
| "W" | SSFF | SSFF | Likely not |
| "X" | SSFF | Not | Likely SSFF |
| "Z" | SSFF | Not | Likely not |
| "L" | Not | SSFF | Likely not |
| "M" | Not | SSFF | SSFF |
| "UR" | SSFF | Cannot determine | Cannot determine |

| Disposition | W | X | Z | L | M |
|---------------------------------|---|------------------------------------|---|---|---|
| Fire/Helb/seismic – not SSFF | 23 – do not assume additional failures | 0 | 50 – hot shorts, AppR, or helb - assume additional failures | 11 – do not assume additional failures | - |
| Creacus – | 1 – met GDC | 2 – did not meet GDC | 20 – GDC met | 0 | 3 - did not meet GDC |
| OOS – | 0 | 24 – other train unavailable | 34 – other train available | 1 – other train available | 2 – other train unavailable |
| Design or operability | 4 – function not lost | 15 – function really lost | 62 – function not lost | 4 – function not lost | 11 – function really lost |
| Other | 0 | 0 | 3 retracted LER | 5 – n/a | 37 – not specified, just obviously SSFF |
| TOTAL | 28 | 41 | 169 | 21 | 53 |