

QUESTION REQUEST FORM
ENVY NRC 2004 INSPECTION

REQUEST# 138 DATE 8/16/04

NRC INSPECTOR Bower

ENVY COUNTERPART: Janus

ENVY ASSIGNED PERSON JANUS

Info Request Question Potential CR

QUESTION/REQUEST:

What is located inside B-200 located in the battery room? Reference OP 4215.

LIST OF ATTACHMENTS: Cable & Conduit dwg 40602ADII to 40602EDII, Rev 6

RESOLUTION COMPLETE: _____ YES _____ NO

Cable 40602E, routed to B200, is used to re-charge B-1-1A and B-1-1B per OP 4215. THE UN-TERMINATED CABLE ENDS ARE COILED IN THE BOX.

Matthew E Janus / 8/26/04
ENVY ASSIGNED PERSON SIGNATURE / DATE

John Wick / 8/26/04
INDEPENDENT TECH REVIEW / DATE
(N/A FOR DOCUMENT REQUEST)

B. J. J. J. J. J. / 8/26/04
ENVY TEAM LEADER / DATE

[Signature] / 8/27/04
DATABASE UPDATED / DATE

- *NOTE:
- INFORMATION PROVIDED TO THE NRC IS ONLY AFTER ENVY TEAM LEADER SIGNATURE
 - VY TEAM LEADER DECIDES WHO IT WILL BE ASSIGNED QUESTION/REQUEST
 - RETURN SIGNED OFF FORM TO ADMINISTRATIVE SUPPORT FOR DATABASE UPDATE.

F/11