

*30486219***Z 3103**

<i>30486219</i>	0PGP04-ZE-0309	Rev. 4	Page 62 of 68
004/11/23-98 Design Change Package			
Form 5	Document Change Notice (DCN)		Page 1 of 1
DCP No.: 96-2843-2	Supp.: 0	Page 1876	of _____
DCN No.: 9704763		Page 1	of 134
DOC No. RC5037	SHT.	REV. 5	
KEY DRAWING: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	INCORPORATION REQUIRED: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		
DESCRIPTION OF CHANGE		AFFECTED UNIT <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> Both	
<p>The existing feedwater line for loop D inside containment has been redesigned & reanalyzed in conjunction with the replacement of steam generator "D".</p> <p>Supplement the existing calculation 2C159RC5037 REV 5, with the DCN 9704763, analyzed for the Unit-1 system. Unit-2 continues as is in the existing calculation.</p> <p>Add pages 1 thru 134 to this DCN to existing calculation.</p> <p>There is only one outstanding amendment (DCN SC 165) against the design calc RC 5037. There is no impact due to this DCN which was issued only to incorporate the current revision of documents.</p> <p>Additionally, DCN No. 9800861 directing the use of water hammer results of Calc. # CCO6436 Rev. 0 applies to the existing (Pre-SGR) configurations of Units 1 & 2..</p>			
 <i>A. Papadopoulos</i> 8-25-98			
<i>C. Basavamuni.</i> DESIGN ENCL.	1 7-14-98 DATE	<i>William Sam</i> REVIEWER	1 7/21/98 DATE

Calculation No. RC5037-P-400 Rev. 85
DR 9/16/98
 Page 1B

List of Effective Pages

Page No.	Latest Rev.	Page No.	Latest Rev.	Page No.	Latest Rev.	Page No.	Latest Rev.	Page No.	Latest Rev.	Page No.	Latest Rev.	Page No.	Latest Rev.
11A	5												
1B*	-												
2-9	4												
6	3												
11	4												
12-16	3												
17	4												
18-126	3												
127	4												
128	3												
129,130	4												
131-137	3												
138-141	4												
142-161	3												
168	4												
169	3												
170,171	4												
172-185	3												
191A15	4												
192	4												
193	4												
181-84	5												
<u>* Bechtel Calc RC5037-P-400 Rev. 0 (132 pages) -</u>													
<u>(6 pages)</u>													
<u>(5 pages)</u>													

* affected by DCN 9704763

Total Number of Calculation Pages: 386



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438-100SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____ORIGINATOR PANI

DATE _____

DCP# 96-2843-2, SUPP. 0 page 1 of 134

DCN# 9704763

Page 3 of 134

TABLE OF CONTENTS

	<u>PAGE</u>
1.0 OBJECTIVE/SCOPE	4
2.0 SUMMARY OF RESULTS	4
3.0 METHOD OF ANALYSIS	4.5
4.0 REFERENCES	6
5.0 DESIGN INPUT	7-15
6.0 ASSUMPTIONS	16
7.0 CALCULATIONS	17
8.0 CALCULATION RESULTS AND CONCLUSIONS	18-24
9.0 COMPUTER ANALYSIS	25

ATTACHMENTS

1. ME101 INPUT LISTINGS Weight, Thermal, Seismic & SAM runs Water Hammer run LOCA run	26-50
2. PIPE SUPPORT LOADS Design/Faulted Load . Weight, Thermal, Seismic & SAM runs Water Hammer run LOCA run	51-99
3. HELB Stress Summary	100-106
4. STRESS ISOMETRICS Design Iso (existing portion) 2C369PFW433 -01 -7 AER Iso (existing portion) Stress Iso (new piping)	107-110
5. LOCAL STRESS EVALUATIONS FOR IWAs	111-114
6. EVALUATION OF GENERIC IWA CALCULATION	115-126
7. FLUEDHEAD PENETRATION LOADINGS AND EVALUATION	127-130
8. OTHER INFORMATION	131-132
9. FW Pipe Water Hammer Reanalysis Load Reconcil. (75t draft vs 100t)	133
10. MICROFICHE FILES LOG File # 1, Computer Output: FLEXIBILITY (MFWD5). File # 2, Computer Output: WATER HAMMER (MFWDW). File # 3, Computer Output: LOCA (MFWDL). File # 4, Computer Output: WATER HAMMER (MFWDW7).	134



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438-100SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)CALC NO RC5037-P-400 R0
SHEET NO
SHEET REV ORIGINATOR PANIDATE DCP# 96-2843-2, SUPP. 0 page 77 of

DCN# 9704763

Page 4 of 134

1.0 OBJECTIVE / SCOPE

The purpose of this calculation is to evaluate the revised piping and support configuration associated with the replacement of the steam generators for unit 1. Changes to the pipe routing are required due to the relocation of the steam generator feedwater nozzle.

2.0 SUMMARY OF RESULTS

The rerouted feedwater piping system due to steam generator replacement was stress analyzed, meets the ASME Code and other requirements and is acceptable.

3.0 METHOD OF ANALYSIS

3.1 The analysis was based on Isometric drawings of Attach # 4.

ME101 computer program was utilized. The piping model incorporated the applicable as-built information (support orientations, support stiffnesses, insulation, etc.). The time history forcing functions for water hammer analysis, due to a pipe break outside containment in nonseismic portion, are based on RELAP thermal hydraulic analysis. Thermal, seismic, and LOCA movements for the replacement generator are based on Westinghouse input.

3.2 Acceptance criteria

ASME B&PV Code Section III 1974 Edition thru W75 Addenda

3.3 The following load cases are included in the analysis.

1. DEAD WEIGHT (WT1)
2. THERMAL (THRM1, THRM2, THRM3, THRM4, THRM5, THRM6, THRM7)
3. OBEI (MRS1) Operating Basis Earthquake Inertia
4. SSEI (MRS2) Safe Shutdown Earthquake Inertia
5. SAM (SAM1) OBE Seismic Anchor Movement
6. SAM (SAM2) SSE Seismic Anchor Movement
7. DBA (THRM8) Design Basis Accident Anchor Movement
8. JI Jet Impingement (N/A) (REF # 4.1 & 4.12)
9. OTHER Water hammer due to pipe break (TIME1)
10. LOCA LOCA MOVEMENTS (TIME1, TIME2, TIME3) - see section 5.6'



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438-100SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)CALC NO RC5037-P-400 R0ORIGINATOR PANI

DATE _____

SHEET NO _____

SHEET REV _____

DCP# 96-2843-2, SUPP. 0 page #80 of

DCN# 9704763

Page 5 of 134

3.0 METHOD OF ANALYSIS (Cont)

Seismic Analysis:

The seismic analysis is based on piping models which are terminated at the steam generator centerline without any RSG stick model included. The response spectra used for the steam generator nozzle considered the flexibility and mass distribution of the RSG (Ref 4.9). Multiple response spectra (ISM) based on Reg. Guide 1.61 damping values are utilized.

Jet Impingement (JI) Analysis:

None (Ref. # 4.1)

Analysis for Water Hammer:

Dynamic time history analysis was performed for waterhammer transient effects using RELAP generated forcing functions as input (Ref. # 4.2)

Analysis for LOCA:

Dynamic time history analysis was performed using displacement time histories provided by Westinghouse (Ref# 4.8c) for RHRBRK15 , RHRBRK4, & RHRBRK12. The input time histories included 3 translations as well as 3 rotations.



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438-100

SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)

CALC NO RC5037-P-400 R0

ORIGINATOR PANI

DATE

SHEET NO

SHEET REV

DCP# 96-2843-2, SUPP. 0 page 1881 of

DCN# 9704763

Page 6 of 134

4.0 REFERENCES

- 4.1 STRESS ANALYSIS OF FEED WATER "FW" SYSTEM FROM STEAM GENERATOR 1D THRU FW-1018-GA2 TO PENETRATION M-5, CALC NO. 2C159RC5037 REV. 5
 - 4.2 HYDRAULIC TRANSIENT ANALYSIS OF FEEDWATER LINE BREAK IN CONJUNCTION WITH CHECK VALVE SLAM, CALC.# 5S139MC5668 REV. 2 (DCN # 9800456)
 - 4.3 ME101 Linear Elastic Analysis of Piping----- Version N4
 - 4.4A ASME B&PV CCDE , SECTION III, DIV. 1, 1974 INCLUDING W75 ADDENDA
 - 4.4B ASME B&PV CCDE , SECTION III, DIV. 1, 1980 INCLUDING W81 ADDENDA
 - 4.4C ASME B&PV CCDE , SECTION XI, 1983 INCLUDING S83 ADDENDA
 - 4.5 RE-EVALUATION OF PENETRATIONS M5 THRU M8, CALC. NO. 2L469RC9962 REV. 2
 - 4.6 RCB Digitized Response Spectrum, Bechtel Calc. # RC1425 Rev. 2
 - 4.7 Seismic Analysis of RCB, Brown & Root Calc. # C040-9A
-
- 4.8 Westinghouse Input Information
 - a) Feedwater Nozzle Design Loads (MFW nozzle)
Westinghouse Design Specification #413A42 Rev. 0 p. 77 of 103
 - b) Loop branch nozzle displacements for OBE, SSE, Deadweight, LOCA, Thermal, Westinghouse Calculation # W-SMT-97-027-14
(RCS loop analysis -Displacements for D.W., Thermal, seismic, LOCA
Westinghouse letter #WP-BEC-SGR-97-051 from S.A.Palm to R. Beck, 6/27/97)
 - c) TGX Time history displacements at the intersection of the main feedwater and auxiliary feedwater and steam generator center line for RHR breaks nodes 4, 15, and 12; Westinghouse Calculation # W-SMT-97-027-030 Rev. 1
(Reactor Coolant Loop Reconciliation Results, RSG MFW & AFW Nozzle Disp.
Westinghouse letter #WP-BEC-SGR-98-046 from S.A.Palm to R.Beck, 4/21/98;
Westinghouse letter #WP-BEC-SGR-98-056 from S.A.Palm to R.Beck, 5/18/98;
RCL Supplemental Information, Westinghouse letter #WP-BEC-SGR-98-055
from S.A.Palm to R.Beck, 5/5/1998)
 - 4.9 Bechtel Calc. No. CC06415 Rev. 0, DT. 07/25/97 -
Reconciliation of reactor Building Seismic Analysis Due to Steam Generator Replacement.
 - 4.10 Piping Isometrics
Design Iso (existing portion) 2C369PFW433 -01 -7
ABR Iso (existing portion)
Stress Iso (new piping)
 - 4.11 Piping Stress Analysis Criteria, 5L010RQ1002 Rev. 8
Guidelines for Pipe Stress Analysis and Support Design, PED-023 Rev. 4
 - 4.12 Hazard Analysis, Prob. # FW-04 (DCN# 9606450).
 - 4.13 Drawing # ST401541-01-00044-AB6: Typical thermal wrap Insulation Details for piping (Transco Drawing EW-7756-SK1)
 - 4.14 UFSAR Section 6.6 - STP



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE

DCP# 96-2843-2, SUPP. 0 page 181 of

DCN# 9704763

Page 7 of 134

5.0 DESIGN INPUT

5.1 PIPING DATA

Line #	16" FW-1018-GA2	16" Nczzle	16" Spool @ noz	16" Noz-top elb	16" top elb-red	18" Red-Pen M5
Material	SA508 CL.3A	SA508 CL.3A	SA336 F22	SA333 GR. 6	SA333 GR 6	
Ec psi	27.8 E6	27.8 E6	30.6 E6	27.9 E6	27.9 E6	
Sc psi	22500	22500	18800	15000	15000	
Sh psi	22500	22500	17817	15000	15000	
OD in	16" sch 80	16" sch 80	16" sch 80	16" sch 80	18" sch 80	
Wall thick in	0.843"	0.843"	0.843"	0.843"	0.937"	
Pipe Wt lb/ft	136.46	136.46	136.46	136.46	170.75	
contents lb/ft	69.70	69.70	69.70	69.70	88.50	
Insul. lb/ft	4.50	4.50	4.50	4.50	4.95	
Total wt lb/ft	210.66	210.66	210.66	210.66	264.20	
Insul thick in	2.00	2.00	2.00	2.00	2.00	

Ref. 4.8, 4.4A, 4.4B, 4.13

Notes: 1) * There is no straight spool @ nozzle.

2) The new designation for SA508 CL.3A (originally introduced in S80 addenda) is SA508 Gr. 3, CL. 2

The new designation for SA508 CL.2A (originally introduced in W75 addenda) is SA508 Gr. 2, CL. 2

The new designation for SA336 CL.F22 is SA336 Gr. F22, CL. 3

3) Per Ref. 4.13, the insulation weights used in analysis for new piping are conservative.



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)

CALC NO RC5037-P-400 R0
SHEET NO 0
SHEET REV 0

ORIGINATOR PANI

DATE

DCP# 96-2843-2, SUPP. O page 183 of

DCN# 9704763

Page 8 of 134

5.2 SYSTEM OPERATING MODES

FW Lines 16"-FW-1018-GA2 & 18"-FW-1018-GA2

Mode	Temperature F	Pressure psig	Load case	Remark
1	567	1345	THRM1	Normal operating (Heatup & cooldown)
2	440	1345	THRM2	Normal Loading & Unloading
3	250	1345	THRM3	Normal Loading & Unloading
4	120	1345	THRM4	Normal operating
5	583	1345	THRM5	Emergency & Faulted
6	408	1345	THRM6	Faulted
7	32	1345	THRM7	Minimum temperature

Ref. 4.1

Notes: Design pressure 1350 psig

Peak pressure 1360 psig during upset, emergency & faulted condition

For coefficient of thermal expansion values, see ME101 input.



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)
ORIGINATOR PANI DATE _____
CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

DCP# 96-2843-2, SUPP. 0 page 1884 of

DCN# 9704763

Page 9 of 134

5.3 THERMAL ANCHOR MOVEMENTS

a) EQUIPMENT NOZZLE MOVEMENTS

NODE	EQIP. ID.#	DIR	Thermal movts/ rotations
101	SGR 1R121NSG101D	dx	0.832"
		dy	1.980"
		dz	1.893"
		ROT-X	0.000313 rad
		ROT-Y	0.000332 rad
		ROT-Z	-0.000165 rad

Ref. 4.8 (Applied to all 7 thermal modes)
(Conservatively max. of movements from Ref. 4.8 used)

b) CONTAINMENT PENETRATION MOVEMENTS

NODE	EQIP. ID.#	DIR	Thermal movts.
110	M-5 (EL. 47.5' AZ. 254.55 deg)	dx	0.0379"
		dy	-0.06168"
		dz	-0.01050"

Coordinate system: Global X - South
Global Y - Vert. Up
Global Z - West

Ref. 4.1 (Applied to all 7 thermal modes)



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____ORIGINATOR PANI DATE _____

DCP# 96-2843-2, SUPP. 0 page 108 of

DCN# 9704763

Page 10 of 134

5.4 DESIGN BASIS ACCIDENT (DBA) MOVEMENTS

CONTAINMENT PENETRATION MOVEMENTS

NODE	EQIP. ID.#	DIR	Thermal movts.
110	M-5 (EL. 47.5' AZ. 254.55 deg)	dx	-0.26115"
		dy	0.2352"
		dz	0.07226"

Coordinate system: Global X - South
Global Y - Vert. Up
Global Z - West

Ref. 4.1

(Applied to DBA identified as THRM8 load case)



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE _____

DCP# 96-2843-2, SUPP. O page 1886 of

DCN# 9704763

Page 11 of 134

5.5 SEISMIC ANCHOR MOVEMENTS

a) RCB & RCB Internal Structures (Applied at Penetration M-5)

LL'CASE	DIR.	RCB CTMT EL 47.5'	RCB INT ST EL 72'	RELATIVE MOV'T (TOTAL)
CBE (SAM1)	X	0.0177"	0.0091"	0.0268"
	Y	0.0024	0.0010	0.0034
	Z	0.0165	0.0186	0.0351
SSE (SAM2)	X	0.0355	0.0127	0.0482
	Y	0.0039	0.0019	0.0058
	Z	0.0344	0.0258	0.0602

Ref. 4.7

b) SG Nozzle & RCB Internal Structures (Applied at SGR CL)

LL'CASE	DIR.	SGR CL EL 82.7'	RCB INT ST EL 72'	RELATIVE MOV'T (TOTAL)
CBE (SAM1)	X	0.2900"	0.0091"	0.2991"
	Y	0.0140	0.0010	0.0150
	Z	0.3140	0.0186	0.3326
SSE (SAM2)	X	0.4750	0.0127	0.4877
	Y	0.0290	0.0019	0.0309
	Z	0.5110	0.0258	0.5368

Ref. 4.7, 4.8



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____ORIGINATOR PANI

DATE _____

DCP# 96-2843-2, SUPP. 0 page 87 of

DCN# 9704763

Page 12 of 134

5.6 SGR Feedwater Nozzle Movements due to LOCA

Displacement time histories were provided by Westinghouse (Ref# 4.8c), for RHRBRK15, RHRBRK4, & RHRBRK12. These were utilized and dynamic time history analysis was performed. THE DISPLACEMENTS AND ROTATIONS FROM THE ABOVE BREAKS ENVELOPE THE DISPLACEMENTS AND ROTATIONS DUE TO SECONDARY LINE BREAKS FROM THE OTHER 2 LOOPS LISTED IN REF.# 4.8b.



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE

DCP# 96-2843-2, SUPP. 0 page 108 of

DCN# 9704763

Page 13 of 134

5.7 PIPE SUPPORT DATA SUMMARY

Node	Tag# ***	Support Type	DIRECTION COSINES			Stiffness Kips/in	Sup Comp Wt. (LB)
			W/X	W/Y	W/Z		
001	SGR CL	Anchor				*	---
007	HL5016	Rigid	0.848	0.000	-0.530	715	274
07H	HL5015	Rigid	-0.707	0.000	-0.707	2367	0
07H	HL5015	Rigid	-0.707	0.000	0.707	1451	0
009	HL5014	Spring	0.000	1.000	0.000	-	450
015	SS0001	Snubber	0.380	0.000	0.925	632.37	550
030	SH0001	Spring	0.000	1.000	0.000	-	116
035	HL5009	Snubber	0.000	1.000	0.000	1301.5	935
040	HL5004	Snubber	0.380	0.000	0.925	708.56	527
050	HL5007	Snubber	0.000	0.000	1.000	1520.64	794
055	HL5008	Snubber	1.000	0.000	0.000	541	888
065	SS0006	Snubber	0.000	1.000	0.000	502	496
070	SH0002	Spring	0.008	1.000	0.000	-	146
075	HL5005	Rigid	0.000	1.000	0.000	876.84	413
085	SS0007	Snubber	-0.707	0.000	-0.707	931.62	870
094	HL5002	Rigid	0.000	1.000	0.000	1285	266
092	HL5003	Snubber	-0.707	0.000	0.707	490.87	507
097	HL5006	Snubber	0.000	0.000	1.000	614	832
099	HL5001	Rigid	0.000	1.000	0.000	532.8	344
101	HL5013	Rigid	0.888	0.461	0.000	3620	865
11A	HL5013	Rigid	0.809	-0.588	0.000	798	865
10A	HL5012	Rigid	0.000	0.000	1.000	1128.4	465
110	PEN M5	Anchor				**	--

Notes: * SGR CL modeled as rigid anchor (SG center line)

** Fluedhead Penetration M5 modeled as anchor with the following translational & rotational stiffnesses. (Ref. 4.1)
AA=6.4E6 lb/in; AB=6.4E6 lb/in; AC=6.4E6 lb/in
ARA=7.45E9 in-lb/rad; ARB=7.45E9 in-lb/rad; ARC=7.45E9 in-lb/rad

[The differences between as designed stiffness vs as analyzed are not significant- 007:721 vs 715 K/in; 07H:2363.24' vs 2367K/in ;, 07H:1459.93' vs 1451 K/in; 035:1301, vs 1301.5 K/in; , 065:507 vs 502 K/in]

*** Prefix for Pipe Support tag# : FW-1018-, or FW-9018 (Ref. 4.1 & Attach. 4)



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE

DCP# 96-2843-2, SUPP. 0 page 187 of

DCN# 9704763

Page 14 of 134

5.8 RESPONSE SPECTRA & SAM MOVEMENT INPUT

Node	Tag#	Support Type	Bldg.	Elev	SPECTRA		MRS Grp#	SAM Movt. (in) Phase	
					(OBE) MRS1	(SSE) MRS2		Dir OBE	SSE
001	SGR CL	Anchor	RCB INT	SGROBE	SGRSSE		1	DX 0.2991 0.4877 SG	
								DY 0.0150 0.0309 SG	
								DZ 0.3326 0.5368 SG	
007	HL5016	Rigid	RCB INT	IS83OB	IS83SS		2		
07H	HL5015	Rigid	RCB INT	IS83OB	IS83SS		2		
07H	HL5015	Rigid	RCB INT	IS83OB	IS83SS		2		
009	HL5014	Spring	RCB INT	-----	-----			-	
015	SS0001	Snubber	RCB INT	INTOBE	INTSSE		3		
030	SH0001	Spring	RCB INT	-----	-----			-	
035	HL5009	Snubber	RCB INT	INTOBE	INTSSE		3		
040	HL5004	Snubber	RCB INT	INTOBE	INTSSE		3		
050	HL5007	Snubber	RCB INT	INTOBE	INTSSE		3		
055	HL5008	Snubber	RCB INT	INTOBE	INTSSE		3		
065	SS0006	Snubber	RCB INT	INTOBE	INTSSE		3		
070	SH0002	Spring	RCB INT	-----	-----			-	
075	HL5005	Rigid	RCB INT	INTOBE	INTSSE		3		
085	SS0007	Snubber	RCB INT	INTOBE	INTSSE		3		
094	HL5002	Rigid	RCB INT	INTOBE	INTSSE		3		
092	HL5003	Snubber	RCB INT	INTOBE	INTSSE		3		
097	HL5006	Snubber	RCB INT	INTOBE	INTSSE		3		
099	HL5001	Rigid	RCB INT	INTOBE	INTSSE		3		
101	HL5013	Rigid	RCB INT	INTOBE	INTSSE		3		
11A	HL5013	Rigid	RCB INT	INTOBE	INTSSE		3		
10A	HL5012	Rigid	RCB INT	INTOBE	INTSSE		3		
110	PEN M5	Anchor	CMT	CMTOBE	CMTSSE		4	DX 0.0268 0.0482 CONT	
								DY 0.0034 0.0058 CONT	
								DZ 0.0351 0.0602 CONT	

Notes: 1) Spectra Damping - 2% for OBE; 3% for SSE

2) Spectra (Ref. 4.1, 4.6, 4.9)

SGROBE/SGRSSE - Elev. 91.38'; IS83OB/IS83SS - Int Str Elev. 83'

INTOBE/INTSSE-Int Str Elev. 37'-52'; CMTOBE/CMTSSE - CMT SHL EL.37'-68'

The effect of flexibility & mass distribution of RSG is reconciled in Ref. 4.9.

3) For SAM movements (see sht. 11)

*** Prefix for Pipe Support tag# : FW-1018-, or FW-9018 (Ref. 4.1 & Attach. 4)



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)
ORIGINATOR PANI DATE _____
CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____DCP# 96-2843-2, SUPP. 0 page ^{P/D} of

DCN# 9704763

Page 15 of 134

5.9 STRESS INTENSIFICATION FACTORS

DESCRIPTION	SIF	COMMENT
TTJ @ SG NOZ	1.502	BASED ON 1/32" MISMATCH (DELTA) $i = 1.3 + 0.0036(16/0.843) + [3.6(1/32)(1/0.843)] = 1.502$
TTJ @ PEN M-5	1.9	
BUTTWELDS	1.8	1.0 CAN BE USED FOR 16" & 18" THK PIPES W/ MISMATCH 1/32" AS $t > 3/16"$ & $\text{DELTA}/t < 0.1$ [$t=0.843"$ FOR 16" PIPE] AS $t > 3/16"$ & $\text{DELTA}/t < 0.1$ [$t=0.937"$ FOR 18" PIPE]
18X16 RED	2.0	
@ SMALL HALF CPLGS/SOL	1.0	
WELDED ATTACH	2.1	

Ref. 4.1, 4.4A



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438-100SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)ORIGINATOR PANI

DATE _____

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

DCP# 96-2843-2, SUPP. 0 page 1891 of

DCN# 9704763

Page 16 of 134

6.0 ASSUMPTIONS / OPEN ITEMS

None



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438-100SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)ORIGINATOR PANI

DATE _____

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

DCP# 96-2843-2, SUPP. 0 page 1872 of

DCN# 9704763

Page 17 of 134

7.0 CALCULATIONS

None



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438-100

SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)

ORIGINATOR PANI

DATE _____

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

DCP# 96-2843-2, SUPP. 0 page 1873 of

DCN# 9704763

Page 18 of 134

8.0 CALCULATION RESULTS AND CONCLUSIONS

8.1 ME101 Input Listing:

Attachment #1 contains the input listings for the me101 analysis.

8.2 Piping Stresses:

All stresser are within the code allowables. (See Section 8.14).

8.3 Fluedhead Penetration loads:

The revised loadings on fluedhead penetration M-5 are summarized on section 8.15. These loadings are reviewed, evaluated and found to be acceptable (See attachment #7).

8.4 Equipment Nozzle Loads

The loads imposed by the piping on the replacement steam generator feedwater nozzle are summarized and compared with the allowable nozzle loads. (see section 8.16). The nozzle loadings are submitted to Westinghouse for acceptance. (See Attachment# 8).

8.5 Floor and Wall penetrations:

The displacements at floor and wall penetrations are summarized, evaluated against the available clearances, and are acceptable. (See sector 8.18).

8.6 Branch connections:

The piping movements for the small pipe connections are summarized (See sector 8.17).

8.7 Valve Acceleration and End Loads:

There are no valves within the boundaries of this stress problem.

8.8 Support Information:

Pipe support loads and other information were provided to the pipe support group for design, evaluation, and any modification. (Attach.#2)

3 new supports were added on the new section of the pipe (2 rigids, & 1 spring hanger).



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438-100SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)
ORIGINATOR PANI DATE _____
CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____DCP# 96-2843-2, SUPP. 0 page 874 of

DCN# 9704763

Page 19 of 134

8.0 CALCULATION RESULTS AND CONCLUSIONS (cont'd.)

8.9 Welded Attachments:

The local stresses at welded attachments are evaluated and found to be acceptable. (See attachment #5). The impact of revised loads on the generic IWA calculation is evaluated (see attachment #6).

8.10 Flanges:

There are no flanges in this stress problem.

8.11 HELB Criteria:

The combined eq. 9-B and eq. 10 stresses meet the high energy piping criteria. No intermediate pipe break locations are identified. (See Attachment #3)

8.12 Functional Capability:

Per reference # 4.11, this system is not an essential system and therefore does not require functional capability evaluation.

8.13 Conclusion:

As shown by the stress analysis evaluation, the revised feedwater piping system due to the steam generator replacement is acceptable.



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100SUBJECT FEEDWATER "FN" SYSTEM - SG 1D TO N5CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____ORIGINATOR PANI

DATE _____

DCP# 96-2843-2, SUPP. 0 page 1095 of

DCN# 9704763

Page 20 of 134

8.14 Pipe Stress Summary

STRESS SUMMARY

ASME-SEC 111-74

NODE POINT	STRESS EQUATION	CALCULATED STRESS (PSI)	ALLOWABLE STRESS (PSI)	STRESS RATIO	REMARKS
110	EQUATION 8	7424.	15000.	.495	O.K.
110	EQUATION 9B (UPSET)	8190.	18000.	.455	O.K.
050	EQUATION 9D (FAULTED w/ SSE)	9327.	36000.	.259	O.K.
050	EQUATION 9D (FAULTED w/WAT HAMMER):	31258.	36000.	.868	O.K.
N02	EQUATION 9D (FAULTED w/LOCA):	10568.	42761.	.247	O.K.
102 E	EQUATION 10,11	16168.	22500.	.719	O.K.



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE

DCP# 96-2843-2, SUPP. O page 1896 of

DCN# 9704763

Page 21 of 134

8.15 Penetration Load Summary

SECTION 8.15 PENETRATION LOAD SUMMARY

NODE NUMBER : 110

EQUIPMENT ID: PEN M-5

COSAX, COSAY, COSAZ : 1.000 .000 .000

COSBX, COSBY, COSBZ : .000 1.000 .000

COSCX, COSCY, COSCZ : .000 .000 1.000

LOAD CASE	NOZZLE FORCE (LBS)			NOZZLE MOMENT (FT-LBS)		
	FA	FB	FC	MA	MB	MC
WT1	-827.	-3080.	-52.	-8789.	-10.	-22590.
THRM1	-26296.	8424.	-20367.	-7735.	-13145.	68232.
THRM2	-19567.	7118.	-14346.	-5822.	-13340.	59833.
THRM3	-10277.	5315.	-6035.	-3182.	-13609.	48239.
THRM4	-4603.	4214.	-959.	-1570.	-13773.	41156.
THRM5	-27165.	8593.	-21144.	-7982.	-13120.	69315.
THRM6	-17930.	6800.	-12881.	-5356.	-13387.	57790.
THRM7	-861.	3487.	2389.	-506.	-13882.	36486.
THRM8	21341.	-14280.	-5511.	32563.	95328.	-112846.
THRMP	0.	8593.	2389.	0.	0.	69315.
THRMN	-27165.	0.	-21144.	-7982.	-13882.	0.
SAM1	4266.	242.	9148.	724.	46224.	2251.
SAM2	7617.	423.	15704.	1254.	79280.	3949.
SEISA1	1001.	350.	169.	5081.	1581.	7366.
SEISA2	2408.	762.	414.	11223.	3305.	16297.
TIME1	271747.	7862.	20442.	36556.	64210.	63793.
LOCA	466.	78.	64.	1761.	346.	1814.



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO N5

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE _____

DCP# 96-2843-2, SUPP. 0 page 897 of

DCN# 9704763

Page 22 of 134

SECTION 8.16 EQUIPMENT NOZZLE LOAD SUMMARY

NODE NUMBER : N02 EQUIPMENT ID. : FW NOZZLE
 COSAX, COSAY, COSAZ : .875 .000 .485
 COSBX, COSBY, COSBZ : .485 .000 -.875
 COSCX, COSCY, COSCZ : .000 1.000 .000

LOAD CASE	NOZZLE FORCE (LBS)			NOZZLE MOMENT (FT-LBS)		
	FA	FB	FC	MA	MB	MC
WT1	10.	-54.	753.	131.	-849.	143.
THRMP	7162.	218.	2113.	0.	0.	0.
THRMN	-603.	-8400.	-30.	-56131.	-77533.	-47848.
C5	3947.	6647.	4714.	24001.	17112.	19925.
C6	6890.	11080.	10540.	40658.	37184.	36158.
TIME1	25664.	24060.	82123.	157872.	232870.	78464.
LOCA	10294.	14552.	10066	21700.	29834.	29194.

LOAD CASE	ALLOWABLE FORCE (LBS)			ALLOWABLE MOMENT (FT-LBS)		
	FA	FB	FC	MA	MB	MC
WT1	6000.	16800.	16800.	30000.	57000.	57000.
THRMP	10000.	10000.	50000.	125000.	291667.	159083.
THRMN	10000.	10000.	50000.	125000.	291667.	159083.
C5	48000.	36000.	36000.	110000.	144000.	144000.
C6	92400.	84000.	84000.	170000.	200000.	200000.
TIME1	506000.	358000.	358000.	1094000.	644900.	644900.
RUPTURE	35000.	26000.	26000.	118750.	298417.	298417.

LOAD CASE	FORCE RATIOS			MOMENT RATIOS			REMARKS
	FA	FB	FC	MA	MB	MC	
WT1	0.002	0.003	0.045	0.004	0.015	0.003	OK
THRMP	0.716	0.022	0.042	0	0	0	OK
THRMN	0.060	0.840	0.001	0.449	0.266	0.301	OK
C5	0.082	0.185	0.131	0.218	0.119	0.138	OK
C6	0.075	0.132	0.125	0.239	0.186	0.181	OK
TIME1	0.051	0.067	0.229	0.144	0.361	0.122	OK
RUPTURE	0.294	0.560	0.387	0.183	0.100	0.098	OK

NOTES: C5 - SRSS OF OBEI & OBESAM; C6 - SRSS OF SSEI & SSESAM
 TIME1 - WATER HAMMER ; RUPTURE = LOCA



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE

DCP# 96-2843-2, SUPP. 0 page 107 of 134

DCN# 9704763

Page 23 of 134

SECTION 8.17 MOVEMENTS FOR SMALL PIPE CONNECTIONS & PENETRATIONS

**FOR ISO. NO.,
SEE ATTACH. 4.*

MFID : 503406

ISO. NO.*	NODE NO.	LOAD CASE	BRANCH NO./ PENET. NO.	DX (IN)	DY (IN)	DZ (IN)	RX (RAD)	RY (RAD)	RZ (RAD)
086	WT1			.037	.001	-.061	-.00036	.00002	-.00006
086	THRMP			.000	.005	4.141	.00189	.00190	.00047
086	IHRMN			-.148	-.093	-.167	.00000	.00000	-.00033
086	C5			.026	.018	.031	.00069	.00022	.00014
086	C6			.061	.039	.073	.00153	.00051	.00030
087	WT1	SLEEVE#280		.038	.015	-.060	-.00041	.00004	-.00009
087	THRMP	SLEEVE#280		.000	.000	4.295	.00189	.00095	.00018
087	IHRMN	SLEEVE#280		-.214	-.158	-.156	.00000	.00000	-.00014
087	C5	SLEEVE#280		.031	.042	.026	.00072	.00020	.00013
087	C6	SLEEVE#280		.074	.093	.062	.00159	.00047	.00028
028	WT1	1.5FW1075GA2		.024	-.028	-.026	.00010	-.00014	.00022
028	THRMP	1.5FW1075GA2		.653	1.625	.149	.00545	.01178	.00409
028	IHRMN	1.5FW1075GA2		.000	-.751	-1.231	.00000	.00000	.00000
028	C5	1.5FW1075GA2		.048	.024	.020	.00036	.00010	.00050
028	C6	1.5FW1075GA2		.106	.052	.044	.00072	.00021	.00112



**SOUTH TEXAS PROJECT
JOBNO. 23438
CALCULATION SHEET**

CALC. NO. RC 5037-P-400 R0

SUBJECT: MFW System -SG 1D To PEN. # MS

SHEET NO. _____


REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE

DCP # 96-2843-2, SUPP. 0 PAGE ¹⁹⁹ OF

DCN# 9704763

PAGE 24 OF 134

SLEEVE #280



8.18 Pipe Sleeve Clearance Summary

NODE	SLEEVE		PIPE O.D.	INSULAT-TION(IN)	RADIAL MVNT(5)	AXIAL MVNT	CLEARANCE(1)
	NO.	I.D.					
086-087	280	29"	18"	2	3.705	3.678	-0.205"

Axial movt= $(DX+DZ) \cos 15^\circ$; Radial Movt = SRSS of axial and Y
+ AS-BUILT CLEARANCE=4.625"

NODE	GLOBA-L DIR.	LOCAL DIR.	PIPE MOVEMENT (IN)						COMBINED (3)
			WT	TH (+)	TH (-)	SEIS (4)	LOCA	OTHER(6) WH	
086-087	X	SKEW	0.038	0	-0.214	0.074	0.021	0.368	0.544
	Y	LAT(b)	0.015	0.005	-0.158	0.093	0.010	0.307	0.450
	Z	SKEW	-0.061	4.295	-0.167	0.073	0.022	0.423	4.657
	X								
	Y								
	Z								
	X								
	Y								
	Z								

NOTES :1. CLEARANCE = $\frac{1}{2}$ (SLEEVE ID - PIPE OD) -(INSULATION+RADIALMOVEMENT).

2. RADIAL MOVEMENT = $(\Delta x^2 + \Delta y^2)^{1/2}$ or $(\Delta x^2 + \Delta z^2)^{1/2}$ or $(\Delta y^2 + \Delta z^2)^{1/2}$

3. PIPING MOVEMENT SHALL BE COMBINED IN ACCORDANCE WITH TABLE 4 OF RQ-1002.

4A. SEISM= $[SSE^2 + SSE(SAM)]^{1/2}$ FOR SYSTEM REQUIRING FUNCTIONAL CAPABILITY EVALUATION.

4B. SEISM= $[OBE^2 + OBE(SAM)]^{1/2}$ FOR SYSTEM NOT INCLUDED IN NOTE 4A.

5. IF RADIAL MOVEMENT IS GREATER THAN 3/16", FURTHER EVALUATION PER PED-023 SHOULD BE PERFORMED

6. PIPING MOVEMENTS DUE TO JET IMPINGEMENT NEED NOT BE CONSIDERED



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438-100

SUBJECT EVALUATION OF MFW PIPING SYSTEM DUE TO SGR (UNIT 1 LOOP D)

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE

DCP# 96-2843-2, SUPP. 0 page 100 of

DCN# 9704763

Page 25 of 134

9.0 COMPUTER ANALYSIS

ME101 Computer program Version N4 / PC Version was utilized. The results of ME101 are fully verified against the results of bench mark problems. In addition, the results are also benchmarked with the existing analysis (ref 4.1) results. The ME101 PC Program software is fully controlled by an authorization code and security key for an assigned PC machine.

Program	File Name	MFID	Run Date	UNIT/ LOOP
ME101	MFWDW.FOR	-	-	1/D
	*MFWDW7.FOR	-	-	
	7632BK4.MFL	-	-	
	(RHRBRK4)	-	-	
	7632B12.MFL	-	-	
	(RHRBRK12)	-	-	
	7632B15.MFL	-	-	
	(RHRBRK15)	-	-	
	MFWDS.INP	-	-	
	MFWDW.INP	-	-	
	MFWDL.INP	-	-	
	MFWDS.OUT	SO3406	10/28/97	
	MFWDW.OUT	8K1703	07/08/98	
	*MFWDW7.OUT	SP3018	11/05/97	
	MFWDL.OUT	MG4946	05/22/98	

Note: Computer input, forcing function, and LOCA time history input files are provided in the attached diskettes.

* Water hammer files from 75% draft package



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438001SUBJECT FW-PIPING FRCM S.G. 1D TO M5ORIGINATOR PANI CB DATE 3/1/98 CALC NO RC5037-P-400 R0
CHK. WSS: SHEET NO _____
SHEET REV _____

DCP# 96-2843-2, SUPP. 0 page 901 of

DCN# 9704763

Page 26 of 134

ATTACHMENT 1.0 PIPE STRESS ME101 COMPUTER IMAGE

PAGES

COVER SHEET (26)	1
WEIGHT/ THERMAL/SEISMIC/SAM (27-39)	13
WATER HAMMER (40-45)	6
LOCA (46-50)	5

TOTAL PAGES: 25



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE _____

ATTACHMENT 1.0 PIPE STRESS ME101 COMPUTER IMAGE

*** DATA FILE FOR UNIT-1

CTL
HED

MFWD.S.INP

RUN

OUTPUT=SHORT,
TITLE=FEEDWATER "FW" SYSTEM -
SG 1D TO M5,
PROJNO=23438100,
PROBNO=RC5037-P-400 R0,
USER=PANI,
UNITS=2,
MODES=100,
COEF=CS4, PER=0.02,
LDCASE=WT1 (N),
LDCASE=THRM1 (A+N),
LDCASE=THRM2 (B+N),
LDCASE=THRM3 (C+N),
LDCASE=THRM4 (D+N),
LDCASE=THRM5 (E+N),
LDCASE=THRM6 (F+N),
LDCASE=THRM7 (G+N),
LDCASE=THRM8 (H+P+O),
LDCASE=SAM1 (R+X),
LDCASE=SAM2 (R+Y),
LDCASE=MRS1 (S+R),
LDCASE=MRS2 (T+R),

*** WT1 --- NORMAL OPERATING WEIGHT ANALYSIS
 *** THRM1 --- THERMAL NORMAL OPERATING MODE (HEAT-UP, COLD DOWN) @ 567 DEGREE
 *** THRM2 --- THERMAL NORMAL OPERATING MODE (LOADING, UNLOADING) @ 440 DEGREE
 *** THRM3 --- THERMAL NORMAL OPERATING MODE (LOADING, UNLOADING) @ 250 DEGREE
 *** THRM4 --- THERMAL NORMAL OPERATING MODE @ 120 DEGREE
 *** THRM5 --- THERMAL EMERGENCY OPERATING MODE @ 583 DEGREE
 *** THRM6 --- THERMAL FAULTED OPERATING MODE @ 408 DEGREE
 *** THRM7 --- THERMAL MINIMUM TEMPERATURE @ 32 DEGREE
 *** THRM8 --- POST-LOCA THERMAL ANALYSIS (DESIGN BASE ACCIDENT ANALYSIS)
 *** SAM1 --- OBE SEISMIC ANCHOR MOVEMENT ANALYSIS
 *** SAM2 --- SSE SEISMIC ANCHOR MOVEMENT ANALYSIS
 *** MRS1 --- OBE SEISMIC INERTIA ANALYSIS
 *** MRS2 --- SSE SEISMIC INERTIA ANALYSIS

 *** CAD. ISO. 3C369PFW433 SHT.01 REV. 4

 *** MATL:SA-508 CL. 3A FOR SGR NOZZLE
 *** MATL:SA-508 GR.2 CL.2 FOR (IF ANY) ST SPOOL NEAR NOZZLE
 *** MATL:SA-336 GR.F22 CL.3-PIPE 16" SCH.80 FROM SGR NOZ THRU TOP ELB OF RISER



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

OBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5

ORIGINATOR PANI

DATE

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

*** MATL:SA-333 GR.6 AFTER TOP ELBOW OF RISER & REST: 16" SCH 80/ 18" SCH 80

*** MODEL STEAM GENERATOR LOOP D

SAP 002 82.719

*** 001,002,N02 ARE NODES ON SGR CL;SGR SURFACE; FW NOZ END RESPECTIVELY

002

001 -7-3.208

-4-0.340

OD=199.42, THI=4.71,
 LBS/FT=1.00,
 E=27.8E6,
 CODE=SC3W75, CLASS=2,
 MAT=SA508-CL. 3A,
 SC=22500, SH=22500,
 DPRESS=1.0, PPRESS=1.0,
 TEMP=567, EXP=4.2766, *A
 TEMP=440, EXP=3.068, *B
 TEMP=250, EXP=1.40, *C
 TEMP=120, EXP=0.382, *D
 TEMP=583, EXP=4.433, *E
 TEMP=408, EXP=2.774, *F
 EXP=-0.2908, TEMP=32, *G
 TEMP=70, EXP=0., *H
 TEMP=70., EXP=0., *O

*** nozzle material

*** LINE NO. 18"FW-1014-GA2

ANC 001	0.832	1.980	1.893	
ANC 001				*N
ANC 001				*O
				*R

COSAX=0.8746, COSAZ=0.4848,
 COSCX=-.4848, COSCZ=0.8746,
 RSNAME=SGROBE, *S
 RSNAME=SGRSSE, *T
 DTITLE=CENTER SG,
 DX=.299,DY=.0150,DZ=.333, *X
 DX=.488,DY=.031,DZ=.537, *Y
 PHASE=SG,
 ROT-X=0.313E-3, *N
 ROT-Y=0.332E-3, *N
 ROT-Z=-0.165E-3, *N
 ETI=1R121NSG101D,

*** BEGIN FW LINE REROUTE DUE TO SG REPLACEMENT/NEW FW NOZZLE LOCATION

002N02 1.3790

0.7644

SIF=1.502,
 OD=16.0, THICK=.843,



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE _____

DLD N02 0.8746 0.4848
 005 0-7.325 0-4.061

LBS/FT=210.66,
DTITLE=FW NOZZLE,
DPRESS=1350,PPRESS=1360,
TFOR= 15,MULTI=1.,
JOINT=BTWELD,
MAT=SA336-GR.F22,
SC=18800,SH=17817,
E=30.6E6,
TEMP=567,EXP=4.3864, *A
TEMP=440,EXP=3.160, *B
TEMP=250,EXP=1.45, *C
TEMP=120,EXP=0.378, *D
TEMP=583,EXP=4.534, *E
TEMP=408,EXP=2.872, *F
EXP=-0.2892,TEMP=32, *G
TEMP=70,EXP=0., *H
TEMP=70.,EXP=0., *O
JOINT=BTWELD,

*** 006 5-0.904 -0-10.192
 SA333-GR.6

DLD 006 0.9863 -0.1651
 007 -11-10-5/8

TFOR= 14,MULTI=1.,
SEG=2,
SC=15000,SH=15000,
E=27.9E6,
TEMP=567,EXP=4.2766, *A
TEMP=440,EXP=3.068, *B
TEMP=250,EXP=1.40, *C
TEMP=120,EXP=0.382, *D
TEMP=583,EXP=4.433, *E
TEMP=408,EXP=2.774, *P
EXP=-0.2908,TEMP=32, *G
TEMP=70,EXP=0., *H
TEMP=70.,EXP=0., *O
OD=16.0,THICK=.843,
LBS/FT=210.66,
ADDWT=274,

RAD 007 .8480 -.5299

AA=715E3,ETI=HL5016,
RSNAME=IS830B, *S
RSNAME=IS83SS, *T

DLD 007 -1.0
 07G -4-1-3/8
 07H -8-10-5/8

RAD 07H -0.707 0.707

AA=1451E3,ETI=HL5015,
RSNAME=IS830B, *S
RSNAME=IS83SS, *T

RAD 07H -0.707 -0.707



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE _____

009	-5-4	AA=2367E3, ETI=HL5015, RSNAME=IS83OB, *S RSNAME=IS83SS, *T
SPD	009	1.0 ADDWT=450,
DLD	09A	-2-6 ETI=HL5014,
	09B	-5-9.11 0-7.386 L JOINT=BTWELD,
	09B	-0.9943 0.1063 L JOINT=BTWELD,
	09C	-5-0 TFOR= 12, MULTI=1., JOINT=BTWELD,
	010	-0-9-3/16 JOINT=RED, DTI=CUT LOCN,

*** END OF FW LINE REROUTE DUE TO SG REPLACEMENT/NEW FW NOZZLE LOCATION

*****	011	-1-3 JOINT=BTWELD, OD=18.0, THICK=0.937, LBS/FT=264.2, LBS/FT=272.95,
***	012	-0-7 SIF=1.0, ADDWT=25,
	12A	-1-0 SIF=1.0, ADDWT=25,
DLD	12A	-1.0 TFOR= 11, MULTI=1., SIF=1.0, ADDWT=50,
	013	-1-0
	014	-4-0 L JOINT=BTWELD, DTITLE=FW9018SS0001, ADDWT=550,
	015	-2.732 1.1211 AA=632.37E03, RSNAME=INTOBE, *S RSNAME=INTSSE, *T DTITLE=FW9018SH0001, ADDWT=116,
SNB	015	0.3796 0.9251
	030	-1.1564 0.4745
SPR	030	1.0 FORCE=8136., AA=1., DTITLE=1.5FW1075GA2,
	028	-1.007 0.41325 SIF=1.0, ADDWT=25, SIF=1.0, ADDWT=25, SIF=1.0, ADDWT=25,
	029	-0.9254 0.3746
	032	-1.3877 0.5695
	035	-0.8866 0.3638 DTITLE=FW9018HL5009, ADDWT=935, AA=1301.5E03,
SNB	035	1.0



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT FEEDWATER "FK" SYSTEM - SG 1D TO M5ORIGINATOR PANI

DATE _____

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

DLD	035 -0.9251	0.3796	RSNAME=INTOBE, RSNAME=INTSSE, TFOR= 10,MULTI=1., DTITLE=FW9018HL5004, SEGMENT=2, ADDWT=527, AA=708.56E03,	*S *T
	040 -0.62635	0.2570	RSNAME=INTOBE, RSNAME=INTSSE,	*S *T
SNB	040 0.3796	0.9251	JOINT=BTWELD,	
	045 -4.96297	2.03659 L	DTITLE=FW9018HL5007, ADDWT=794, SIF=2.1, AA=1520.64E03,	*S *T
	050	6-1-13/16	RSNAME=INTOBE, RSNAME=INTSSE,	
SNB	050	1.0	TFOR= 9,MULTI=1., DTITLE=FW9018HL5008, SEGMENT=2, ADDWT=888, AA=541E03,	*S *T
DLD	050	1.0	RSNAME=INTOBE, RSNAME=INTSSE,	
	055	2-0	JOINT=BTWELD,	
SNB	055 1.0		DTITLE=FW9018SS0006, ADDWT=496, AA=502.00E03,	*S *T
	060	3-2	RSNAME=INTOBE, RSNAME=INTSSE,	
	065 -2-8-1/4		JOINT=BTWELD,	
SNB	065	1.0	DTITLE=FW9018SH0002, SEGMENT=2, ADDWT=146,	*S *T
	067 -1-3		FORCE=9636.,AA=1., JOINT=BTWELD,	
	070 -1-0		JOINT=BTWELD,SEG=2, TFOR= 8,MULTI=1., DTITLE=FW9018HL5005, SEGMENT=2,	
***SPD	070	1.0		
SPR	070	1.0		
	071 -3-3-3/8			
	072 -8-11-5/8			
DLD	072 -1.0			
	075 -7-4			



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE _____

RAD	075	1.0	ADDWT=413, AA=876.84E03, RSNAME=INTOBE, RSNAME=INTSSE, 080 -3-2-3/4	L JOINT=BTWELD, DTITLE=FW9018SS0007, ADDWT=870, AA=931.62E03, RSNAME=INTOBE, RSNAME=INTSSE, TFOR= 7,MULTI=1., DTITLE=SLEEVE#280, SEGMENT=2,	*S *T
SNB	085 -0.7071	-0.7071			*S *T
DLD	085 -0.7071	0.7071			
	086 -0.4971	0.4971			
	087 -2.4749	2.4749			
	090 -1.76777	1.76777	L		
	094 -7.4614	-7.4614		JOINT=BTWELD, DTITLE=FW9018HL5002, SEGMENT=2, ADDWT=266, AA=1285E03, RSNAME=INTOBE, RSNAME=INTSSE, TFOR= 6,MULTI=1., DTITLE=FW9018HL5003, ADDWT=507, SEGMENT=2, AA=490.87E03, RSNAME=INTOBE, RSNAME=INTSSE, SEGMENT=2, JOINT=BTWELD, DTITLE=FW9018HL5006, ADDWT=832, SIF=2.1, AA=614E03, RSNAME=INTOBE, RSNAME=INTSSE, TFOR= 5,MULTI=1., SEG=2, DTITLE=FW1018HL5001, ADDWT=344, AA=532.80E03, RSNAME=INTOBE, RSNAME=INTSSE,	*S *T
RAD	094	1.0			
DLD	094 -0.7071	-0.7071			
	092 -1.04593	-1.04593			
SNB	092 -0.7071	0.7071			
	095 -10.09837	-10.09837	L		
	097 -4-6				
SNB	097	1.0			
DLD	097 -1.0				
	099 -7-0				
RAD	099	1.0			
	100 -3-9		L		



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO MSORIGINATOR PANI

DATE _____

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

101	-3-1-5/8	JOINT=BTWELD, DTITLE=FW9018HL5013, ADDWT=865, AA=3620.0E03, RSNAME=INTOBE, RSNAME=INTSSE, DTITLE=FW9018HL5013, ADDWT=865, AA=798.00E03, RSNAME=INTOBE, RSNAME=INTSSE, DTITLE=ABAND STANCH, ADDWT=244,		
RAD	101 0.8875	0.4608	*S *T	
	11A	-0-10		
RAD	11A 0.8090	-0.5878		
DLD	11A	-1.0		
	11B	-1-7		
	102	-3-2-3/8 L		
	10A -4-1-1/2			
RAD	10A	1.0		
DLD	10A -1.0			
	105 -5-9			
	110 -0-4-5/8			
ANC	110 .037895	-.06168	-.01050	*N
ANC	110 -.26115	.2352	.07226	*P
ANC	110			*R

COSAX=1, COSAZ=0,
COSCX=0, COSCZ=1,
AA=6.4E6, AB=6.4E6, AC=6.4E6,
ARA=7.45E9, ARB=7.45E9,
ARC=7.45E9,
DX=.0268, DY=.00337, DZ=.0351, *X
DX=.0482, DY=.00577, DZ=.0602, *Y
PHASE=CONT,
RSNAME=CMTOBE,
RSNAME=CMTSSE,

ACE

ACE

ACE

ACE

ACE

TITLE= OBE 2#D CNT SHELL EL.

37' TO 68',

RSNAME=CMTOBE,

TYP=3, POI=24,

DIR=X

.5000,	.0750,	.8000,	.1500,	.9000,	.2000,
1.0000,	.2300,	1.1000,	.3000,	1.1800,	.3300,
1.8700,	.3300,	2.5000,	.2000,	3.3000,	.2000,



CALCULATION SHEET

PROJECT STP-SGR
 JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5

CALC NO RC5037-P-400 R0
 SHEET NO _____
 SHEET REV _____

ORIGINATOR PANI

DATE _____

ACE

3.8000,	.6700,	5.0000,	.6700,	5.5000,	.6000,
6.5000,	.2550,	7.4000,	.2550,	7.5000,	.2432,
8.2000,	.1742,	8.9000,	.1650,	9.4000,	.2321,
11.0000,	.5400,	13.5000,	.5400,	16.3500,	.1600,
20.0000,	.1050,	35.0000,	.1050,	35.0010,	.1050,
DIR=Y					
.8500,	.1000,	1.0000,	.1000,	2.6000,	.2300,
4.4700,	.2750,	5.4700,	.2750,	10.0000,	.2800,
11.0000,	.5250,	13.3000,	.5250,	14.0000,	.3625,
15.0000,	.2532,	15.5000,	.2500,	16.0000,	.1730,
18.4000,	.1200,	22.0000,	.1000,	35.0000,	.1000,
35.0010,	.1000,	35.0020,	.1000,	35.0030,	.1000,
35.0040,	.1000,	35.0050,	.1000,	35.0060,	.1000,
35.0070,	.1000,	35.0080,	.1000,	35.0090,	.1000,

ACE

.5000,	.0800,	.6000,	.0800,	.7900,	.1500,
.9000,	.2000,	1.0000,	.2500,	1.3000,	.3300,
1.8600,	.3300,	2.0000,	.2900,	3.0000,	.1700,
3.5000,	.2600,	4.6000,	.2600,	4.7000,	.2368,
5.0000,	.1905,	5.2000,	.1800,	7.5000,	.1800,
8.0000,	.1700,	8.4000,	.1700,	8.8000,	.2286,
10.1000,	.4316,	10.1500,	.6500,	14.0000,	.6500,
17.0000,	.1350,	25.0000,	.0800,	35.0000,	.0800,

EQA

ACE

ACE

ACE

ACE

ACE

TITLE= SSE 3D CNT SHELL EL.

37' TO 68',

RSNAME=CMTSSE,

TYP=3, POI=23,

DIR=X

.3000,	.0700,	.6000,	.1950,	.7700,	.2965,
1.0000,	.4500,	1.2000,	.5900,	1.8500,	.5900,
2.5000,	.4000,	2.6000,	.4200,	3.0000,	.5000,
3.5000,	.6800,	4.0000,	1.7000,	5.0000,	1.7000,
5.5000,	.9890,	6.0000,	.3500,	7.3000,	.3500,
9.5000,	.3952,	10.0000,	.5467,	10.7000,	.7600,
13.5000,	.7600,	15.7000,	.3079,	16.6000,	.2470,
20.0000,	.1775,	35.0000,	.1700,		

ACE

1.0000,	.1800,	2.7000,	.4100,	4.8000,	.4800,
8.0500,	.4850,	10.8000,	.6080,	13.5000,	.6080,
15.8000,	.2750,	21.5000,	.1600,	35.0000,	.1600,
35.0010,	.1600,	35.0020,	.1600,	35.0030,	.1600,
35.0040,	.1600,	35.0050,	.1600,	35.0060,	.1600,
35.0070,	.1600,	35.0080,	.1600,	35.0090,	.1600,
35.0100,	.1600,	35.0110,	.1600,	35.0120,	.1600,
35.0130,	.1600,	35.0140,	.1600,		

ACE

DIR=Z



CALCULATION SHEET

PROJECT STP-SGR
 JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5

ORIGINATOR PANI DATE _____ CALC NO RC5037-P-400 R0
 SHEET NO _____
 SHEET REV _____

.3000,	.0700,	.5000,	.1653,	.6000,	.2010,
.7700,	.3209,	1.0000,	.5000,	1.2000,	.5500,
1.8000,	.5500,	2.1000,	.4600,	2.4000,	.3900,
3.0000,	.5000,	3.9000,	.9400,	6.9000,	.9400,
8.0000,	.4000,	10.5000,	1.1250,	18.0000,	1.1250,
22.0000,	.4800,	27.0000,	.2700,	35.0000,	.2500,
35.0010,	.2500,	35.0020,	.2500,	35.0030,	.2500,
35.0040,	.2500,	35.0050,	.2500,		

EOA

ACE

ACE

ACE

ACE

ACE

.4000,	.0800,	.5000,	.0800,	.7000,	.1480,
.9100,	.2200,	1.0000,	.2405,	1.1000,	.2700,
1.2000,	.2800,	1.9000,	.2800,	2.0500,	.2579,
3.0000,	.1975,	3.8000,	.2448,	4.0000,	.2600,
4.4000,	.2600,	5.0000,	.3600,	5.4000,	.3600,
6.1000,	.6400,	7.8000,	.6400,	7.9000,	.5400,
9.0000,	.5400,	11.0000,	.2200,	16.0000,	.1100,
24.0000,	.1100,	25.0000,	.0976,	26.5000,	.0900,
35.0000,	.0900,	35.0010,	.0900,		

ACE

1.0000,	.0900,	2.6000,	.2125,	4.0000,	.2450,
4.4000,	.2500,	5.3000,	.2500,	5.8000,	.2450,
7.9000,	.1875,	9.9000,	.1730,	12.0000,	.1383,
13.0000,	.1300,	16.0000,	.1300,	16.5000,	.1600,
21.0000,	.1600,	22.0000,	.1170,	25.5000,	.1170,
27.0000,	.1100,	33.0000,	.0750,	35.0000,	.0750,
35.0010,	.0750,	35.0020,	.0750,	35.0030,	.0750,
35.0040,	.0750,	35.0050,	.0750,	35.0060,	.0750,
35.0070,	.0750,	35.0080,	.0750,		

ACE

.4000,	.0800,	.5000,	.0800,	.6000,	.1010,
.7000,	.1283,	.9100,	.2200,	1.1000,	.2700,
1.2000,	.2800,	1.9000,	.2800,	2.4000,	.2235,
3.0500,	.1757,	3.3000,	.1641,	3.4000,	.1687,
4.2000,	.2300,	4.4000,	.2587,	4.9000,	.3579,
5.0000,	.3800,	5.4000,	.4200,	5.5000,	.5080,
7.0200,	.5080,	7.7000,	.2500,	8.1000,	.3750,
10.0000,	.3750,	12.0000,	.1600,	15.0000,	.1350,
20.0000,	.1100,	35.0000,	.1100,		

EOA

ACE

ACE

ACE

TITLE= SSE 3D INT STR EL 37'
 TO 52',
 RSNAME=INTSSE,



CALCULATION SHEET

PROJECT STP-SGR
 JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5

CALC NO RC5037-P-400 R0
 SHEET NO _____
 SHEET REV _____

ORIGINATOR PANI

DATE _____

ACE	TYP=3, POI=20, DIR=X					
	.5000,	.1600,	1.1000,	.5800,	1.8500,	.5800,
	1.9000,	.5673,	3.0000,	.3957,	4.0000,	.3979,
	4.0500,	.4000,	4.8000,	.4280,	5.0000,	1.5000,
	5.8000,	1.5000,	6.1000,	1.3900,	7.1000,	1.9200,
	8.3000,	1.9200,	9.0000,	1.3600,	10.0500,	.4700,
	11.0000,	.4700,	15.0000,	.2281,	17.0000,	.1900,
	24.0000,	.1900,	40.0000,	.1800,		
ACE	DIR=Y					
	1.0000,	.1650,	2.6000,	.3750,	4.5000,	.4250,
	5.6000,	.4250,	9.1000,	.3400,	12.0000,	.2400,
	20.0000,	.2400,	35.0000,	.1108,	40.0000,	.1000,
	40.0010,	.1000,	40.0020,	.1000,	40.0030,	.1000,
	40.0040,	.1000,	40.0050,	.1000,	40.0060,	.1000,
	40.0070,	.1000,	40.0080,	.1000,	40.0090,	.1000,
	40.0100,	.1000,	40.0110,	.1000,		
ACE	DIR=Z					
	.5000,	.1600,	1.1000,	.5800,	1.8000,	.5800,
	4.0000,	.7700,	5.1000,	1.0500,	6.9000,	1.0500,
	8.0000,	1.2300,	14.0000,	1.2300,	20.0000,	.3500,
	30.0000,	.2600,	40.0000,	.2600,	40.0010,	.2600,
	40.0020,	.2600,	40.0030,	.2600,	40.0040,	.2600,
	40.0050,	.2600,	40.0060,	.2600,	40.0070,	.2600,
	40.0080,	.2600,	40.0090,	.2600,		
EOA	TITLE= OBE 24D INT STRUC EL.					
ACE	83', RSNAME=IS830B,					
ACE	TYP=3, POI=24,					
ACE	DIR=X					
	.4100,	.1900,	.5000,	.1900,	1.1000,	.4000,
	2.0000,	.4000,	3.4000,	.2800,	5.7000,	1.1000,
	9.8000,	1.1000,	10.1000,	.9000,	12.0000,	.9000,
	13.5000,	.8000,	15.0000,	.3500,	25.0000,	.3500,
	36.0000,	.1900,	50.0000,	.1900,		
ACE	DIR=Y					
	.9000,	.0800,	2.6000,	.2200,	3.4000,	.2800,
	5.0000,	.2800,	8.0000,	.2000,	10.4000,	.1650,
	11.0000,	.1980,	14.5000,	.1980,	15.0000,	.2300,
	20.5000,	.2300,	22.0000,	.1900,	28.0000,	.1900,
	35.0000,	.0850,	60.0000,	.0850,		
ACE	DIR=Z					
	.4100,	.1900,	.5000,	.1900,	1.1000,	.4000,
	2.0000,	.4000,	3.4000,	.2800,	5.7000,	1.1000,
	9.8000,	1.1000,	10.1000,	.9000,	12.0000,	.9000,
	13.5000,	.8000,	15.0000,	.3500,	25.0000,	.3500,



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE _____

EOA .36.0000, .1900, 50.0000, .1900,
 ACE TITLE= SSE 3*D INT STRUCT EL.
 ACE 83',
 ACE RSNAME=IS83SS,
 ACE TYP=3,POI=15,

 ***** NO DIGITIZED DATA AVAILABLE - READ FROM GRAPH *****

ACE DIR=X
 .4200, .3000, .8000, .5000, 1.0500, .7000,
 2.0000, .7000, 3.0200, .5000, 4.1000, 1.2000,
 7.0000, 2.0500, 10.0000, 2.0500, 12.0000, 1.6000,
 14.0000, 1.6000, 18.0000, .8800, 21.0000, .6600,
 26.0000, .4200, 31.0000, .3300, 40.0000, .3300,

ACE DIR=Y
 1.0000, .1750, 2.0000, .4000, 3.3000, .4750,
 5.0000, .4750, 8.0000, .3800, 12.0000, .3000,
 13.0000, .3400, 21.0000, .3400, 22.0000, .2900,
 27.0000, .2900, 38.0000, .1400, 40.0000, .1400,
 45.0000, .1400, 50.0000, .1400, 60.0000, .1400,

ACE DIR=Z
 .4200, .3000, .8000, .5000, 1.0500, .7000,
 2.0000, .7000, 3.0200, .5000, 4.1000, 1.2000,
 7.0000, 2.0500, 10.0000, 2.0500, 12.0000, 1.6000,
 14.0000, 1.6000, 18.0000, .8800, 21.0000, .6600,
 26.0000, .4200, 31.0000, .3300, 40.0000, .3300,

EOA
 ACE TITLE= OBE 2*D SGR SPECT EL.
 ACE 91.38,
 ACE RSNAME=SGROBE,
 ACE TYP=3,POI=15,
 ACE DIR=X

ACE
 1.0000, .2500, 2.0000, .4000, 3.0000, .2500,
 4.0000, .7500, 5.0000, 4.0500, 7.0000, 4.0500,
 8.0000, .8000, 10.0000, .5100, 20.0000, .4000,
 30.0000, .3500, 40.0000, .3500,

ACE DIR=Y
 0.7000, .0600, 1.0000, .1000, 2.0000, .2000,
 3.5000, .3100, 5.0000, .3100, 7.0000, .3600,
 8.5000, .3800, 10.0000, .6800, 17.0000, .6800,
 18.0000, .2000, 20.0000, .1800, 30.0000, .1200,
 40.0000, .1000,

ACE DIR=Z
 1.0000, .2500, 2.0000, .4000, 3.5000, .2500,
 4.0000, .7500, 5.0000, 3.2000, 7.0000, 3.2000,
 8.0000, 1.0000, 10.0000, .5000, 11.0000, .3000,



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100

SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE _____

EOA	20.0000,	.3000,	30.0000,	.2500,	40.0000,	.2500,
ACE	TITLE= SSE 3&D SGR SPECT EL.					
ACE	91.38,					
ACE	RSNAME=SGRSSE,					
ACE	TYP=3, POI=12,					
ACE	DIR=X					
	1.0000,	.5000,	2.0000,	.7000,	3.0000,	.5000,
	4.0000,	1.5000,	5.0000,	6.4000,	7.0000,	6.4000,
	8.0000,	1.6000,	10.0000,	1.0200,	20.0000,	.8000,
	30.0000,	.7000,	40.0000,	.7000,		
ACE	DIR=Y					
	0.7000,	.1200,	1.0000,	.1800,	2.0000,	.3600,
	3.5000,	.5000,	5.0000,	.5000,	8.0000,	.6400,
	9.0000,	1.1000,	17.0000,	1.1000,	18.0000,	.4000,
	20.0000,	.3600,	30.0000,	.2400,	40.0000,	.2000,
ACE	DIR=Z					
	1.0000,	.5000,	2.0000,	.8000,	3.5000,	.5000,
	4.0000,	1.5000,	5.0000,	4.8000,	7.0000,	4.8000,
	8.0000,	2.0000,	10.0000,	.1000,	11.0000,	.6000,
	20.0000,	.6000,	30.0000,	.6000,	40.0000,	.5000,
EOA	CO=0.*THRM1,					
CMB	C1=THRM1&THRM2&THRM3&THRM4					
CMB	&CO,					
CMB	C2=THRM1#THRM2#THRM3#THRM4					
CMB	#CO,					
CMB	C3=WT1+C1,					
CMB	C4=WT1+C2,					
CMB	D1=C1&THRM7,					
CMB	D2=C2#THRM7,					
CMB	D3=WT1+D1,					
CMB	D4=WT1+D2,					
CMB	SEISA1=1.*MRS1,					
CMB	SEISA2=1.*MRS2,					
CMB	DBA=ABS(THRM8),					
CMB	THRMP=D1&THRM5&THRM6,					
CMB	THRMN=D2#THRM5#THRM6,					
CMB	D5=WT1+THRMP+CO,					
CMB	D6=WT1+THRMN+CO,					
CMB	NORMP=C3&C1&CO,					
CMB	NORMN=C4#C2#CO,					
CMB	C5=SEISA1\$SAM1,					
CMB	A1=D3&WT1&CO,					
CMB	A2=D4#WT1#CO,					
CMB	UPSETP=A1+C5,					
CMB	UPSETN=A2-C5,					



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438100SUBJECT FEEDWATER "FW" SYSTEM - SG 1D TO M5CALC NO RC5037-P-400 R0
SHEET NO
SHEET REV ORIGINATOR PANIDATE

CMB
CMB
CMB
CMB
CMB
CMB
CMB
RLS

C6=SEISA2\$SAM2,
A3=D5+DBA,
A4=D5+C6,
FAULTP=A3&CO&A4,
A5=D6-DBA,
A6=D6-C6,
FAULTN=A5#CO#A6,
LIST=WT1+THRM1+THRM2+THRM3+
THRM4+THRM5+THRM6+THRM7+DBA+
SEISA1+SEISA2+SAM1+SAM2,
LIST=NORMP+NORMN+UPSETP+
UPSETN+FAULTP+FAULTN,
LIST=THRMP+THRMN+FAULTP+
FAULTN+D5+D6,
INCLUDE=WT1,
INCLUDE=WT1+THRM1+THRM2+THRM3+
THRM4+THRM5+THRM6+THRM7+SAM1,
INCLUDE=WT1+SEISA1, LEVEL=B,
INCLUDE=WT1+SEISA2, LEVEL=D,
INCLUDE=WT1+THRM1+THRM2+
THRM3+THRM4+THRM5+THRM6+
THRM7+SAM1+SEISA1,
FPB=0.8,

RLS

STD

SLA
TEA

OLA
OLA
PBA

END

INPUT CARD IMAGES

ME101/N4 GAKU/S4 (8K1703) 07/08/98 8K1703 PAGE 1

DCP# 96-2843-2, SUPP. 0 page 115 of 115

DCN# 9704763 page 40 of 134

INPUT CARD IMAGES

ME101/W4 GANU/S4 (8K1703) 07/06/98 8K1703 PAGE 2

56 .
 57 .
 58 .
 59 . *** LINE NO. 18*FW-1014-GA2
 60 . ABC 001 0.832 1.980 1.893
 61 . ABC 001
 62 . ABC 001
 63 .
 64 . COSAX=0.8746,COSAZ=0.4848,
 65 . COSCX=-.4848,COSCZ=0.8746,
 66 . RENAME=SCRMX,
 67 . RENAME=SCRMZ,
 68 . DTITLE=CENTRE SG,
 69 . DX=.298,DY=.0150,DZ=.333,
 70 . DX=.488,DY=.031,DZ=.537,
 71 . PHASE=S0,
 72 . ROT-X=0.3132-3,
 73 . ROT-Y=0.3322-3,
 74 . ROT-Z=-0.1658-3,
 75 . ETI=1R121MEG101D,
 76 .
 77 . *** BEGIN FW LINE REROUTE DUE TO SG REPLACEMENT/NEW JW NOZZLE LOCATION
 78 . 002N02 1.3790 0.7646 SIF-1.562,
 79 . 003 0-7.325 0-4.061 L OD-16.0,THICK-.843,
 80 . LBS/FT-210.66,
 81 . DTITLE=FW NOZZLE,
 82 . DPRESS-1350,PFIXSS-1360,
 83 . DLD. N02 0.9746 0.4868 TFOR= 14,MULTI-1..
 84 . 005 0-7.325 0-4.061 L JOINT=BTWELD,
 85 . *** MAT=SA333-GR.F22,
 86 . SC-18800,SH-17817,
 87 . E-30.636,
 88 . TEMP-567,EXP-4.3864,
 89 . TEMP-440,EXP-3.160,
 90 . TEMP-250,EXP-1.45,
 91 . TEMP-130,EXP-0.378,
 92 . TEMP-583,EXP-4.534,
 93 . TEMP-408,EXP-2.872,
 94 . TEMP-350,EXP-2.710,
 95 . EXP-0.2892,TEMP-32,
 96 . TEMP-70,EXP-0.,
 97 . TEMP-70.,EXP-0.,
 98 . 006 5-0.904 -0-10.192 L JOINT=BTWELD,
 99 . *** SA333-GR.6
 100 . DLD 006 0.9863 -0.1651 TFOR= 14,MULTI-1..
 101 . 007 -11-10-5/8 SEQ=2,
 102 .
 103 .
 104 .
 105 .
 106 .
 107 .
 108 .
 109 . ***
 110 .
 111 .
 112 .
 113 .
 114 .
 115 .
 116 . ADDWT=274,

DCP# 96-2843-2, SUPPL. 0 page 1916 of 1DCN# 9704763 page 41 of 134

INPUT CARD IMAGES				ME101/M4 GAEU/S4	(8K1703) 07/08/98 8K1703 PAGE	3
117 .	RAD	007 .8480	-.5299			
118 .				AA-715E3,ETI=NL5016, RENAME=IS830B, RENAME=IS8388,	*S	TAG NOT USED - CARD IGNORED
119 .				TFOR=13,MULTI=1.. JOINT=BTWELD, SEG=2,	*T	TAG NOT USED - CARD IGNORED
120 .						
121 .	DLD	007	-1.0			
122 .		07G	-4-1-3/8			
123 .		07K	-8-10-5/8			
124 .	RAD	07K -0.707	0.707			
125 .				AA-1451E3,ETI=NL5015, RENAME=IS830B, RENAME=IS8388,	*S	TAG NOT USED - CARD IGNORED
126 .				TFOR=13,MULTI=1.. JOINT=BTWELD, SEG=2,	*T	TAG NOT USED - CARD IGNORED
127 .						
128 .	RAD	07K -0.707	-0.707			
129 .				AA-2367E3,ETI=NL5015, RENAME=IS830B, RENAME=IS8388,	*S	TAG NOT USED - CARD IGNORED
130 .				TFOR=13,MULTI=1.. JOINT=BTWELD, SEG=2,	*T	TAG NOT USED - CARD IGNORED
131 .						
132 .		009	-5-4			
133 .				ADDWT=450,		
134 .	SPD	009	1.0			
135 .				ETI=NL5014, JOINT=BTWELD,		
136 .		09A	-2-6	JOINT=BTWELD, JOINT=BTWELD, TFOR=13,MULTI=1.. JOINT=BTWELD, JOINT=RED,		
137 .	DLD	09B -5-9.11	0-7.386	L 0.98 -0.9943 0.1063		
138 .				TFOR=13,MULTI=1.. JOINT=BTWELD, JOINT=RED, DTX-CUT LOCH,		
139 .		09C	-5-0			
140 .		010	-0-9-3/16			
141 .						
142 .				*** END OF FW LINE REROUTE DUE TO SG REPLACEMENT/NEW FW NOZZLE LOCATION		
143 .						
144 .		011	-1-3			
145 .				JOINT=BTWELD, OD=16.0,THICK=0.937, LBS/FT=264.2, LBS/FT=272.95,		
146 .				SIF=1.0, ADDWT=25, SIF=1.0, ADDWT=25, ADDWT=50,		
147 .		012	-0-7			
148 .		12A	-1-0			
149 .				TFOR=11,MULTI=1.. SIF=1.0, ADDWT=50,		
150 .	DLD	12A	-1-0			
151 .		013	-1-0			
152 .						
153 .		014	-4-0	L		
154 .				JOINT=BTWELD, DTITLE=FW9018SH0001, ADDWT=550, AA=632.17E03,		
155 .		015 -2.732	1.1211	RENAME=INT0E, RENAME=INT88E, DTITLE=FW9018SH0001, ADDWT=116,		
156 .						
157 .	BMB	015 0.3796	0.9251			
158 .						
159 .		030 -1.1564	0.4745			
160 .						
161 .						
162 .						
163 .						
164 .	***SPD	030	1.0			
165 .	BPR	030	1.0			
166 .		028 -1.007	0.41325	FORCE=8136.,AA=1.. DTITLE=1.5FW1075GA2, SIF=1.0,ADDWT=25, SIF=1.0,ADDWT=25, SIF=1.0,ADDWT=25,		
167 .						
168 .		029 -0.9254	0.3746			
169 .		032 -1.3877	0.5695			
170 .						
171 .		035 -0.8866	0.3638			
172 .						
173 .				DTITLE=FW9018HL5009, ADDWT=935, AA=1301.5E03, RENAME=INT0E, RENAME=INT88E,		
174 .						
175 .	BMB	035	1.0			
176 .						
177 .						

				ME103/W4	GAEU/54	(8K1703) 07/08/98	8K1703 PAGE	4
178	.	DLD	035 -0.9251	0.3796		TFOR- 10,MULTI-1..		
179	.		040 -0.62639	0.2570		DTITLE-FW9018HL5004, SEGMENT-2, ADDWT-527, AA-701.55E03,		
180	.					RNAME=INTODE, RNAME=INTSSE,		
181	.					"S	TAG NOT USED - CARD IGNORED	
182	.					"T	TAG NOT USED - CARD IGNORED	
183	.	SNB	040 0.3796	0.9251				
184	.					JOINT-BTWELD,		
185	.					DTITLE-FW9018HL5007, ADDWT-734, SIP-2.1, AA-1520.64E03,		
186	.		045 -4.96297	2.03659	L	RNAME=INTODE, RNAME=INTSSE,		
187	.					"S	TAG NOT USED - CARD IGNORED	
188	.		050	6-1-13/16		"T	TAG NOT USED - CARD IGNORED	
189	.					JOINT-BTWELD,		
190	.					DTITLE-FW9018HL5008, SEGMENT-2, ADDWT-838, AA-541E03,		
191	.					RNAME=INTODE, RNAME=INTSSE,		
192	.	SNB	050 1.0	1.0		"S	TAG NOT USED - CARD IGNORED	
193	.					"T	TAG NOT USED - CARD IGNORED	
194	.					JOINT-BTWELD,		
195	.	DLD	050 1.0	1.0		DTITLE-FW9018HL5009, SEGMENT-2, ADDWT-938, AA-541E03,		
196	.		055	2.0		RNAME=INTODE, RNAME=INTSSE,		
197	.					"S	TAG NOT USED - CARD IGNORED	
198	.					"T	TAG NOT USED - CARD IGNORED	
199	.					JOINT-BTWELD,		
200	.	SNB	055 1.0	1.0		DTITLE-FW9018SH0006, SEGMENT-2, ADDWT-1038, AA-502.00E03,		
201	.					RNAME=INTODE, RNAME=INTSSE,		
202	.					"S	TAG NOT USED - CARD IGNORED	
203	.		060	3-2	L	"T	TAG NOT USED - CARD IGNORED	
204	.					JOINT-BTWELD,		
205	.		065 -2-8-1/4			DTITLE-FW9018SH0006, SEGMENT-2, ADDWT-496, AA-502.00E03,		
206	.					RNAME=INTODE, RNAME=INTSSE,		
207	.	SNB	065 1.0	1.0		"S	TAG NOT USED - CARD IGNORED	
208	.					"T	TAG NOT USED - CARD IGNORED	
209	.					JOINT-BTWELD,		
210	.		067 -1-3			DTITLE-FW9018SH0007, SEGMENT-2, ADDWT-146,		
211	.		070 -1-0			RNAME=INTODE, RNAME=INTSSE,		
212	.					"S	TAG NOT USED - CARD IGNORED	
213	.					"T	TAG NOT USED - CARD IGNORED	
214	.					JOINT-BTWELD,		
215	.	***SPD	070 1.0	1.0		DTITLE-FW9018SH0007, SEGMENT-2, ADDWT-413,		
216	.	SPR	070 1.0	1.0		RNAME=INTODE, RNAME=INTSSE,		
217	.		071 -3-3-3/8			"S	TAG NOT USED - CARD IGNORED	
218	.		072 -8-11-5/8			"T	TAG NOT USED - CARD IGNORED	
219	.	DLD	072 -1.0			JOINT-BTWELD,		
220	.		075 -7-4			DTITLE-FW9018HL5605, SEGMENT-2, ADDWT-413,		
221	.					AA-876.84E03,		
222	.					RNAME=INTODE, RNAME=INTSSE,		
223	.					"S	TAG NOT USED - CARD IGNORED	
224	.	RAD	075 1.0	1.0		"T	TAG NOT USED - CARD IGNORED	
225	.					JOINT-BTWELD,		
226	.					DTITLE-FW9018SH0007, SEGMENT-2, ADDWT-170,		
227	.		080 -3-2-3/4		L	AA-931.62E03,		
228	.					RNAME=INTODE, RNAME=INTSSE,		
229	.		085 -0.9023	0.9023		"S	TAG NOT USED - CARD IGNORED	
230	.					"T	TAG NOT USED - CARD IGNORED	
231	.	SNB	085 -0.7071	-0.7071		JOINT-BTWELD,		
232	.					DTITLE-FW9018SH0007, SEGMENT-2, ADDWT-170,		
233	.					AA-931.62E03,		
234	.	DLD	085 -0.7071	0.7071		RNAME=INTODE, RNAME=INTSSE,		
235	.		086 -0.4971	0.4971		"S	TAG NOT USED - CARD IGNORED	
236	.		087 -2.4749	2.4749		"T	TAG NOT USED - CARD IGNORED	
237	.					JOINT-BTWELD,		
238	.		090 -1.76777	1.76777	L	DTITLE-SLEEVE8280, SEGMENT-2,		

INPUT CARD IMAGES

239 .								
240 .	094 -7.4614		-7.4614					
241 .								
242 .								
243 .								
244 .	RAD 094	1.0						
245 .								
246 .								
247 .	DLD 094 -0.7071		-0.7071					
248 .	092 -1.04593		-1.04593					
249 .								
250 .								
251 .	SXB 092 -0.7071		0.7071					
252 .								
253 .								
254 .	095 -10.09837		-10.09837 L					
255 .								
256 .	097 -4-6							
257 .								
258 .								
259 .	SXB 097	1.0						
260 .								
261 .								
262 .	DLD 097 -1.0							
263 .	099 -7-0							
264 .								
265 .								
266 .	RAD 099	1.0						
267 .								
268 .								
269 .	100 -3-9			L				
270 .								
271 .	101		-3-1-5/8					
272 .								
273 .	RAD 101 0.8875	0.4608						
274 .								
275 .								
276 .	11A		-0-10					
277 .								
278 .	RAD 11A 0.8090	-0.5878						
279 .								
280 .								
281 .	DLD 11A		-1.0					
282 .	11B		-1-7					
283 .								
284 .	102		-3-2-3/8 L					
285 .								
286 .	10A -4-1-1/2							
287 .								
288 .	RAD 10A	1.0						
289 .								
290 .								
291 .	DLD 10A -1.0							
292 .	105 -5-9							
293 .	110 -0-4-5/8							
294 .	ANC 110 .037895	-.06168	-.01050					
295 .	ANC 110 -.26115	.2352	.07226					
296 .	ANC 110							
297 .								
298 .								
299 .								

M8101/X4 GAEU/S4 (8X1703) 07/08/98 8X1703 PAGE 5

DCP# 96-2843-2, SUPP.0 page 1919 of _____

DCN# 9704763 page 44 of 134

JOINT-BTWEGL,
DTITLE-FW9018HL5002,
SEGMENT=2,
ADDWT=266,
AA=1285E03,
RNAME=INTOBE,
*E *T TAG NOT USED - CARD IGNORED
RNAME=INTSSE,
TFOR= 6,MULTI=1.,
DTITLE-FW9018HL5003,
ADDWT=807,
SEGMENT=2,
AA=490.87E03,
RNAME=INTOBE,
*E *T TAG NOT USED - CARD IGNORED
RNAME=INTSSE,
SEGMENT=2,
JOINT-BTWEGL,
DTITLE-FW9018HL5006,
ADDWT=832,
SIF=2.1,
AA=614E03,
RNAME=INTOBE,
*E *T TAG NOT USED - CARD IGNORED
RNAME=INTSSE,
TFOR= 5,MULTI=1.,
SEG=2,
DTITLE-FW1018HL5001,
ADDWT=344,
AA=832.80E03,
RNAME=INTOBE,
*E *T TAG NOT USED - CARD IGNORED
RNAME=INTSSE,
TAG NOT USED - CARD IGNORED
L
JOINT-BTWEGL,
DTITLE-FW9018HL5013,
ADDWT=465,
AA=3620.0E03,
RNAME=INTOBE,
*E *T TAG NOT USED - CARD IGNORED
RNAME=INTSSE,
DTITLE-FW9018HL5013,
ADDWT=465,
AA=798.00E03,
RNAME=INTOBE,
*E *T TAG NOT USED - CARD IGNORED
RNAME=INTSSE,
TFOR= 4,MULTI=1.,
DTITLE-FABAND STARCH,
ADDWT=244,
JOINT-BTWEGL,
DTITLE-FW9018HL5012,
ADDWT=465,
AA=1120.4E03,,
RNAME=INTOBE,
*E *T TAG NOT USED - CARD IGNORED
RNAME=INTSSE,
TFOR= 2,MULTI=1.,
SIF=1.9,
DTITLE-FW M-5,
*E *P *R WT1 THERM2 THERM3 THERM6 TIME1
COSAX=1,COSAE=0,
COSCX=0,COSCZ=1,
AA=6.4E6,AB=6.4E6,AC=6.4E6,

INPUT CARD IMAGES

ME101/W4 GAEU/S4 (8K1703) 07/08/98 8K1703 PAGE 6

```

300 .
301 .
302 .
303 .
304 .
305 .
306 .
307 .
308 .
309 .
310 .
311 .
**** *****
**** CND
**** RLE
**** STD.
**** SLA
**** OLA
**** END

```

```

ARA=7.45E9,ARB=7.45E9,
ARC=7.45E9,
DX=.0268,DX=.00337,DX=.0351,*X . TAG NOT USED - CARD IGNORED
DX=.0482,DX=.00577,DX=.0602,*Y . TAG NOT USED - CARD IGNORED
PHASE=CONT,
RSNAME=CMTORE, *S . TAG NOT USED - CARD IGNORED
RSNAME=CMTSSE, *T . TAG NOT USED - CARD IGNORED

C0=0.*TERM2.
SEIST=1.0*TIME1,
C1=TERM2&TERM3&TERM6
AC0,
C2=TERM2&TERM3&TERM6
#C0,
C3=WT1+C1,
C4=WT1+C2,
C5=C3+TIME1,
C6=C4-TIME1,
FAULTP=CO&CS,
FAULTH=C0&C6,
LIST=WT1+TERM7+TIME1+FAULTP+
FAULTH,
LIST=NONE,
INCLUDE=WT1,
INCLUDE=WT1+SEIST,LEVEL=D,

```

ADD MFWDW.FOR

INPUT CARD IMAGES

ME101/W4 GAEU/54 (MG4946) 05/23/98 MG4946 PAGE 1

ME101
 INPUT CARD IMAGES

INPUT CARD SEQ . 1 11 21 31 41 51 61 71 80 . LOAD CASE(S)

1 . * . * . * . * . * . * . * .

2 . *** DATA FILE FOR UNIT-1 MPNDL.IMP

3 . *** WESTINGHOUSE AXES: X WEST, Y VERT UP, Z NORTH

4 . *** TIMEL1: LOCA DISP/ROT HISTORY RHRBRK4 FOR FM NOZZLE (W MODE 7632)

5 . *** TIMEL2: LOCA DISP/ROT HISTORY RHRBRK15 FOR FM NOZZLE (W MODE 7632)

6 . *** TIMEL3: LOCA DISP/ROT HISTORY RHRBRK12 FOR FM NOZZLE (W MODE 7632)

7 . ***

8 . CTL OUTPUT-SHORT.

9 . NED TITLE-FEEDWATER "FM" SYSTEM -

10 . SQ ID TO NS,

11 . PROJNO-23438001,

12 . PROBNO-2C159KC5037,

13 . USER-PANI,

14 . UNITS=2,

15 . COEF=CS4,

16 . MODELS=150,

17 . DAMP=.03,

18 . TPER=.0050,TZERO=0.,TFIN=.65, \

19 . RUN LDCASE-W1(N),

20 . ,RUN LDCASE-TIMEL1(T),

21 . RUN LDCASE-TIMEL2(U),

22 . RUN LDCASE-TIMEL3(V),

23 . ***

24 . *** NT1 --- NORMAL OPERATING WEIGHT ANALYSIS

25 . ***

26 . *** CAD. ISO. 3C369PPM433 SHT.01 REV. 4

27 . ***

28 . *** MATL:SA-508 CL. 3A FOR SGR NOZZLE

29 . *** MATL:SA-508 GR.2 CL.2 FOR (IF ANY) ST SPOOL NEAR NOZZLE

30 . *** MATL:SA-336 GR.F22 CL.3-PIPE 16° SCH.80 FROM SGR NOZ THRU TOP ELB OF RISER

31 . *** MATL:SA-333 GR.6 AFTER TOP ELBOW OF RISER & REST: 16° SCH 80/ 18° SCH 80

32 . ***

33 . ***

34 . *** MODEL STEAM GENERATOR LOOP D

35 . ***

36 . SAP 002 82.719 001,002,003 ARE NODES ON SGR CL,SGR SURFACE, FM NOZ END RESPECTIVELY

37 . ***

38 . ***

39 . 002

40 . 001 -7-3.208 -4-0.340 OD-199.42,THI-4.71,
41 . LBS/FT-1.00,
42 . E-27.0E6,
43 . CODE=SC3N75,CLASS=2,
44 . MATL=SA508-CL. 3A,
45 . SC-22500,SH-22500,
46 . DPRESS=1.0,PFRESS=1.0,
47 . ***

48 . *** LINE NO. 18-FM-1014-GA2

49 . ANC 001 * * NT1

50 . DTITLE-CENTER SG,
51 . PHASE-SG,
52 . DX-.030,DY-.0300,DZ-.030, * * TAG NOT USED - CARD IGNORED
53 . SRX-.00010,ERY-.00050, * * TAG NOT USED - CARD IGNORED
54 . ERZ-.00010, * * TAG NOT USED - CARD IGNORED
55 . PHASE-SG, * * TAG NOT USED - CARD IGNORED

INPUT CARD IMAGES

56 .
 57 .
 58 .
 59 .
 60 .
 61 .
 62 .
 63 .
 64 .
 65 .
 66 .
 67 .
 68 .
 69 .
 70 .
 71 .
 72 .
 73 .
 74 .
 75 .
 76 .
 77 .
 78 .
 79 .
 80 .
 81 .
 82 .
 83 .
 84 .
 85 .
 86 .
 87 .
 88 .
 89 .
 90 .
 91 .
 92 .
 93 .
 94 .
 95 .
 96 .
 97 .
 98 .
 99 .
 100 .
 101 .
 102 .
 103 .
 104 .
 105 .
 106 .
 107 .
 108 .
 109 .
 110 .
 111 .
 112 .
 113 .
 114 .
 115 .
 116 .

ME101/H4 CARU/54 (MG4946) 05/22/98 MG4946 PAGE 2
 DX-.009,DY-.0530,DZ-.011, *R . TAG NOT USED - CARD IGNORED
 SRX-.00053,RY-.00262, *R . TAG NOT USED - CARD IGNORED
 SRZ-.00008, *R . TAG NOT USED - CARD IGNORED
 PHASE-B6,
 DX-.009,DY-.0530,DZ-.011, *P . TAG NOT USED - CARD IGNORED
 SRX-.00053,RY-.00050, *P . TAG NOT USED - CARD IGNORED
 SRZ-.00008, *P . TAG NOT USED - CARD IGNORED
 ETI-1R1211NSG101D.

 *** BEGIN FW LINE REROUTE DUE TO SG REPLACEMENT/NEW FW NOZZLE LOCATION

 RAD 001 1.0 TDIS-B43, *T . TIMEL1
 RAD 001 1.0 TDIS-B42, *T . TIMEL1
 RAD 001 1.0 TDIS-B41, *T . TIMEL1
 RAD 001 1.0 TROT-B46, *T . TIMEL1
 RAD 001 1.0 TROT-B45, *T . TIMEL1
 RAD 001 1.0 TROT-B44, *T . TIMEL1
 RAD 001 1.0 TDIS-B53, *U . TIMEL2
 RAD 001 1.0 TDIS-B52, *U . TIMEL2
 RAD 001 1.0 TDIS-B51, *U . TIMEL2
 RAD 001 1.0 TROT-B56, *U . TIMEL2
 RAD 001 1.0 TROT-B55, *U . TIMEL2
 RAD 001 1.0 TROT-B54, *U . TIMEL2
 RAD 001 1.0 TDIS-B23, *V . TIMEL3
 RAD 001 1.0 TDIS-B22, *V . TIMEL3
 RAD 001 1.0 TDIS-B21, *V . TIMEL3
 RAD 001 1.0 TROT-B26, *V . TIMEL3
 RAD 001 1.0 TROT-B25, *V . TIMEL3
 RAD 001 1.0 TROT-B24, *V . TIMEL3
 002H02 1.3790 0.7646 SIF-1.502,
 OD-16.0,THICK-.843,
 LBS/FT-210.66,
 DTITLE-FW NOZZLE,
 DPRESS-1350,PPRESS-1360,
 JOINT-BTWEELD,
 MAT-8A336-GR.F22,
 SC-18800,SH-17817,
 E-30.6E6,
 005 0-7.325 0-4.061 L JOINT-BTWEELD,
 *** 006 5-0.904 -0-10.192 L JOINT-BTWEELD,
 SA333-GX.6
 007 -11-10-5/8 SFG-2,
 SC-15000,SH-15000,
 E-27.9E6,
 OD-16.0,THICK-.843,
 LBS/FT-210.66,
 ADDWT-274,
 RAD 007 .8480 -.5299 AA-715R,ETI-HL5016,
 JOINT-BTWEELD,
 07G -4-1-3/8 SFG-2,
 07X -8-10-5/8 0.707 AA-14518J,ETI-HL5015,
 RAD 07X -0.707 -0.707 AA-2367EJ,ETI-HL5015,
 RAD 07X -0.707 -0.707 ADDWT-450,
 009 -5-4
 SPD 009 1.0 ETI-HL5014,
 09A -2-6 L JOINT-BTWEELD,
 09B -5-9.11 0-7.386 L JOINT-BTWEELD,
 09C -6-6 JOINT-BTWEELD,

DCN# 96-2843-2,SUPP.0 page 1922 of 1DCN# 9704763 page 47 of 134

INPUT CARD IMAGES

			ME101/M4 GAEU/S4	(HQ4946) 05/22/98 HQ4946 PAGE
117	010	-0-9-3/16	JOINT=RED,	1
118			DTI=CUT LOCN,	
119	***	END OF FW LINE REROUTE DUE TO SG REPLACEMENT/NEW FW NOZZLE LOCATION	LBS/FT=264.2,	
120	LBS/FT=272.95,	
121	011	-1-3	SIF=1.0,	
122			ADDWT=25,	
123			SIF=1.0,	
124	***		ADDWT=25,	
125	012	-0-7	SIF=1.0,	
126			ADDWT=50,	
127	12A	-1-0	JOINT-BTWEILD,	
128			DTITLE=FW9018880001,	
129	013	-1-0	ADDWT=50,	
130			AA=632.37E03,	
131	014	-4-0	DTITLE=FW901888K0001,	
132			ADDWT=116,	
133	015 -2.732	1.1211	FORCE=8136.,AA=1..,	
134			DTITLE=1.57W1075GAZ,	
135	SNB 015 0.3796	0.9251	SIF=1.0,ADDWT=25,	
136	030 -1.1564	0.6745	SIF=1.0,ADDWT=25,	
137			SIF=1.0,	
138	***SPD 030	1.0	ADDWT=25,	
139	SPR 030	1.0	JOINT-BTWEILD,	
140	028 -1.007	0.41325	DTITLE=FW901888L5009,	
141			ADDWT=935,	
142			AA=1301.9E03,	
143	028 -0.9254	0.3746	DTITLE=FW901888L5004,	
144	032 -1.3877	0.5695	SEGMENT=2,	
145			ADDWT=537,	
146	035 -0.8866	0.3638	AA=708.56E03,	
147			JOINT-BTWEILD,	
148			DTITLE=FW901888L5007,	
149	SNB 035 1.0	0.2570	ADDWT=734,	
150	040 -0.62639	0.2570	SIF=2.1,	
151			AA=1520.64E03,	
152			DTITLE=FW901888L5006,	
153			SEGMENT=2,	
154	SNB 040 0.3796	0.9251	ADDWT=888,	
155	045 -4.96297	2.03659	AA=541E03,	
156			JOINT-BTWEILD,	
157	050	6-1-13/16	DTITLE=FW901888L5005,	
158			SEGMENT=2,	
159			ADDWT=935,	
160			SIF=2.1,	
161	SNB 050	1.0	AA=1520.64E03,	
162	055	2-0	DTITLE=FW901888L5004,	
163			SEGMENT=2,	
164			ADDWT=888,	
165	SNB 055 1.0	3-2	AA=541E03,	
166	060	3-2	JOINT-BTWEILD,	
167			DTITLE=FW901888S0006,	
168			ADDWT=436,	
169	065 -2-8-1/4		AA=352.09E03,	
170			JOINT-BTWEILD,	
171	SNB 065	1.0	DTITLE=FW901888K0002,	
172	067 -1-3		SEGMENT=2,	
173	070 -1-0		ADDWT=146,	
174				
175				
176				
177	***SPD 070	1.0		

INPUT CARD IMAGES

178 . SPR 070 1.0
 179 . 071 -3-3-3/8
 180 . 072 -8-11-5/8
 181 . 075 -7-6
 182 .
 183 .
 184 .
 185 . RAD 075 1.0
 186 . 080 -3-2-3/4
 187 .
 188 . 085 -0.9023 0.9023
 189 .
 190 . SNS 085 -0.7071 -0.7071
 191 . 086 -0.4971 0.4971
 192 . 087 -3.4749 2.4749
 193 .
 194 . 090 -1.76777 1.76777 L
 195 .
 196 . 094 -7.4614 -7.4614
 197 .
 198 .
 199 .
 200 . RAD 094 1.0
 201 . 092 -1.04593 -1.04593
 202 .
 203 .
 204 . SNS 092 -0.7071 0.7071
 205 . 095 -10.09837 -10.09837 L
 206 .
 207 . 097 -6-6
 208 .
 209 .
 210 . SNS 097 1.0
 211 . 099 -7-0
 212 .
 213 .
 214 . RAD 099 1.0
 215 . 100 -3-9 L
 216 .
 217 . 101 -3-1-5/8
 218 .
 219 . RAD 101 0.8875 0.4608
 220 . 11A -0-10
 221 .
 222 . RAD 11A 0.8890 -0.5878
 223 . 11B -1-7
 224 .
 225 . 102 -3-2-3/8 L
 226 .
 227 . 10A -4-1-1/2
 228 .
 229 . RAD 10A 1.0
 230 . 105 -5-9
 231 . 110 -0-4-5/8
 232 . ANC 110 .037895 -.06168 -.01050
 233 . ANC 110
 234 . ANC 110
 235 . ANC 110
 236 .
 237 .
 238 .

ME101/W4 GARI/54

(MD4946) 05/22/98 MD4946 PAGE 4

FORCH-9636.,AA-1..
 JOINT-BTWELD,
 JOINT-BTWELD,SEG-2,
 DTITLE-FW9018HL5003,
 SEGMENT-2,
 ADDWT-413,
 AA-876.84E03,
 JOINT-BTWELD,
 DTITLE-FW9018SS0007,
 ADDWT-870,
 AA-331.62E03,
 DTITLE-SLEEVE#280,
 SEGMENT-2,
 JOINT-BTWELD,
 DTITLE-FW9018HL5002,
 SEGMENT-2,
 ADDWT-356,
 AA-1285E03,
 DTITLE-FW9018HL5003,
 ADDWT-507,
 SEGMENT-2,
 AA-490.87E03,
 SEGMENT-2,
 JOINT-BTWELD,
 DTITLE-FW9018HL5006,
 ADDWT-832,
 SIF-2.1,
 AA-614E03,
 SEG-2,
 DTITLE-FW1018HL5001,
 ADDWT-344,
 AA-532.80E03,
 JOINT-BTWELD,
 DTITLE-FW9018HL5013,
 ADDWT-865,
 AA-3620.0E03,
 DTITLE-FW9018HL5013,
 ADDWT-865,
 AA-798.00E03,
 DTITLE-ABAND STANCH,
 ADDWT-244,
 JOINT-BTWELD,
 DTITLE-FW9018HL5012,
 ADDWT-465,
 AA-1128.4E03,,
 SIF-1.9,
 SIF-1.9,DTITLE-PEN M-5,
 SW . WT1
 ST . TIMEL1
 SU . TIMEL2
 SV . TIMEL3
 COSAX=1,COSAZ=0,
 COSCX=0,COSCY=1,
 AA=6.4E6,AB=6.4E6,AC=6.4E6,

INPUT CARD IMAGES

239 .
240 .
241 .
242 .
243 . ADD 7632BK4.MPL
244 . ADD 7632B15.MPL
245 . ADD 7632B12.MPL
246 .
247 . CMB
248 . CMB
249 .
250 . STD
251 . RLS
252 .
253 . OLA
254 .
255 . END
256 .
257 .
258 .

NE101/E4 GAZU/54 (MG4946) 05/22/98 MG4946 PAGE 5

ARA=7.45E9,ARB=7.45E9,
ARC=7.45E9,
*T . TIMEL1
*U . TIMEL2
*V . TIMEL3

SEISL-TIMEL1|TIMEL2|TIMEL3.
LOCA=ANAX(TIMEL1,TIMEL2,
TIMEL3),
LIST=NONE,
LIST=WT1|TIMEL1+TIMEL2+
TIMEL3+LOCA,
INCLUD=WT1+SEISL,LEVEL=D,

DCP# 96-2843-2, SUPP. 0 page 195 of 1DCN# 9704763 page 50 of 134



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438001

SUBJECT FW-PIPING FROM S.G. 1D TO PEN.# M5'

ORIGINATOR PANI

DATE

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

DCP# 96-2843-2, SUPP. 0 page 196 of

DCN# 9704763

Page 51 of 134

ATTACHMENT 2.0 PIPE SUPPORT LOADS

TOTAL NO OF SHEETS

This sheet (51)	1
DESIGN/FAULTED LOAD FOR LOOP D (52-53)	2
WEIGHT/ THERMAL/SEISMIC/SAM (54-77)	24
WATER HAMMER (78-89)	12
LOCA (90-99)	10
TOTAL	<u>49</u>

Load Case Names:

WTX - Dead weight analysis
THRMXX - Thermal expansion/anchor movement analysis.
TIME_X - Time history analysis
SAM_X - Seismic anchor movement analysis
SEISAX - Seismic inertia analysis
DBA - Design Basis Accident
LOCA - LOCA Analysis

NORMP - Normal Positive
NORMN - Normal Negative
UPSETP - Upset Positive
UPSETN - Upset Negative
FAULTP - Faulted Positive
FAULTN - Faulted Negative

Support Types:

RAD - Rigid translational restraint
RAR - Rigid rotational restraint
SPR/SPD - Spring hanger
SNB - Snubber
ANC - Anchor (may be specified as RAD and RAR in each of the three translational and rotational directions).

Co-ordinates: North = -X (Global)

Note: Spring settings are based on Normal operating (THRM2) case and verified for topping or bottoming out due to movements from all other load cases. Snubbers are set so that thermal movements are not restricted and reserve travel checked for max thermal movements.

DESIGN/FAULTED LOAD FOR LOOP D

SUPPORT MK#	DATA PT.	DIR.	WT.	THERMAL FAULTED "	JET LOAD (N/A)	LOCA	WATER HAMMER	FAULTED LOAD			Design Load Ext P.S. Calc
								WT+TH+ LOCA	WT+TH+ WH	WT+TH+ 8SE	
FW-9018-SS-0001	015	LAT	POS	0	0	5466	17688	5466	17688	6074	24592
		SNB	NEG			-5466	-18086	-5466	-18086	-6074	
FW-9018-SH-0001	030	Y	POS		0			0	0	0	0
		SPD	NEG	-8136				-8136	-8136	-8136	
FW-9018-HL-5009	035	Y	POS	0	0	10680	75210	10680	75210	14237	51300
		SNB	NEG			-10680	-72456	-10680	-72456	-14237	
FW-9018-HL-5004	040	LAT	POS	0	0	6107	48236	6107	48236	5600	40690
		SNB	NEG			-6107	-52932	-6107	-52932	-5600	
FW-9018-HL-5001	050	Z	POS	0	0	5703	91399	5703	91399	9899	116000
		SNB	NEG			-5703	-89530	-5703	-89530	-9899	
FW-9018-HL-5008	055	X	POS	0	0	8422	106633	8422	106633	19624	143300
		SNB	NEG			-8422	-103548	-8422	-103548	-19624	
FW-9018-SS-0006	065	Y	POS	0	0	8632	67679	8632	67679	10105	33000
		SNB	NEG			-8632	-75981	-8632	-75981	-10105	
FW-9018-SH-0002	070	Y	POS		0			0	0	0	0
		SPD	NEG	-9636				-9636	-9636	-9636	-8497
FW-9018-HL-5005	075	Y	POS		5799	1134	21131	6933	26930	4064	20525
		RIGID	NEG	-5341	-1213	-1134	-23795	-7688	-30349	-5000	
FW-9018-SS-0007	085	LAT	POS	0	0	3198	65625	3198	65625	12265	101500
		SNB	NEG			-3198	-56691	-3198	-56691	-12265	
FW-9018-HL-5002	094	Y	POS		607	1077	25549	1584	26056	0	48026
		RIGID	NEG	-8361	-5402	-1077	-23100	-14830	-36853	-17149	
FW-9018-HL-5003	092	LAT	POS	0	0	1833	52338	1833	52338	4421	64660
		SNB	NEG			-1833	-39175	-1833	-39175	-4421	
FW-9018-HL-5006	097	Z	POS	0	0	1182	33280	1182	33280	6700	104130
		SNB	NEG			-1182	-37673	-1182	-37673	-6700	
FW-9018-HL-5001	099	Y	POS		8133	605	24471	9738	33604	12774	36200
		RIGID	NEG	-6627	0	-605	-18759	-6232	-24386	-14895	
FW-9018-HL-5013	101	X+Y	POS		0	1231	87605	1231	87605	5341	178720
		RIGID	NEG	-2396	-4658	-1231	-76222	-8285	-83276	-15111	
FW-9018-HL-5012	10A	Z	POS	69	20097	330	61340	20486	81496	36227	71860
		RIGID	NEG		0	-330	-57358	-330	-57358	-18391	
FW-9018-HL-5013	101 (11A)	X-Y	POS	3894	26883	840	40055	31597	70612	65609	118800
		RIGID	NEG		0	-840	-44549	-840	-44549	-30959	
FW-1018-HL-5016	007	POS		454		8080	28144	8534	28598	20215	N/A
		RIGID	NEG	-262	-12239	-8080	-24219	-20581	-36720	-34587	N/A
FW-1018-HL-5016	07H	/-W	POS		0	7225	45957	7225	45957	8480	N/A
		RIGID	NEG	-72	-6557	-7225	-38248	-13854	-44877	-15181	N/A
FW-1018-HL-5015	07H	/-E	POS	62	0	19688	35662	19760	35624	5366	N/A
		RIGID	NEG		-13019	-19688	-29972	-32707	-42991	-18282	N/A
FW-1018-HL-5014	009	SPD	POS		0			0	0	0	N/A
		NEG	-9528					-9528	-9528	-9528	N/A

See Notes on the following sheet



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438001SUBJECT FW-PIPING FROM S.G. 1D TO PEN.# M5CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____ORIGINATOR PANI

DATE _____

DCP# 96-2843-2, SUPP. 0 page 1928 of

DCN# 9704763

Page 53 of 134

NOTES for faulted loads on EXCEL sheet:

1. The positive faulted loads (with water hammer combination & with LOCA+Jet combination) conservatively did not include dead weight. If required, dead weight can be included to reduce conservatism.
2. WT+TH+SSE*: Higher of WT+TH+SRSS(SSET & SSESAM) or WT+TH+DBA. Refer to Computer Run# S03406 Dt. 10/28/97 for pipe displacements and individual & combined loads
3. WT+TH+LOCA + JET: Refer to Computer Run# MG4946 Dt. 05/22/98 for pipe displacements and individual loads
4. WT+TH+WH : This faulted combination with Water Hammer conservatively included THRM1 thru THRM6(**). If required, the conservatism can be reduced by including only those Thermals (THRM2, or THRM3, or THRM6) which could be concurrent with Water Hammer. (ex. HL5012 node 10A) - Refer to Computer Run# 8K1703 Dt. 07/08/98 for pipe displacements and individual & combined loads.

2C159RC5037 RESTRAINT LOAD SUMMARY ME101/N4 GAZU/54 (SO3406) 10/28/97 SO3406 -PROT-

TITLE : FEEDWATER "PM" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
035	SNB	FM9018XL5009							.022	-.040	-.031
		WT1							.683	-.789	.598
		THRM1							.585	-.235	.130
		THRM2							.450	.577	-.515
		THRM3							.368	1.062	-.998
		THRM4							.696	-.863	.658
		THRM5							.561	-.076	.016
		THRM6							.314	1.381	-1.168
		THRM7							.135	.080	.151
		DBA							.047	.004	.019
		SEISA1	0.	5078.	0.	0.	0.	0.	.105	.009	.042
		SEISA2	0.	12096.	0.	0.	0.	0.	.010	.003	.005
		SAM1	0.	4532.	0.	0.	0.	0.	.018	.006	.009
		SAM2	0.	7508.	0.	0.	0.	0.			
040	SNB	FM9018XL5004							.022	-.042	-.032
		WT1							.491	-.809	.694
		THRM1							.593	-.243	.204
		THRM2							.458	.539	-.471
		THRM3							.376	1.018	-.883
		THRM4							.704	-.882	.757
		THRM5							.569	-.105	.085
		THRM6							.321	1.332	-1.156
		THRM7							.133	.081	.155
		DBA							.047	.003	.019
		SEISA1	891.	0.	2172.	0.	0.	0.	.105	.006	.042
		SEISA2	1990.	0.	4850.	0.	0.	0.	.010	.002	.006
		SAM1	458.	0.	1115.	0.	0.	0.	.017	.003	.010
		SAM2	748.	0.	1823.	0.	0.	0.			
050	SNB	FM9018XL5007							.023	-.054	-.041
		WT1							.899	-.649	1.696
		THRM1							.681	-.229	1.056
		THRM2							.380	.350	.172
		THRM3							.196	.704	-.368
		THRM4							.927	-.703	1.779
		THRM5							.628	-.128	.900
		THRM6							.075	.937	-.724
		THRM7							.143	.082	.192
		DBA							.020	.010	.003
		SEISA1	0.	0.	4187.	0.	0.	0.	.048	.024	.007
		SEISA2	0.	0.	9893.	0.	0.	0.	.003	.007	.000
		SAM1	0.	0.	207.	0.	0.	0.	.005	.012	.000
		SAM2	0.	0.	362.	0.	0.	0.			

2C159RC5037 RESTRAINT LOAD SUMMARY ME101/M4 GAEU/S4 (S03406) 10/28/97 S03406 PROG - 17

TITLE : FEEDWATER "FW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23430001
 PROBLEM NUMBER : 2C159RC5037
 USER : PANI
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
055	ENB	FW9018HL5008									
	WT1								.027	-.054	-.042
	THRM1								.963	-.564	1.779
	THRM2								.702	-.168	1.144
	THRM3								.343	.378	.268
	THRM4								.123	.712	-.267
	THRM5								.997	-.614	1.863
	THRM6								.639	-.072	.990
	THRM7								-.022	.332	-.620
	DBA								.153	-.082	.192
	SEISA1	8097.	0.	0.	0.	0.	0.	0.	.015	.010	.009
	SEISA2	13581.	0.	0.	0.	0.	0.	0.	.036	.024	.021
	SAM1	779.	0.	0.	0.	0.	0.	0.	.001	.007	.003
	SAM2	1305.	0.	0.	0.	0.	0.	0.	.002	-.012	.005
065	ENB	FW9018SS0006									
	WT1								.037	-.042	-.048
	THRM1								.945	-.355	2.168
	THRM2								.652	-.050	1.480
	THRM3								.247	.371	.532
	THRM4								.000	.629	-.047
	THRM5								.983	-.395	2.257
	THRM6								.581	.024	1.313
	THRM7								-.164	.738	-.429
	DBA								.169	.070	.217
	SEISA1	0.	3975.	0.	0.	0.	0.	0.	.022	.008	.028
	SEISA2	0.	9201.	0.	0.	0.	0.	0.	.051	.018	.063
	SAM1	0.	2523.	0.	0.	0.	0.	0.	.002	.005	.007
	SAM2	0.	4178.	0.	0.	0.	0.	0.	.003	.008	.011
085	ENB	FW9018SS0007									
	WT1								.037	-.002	-.061
	THRM1								-.136	.009	3.966
	THRM2								-.121	-.014	2.872
	THRM3								-.101	-.046	1.362
	THRM4								-.089	-.066	.440
	THRM5								-.118	-.013	4.107
	THRM6								-.118	-.020	2.606
	THRM7								-.081	-.079	-.163
	DBA								.164	.004	.442
	SEISA1	3614.	0.	3614.	0.	0.	0.	0.	.025	.013	.032
	SEISA2	8643.	0.	8643.	0.	0.	0.	0.	.058	.028	.076
	SAM1	400.	0.	600.	0.	0.	0.	0.	.002	.001	.002
	SAM2	715.	0.	715.	0.	0.	0.	0.	.004	.001	.003

DCP# 96-2843-2, STPP.0 page 1935 of _____

DCN# 9704763 page 60 of 134

2C159RCS037 RESTRAINT LOAD SUMMARY ME101/R4 GAEU/S4 (S03406) 10/26/97 S03406 PROG

TITLE : FEEDWATER "FW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RCS037
 USER : PAMI
 LOAD CASE :

DATA TYPE	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
092	SUB	FW9018NL5003									
	WT1								.694	-.014	-.043
	THRM1								-.151	.006	3.329
	THRM2								-.123	.004	3.424
	THRM3								-.084	.012	1.175
	THRM4								-.061	.014	4.412
	THRM5								-.155	.005	3.446
	THRM6								-.116	.009	2.204
	THRM7								-.045	.016	-.091
	DBA								.161	.001	.487
	SEISA1	1328.	0.	1328.	0.	0.	0.	0.	.009	.009	.007
	SEISA2	3113.	0.	3113.	0.	0.	0.	0.	.022	.020	.016
	SAM1	165.	0.	165.	0.	0.	0.	0.	.005	.001	.005
	SAM2	281.	0.	281.	0.	0.	0.	0.	.009	.001	.009
097	SUB	FW9018NL5006									
	WT1								.003	-.077	-.014
	THRM1								.135	.028	1.566
	THRM2								.992	.040	1.144
	THRM3								.033	.057	.561
	THRM4								-.004	.068	.205
	THRM5								.141	.027	1.620
	THRM6								.082	.043	1.041
	THRM7								-.028	.074	-.030
	DBA								.123	.000	.376
	SEISA1	0.	0.	2590.	0.	0.	0.	0.	.005	.047	.004
	SEISA2	0.	0.	6205.	0.	0.	0.	0.	.011	.104	.010
	SAM1	0.	0.	1409.	0.	0.	0.	0.	.008	.003	.002
	SAM2	0.	0.	2527.	0.	0.	0.	0.	.015	.005	.004

2C159RC5037 RESTRAINT LOAD SUMMARY ME101/N4 GANU/54 (S03406) 10/20/97 S03406 →

TITLE : FEEDWATER "FW" SYSTEM - SG ID TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)						DIRECTION COSINES					
			FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
001 ANC	IR121NSG101D																
WT1	-10	-1085	-54	-131	388	-11315	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
THRM1	-6913	-41	-55	30739	47918	-77030	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
THRM2	-4930	-589	-2253	37421	66147	-75231	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
THRM3	-2184	-1346	-5303	46704	91520	-72712	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
THRM4	-491	-1009	-7193	52448	107350	-71118	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
THRM5	-7162	29	218	29914	45696	-77249	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
THRM6	-4454	-722	-2778	39011	70455	-74815	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
THRM7	603	-2113	-8400	56133	117306	-70148	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
DBA	22	89	228	853	1660	661	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
SEISA1	1479	4219	1388	7172	22542	55323	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
SEISA2	3449	9955	3359	16638	54438	131131	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
SAM1	3660	2117	6502	22904	81615	17257	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
SAM2	5965	3506	10561	37097	132510	29121	.87	.00	.48	.00	1.00	.00	-.48	.00	.87		
007 RAD	NLS016																
WT1	-262	0	0	0	0	0	0	.85	.00	-.53							
THRM1	-11							0	.85	.00	-.53						
THRM2	-3772							0	.85	.00	-.53						
THRM3	-8956							0	.85	.00	-.53						
THRM4	-12239							0	.85	.00	-.53						
THRM5	454							0	.85	.00	-.53						
THRM6	-4568							0	.85	.00	-.53						
THRM7	-14302							0	.85	.00	-.53						
DBA	1181							0	.85	.00	-.53						
SEISA1	1770							0	.85	.00	-.53						
SEISA2	4051							0	.85	.00	-.53						
SAM1	12060							0	.85	.00	-.53						
SAM2	19809							0	.85	.00	-.53						
07H RAD	NLS015																
WT1	-72	0	0	0	0	0	0	0	-.71	.00	.71						
THRM1	-6523	0	0	0	0	0	0	0	-.71	.00	.71						
THRM2	-3222							0	-.71	.00	.71						
THRM3	-6058							0	-.71	.00	.71						
THRM4	-5916							0	-.71	.00	.71						
THRM5	-6557							0	-.71	.00	.71						
THRM6	-6266							0	-.71	.00	.71						
THRM7	-5793							0	-.71	.00	.71						
DBA	1847							0	-.71	.00	.71						
SEISA1	2407							0	-.71	.00	.71						
SEISA2	5331							0	-.71	.00	.71						
SAM1	4108							0	-.71	.00	.71						
SAM2	6688							0	-.71	.00	.71						

DCP

DCN# 9704763 page 62 of 134

3C159RC5037 RESTRAINT LOAD SUMMARY ME101/N4 GAEU/S4 (S03406) 10/28/97 S03406 PAGE →
 TITLE : FEEDWATER "FW" SYSTEM - SG ID TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD RAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
			FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
07H RAD		HLS015															
	WT1	62	0	0	0	0	0	0	0	-71	00	-71					
	THRM1	-12754	0	0	0	0	0	0	0	-71	00	-71					
	THRM2	-10711	0	0	0	0	0	0	0	-71	00	-71					
	THRM3	-7893	0	0	0	0	0	0	0	-71	00	-71					
	THRM4	-6175	0	0	0	0	0	0	0	-71	00	-71					
	THRM5	-13019	0	0	0	0	0	0	0	-71	00	-71					
	THRM6	-10213	0	0	0	0	0	0	0	-71	00	-71					
	THRM7	-5037	0	0	0	0	0	0	0	-71	00	-71					
	DBA	842	0	0	0	0	0	0	0	-71	00	-71					
	SEISA1	1908	0	0	0	0	0	0	0	-71	00	-71					
	SEISA2	4429	0	0	0	0	0	0	0	-71	00	-71					
	SAM1	1827	0	0	0	0	0	0	0	-71	00	-71					
	SAM2	2955	0	0	0	0	0	0	0	-71	00	-71					
009 SPD		HLS014							0	00	1.00	00					
	WT1	-9528	0	0	0	0	0	0	0	00	1.00	00					
	THRM1																
	THRM2																
	THRM3																
	THRM4																
	THRM5																
	THRM6																
	THRM7																
	DBA																
	SEISA1																
	SEISA2																
	SAM1																
	SAM2																
030 SFR		FW9018SH0001															
	WT1	-8136	1	0	0	0	0	0	0	00	1.00	00					
	THRM1	1	0	0	0	0	0	0	0	00	1.00	00					
	THRM2	1	0	0	0	0	0	0	0	00	1.00	00					
	THRM3	1	0	0	0	0	0	0	0	00	1.00	00					
	THRM4	1	0	0	0	0	0	0	0	00	1.00	00					
	THRM5	1	0	0	0	0	0	0	0	00	1.00	00					
	THRM6	1	0	0	0	0	0	0	0	00	1.00	00					
	THRM7	2	0	0	0	0	0	0	0	00	1.00	00					
	DBA	0	0	0	0	0	0	0	0	00	1.00	00					
	SEISA1	0	0	0	0	0	0	0	0	00	1.00	00					
	SEISA2	0	0	0	0	0	0	0	0	00	1.00	00					
	SAM1	0	0	0	0	0	0	0	0	00	1.00	00					
	SAM2	0	0	0	0	0	0	0	0	00	1.00	00					

DCFM#96-2843-2, SUPP. 0 page 136 of 136

DCN#9704763 page 63 of 134

2C159RC5037

RESTRAINT LOAD SUMMARY

ME101/H4 GAEU/S4

(S03406) 10/28/97 S03406 PAGE 31

TITLE : FEEDWATER "FW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PANI
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
			FA	FB	FC	MA	MB	MC	COS AX	COS AT	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
070 SPR	FW9018SH0002	WT1 -4636 1/18 THR1 2/20/98	0	0	0	0	0	0	0 .00	1.00	.00						
	THR2		0	0	0	0	0	0	0 .00	1.00	.00						
	THR3		0	0	0	0	0	0	0 .00	1.00	.00						
	THR4		0	0	0	0	0	0	0 .00	1.00	.00						
	THR5		0	0	0	0	0	0	0 .00	1.00	.00						
	THR6		0	0	0	0	0	0	0 .00	1.00	.00						
	THR7		0	0	0	0	0	0	0 .00	1.00	.00						
	DBA		0	0	0	0	0	0	0 .00	1.00	.00						
	SEISA1		0	0	0	0	0	0	0 .00	1.00	.00						
	SEISA2		0	0	0	0	0	0	0 .00	1.00	.00						
	SAM1		0	0	0	0	0	0	0 .00	1.00	.00						
	SAM2		0	0	0	0	0	0	0 .00	1.00	.00						
075 RAD	FW9018HL5005	WT1 -3341 THR1 -944 THR2 1146 THR3 4033 THR4 5799 THR5 -1213 THR6 1653 THR7 6960 DBA 315 SEISA1 1192 SEISA2 2437 SAM1 123 SAM2 203	0	0	0	0	0	0	0 .00	1.00	.00						
094 RAD	FW9018HL5002	WT1 -8351 THR1 280 THR2 -1481 THR3 -3914 THR4 -5402 THR5 507 THR6 -1909 THR7 -6381 DBA 243 SEISA1 1140 SEISA2 2416 SAM1 54 SAM2 90	0	0	0	0	0	0	0 .00	1.00	.00						

DCFM 96-2843-2, SUPP. 0 page 1939 of _____

DCN# 9704763 page 64 of 134

2C159RC5037

RESTRAINT LOAD SUMMARY

ME101/E4 GAEU/54

(803406) 10/28/97 SO3406 TRG05

TITLE : FEDWATER "FW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PANI
 LOAD CASE :

DATA TYPE PT	LOAD RAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)						DIRECTION COSINES					
			FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
099	RAD	FW1018HL5001	WT1	-5627	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
			THRM1	1966	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
			THRM2	2673	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
			THRM3	5888	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
			THRM4	4799	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
			THRM5	9133	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
			THRM6	7358	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
			THRM7	4077	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
			DBA	9268	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
			SEISA1	1843	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
			SEISA2	4101	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
			SAM1	164	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
			SAM2	282	0	0	0	0	0	0.00	1.00	0.00	0	0	0	0	0
101	RAD	FW9018HL5013	WT1	-2396	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
			THRM1	-2806	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
			THRM2	-3381	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
			THRM3	-4174	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
			THRM4	-4658	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
			THRM5	-2732	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
			THRM6	-3521	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
			THRM7	-4978	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
			DBA	6607	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
			SEISA1	2348	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
			SEISA2	5654	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
			SAM1	2965	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
			SAM2	5282	0	0	0	0	0	0.89	.46	.00	0	0	0	0	0
11A	RAD	FW9018HL5013	WT1	3894	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0
			THRM1	26186	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0
			THRM2	20941	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0
			THRM3	13702	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0
			THRM4	9281	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0
			THRM5	26963	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0
			THRM6	19665	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0
			THRM7	6364	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0
			DBA	34852	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0
			SEISA1	1522	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0
			SEISA2	3629	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0
			SAM1	2531	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0
			SAM2	4529	0	0	0	0	0	0.81	-.59	.00	0	0	0	0	0

DCN# 962843-2 SUPP. 0 page 1940 of 1

DCN# 9704763 page 65 of 134

2C159RC5037

RESTRAINT LOAD SUMMARY

ME101/M4 CABO/S4

(S03406) 10/28/97 S03406 TRUE

TITLE : FEDDOWATER "FW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PANI
 LOAD CASE :

DATA TYPE PT	LOAD RAD	TITLE FW9018HL5012	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
			FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
10A	RAD	WT1	59	0	0	0	0	0	0	0.00	0.00	1.00					
		THRM1	19355	0	0	0	0	0	0.00	0.00	1.00						
		THRM2	13604	0	0	0	0	0	0.00	0.00	1.00						
		THRM3	5667	0	0	0	0	0	0.00	0.00	1.00						
		THRM4	819	0	0	0	0	0	0.00	0.00	1.00						
		THRM5	20097	0	0	0	0	0	0.00	0.00	1.00						
		THRM6	12205	0	0	0	0	0	0.00	0.00	1.00						
		THRM7	-3379	0	0	0	0	0	0.00	0.00	1.00						
		DBA	806	0	0	0	0	0	0.00	0.00	1.00						
		SEISA1	1503	0	0	0	0	0	0.00	0.00	1.00						
		SEISA2	3140	0	0	0	0	0	0.00	0.00	1.00						
		SAM1	2190	0	0	0	0	0	0.00	0.00	1.00						
		SAM2	15761	0	0	0	0	0	0.00	0.00	1.00						
110	ANC	PEN M-5	WT1	-827	-3080	-52	-8789	-10	-22590	1.00	.00	.00	1.00	.00	.00	.00	1.00
			THRM1	-25296	8424	-20367	-7726	-13245	68232	1.00	.00	.00	1.00	.00	.00	.00	1.00
			THRM2	-19567	7118	-14346	-5822	-13340	59133	1.00	.00	.00	1.00	.00	.00	.00	1.00
			THRM3	-30277	5315	-6035	-3182	-13609	48239	1.00	.00	.00	1.00	.00	.00	.00	1.00
			THRM4	-1603	4214	-959	-1570	-13773	41156	1.00	.00	.00	1.00	.00	.00	.00	1.00
			THRM5	-27165	8593	-21144	-7982	-13320	69315	1.00	.00	.00	1.00	.00	.00	.00	1.00
			THRM6	-37930	6800	-12881	-5356	-13337	57790	1.00	.00	.00	1.00	.00	.00	.00	1.00
			THRM7	-861	3487	2389	-506	-13882	36486	1.00	.00	.00	1.00	.00	.00	.00	1.00
			DBA	21341	14280	5511	32563	95328	112846	1.00	.00	.00	1.00	.00	.00	.00	1.00
			SEISA1	1001	350	169	5081	1581	7366	1.00	.00	.00	1.00	.00	.00	.00	1.00
			SEISA2	2408	762	414	11223	3305	16297	1.00	.00	.00	1.00	.00	.00	.00	1.00
			SAM1	4266	242	9148	724	46224	2351	1.00	.00	.00	1.00	.00	.00	.00	1.00
			SAM2	7617	423	15704	1254	79280	3949	1.00	.00	.00	1.00	.00	.00	.00	1.00
015	SNE	FW9018SS0001	WT1														
			THRM1														
			THRM2														
			THRM3														
			THRM4														
			THRM5														
			THRM6														
			THRM7														
			DBA														
			SEISA1	2364	0	0	0	0	0	0.38	0.00	.93					
			SEISA2	5497	0	0	0	0	0	0.38	0.00	.93					
			SAM1	1590	0	0	0	0	0	0.38	0.00	.93					
			SAM2	2382	0	0	0	0	0	0.38	0.00	.93					

DCP#962843-2, SUPP.0 page 141 of

DCN#9704763 page 66 of 134

2C159RC5037 RESTRAINT LOAD SUMMARY ME101/X6 QAKU/S6 (S03406) 10/28/97 S03406 TRNG - 74

TITLE : FEEDWATER "FW" SYSTEM - SG ID TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PANI
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES (LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
			FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
035	SNB	FW9018HL5003															
		WT1															
		TERM1															
		TERM2															
		TERM3															
		TERM4															
		TERM5															
		TERM6															
		TERM7															
		DBA															
		SEISA1	5078	0	0	0	0	0	0	0.00	1.00	.00					
		SEISA2	12096	0	0	0	0	0	0	0.00	1.00	.00					
		SAM1	4512	0	0	0	0	0	0	0.00	1.00	.00					
		SAM2	7508	0	0	0	0	0	0	0.00	1.00	.00					
040	SND	FW9018HL5004															
		WT1															
		TERM1															
		TERM2															
		TERM3															
		TERM4															
		TERM5															
		TERM6															
		TERM7															
		DBA															
		SEISA1	2348	0	0	0	0	0	0	.38	.00	.93					
		SEISA2	5242	0	0	0	0	0	0	.38	.00	.93					
		SAM1	1206	0	0	0	0	0	0	.38	.00	.93					
		SAM2	1970	0	0	0	0	0	0	.38	.00	.93					
050	SNB	FW9018HL5007															
		WT1															
		TERM1															
		TERM2															
		TERM3															
		TERM4															
		TERM5															
		TERM6															
		TERM7															
		DBA															
		SEISA1	4187	0	0	0	0	0	0	0.00	0.00	1.00					
		SEISA2	9893	0	0	0	0	0	0	0.00	0.00	1.00					
		SAM1	207	0	0	0	0	0	0	0.00	0.00	1.00					
		SAM2	362	0	0	0	0	0	0	0.00	0.00	1.00					

2C159RC5037

RESTRAINT LOAD SUMMARY

TITLE : FEDWATERX "PM" SYSTEM - SD 1D TO NS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PANI
 LOAD CASE :

ME101/H4 GA20/54 (S03406) 10/26/97 803406 PH00000000

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)						DIRECTION COSINES					
			XA	YA	ZA	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
055	SNB	FH9018550006															
		WT1															
		THRM1															
		THRM2															
		THRM3															
		THRM4															
		THRM5															
		THRM6															
		THRM7															
		DBA															
		SEISA1	8097	0	0	0	0	0	0	1.00	.00	.00					
		SEISA2	19581	0	0	0	0	0	0	1.00	.00	.00					
		SAM1	777	0	0	0	0	0	0	1.00	.00	.00					
		SAM2	1305	0	0	0	0	0	0	1.00	.00	.00					
065	SNB	FH9018550006															
		WT1															
		THRM1															
		THRM2															
		THRM3															
		THRM4															
		THRM5															
		THRM6															
		THRM7															
		DBA															
		SEISA1	3975	0	0	0	0	0	0	0	0	1.00	.00	.00			
		SEISA2	9201	0	0	0	0	0	0	0	0	0	1.00	.00	.00		
		SAM1	2523	0	0	0	0	0	0	0	0	0	0	1.00	.00	.00	
		SAM2	4178	0	0	0	0	0	0	0	0	0	0	0	1.00	.00	.00
085	SNB	FH9018550007															
		WT1															
		THRM1															
		THRM2															
		THRM3															
		THRM4															
		THRM5															
		THRM6															
		THRM7															
		DBA															
		SEISA1	5121	0	0	0	0	0	0	0	0	0	0	0	0	0	0
		SEISA2	12223	0	0	0	0	0	0	0	0	0	0	0	0	0	0
		SAM1	566	0	0	0	0	0	0	0	0	0	0	0	0	0	0
		SAM2	1011	0	0	0	0	0	0	0	0	0	0	0	0	0	0

DCN# 96-2843-2, SUPP. 0 page 143 of 1DCN# 9704763 page 68 of 134

2C159RC5037

RESTRAINT LOAD SUMMARY

ME101/N4 GAZU/S4

(803406) 10/28/97 SO3406 PROG

TITLE : FEEDWATER "FW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
			PA	PB	PC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
092 SNB	FW9018HL5003																
	WT1																
	THRM1																
	THRM2																
	THRM3																
	THRM4																
	THRM5																
	THRM6																
	THRM7																
	DBA																
	SEISA1	1879	0	0	0	0	0	0	0	-.71	.00	.71					
	SEISA2	4403	0	0	0	0	0	0	0	-.71	.00	.71					
	SAM1	233	0	0	0	0	0	0	0	-.71	.00	.71					
	SAM2	397	0	0	0	0	0	0	0	-.71	.00	.71					
097 SNB	FW9018HL5006																
	WT1																
	THRM1																
	THRM2																
	THRM3																
	THRM4																
	THRM5																
	THRM6																
	THRM7																
	DBA																
	SEISA1	2590	0	0	0	0	0	0	0	.00	.00	1.00					
	SEISA2	6205	0	0	0	0	0	0	0	.00	.00	1.00					
	SAM1	1403	0	0	0	0	0	0	0	.00	.00	1.00					
	SAM2	2527	0	0	0	0	0	0	0	.00	.00	1.00					

2C159RC5037 RESTRAINT LOAD SUMMARY

ME101/M4 GABU/54 (S03406) 10/28/97 S03406 PROG

TITLE : FEEDWATER "FW" SYSTEM - SG ID TO M5
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : FAMI
 LOAD CASE :

DATA TYPE PT	LOAD TITLE	FX	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
			PY	PZ	MX	MY	MZ	DX	DY	DZ	
001 ANC	IR121NSC101D										
	NORMP	3513.	0.	0.	88720.	107734.	25417.	.812	.980	1.993	
	NORMN	-6054.	-2894.	-9694.	-115.	0.	-77331.	.000	.000	.000	
	UPSETP	11293.	4720.	8016.	140898.	203366.	89472.	1.131	1.995	2.226	
	UPSETN	-12730.	-7918.	-18478.	-49202.	-84671.	-139653.	-.299	.015	-.333	
	FAULTP	16017.	9499.	13465.	192594.	260951.	154469.	1.320	2.011	2.430	
	FAULTN	-17751.	-13753.	-23904.	-95312.	-142068.	-214710.	-.488	-.031	-.537	
007 RAD	RL5016										
	NORMP	0.	0.	6624.	0.	0.	0.	.680	1.862	1.089	
	NORMN	-10601.	0.	0.	0.	0.	0.	-.001	-.001	-.001	
	UPSETP	10337.	0.	14178.	0.	0.	0.	.773	1.997	1.236	
	UPSETN	-21688.	0.	-6460.	0.	0.	0.	-.094	-.061	-.148	
	FAULTP	17163.	0.	18329.	0.	0.	0.	.642	2.051	1.342	
	FAULTN	-29331.	0.	-10712.	0.	0.	0.	-.159	-.115	-.250	
07H RAD	RL5015										
	NORMP	4664.	0.	0.	0.	0.	0.	.007	1.793	.001	
	NORMN	0.	0.	-4664.	0.	0.	0.	.000	.000	-.001	
	UPSETP	8031.	0.	3367.	0.	0.	0.	.010	2.035	.003	
	UPSETN	-3167.	0.	-8031.	0.	0.	0.	-.003	-.061	-.004	
	FAULTP	10735.	0.	5996.	0.	0.	0.	.012	2.089	.005	
	FAULTN	-3996.	0.	-10735.	0.	0.	0.	-.005	-.114	-.006	
07H RAD	RL5015										
	NORMP	9019.	0.	9019.	0.	0.	0.	.007	1.792	.001	
	NORMN	-44.	0.	-44.	0.	0.	0.	.000	.000	-.001	
	UPSETP	10443.	0.	10843.	0.	0.	0.	.010	2.035	.003	
	UPSETN	-1911.	0.	-1911.	0.	0.	0.	-.003	-.061	-.004	
	FAULTP	12927.	0.	12927.	0.	0.	0.	.012	2.089	.005	
	FAULTN	-3808.	0.	-3808.	0.	0.	0.	-.005	-.114	-.006	
009 SPD	RL5014										
	NORMP	0.	-9528.	0.	0.	0.	0.	.005	1.772	.000	
	NORMN	0.	-9528.	0.	0.	0.	0.	-.163	.000	-.420	
	UPSETP	0.	-9528.	0.	0.	0.	0.	.045	2.053	.047	
	UPSETN	0.	-9528.	0.	0.	0.	0.	-.214	-.060	-.467	
	FAULTP	0.	-9528.	0.	0.	0.	0.	.085	2.105	.087	
	FAULTN	0.	-9528.	0.	0.	0.	0.	-.254	-.114	-.509	
030 SPR	FW9018SH0001										
	NORMP	0.	-8136.	0.	0.	0.	0.	.652	1.359	.000	
	NORMN	0.	-8136.	0.	0.	0.	0.	.000	-.656	-.1098	
	UPSETP	0.	-8136.	0.	0.	0.	0.	.700	1.707	.020	
	UPSETN	0.	-8136.	0.	0.	0.	0.	-.048	-.688	-.1294	
	FAULTP	0.	-8136.	0.	0.	0.	0.	.812	1.744	.097	
	FAULTN	0.	-8136.	0.	0.	0.	0.	-.122	-.803	-.1395	

2C159RC5037 RESTRAINT LOAD SUMMARY ME101/N4 GAEU/54 (803406) 10/28/97 803406 FRCT

TITLE : FEEDWATER "FW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
070 SPR	FM9018SH0002		0.	1.	0.	0.	0.	0.	.887	.551	.171
	NORMP		0.	-9636	1.	0.	0.	0.	-.009	-.336	-.050
	NORMN		0.			0.	0.	0.	.908	.674	2.355
	UPSETP		0.	1.	0.	0.	0.	0.	-.142	-.345	-.487
	UPSETN		0.	-9636	1.	0.	0.	0.	1.090	.726	2.653
	FAULTP		0.			0.	0.	0.	-.289	-.430	-.690
	FAULTN		0.	-9636	1.	0.	0.	0.			
075 RAD	FM9018HL5005		0.	5799.	0.	0.	0.	0.	.050	.007	3.754
	NORMP		0.	-6285.	0.	0.	0.	0.	-.084	-.007	-.061
	NORMN		0.			0.	0.	0.	.073	.003	3.736
	UPSETP		0.	2817.	0.	0.	0.	0.	-.086	-.009	-.305
	UPSETN		0.	-7484.	0.	0.	0.	0.	.223	.005	4.241
	FAULTP		0.	4064.	0.	0.	0.	0.	-.232	-.010	-.674
	FAULTN		0.	-3600.	0.	0.	0.	0.			
094 RAD	FM9018HL5002		0.	280.	0.	0.	0.	0.	.027	.000	3.456
	NORMP		0.	-13753.	0.	0.	0.	0.	-.189	-.011	-.045
	NORMN		0.			0.	0.	0.	.040	.001	3.419
	UPSETP		0.	1142.	0.	0.	0.	0.	-.175	-.012	-.150
	UPSETN		0.	-15873.	0.	0.	0.	0.	.187	.000	4.019
	FAULTP		0.	0.	0.	0.	0.	0.	-.327	-.013	-.629
	FAULTN		0.	-17149.	0.	0.	0.	0.			
099 RAD	FM1018HL5001		0.	8966.	0.	0.	0.	0.	.003	.017	.908
	NORMP		0.	-5627.	0.	0.	0.	0.	-.163	-.011	-.004
	NORMN		0.			0.	0.	0.	.012	.010	.915
	UPSETP		0.	5189.	0.	0.	0.	0.	-.170	-.014	-.037
	UPSETN		0.	-7477.	0.	0.	0.	0.	.126	.024	1.159
	FAULTP		0.	12774.	0.	0.	0.	0.	-.289	-.028	-.250
	FAULTN		0.	-14895.	0.	0.	0.	0.			
101 RAD	FM9018HL5013		0.	0.	0.	0.	0.	0.	.001	.031	.414
	NORMP		0.	-6261.	0.	0.	0.	0.	-.017	-.007	-.000
	NORMN		0.	-3251.	0.	0.	0.	0.	.006	.031	.424
	UPSETP		0.	3156.	0.	0.	0.	0.	-.018	-.016	-.022
	UPSETN		0.	-9300.	0.	0.	0.	0.	.009	.038	.538
	FAULTP		0.	4740.	0.	0.	0.	0.	-.022	-.021	-.121
	FAULTN		0.	-13411.	0.	0.	0.	0.			
11A RAD	FM9018HL5013		24334.	0.	0.	0.	0.	0.	.064	.033	.378
	NORMP		0.	-17681.	0.	0.	0.	0.	.000	-.010	.000
	NORMN		0.			0.	0.	0.	.069	.027	.389
	UPSETP		26724.	0.	0.	0.	0.	0.	-.005	-.018	-.020
	UPSETN		-2389.	-19417.	0.	0.	0.	0.	.107	.045	.501
	FAULTP		53078.	18198.	0.	0.	0.	0.	-.060	-.035	-.218
	FAULTN		-25046.	-38565.	0.	0.	0.	0.			

2C159RC5037 RESTRAINT LOAD SUMMARY NE101/H4 GAEU/S4 (803406) 10/28/97 303406 0400-33

TITLE : FEDDWATER "FW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAKI
 LOAD CASE :

DATA PT	TYPE	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES									
				FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ	
10A RAD			FW9018HL5012	NORMP NORMN UPSETP UPSETN FAULTP FAULTN	19414 0 28725 -11632 36227 -18391	0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0 0	0 .00 0 .00 0 .00 0 .00 0 .00 0 .00	0 .00 0 .00 0 .00 0 .00 0 .00 0 .00	0 1.00 0 1.00 0 1.00 0 1.00 0 1.00 0 1.00								
310 ANC			FW M-5	NORMP NORMN UPSETP UPSETN FAULTP FAULTN	0 -27123 4381 -31505 20514 -49332	8424 -3080 5770 -3505 19793 -17360	0 -20418 11487 -29568 18047 -36905	0 -16523 5132 -21656 23775 -49334	0 -13783 46251 -60142 95318 -109220	68232 -22590 53346 -30292 159571 -135435	1.00 1.00 1.00 1.00 1.00 1.00	.00 .00 .00 .00 .00 .00	.00 .00 .00 .00 .00 .00	1.00 1.00 1.00 1.00 1.00 1.00	.00 .00 .00 .00 .00 .00	.00 .00 .00 .00 .00 .00	.00 .00 .00 .00 .00 .00	.00 .00 .00 .00 .00 .00	1.00 1.00 1.00 1.00 1.00 1.00
015 SWB			FW9018SS0001	NORMP NORMN UPSETP UPSETN FAULTP FAULTN	2849 -2849 6074 -6074	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 .38 0 .38 0 .38 0 .38	0 .00 0 .00 0 .00 0 .00	0 .93 .93 .93 .93							
035 SWB			FW9018HL5009	NORMP NORMN UPSETP UPSETN FAULTP FAULTN	6806 -6806 14237 -14237	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 .00 0 .00 0 .00 0 .00	1.00 1.00 3.00 1.00								
040 SWB			FW9018HL5004	NORMP NORMN UPSETP UPSETN FAULTP FAULTN	2639 -2639 5600 -5600	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 .38 0 .38 0 .38 0 .38	0 .00 0 .00 0 .00 0 .00	0 .93 .93 .93 .93							
050 SWB			FW9018HL5007	NORMP NORMN UPSETP UPSETN FAULTP FAULTN	4192 -4192 3899 -3899	0 0 0 0	0 0 0 0	0 0 0 0	0 0 0 0	0 .00 0 .00 0 .00 0 .00	0 .00 0 .00 0 .00 0 .00	0 1.00 0 1.00 0 1.00 0 1.00							

DCP# 96-2843-2, SUPP. 0 page 1951 of _____

DCN# 9704763 page 76 of 134

2C159RC5037 RESTRAINT LOAD SUMMARY ME101/M4 GAZU/54 (S03406) 10/28/97 S03406 SN000 24

TITLE : FEEDWATER "PWN" SYSTEM - SG 1D TO MS
PROJECT NUMBER : 23438001
PROBLEM NUMBER : 2C159RC5037
USER : PANI
LOAD CASE :

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)						DIRECTION COSINES					
			PA	PB	PC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
055	SNB	PW9018HL5008	NORMP						0 1.00	.00	.00						
			NORMH						0 1.00	.00	.00						
			UPSETP	8134	0	0	0	0	0 1.00	.00	.00						
			UPSETM	-8134	0	0	0	0	0 1.00	.00	.00						
			FAULTP	19624	0	0	0	0	0 1.00	.00	.00						
			FAULTM	-19624	0	0	0	0	0 1.00	.00	.00						
065	SNB	PW9018SS0006	NORMP														
			NORMH														
			UPSETP	4708	0	0	0	0	0 0.00	1.00	.00						
			UPSETM	-4708	0	0	0	0	0 0.00	1.00	.00						
			FAULTP	10105	0	0	0	0	0 0.00	1.00	.00						
			FAULTM	-10105	0	0	0	0	0 0.00	1.00	.00						
085	SNB	PW9018SS0007	NORMP														
			NORMH														
			UPSETP	5143	0	0	0	0	0 -0.71	.00	.71						
			UPSETM	-5143	0	0	0	0	0 -0.71	.00	.71						
			FAULTP	12265	0	0	0	0	0 -0.71	.00	.71						
			FAULTM	-12265	0	0	0	0	0 -0.71	.00	.71						
092	SNB	PW9018HL5003	NORMP														
			NORMH														
			UPSETP	1893	0	0	0	0	0 -0.71	.00	.71						
			UPSETM	-1893	0	0	0	0	0 -0.71	.00	.71						
			FAULTP	4421	0	0	0	0	0 -0.71	.00	.71						
			FAULTM	-4421	0	0	0	0	0 -0.71	.00	.71						
097	SNB	PW9018HL5006	NORMP														
			NORMH														
			UPSETP	2948	0	0	0	0	0 0.00	.00	1.00						
			UPSETM	-2948	0	0	0	0	0 0.00	.00	1.00						
			FAULTP	6700	0	0	0	0	0 0.00	.00	1.00						
			FAULTM	-6700	0	0	0	0	0 0.00	.00	1.00						
ME101LC	VERSION N4	STOP ON 10/28/97 AT 15:38:11,	CPU- 878053091														
ME101LC	VERSION N4	EXECUTION TIME	CPU- 55														
ME101SA	VERSION N4	START ON 10/28/97 AT 15:38:12,	CPU- 878053092														

DCP# 96-2843-2, SUPP. O page 1952 of 1

DCN# 9704763 page 77 of 134

2C159RC5037 TIME1 ACTIONS ON SUPPORTS & ANCHORS

ME101/M4 GARE/54 (8K1703) 07/08/98 8K1703 PAGE 1

TITLE : FEEDWATER "FW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE : TIME1

DATA PT	TYPE	LOCAL FORCES (LB)				LOCAL MOMENTS (FT-LB)					
		FA MAX/ MIN	FA TIME	FE MAX/ MIN	FE TIME	FC MAX/ MIN	FC TIME	MA MAX/ MIN	MA TIME	MB MAX/ MIN	MB TIME
001	ANA	26978. -34979.	.362 .361	0. 0.	.000 .000	0. 0.	.000 .000	154610. -157861.	.270 .369	0. 0.	.000 .000
001	ANB	0. 0.	.000 .000	82362. -80512.	.270 .370	0. 0.	.000 .000	0. 0.	.000 .000	240021. -269181.	.100 .261
001	ANC	0. 0.	.000 .000	0. 0.	.000 .000	24208. -20950.	.261 .100	0. 0.	.000 .000	0. 0.	.000 .000
007	RAD	28144. -24219.	.425 .325	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000
07H	RAD	45957. -38248.	.352 .450	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000
07H	RAD	35562. -29972.	.351 .446	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000
015	SNB	17688. -18086.	.321 .160	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000
030	SPR	0. 0.	.238 .386	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000
035	SNB	75210. -72456.	.265 .383	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000
040	SNB	48236. -52932.	.477 .506	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000
050	SNB	91399. -89530.	.504 .474	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000
055	SNB	108633. -103548.	.442 .343	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000
065	SNB	67679. -75981.	.385 .285	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000	0. 0.	.000 .000

DCN# 96-2443-2, SUPP.0 page 1953 of 1DCN# 9704763 page 78 of 134

2C159RC6937 TIME1 ACTIONS ON SUPPORTS & ANCHORS ME101/W4 GAEU/84 (8K1703) 07/08/98 8K1703 PAGE 2

LOCAL FORCES (LB)												LOCAL MOMENTS (FT-LB)											
DATA PT	TYPE	FA	FB	FC	MA	MB	MC	PT	TYPE	FA	FB	FC	MA	MB	MC								
		MAX/ MIN	MAX/ MIN	MAX/ MIN	MAX/ MIN	MAX/ MIN	MAX/ MIN			MAX/ MIN	MAX/ MIN	MAX/ MIN	MAX/ MIN	MAX/ MIN	MAX/ MIN								
070	SPR	0.	.568	0.	.000	0.	.000	0.	SPR	0.	.286	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000
075	RAD	21131.	.444	0.	.000	0.	.000	-23795.	RAD	.544	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	
085	SNB	65625.	.256	0.	.000	0.	.000	-66691.	SNB	.288	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	
094	RAD	28549.	.542	0.	.000	0.	.000	-23100.	RAD	.510	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	
092	SNB	52238.	.401	0.	.000	0.	.000	-39175.	SNB	.507	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	
097	SNB	33280.	.238	0.	.000	0.	.000	-37673.	SNB	.384	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	
099	RAD	24471.	.328	0.	.000	0.	.000	-18759.	RAD	.503	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	
101	RAD	87605.	.227	0.	.000	0.	.000	-76222.	RAD	.325	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	
11A	RAD	40055.	.353	0.	.000	0.	.000	-44549.	RAD	.327	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	
10A	RAD	61340.	.426	0.	.000	0.	.000	-57358.	RAD	.447	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	0.	.000	
110	ANA	271747.	.216	0.	.000	0.	.000	-101197.	ANA	.011	0.	.000	0.	.000	25034.	.546	0.	.000	0.	.000	0.	.000	
110	ANB	0.	.000	7633.	.084	0.	.000	0.	ANB	0.	.000	-7862.	.099	0.	.000	-36556.	.377	0.	.000	62312.	.241	0.	.000
110	ANC	0.	.000	0.	.000	16120.	.237	-20442.	ANC	0.	.000	-20442.	.324	0.	.000	0.	.000	-64210.	.426	0.	.000	63793.	.450

DCP# 96-2843-2, SUPP.0 page 1954 of _____

DCN# 9704763 page 79 of 134

ZC159RC5037 RESTRAINT LOAD SUMMARY ME101/M4 GAZU/S4 (8K1703) 07/08/98 8K1703 PAGE 1

TITLE : FEEDWATER "Y" SYSTEM - SG 1D TO M5
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : ZC159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
		FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
001 ANC 1R121M5G101D										
WT1	18.	-1085.	.52.	6371.	188.	-4960.	.000	.000	.000	.000
THRM2	-3220.	-509.	-4361.	69202.	66147.	-47656.	.832	1.980	1.893	
THRM3	661.	-1346.	-5697.	76100.	91520.	-40953.	.832	1.980	1.893	
THRM6	-2176.	-796.	-4715.	71052.	72870.	-43385.	.832	1.980	1.893	
TIMEL	42330.	82262.	38131.	665173.	269181.	991372.	.000	.000	.000	
FAULTP	44918.	81176.	38079.	727864.	361089.	1004055.	.832	1.980	1.893	
FAULTN	-46524.	-84692.	-45211.	-639802.	-268792.	-1067130.	.000	.000	.000	
007 RAD XL5016										
WT1	-222.	0.	139.	0.	0.	0.	-.001	-.001	-.001	
THRM2	-3199.	0.	1999.	0.	0.	0.	.649	1.454	1.048	
THRM3	-7629.	0.	4767.	0.	0.	0.	.605	1.694	.992	
THRM6	-4382.	0.	2738.	0.	0.	0.	.637	1.519	1.033	
TIMEL	23867.	0.	16914.	0.	0.	0.	.169	.553	.281	
FAULTP	23645.	0.	19821.	0.	0.	0.	.817	2.246	1.328	
FAULTN	-31719.	0.	-14776.	0.	0.	0.	-.170	-.554	-.281	
07H RAD XL5015										
WT1	51.	0.	-.51.	0.	0.	0.	.000	.000	.000	
THRM2	4471.	0.	-4471.	0.	0.	0.	.006	1.055	.000	
THRM3	4283.	0.	-4283.	0.	0.	0.	.005	1.512	-.001	
THRM6	4421.	0.	-4421.	0.	0.	0.	.006	1.179	.000	
TIMEL	32497.	0.	32497.	0.	0.	0.	.033	.554	.013	
FAULTP	32677.	0.	32677.	0.	0.	0.	.039	2.066	.013	
FAULTN	-32465.	0.	-37018.	0.	0.	0.	-.033	-.555	-.014	
07H RAD XL5015										
WT1	-44.	0.	-.44.	0.	0.	0.	.000	.000	.000	
THRM2	7574.	0.	7574.	0.	0.	0.	.006	2.055	.000	
THRM3	5581.	0.	5581.	0.	0.	0.	.005	1.512	-.001	
THRM6	7028.	0.	7028.	0.	0.	0.	.006	1.179	.000	
TIMEL	25146.	0.	25146.	0.	0.	0.	.033	.554	.013	
FAULTP	32677.	0.	32677.	0.	0.	0.	.039	2.066	.013	
FAULTN	-25190.	0.	-25190.	0.	0.	0.	-.033	-.555	-.014	
009 SPD XL5014										
WT1	0.	-9528.	0.	0.	0.	0.	.005	.000	-.001	
THRM2							-.097	.891	-.407	
THRM3							-.138	1.437	-.391	
THRM6							-.108	1.040	-.403	
TIMEL							.400	.554	.182	
FAULTP	0.	-9528.	0.	0.	0.	0.	-.405	1.991	.182	
FAULTN	0.	-9528.	0.	0.	0.	0.	-.832	-.554	-.591	

2C159RC5037

RESTRAINT LOAD SUMMARY

TITLE : FEEDWATER "FF" SYSTEM - SG ID TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

ME101/R4 GAEU/54 (8K1703) 07/08/98 8K1703 PAGE 9

DCP#962843-2.SUPP.0 page 105 of 105

DATA TYPE PT	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
030 SPR	FW9018SH0001		WT1	0.	-8136.		0.	0.	.694	-.026	-.024
			THRM2	0.	0.		0.	.531	-.014	-.370	
			THRM3	0.	1.		0.	.399	.038	-.807	
			THRM6	0.	0.		0.	.495	.218	-.490	
			TIM21	0.	0.		0.	.453	.334	.189	
			FAULTP	0.	1.		0.	1.009	1.151	.165	
			FAULTN	0.	-8136.		0.	-.428	-.378	-1.021	
070 SPR	FW9018SH0002		WT1	0.	-9636.		0.	0.	.037	-.032	-.050
			THRM2	0.	0.		0.	.583	-.039	1.637	
			THRM3	0.	0.		0.	.216	.327	.624	
			THRM6	0.	0.		0.	.483	.061	1.359	
			TIM21	0.	0.		0.	.394	.146	.579	
			FAULTP	0.	0.		0.	1.015	.461	2.166	
			FAULTN	0.	-9636.		0.	-.357	-.217	-.629	
075 RAD	FW9018HL5005		WT1	0.	-5341.		0.	0.	.037	-.006	-.061
			THRM2	0.	1146.		0.	0.	-.017	.001	2.707
			THRM3	0.	4033.		0.	0.	-.058	.005	1.263
			THRM6	0.	1933.		0.	0.	-.028	.002	2.312
			TIM21	0.	23795.		0.	0.	.402	.027	.327
			FAULTP	0.	22486.		0.	0.	.439	.026	2.973
			FAULTN	0.	-23136.		0.	0.	-.423	-.033	-.387
094 RAD	FW9018HL5002		WT1	0.	-8351.		0.	0.	.027	-.006	-.045
			THRM2	0.	-1481.		0.	0.	-.151	.001	2.516
			THRM3	0.	-3914.		0.	0.	-.098	-.003	1.218
			THRM6	0.	-2145.		0.	0.	-.136	-.002	2.161
			TIM21	0.	25549.		0.	0.	.141	.020	.208
			FAULTP	0.	17198.		0.	0.	.168	.013	3.679
			FAULTN	0.	-37613.		0.	0.	-.265	-.029	-.252
099 RAD	FW1018RL5001		WT1	0.	-5627.		0.	0.	.003	-.011	-.004
			THRM2	0.	7673.		0.	0.	-.122	.014	.662
			THRM3	0.	5888.		0.	0.	-.065	.011	.321
			THRM6	0.	7185.		0.	0.	-.107	.013	.569
			TIM21	0.	24471.		0.	0.	.169	.046	.080
			FAULTP	0.	26517.		0.	0.	.172	.050	.738
			FAULTN	0.	-30098.		0.	0.	-.218	-.056	-.014

DCP#9704763 page 81 of 134

2C159RC5037 RESTRAINT LOAD SUMMARY
 TITLE : FEEDWATER "PN" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23638001
 PROBLEM NUMBER : 2C159RC5037
 USER : PANE
 LOAD CASE :

DATA TYPE	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
101	RAD	PW9018HL5013									
	WT1	-2126.	-1104.	0.	0.	0.	0.	0.	.001	-.001	.000
	THRM2	-3000.	-1561.	0.	0.	0.	0.	0.	-.032	.020	.301
	THRM3	-3704.	-1923.	0.	0.	0.	0.	0.	-.004	.005	.146
	THRM6	-3193.	-1681.	0.	0.	0.	0.	0.	-.009	.016	.258
	TIME1	77750.	40369.	0.	0.	0.	0.	0.	.050	.057	.142
	FAULTP	75624.	39265.	0.	0.	0.	0.	0.	.051	.075	.143
	FAULTN	-83581.	-43356.	0.	0.	0.	0.	0.	-.061	-.060	-.141
11A	RAD	PW9018HL5013									
	WT1	3150.	-2289.	0.	0.	0.	0.	0.	.000	-.006	.000
	THRM2	16942.	-12309.	0.	0.	0.	0.	0.	.048	.021	.275
	THRM3	11045.	-8054.	0.	0.	0.	0.	0.	.026	.007	.134
	THRM6	25340.	-11146.	0.	0.	0.	0.	0.	.042	.018	.227
	TIME1	36041.	26186.	0.	0.	0.	0.	0.	.036	.059	.141
	FAULTP	56132.	33958.	0.	0.	0.	0.	0.	.084	.073	.117
	FAULTN	-32891.	-40784.	0.	0.	0.	0.	0.	-.035	-.067	-.141
10A	RAD	PW9018HL5012									
	WT1	0.	0.	59.	0.	0.	0.	0.	.000	-.015	.000
	THRM2	0.	0.	13604.	0.	0.	0.	0.	.222	-.023	.012
	THRM3	0.	0.	5667.	0.	0.	0.	0.	.122	-.030	.005
	THRM6	0.	0.	11434.	0.	0.	0.	0.	.195	-.025	.010
	TIME1	0.	0.	61340.	0.	0.	0.	0.	.056	-.042	.054
	FAULTP	0.	0.	75004.	0.	0.	0.	0.	.277	-.028	.066
	FAULTN	0.	0.	-61281.	0.	0.	0.	0.	-.056	-.087	-.054
110	ANC	PEN M-S									
	WT1	.827.	-3080.	-.52.	-8789.	-10.	-22590.	.000	.000	.000	
	THRM2	-19567.	7118.	-14746.	5822.	-13340.	59833.	.035	-.061	-.013	
	THRM3	-10277.	5335.	-6035.	-3182.	-13609.	48239.	.036	-.061	-.011	
	THRM6	-17027.	6625.	-12074.	-5099.	-13413.	56664.	.035	-.061	-.012	
	TIME1	271747.	7862.	20442.	36556.	64210.	63793.	.042	.001	.003	
	FAULTP	270920.	11901.	20390.	27767.	64200.	101036.	.079	.001	.003	
	FAULTN	-292140.	-10942.	-34939.	-51167.	-77828.	-86383.	-.043	-.063	-.016	
013	SNB	PW9018880001									
	WT1								.026	-.023	-.022
	THRM2								.516	.046	-.508
	THRM3								.385	.911	-.888
	THRM6								.480	.282	-.612
	TIME1	6866.	0.	16732.	0.	0.	0.	0.	.452	.426	.193
	FAULTP	6866.	0.	16732.	0.	0.	0.	0.	.994	1.315	.171
	FAULTN	-6866.	0.	-16732.	0.	0.	0.	0.	-.426	-.449	-.103

DCM# 962843-2, SUPP.0 page 457 of

DCM# 9704763 page 82 of 134

2C159RC5037 RESTRAINT LOAD SUMMARY ME101/W4 GABU/S4 (8X1703) 07/08/98 8X1703 PAGE 11

TITLE : FEDDWATER "FW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 2343BD01
 PROBLEM NUMBER : 2C159RC5037
 USER : PABH
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
035 SNS	FW9018HL5003								.022	-.040	.021
	WT1								.585	-.215	.130
	THRM2								.450	.577	-.515
	THRM3								.548	.001	-.046
	THRM6								.556	-.029	.019
	TIME1	0.	75210.	0.	0.	0.	0.	0.	.456	.058	.206
	FAULTP	0.	75210.	0.	0.	0.	0.	0.	1.063	.595	.305
	FAULTN	0.	-75210.	0.	0.	0.	0.	0.	-.434	-.313	-.752
040 SNS	FW9018HL5004								.022	-.042	-.032
	WT1								.593	-.243	.204
	THRM2								.458	.539	-.471
	THRM3								.556	-.029	.019
	THRM6								.556	-.071	.213
	TIME1	20094.	0.	48969.	0.	0.	0.	0.	.457	.043	.213
	FAULTP	20094.	0.	48969.	0.	0.	0.	0.	1.071	.561	.385
	FAULTN	-20094.	0.	-48969.	0.	0.	0.	0.	-.435	-.328	-.717
050 SNS	FW9018HL5007								.023	-.054	-.041
	WT1								.681	-.229	1.056
	THRM2								.380	.350	.172
	THRM3								.579	-.071	.014
	THRM6								.221	.196	.060
	TIME1	0.	0.	91339.	0.	0.	0.	0.	.925	.492	1.075
	FAULTP	0.	0.	91339.	0.	0.	0.	0.	-.199	-.479	-.101
055 SNS	FW9018HL5008								.027	-.054	-.042
	WT1								.702	-.168	1.144
	THRM2								.343	.378	.268
	THRM3								.604	-.019	.904
	THRM6								.201	.196	.213
	TIME1	108633.	0.	0.	0.	0.	0.	0.	.930	.620	1.315
	FAULTP	108633.	0.	0.	0.	0.	0.	0.	-.174	-.418	-.395
065 SNS	FW9018SS50006								.037	-.042	-.048
	WT1								.652	-.050	1.480
	THRM2								.217	.371	.532
	THRM3								.541	.065	1.221
	THRM6								.333	.151	.541
	TIME1	0.	75981.	0.	0.	0.	0.	0.	1.082	.481	1.974
	FAULTP	0.	75981.	0.	0.	0.	0.	0.	-.356	-.243	-.639
	FAULTN	0.	-75981.	0.	0.	0.	0.	0.			

DCP# 96-2843-2, SUPP. 0 page 115 of _____

DCN# 9704763 page 83 of 134

2C159RC5037 RESTRAINT LOAD SUMMARY ME101/M4 GATE/54 (8K1703) 07/08/98 8K1703 PAGE 12

TITLE : FEDWATER "FW" SYSTEM - SG 1D TO M5
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD TITLE	FX	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
			FY	FZ	MX	MY	MZ	DX	DY	DZ	
005 SNB	FW9018880007							.037	-.003	.051	
	WT1							-.121	-.014	2.872	
	THRM2							-.101	-.046	1.362	
	THRM3							-.116	-.023	2.659	
	THRM6										
	TIME1	46404.	0.	46404.	0.	0.	0.	.377	.110	.386	
	FAULTP	46404.	0.	46404.	0.	0.	0.	.415	.103	3.197	
	FAULTN	-46404.	0.	-46404.	0.	0.	0.	.461	-.158	-.446	
092 SNB	FW901888L5003							.024	-.016	.043	
	WT1							-.123	.008	2.424	
	THRM2							-.084	.012	1.175	
	THRM3							-.112	.009	2.083	
	THRM6										
	TIME1	37009.	0.	37009.	0.	0.	0.	.398	.052	.198	
	FAULTP	37009.	0.	37009.	0.	0.	0.	.362	.049	2.580	
	FAULTN	-37009.	0.	-37009.	0.	0.	0.	.236	-.068	-.241	
097 SNB	FW901888L5006							.003	-.077	-.014	
	WT1							.092	.040	1.144	
	THRM2							.033	.057	.561	
	THRM3							.076	.045	.984	
	THRM6										
	TIME1	0.	0.	37673.	0.	0.	0.	.173	.315	.061	
	FAULTP	0.	0.	37673.	0.	0.	0.	.268	.295	1.191	
	FAULTN	0.	0.	-37673.	0.	0.	0.	.170	-.393	-.075	

DCP# 96-2843-2, SUPP. 0 page 1959 of _____

DCN# 9704763 page 84 of 134

2C159RC5037

RESTRAINT LOAD SUMMARY

ME101/H4 GARD/S4

(8X1703) 07/08/98 8X1703 PAGE

13

TITLE : FEEDWATER "Y" SYSTEM - SG ID TO MS
 PROJECT NUMBER : 22438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)						DIRECTION COSINES					
			PA	PB	PC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
001 ANC	IR121NEG101D		WT1 -10 THR2 -4930 THR3 -2184 THR6 -4150 TIME1 34579 FAULTP 34570 FAULTN -39319	-1085 -589 -2253 -1346 -5303 -796 -3069 39838 24208 82262 81176 -84692	-54 -2253 46704 91520 32170 -74579 1045986 269181 361089 24154 204434 -23564 -157993	-131 37421 -75231 -72712 -74579 1045986 -1024671 -1132531	388 66147 -77231 -77231 -74579 -1045986 -1024671 -1132531	-11315 -75231 -77231 -77231 -74579 -1045986 -1024671 -1132531	.87 .87 .87 .87 .87 .87 .87 .87	.00 .00 .00 .00 .00 .00 .00 .00	.48 .48 .48 .48 .48 .48 .48 .48	.00 .00 .00 .00 .00 .00 .00 .00	1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.00	.00 .00 .00 .00 .00 .00 .00 .00	-.48 -.48 -.48 -.48 -.48 -.48 -.48 -.48	.00 .00 .00 .00 .00 	.87 .87 .87 .87 .87 .87 .87 .87
007 RAD	HL5016		WT1 -262 THR2 -3772 THR3 -8595 THR6 -5167 TIME1 28144 FAULTP 27882 FAULTN -37603	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	.85 .85 .85 .85 .85 .85 .85 .85 .85	.00 .00 .00 .00 .00 	-.53 -.53 -.53 -.53 -.53 -.53 -.53 -.53 -.53	-.53 -.53 -.53 -.53 -.53 -.53 -.53 -.53 -.53					
07H RAD	HL5015		WT1 -72 THR2 -6322 THR3 -6098 THR6 -6237 TIME1 45387 FAULTP 45385 FAULTN -52352	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	-.71 -.71 -.71 -.71 -.71 -.71 -.71 -.71 -.71	.00 .00 .00 .00 .00 .00 .00 .00 .00	.71 .71 .71 .71 .71 .71 .71 .71 .71						
07H RAD	HL5015		WT1 62 THR2 -10711 THR3 -7893 THR6 -9939 TIME1 35662 FAULTP 35624 FAULTN -46212	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0	-.71 -.71 -.71 -.71 -.71 -.71 -.71 -.71 -.71	.00 .00 .00 .00 .00 .00 .00 .00 .00	.71 .71 .71 .71 .71 .71 .71 .71 .71						
009 SPD	HL5014		WT1 -9528 THR2 THR3 THR6 TIME1 FAULTP FAULTN -9528	0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0 0	0 0 0 0 0 	0 0 0 0 0 0	.00 .00 .00 .00 .00 .00	1.00 1.00 1.00 1.00 1.00 1.00	.00 .00 .00 .00 .00 .00	0 0 0 0 0 0	0 0 0 0 0 0				

DCP#962443.2.SUH.0 page 11 of 11

DCN#9704763 page 85 of 134

2C159RC5037

RESTRAINT LOAD SUMMARY

ME101/H4 GABU/64 (8K1703) 07/08/98 8K1703 PAGE 14

TITLE : FEEDWATER "FM" SYSTEM - SO ID TO MS
PROJECT NUMBER : 23438001
PROBLEM NUMBER : 2C159RC5037
USER : PAMI
LOAD CASE :

DATA TYPE VT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
			FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
030 SPR	FW9018SH0001	WT1 TERM2 TERM3 TERM6 TIME1 FAULTP FAULTN	-8136 0 0 0 0 0 0	CB 11498 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	.00 .00 .00 .00 .00 .00 .00	1.00 1.00 1.00 1.00 1.00 1.00 1.00	.00 .00 .00 .00 .00 .00 .00						
070 SPR	FW9018SH0002	WT1 TERM2 TERM3 TERM6 TIME1 FAULTP FAULTN	-9636 0 0 0 0 0 0	CB 11498 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	.00 .00 .00 .00 .00 .00 .00	1.00 1.00 1.00 1.00 1.00 1.00 1.00	.00 .00 .00 .00 .00 .00 .00						
075 RAD	FW9018HL5005	WT1 TERM2 TERM3 TERM6 TIME1 FAULTP FAULTN	-5341 1146 4033 1933 23795 22486 -29136	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	.00 .00 .00 .00 .00 .00 .00	1.00 1.00 1.00 1.00 1.00 1.00 1.00	.00 .00 .00 .00 .00 .00 .00						
094 RAD	FW9018HL5002	WT1 TERM2 TERM3 TERM6 TIME1 FAULTP FAULTN	-8351 -1481 -3914 -2145 25549 17398 -37613	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	.00 .00 .00 .00 .00 .00 .00	1.00 1.00 1.00 1.00 1.00 1.00 1.00	.00 .00 .00 .00 .00 .00 .00						
099 RAD	FW1018HL5001	WT1 TERM2 TERM3 TERM6 TIME1 FAULTP FAULTN	-5627 7673 5888 7185 24471 26517 -30098	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	0 0 0 0 0 0 0	.00 .00 .00 .00 .00 .00 .00	1.00 1.00 1.00 1.00 1.00 1.00 1.00	.00 .00 .00 .00 .00 .00 .00						

DCR# 96-2843-2, SUPN.0 page 16 of 43DCR# 9704763 page 86 of 134

2C159RC5037 RESTRAINT LOAD SUMMARY ME101/M4 GAEU/S4 (8K1703) 07/08/98 8K1703 PAGE 16

TITLE : FEEDWATER "FW" SYSTEM - 80 ID TO M5
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)						DIRECTION COSINES					
			FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
035 SNE	PW9018HLS009	WT1 THRM2 THRM3 THRM4 TIME1 FAULTP FAULTN	75210 75210 -75210	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	1.00 1.00 1.00	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	
040 SNE	PW9018HLS004	WT1 THRM2 THRM3 THRM4 TIME1 FAULTP FAULTN	52932 52932 -52932	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	.38 .38 .38	0 0 0	0 0 0	0 0 0	0 0 0	
050 SNE	PW9018HLS007	WT1 THRM2 THRM3 THRM4 TIME1 FAULTP FAULTN	91399 91399 -91399	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	1.00 1.00 1.00	
055 SNE	PW9018HLS008	WT1 THRM2 THRM3 THRM4 TIME1 FAULTP FAULTN	108633 108633 -108633	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	1.00 1.00 1.00	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	
065 SNE	PW9018SS0006	WT1 THRM2 THRM3 THRM4 TIME1 FAULTP FAULTN	75981 75981 -75981	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	1.00 1.00 1.00	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	

DCP# 96-2843-2, SUPP. 0 page 143 of _____

DCN# 9704763 page 88 of 134

2C189RC5037

RESTRAINT LOAD SUMMARY

TITLE : FEEDWATER "FW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C189RC5037
 USER : PANI
 LOAD CASE :

ME101/M4 GAEU/54 (8K1703) 07/08/98 8K1703 PAGE 17

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
			FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
086 SWB	FN9018680007	WT1 THRM2 THRM3 THRM6 TIME1 FAULTP FAULTN	65625 65625 -65625	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	-0.71 -0.71 -0.71	0.00 0.00 0.00	0.71 0.71 0.71					
092 SWB	FN901868L5003	WT1 THRM2 THRM3 THRM6 TIME1 FAULTP FAULTN	52338 52338 -52338	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	-0.71 -0.71 -0.71	0.00 0.00 0.00	0.71 0.71 0.71					
097 SWB	FN901868L5006	WT1 THRM2 THRM3 THRM6 TIME1 FAULTP FAULTN	37673 37673 -37673	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0 0 0	0.00 0.00 0.00	0.00 0.00 0.00	1.00 1.00 1.00				

DCN# 96-2843-2, SUPP. 0 page 174 of 174DCN# 9704763 page 89 of 134

2C159RC5037 RESTRAINT LOAD SUMMARY ME1D1/E4 OAKU/54 (HQ4946) 05/22/98 HQ4946 PAGE 10

TITLE : FEDWATER "FW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
		Fx	Fy	Fz	Mx	My	Mz	Dx	Dy	Dz
001 ANC	IRI21NSG101D	18.	-1085.	-52.	5371.	388.	-9960.	.000	.000	.000
	WT1							.028	.028	.027
	TINEL1							.032	.031	.028
	TINEL2							.031	.030	.027
	TINEL3							.032	.031	.028
	LOCA									
007 RAD	HL5016	-122.	0.	139.	0.	0.	0.	-.001	-.001	-.001
	WT1							.056	.068	.095
	TINEL1	6589.	0.	6117.	0.	0.	0.			
	TINEL2	6852.	0.	4282.	0.	0.	0.	.056	.084	.096
	TINEL3	6454.	0.	4033.	0.	0.	0.	.045	.069	.076
	LOCA	6852.	0.	6282.	0.	0.	0.	.056	.084	.096
07H RAD	HL5015	51.	0.	-51.	0.	0.	0.	.000	.000	.000
	WT1							.006	.068	.007
	TINEL1	5002.	0.	5002.	0.	0.	0.			
	TINEL2	4999.	0.	4999.	0.	0.	0.	.006	.084	.007
	TINEL3	5109.	0.	5109.	0.	0.	0.	.006	.069	.007
	LOCA	5109.	0.	5109.	0.	0.	0.			
07H RAD	HL5015	-44.	0.	-44.	0.	0.	0.	.000	.000	.000
	WT1							.006	.068	.007
	TINEL1	13732.	0.	13732.	0.	0.	0.			
	TINEL2	13633.	0.	13633.	0.	0.	0.	.006	.084	.007
	TINEL3	13921.	0.	13921.	0.	0.	0.	.006	.069	.007
	LOCA	13921.	0.	13921.	0.	0.	0.	.006	.084	.007
009 SPD	HL5014	0.	-9528.	0.	0.	0.	0.	.005	.000	-.001
	WT1							.039	.068	.060
	TINEL1							.036	.084	.068
	TINEL2							.031	.069	.049
	TINEL3							.039	.084	.068
	LOCA									
030 SPR	FW3018SH0001	0.	-8136	0.	0.	0.	0.	.025	-.025	-.024
	WT1							.031	.045	.014
	TINEL1	0.	0.	0.	0.	0.	0.			
	TINEL2	0.	0.	6/25/98	0.	0.	0.	.037	.053	.016
	TINEL3	0.	0.	0.	0.	0.	0.	.029	.042	.014
	LOCA	0.	0.	0.	0.	0.	0.	.037	.053	.016

2C159RC5037
 RESTRAINT LOAD SUMMARY
 TITLE : FEEDWATER "FW" SYSTEM - SG ID TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

MN101/R4 GAZU/S4 (MG4946) 05/22/98 MG4946 PAGE 11

DCP#962443.2, SUPP.0 page 166 of —

DCN#9704763 page 9 of 134

DATA TYPE PT	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
070 SPR		FM9018SH0002		-9636	725	0.	0.	0.	.017	-.012	-.050
	WT1		0.	0.	0.	0.	0.	0.	.018	.011	.027
	TIMEL1		0.	0.	0.	0.	0.	0.	.021	.012	.036
	TIMEL2		0.	0.	0.	0.	0.	0.	.015	.009	.023
	TIMEL3		0.	0.	0.	0.	0.	0.	.021	.012	.036
	LOCA		0.	0.	0.	0.	0.	0.			
075 RAD		FM9018HL5005									
	WT1		0.	-5341.	0.	0.	0.	0.	.037	-.006	-.061
	TIMEL1		0.	1027.	0.	0.	0.	0.	.018	.001	.017
	TIMEL2		0.	1134.	0.	0.	0.	0.	.022	.001	.021
	TIMEL3		0.	969.	0.	0.	0.	0.	.015	.001	.016
	LOCA		0.	1134.	0.	0.	0.	0.	.022	.001	.021
094 RAD		FM9018HL5002									
	WT1		0.	-8351.	0.	0.	0.	0.	.027	-.006	-.045
	TIMEL1		0.	825.	0.	0.	0.	0.	.005	.001	.004
	TIMEL2		0.	1077.	0.	0.	0.	0.	.006	.001	.005
	TIMEL3		0.	701.	0.	0.	0.	0.	.005	.001	.004
	LOCA		0.	1077.	0.	0.	0.	0.	.006	.001	.005
099 RAD		FM1018HL5001									
	WT1		0.	-8627.	0.	0.	0.	0.	.003	-.011	-.004
	TIMEL1		0.	505.	0.	0.	0.	0.	.002	.001	.001
	TIMEL2		0.	605.	0.	0.	0.	0.	.003	.001	.001
	TIMEL3		0.	493.	0.	0.	0.	0.	.002	.001	.001
	LOCA		0.	605.	0.	0.	0.	0.	.003	.001	.001
101 RAD		FM9018HL5013									
	WT1		-2126.	-1104.	0.	0.	0.	0.	.001	-.003	0.000
	TIMEL1		698.	466.	0.	0.	0.	0.	.001	.001	.001
	TIMEL2		1092.	567.	0.	0.	0.	0.	.001	.002	.001
	TIMEL3		807.	419.	0.	0.	0.	0.	.001	.001	.001
	LOCA		1092.	567.	0.	0.	0.	0.	.001	.002	.001
11A RAD		FM9018HL5013									
	WT1		3150.	-2289.	0.	0.	0.	0.	.000	-.008	0.000
	TIMEL1		496.	360.	0.	0.	0.	0.	.001	.001	.001
	TIMEL2		679.	494.	0.	0.	0.	0.	.002	.001	.001
	TIMEL3		484.	352.	0.	0.	0.	0.	.001	.001	.001
	LOCA		679.	494.	0.	0.	0.	0.	.001	.001	.001

2C159RC5037 RESTRAINT LOAD SUMMARY NE101/H4 GARE/54 (MG4946) 05/22/98 MG4946 PAGE 12

TITLE : FEEDWATER "PW" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
10A RAD	PW9018EL5012										
	WT1	0.	0.	69.	0.	0.	0.	0.	.000	-.015	.000
	TIME1	0.	0.	255.	0.	0.	0.	0.	.000	.001	.000
	TIME1	0.	0.	330.	0.	0.	0.	0.	.000	.001	.000
	TIME1	0.	0.	245.	0.	0.	0.	0.	.000	.001	.000
	LOCA	0.	0.	330.	0.	0.	0.	0.	.000	.001	.000
210 ANC	PW N-S										
	WT1	-827.	-3080.	-52.	-8769.	-30.	-32590.	.000	.000	.000	
	TIME1	377.	69.	64.	1306.	267.	1472.	.000	.000	.000	
	TIME1	466.	78.	63.	1761.	246.	1814.	.000	.000	.000	
	TIME1	339.	68.	64.	1213.	260.	1523.	.000	.000	.000	
	TIME1	466.	78.	64.	1761.	346.	1814.	.000	.000	.000	
001 RAD	CENTER SG										
	WT1								.000	.000	.000
	TIME1	13772.	0.	0.	0.	0.	0.	0.	.028	.028	.027
	TIME1	13874.	0.	0.	0.	0.	0.	0.	.032	.031	.028
	TIME1	13692.	0.	0.	0.	0.	0.	0.	.031	.030	.027
	TIME1	13874.	0.	0.	0.	0.	0.	0.	.032	.031	.028
001 RAD	CENTER SG										
	WT1								.000	.000	.000
	TIME1	0.	8950.	0.	0.	0.	0.	0.	.028	.028	.027
	TIME1	0.	10074.	0.	0.	0.	0.	0.	.032	.031	.028
	TIME1	0.	7617.	0.	0.	0.	0.	0.	.031	.030	.027
	TIME1	0.	10074.	0.	0.	0.	0.	0.	.032	.031	.028
001 RAD	CENTER SG										
	WT1								.000	.000	.000
	TIME1	0.	0.	11232.	0.	0.	0.	0.	.028	.028	.027
	TIME1	0.	0.	11313.	0.	0.	0.	0.	.032	.031	.028
	TIME1	0.	0.	11169.	0.	0.	0.	0.	.031	.030	.027
	TIME1	0.	0.	11313.	0.	0.	0.	0.	.032	.031	.028
001 BAR	CENTER SG										
	WT1								.000	.000	.000
	TIME1	0.	0.	0.	44015.	0.	0.	0.	.028	.028	.027
	TIME1	0.	0.	0.	51645.	0.	0.	0.	.032	.031	.028
	TIME1	0.	0.	0.	38570.	0.	0.	0.	.031	.030	.027
	TIME1	0.	0.	0.	51645.	0.	0.	0.	.032	.031	.028

DCP# 96-2843-2, SUPP.0 page 1961 of —DCN# 9704763 page 92 of 134

2C159RC5037

RESTRAINT LOAD SUMMARY

TITLE : YEEOWATER "7W" SYSTEM - SG 1D TO M5
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

NE101/W4 QABU/54

(NG4946) 05/22/98 NG4946 PAGE

13

DATA TYPE PT	LOAD	TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
			FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
001	RAR	CENTER SG									
	WT1										
	TIMEL1	0.	0.	0.	0.	0.	178613.	0.	.000	.000	.000
	TIMEL2	0.	0.	0.	0.	0.	179971.	0.	.028	.028	.027
	TIMEL3	0.	0.	0.	0.	0.	177613.	0.	.032	.031	.028
	LOCA	0.	0.	0.	0.	0.	179971.	0.	.031	.030	.027
001	RAR	CENTER SG									
	WT1										
	TIMEL1	0.	0.	0.	0.	0.	106569.	0.	.000	.000	.000
	TIMEL2	0.	0.	0.	0.	0.	119225.	0.	.028	.028	.027
	TIMEL3	0.	0.	0.	0.	0.	89895.	0.	.032	.031	.028
	LOCA	0.	0.	0.	0.	0.	119225.	0.	.032	.031	.028
015	SWB	FW9018SE0001									
	WT1										
	TIMEL1	1900.	0.	4630.	0.	0.	0.	0.	.026	.023	-.022
	TIMEL2	2075.	0.	5057.	0.	0.	0.	0.	.032	.056	.017
	TIMEL3	1618.	0.	3942.	0.	0.	0.	0.	.037	.067	.016
	LOCA	2075.	0.	5057.	0.	0.	0.	0.	.037	.053	.014
035	SWB	FW9018KL5009									
	WT1										
	TIMEL1	0.	9274.	0.	0.	0.	0.	0.	.022	-.040	-.031
	TIMEL2	0.	10880.	0.	0.	0.	0.	0.	.029	.007	.015
	TIMEL3	0.	9280.	0.	0.	0.	0.	0.	.035	.008	.018
	LOCA	0.	10880.	0.	0.	0.	0.	0.	.035	.008	.018
040	SWB	FW9018KL5004									
	WT1										
	TIMEL1	1866.	0.	4548.	0.	0.	0.	0.	.022	-.042	-.032
	TIMEL2	2318.	0.	5650.	0.	0.	0.	0.	.029	.005	.016
	TIMEL3	1697.	0.	4134.	0.	0.	0.	0.	.034	.005	.019
	LOCA	2318.	0.	5650.	0.	0.	0.	0.	.034	.005	.015
050	SWB	FW9018KL5007									
	WT1										
	TIMEL1	0.	0.	4397.	0.	0.	0.	0.	.023	-.054	-.061
	TIMEL2	0.	0.	5703.	0.	0.	0.	0.	.012	.022	.003
	TIMEL3	0.	0.	3655.	0.	0.	0.	0.	.014	.025	.004
	LOCA	0.	0.	5703.	0.	0.	0.	0.	.014	.025	.003

2C159RC5037 RESTRAINT LOAD SUMMARY ME101/N4 GAEU/S4 (HQ4946) 05/22/98 HQ4946 PAGE 14

TITLE : FEEDWATER "FW" SYSTEM - SG ID TO MS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PANY
 LOAD CASE :

DATA TYPE PT	LOAD TITLE	GLOBAL FORCES (LB)			GLOBAL MOMENTS (FT-LB)			DISPLACEMENT (IN)		
		FX	FY	FZ	MX	MY	MZ	DX	DY	DZ
055	SNB	FW9018HLS008						.027	-.064	-.042
		WT1	5189.	0.	0.	0.	0.	.010	.022	.012
		TIME1						.012	.025	.015
		TIME2	6422.	0.	0.	0.	0.			
		TIME3	4524.	0.	0.	0.	0.	.008	.020	.010
		LOCA	6422.	0.	0.	0.	0.	.012	.023	.015
065	SNB	FW9018S80006						.037	-.042	-.048
		WT1	0.	7609.	0.	0.	0.	.018	.015	.027
		TIME1						.021	.017	.035
		TIME2	0.	8632.	0.	0.	0.			
		TIME3	0.	6919.	0.	0.	0.	.015	.014	.023
		LOCA	0.	8632.	0.	0.	0.	.021	.017	.035
085	SNB	FW9018S80007						.037	-.002	-.061
		WT1	2040.	0.	2040.	0.	0.	.017	.002	.018
		TIME1						.021	.003	.022
		TIME2	2261.	0.	2261.	0.	0.			
		TIME3	1969.	0.	1969.	0.	0.	.015	.002	.016
		LOCA	2261.	0.	2261.	0.	0.	.021	.003	.022
092	SNB	FW9018HLS003						.024	-.016	-.043
		WT1	1102.	0.	1102.	0.	0.	.004	.002	.003
		TIME1						.005	.003	.004
		TIME2	1296.	0.	1296.	0.	0.			
		TIME3	928.	0.	928.	0.	0.	.004	.002	.003
		LOCA	1296.	0.	1296.	0.	0.	.005	.003	.004
097	SNB	FW9018HLS006						.003	-.077	-.014
		WT1	0.	0.	1001.	0.	0.	.002	.012	.002
		TIME1						.003	.016	.002
		TIME2	0.	0.	1182.	0.	0.			
		TIME3	0.	0.	968.	0.	0.	.002	.011	.002
		LOCA	0.	0.	1182.	0.	0.	.003	.016	.002

2C159RC5037

RESTRAINT LOAD SUMMARY

TITLE : FEDOWATER "FW" SYSTEM - SG 1D TO M5
 PROJECT NUMBER : 23436001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

ME101/M4 GAHU/S4 (MG4946) 05/22/98 MG4946 PAGE 16

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
			FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
001 ANC		IR121MSG101D															
	WT1		18	-1085	-52	5371	388	-9960	1.00	.00	.00	.00	1.00	.00	.00	.00	1.00
	TIMEL1																
	TIMEL2																
	TIMEL3																
	LOCA																
007 RAD		HL5016															
	WT1		-262	0	0	0	0	0	0	.85	.00	-.53					
	TIMEL1		7770	0	0	0	0	0	0	.85	.00	-.53					
	TIMEL2		8080	0	0	0	0	0	0	.85	.00	-.53					
	TIMEL3		7610	0	0	0	0	0	0	.85	.00	-.53					
	LOCA		8080	0	0	0	0	0	0	.85	.00	-.53					
07H RAD		HL5015															
	WT1		-72	0	0	0	0	0	0	-.71	.00	.71					
	TIMEL1		7074	0	0	0	0	0	0	-.71	.00	.71					
	TIMEL2		7070	0	0	0	0	0	0	-.71	.00	.71					
	TIMEL3		7225	0	0	0	0	0	0	-.71	.00	.71					
	LOCA		7225	0	0	0	0	0	0	-.71	.00	.71					
07H RAD		HL5015															
	WT1		62	0	0	0	0	0	0	-.71	.00	-.71					
	TIMEL1		19419	0	0	0	0	0	0	-.71	.00	-.71					
	TIMEL2		19280	0	0	0	0	0	0	-.71	.00	-.71					
	TIMEL3		19688	0	0	0	0	0	0	-.71	.00	-.71					
	LOCA		19688	0	0	0	0	0	0	-.71	.00	-.71					
009 SPD		HL5014								0	.00	1.00	.00				
	WT1		-9528	0	0	0	0	0	0	0	.00	1.00	.00				
	TIMEL1																
	TIMEL2																
	TIMEL3																
	LOCA																
030 SPR		FW90185N0001															
	WT1		-8136	+ 6/25/98	0	0	0	0	0	0	.00	1.00	.00				
	TIMEL1										0	.00	1.00	.00			
	TIMEL2										0	.00	1.00	.00			
	TIMEL3										0	.00	1.00	.00			
	LOCA										0	.00	1.00	.00			

DCP#96-2843-2, SUPP.0 page 1970 of 1DCN#9704763 page 95 of 134

2C159RC5037

RESTRAINT LOAD SUMMARY

TITLE : FEEDWATER "YM" SYSTEM - SG 1D TO M5
PROJECT NUMBER : 23438601
PROBLEM NUMBER : 2C159RC5037
USER : PAMI
LOAD CASE :

ME101/H4 GABU/S4

(NG4946) 05/22/98 NG4946 PAGE 16

DATA PT	TYPE	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES							
				FA	FB	FC	MA	MB	MC	COS AX	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
070	SPR		FW9018SH0002														
		WT1	-9636	-	0	0	0	0	0	0	.00	1.00	.00				
		TIMEL1		0	0	0	0	0	0	0	.00	1.00	.00				
		TIMEL2		613		0	0	0	0	0	.00	1.00	.00				
		TIMEL3		613		0	0	0	0	0	.00	1.00	.00				
		LOCA	612598	0	0	0	0	0	0	0	.00	1.00	.00				
075	RAD		FW9018HL5005														
		WT1	-5341	-	0	0	0	0	0	0	.00	1.00	.00				
		TIMEL1		1027		0	0	0	0	0	.00	1.00	.00				
		TIMEL2		1134		0	0	0	0	0	.00	1.00	.00				
		TIMEL3		969		0	0	0	0	0	.00	1.00	.00				
		LOCA	1134	0	0	0	0	0	0	0	.00	1.00	.00				
094	RAD		FW9018HL5002														
		WT1	-8351	-	0	0	0	0	0	0	.00	1.00	.00				
		TIMEL1		825		0	0	0	0	0	.00	1.00	.00				
		TIMEL2		1077		0	0	0	0	0	.00	1.00	.00				
		TIMEL3		701		0	0	0	0	0	.00	1.00	.00				
		LOCA	1077	0	0	0	0	0	0	0	.00	1.00	.00				
099	RAD		FW1018HL5001														
		WT1	-5627	-	0	0	0	0	0	0	.00	1.00	.00				
		TIMEL1		505		0	0	0	0	0	.00	1.00	.00				
		TIMEL2		605		0	0	0	0	0	.00	1.00	.00				
		TIMEL3		493		0	0	0	0	0	.00	1.00	.00				
		LOCA	605	0	0	0	0	0	0	0	.00	1.00	.00				
101	RAD		FW9018HL5013														
		WT1	-2396	-	0	0	0	0	0	0	.89	.46	.00				
		TIMEL1		1011		0	0	0	0	0	.89	.46	.00				
		TIMEL2		1231		0	0	0	0	0	.89	.46	.00				
		TIMEL3		909		0	0	0	0	0	.89	.46	.00				
		LOCA	1231	0	0	0	0	0	0	0	.89	.46	.00				
11A	RAD		FW9018HL5013														
		WT1	3894	-	0	0	0	0	0	0	.81	-.59	.00				
		TIMEL1		613		0	0	0	0	0	.81	-.59	.00				
		TIMEL2		840		0	0	0	0	0	.81	-.59	.00				
		TIMEL3		599		0	0	0	0	0	.81	-.59	.00				
		LOCA	840	0	0	0	0	0	0	0	.81	-.59	.00				

DCP#96-2843-2, SUPP.0 page 121 of —DCN#9704763 page 26 of 134

2C159RC5037
TITLE : FEEDWATER "Y" SYSTEM - SG 1D TO MS
PROJECT NUMBER : 23438001
PROBLEM NUMBER : 2C159RC5037
USER : PAMI
LOAD CASE :

RESTRAINT LOAD SUMMARY

ME101/N4 GABU/S4

(HQ4946) 05/22/98 HQ4946 PAGE 17

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
			FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
10A RAD	FW9018NL5012		WT1	59	0	0	0	0	0	.00	.00	1.00					
			TIMEL1	255	0	0	0	0	0	.00	.00	1.00					
			TIMEL2	330	0	0	0	0	0	.00	.00	1.00					
			TIMEL3	245	0	0	0	0	0	.00	.00	1.00					
			LOCA	330	0	0	0	0	0	.00	.00	1.00					
110 ANC	PEM M-5		WT1	-827	-3080	-52	-8789	-10	-22590	1.00	.00	.00	.00	1.00	.00	.00	.00
			TIMEL1	377	69	64	1306	267	1472	1.00	.00	.00	.00	1.00	.00	.00	.00
			TIMEL2	466	78	63	1761	346	1814	1.00	.00	.00	.00	1.00	.00	.00	.00
			TIMEL3	339	69	64	1213	269	1523	1.00	.00	.00	.00	1.00	.00	.00	.00
			LOCA	466	78	64	1761	346	1814	1.00	.00	.00	.00	1.00	.00	.00	.00
001 RAD	CENTER SG		WT1	13772	0	0	0	0	0	1.00	.00	.00					
			TIMEL1	13874	0	0	0	0	0	1.00	.00	.00					
			TIMEL2	13874	0	0	0	0	0	1.00	.00	.00					
			TIMEL3	13692	0	0	0	0	0	1.00	.00	.00					
			LOCA	13874	0	0	0	0	0	1.00	.00	.00					
001 RAD	CENTER SG		WT1	8950	0	0	0	0	0	0	.00	1.00	.00				
			TIMEL1	10074	0	0	0	0	0	0	.00	1.00	.00				
			TIMEL2	10074	0	0	0	0	0	0	.00	1.00	.00				
			TIMEL3	7617	0	0	0	0	0	0	.00	1.00	.00				
			LOCA	10074	0	0	0	0	0	0	.00	1.00	.00				
001 RAD	CENTER SG		WT1	11232	0	0	0	0	0	0	.00	.00	1.00				
			TIMEL1	11313	0	0	0	0	0	0	.00	.00	1.00				
			TIMEL2	11313	0	0	0	0	0	0	.00	.00	1.00				
			TIMEL3	11169	0	0	0	0	0	0	.00	.00	1.00				
			LOCA	11313	0	0	0	0	0	0	.00	.00	1.00				
001 RAD	CENTER SG		WT1	0	0	0	44015	0	0	1.00	.00	.00					
			TIMEL1	0	0	0	51645	0	0	1.00	.00	.00					
			TIMEL2	0	0	0	38570	0	0	1.00	.00	.00					
			TIMEL3	0	0	0	51645	0	0	1.00	.00	.00					
			LOCA	0	0	0											

DCP#96-2843-2, SUPP. 0 page 1912 of 1DCN#9704763 page 27 of 134

2C159RC5037

RESTRAINT LOAD SUMMARY

ME101/M4 QAREU/84 (HQ4946) 08/22/98 HQ4946 PAGE 18

TITLE : FEEDWATER "FW" SYSTEM - SG 1D TO M5
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)						DIRECTION COSINES					
			PA	PB	PC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
001	R&R	CENTER SG															
	WT1		0	0	0	178613	0	0	0 .00	1.00	.00						
	TIMEL1		0	0	0	179871	0	0	0 .00	1.00	.00						
	TIMEL2		0	0	0	177613	0	0	0 .00	1.00	.00						
	TIMEL3		0	0	0	179871	0	0	0 .00	1.00	.00						
	LOCA		0	0	0												
001	R&R	CENTER SG															
	WT1		0	0	0	106569	0	0	0 .00	.00	1.00						
	TIMEL1		0	0	0	119225	0	0	0 .00	.00	1.00						
	TIMEL2		0	0	0	89895	0	0	0 .00	.00	1.00						
	TIMEL3		0	0	0	119225	0	0	0 .00	.00	1.00						
	LOCA		0	0	0												
015	S&B	FW9018S80001															
	WT1		5004	0	0	0	0	0	0 .38	.00	.93						
	TIMEL1		5466	0	0	0	0	0	0 .38	.00	.93						
	TIMEL2		5466	0	0	0	0	0	0 .38	.00	.93						
	TIMEL3		4261	0	0	0	0	0	0 .38	.00	.93						
	LOCA		5466	0	0	0	0	0	0 .38	.00	.93						
035	S&B	FW9018HL5003															
	WT1		9274	0	0	0	0	0	0 .00	1.00	.00						
	TIMEL1		10880	0	0	0	0	0	0 .00	1.00	.00						
	TIMEL2		9280	0	0	0	0	0	0 .00	1.00	.00						
	TIMEL3		10880	0	0	0	0	0	0 .00	1.00	.00						
	LOCA																
040	S&B	FW9018HL5004															
	WT1		4916	0	0	0	0	0	0 .38	.00	.93						
	TIMEL1		6107	0	0	0	0	0	0 .38	.00	.93						
	TIMEL2		4469	0	0	0	0	0	0 .38	.00	.93						
	TIMEL3		6107	0	0	0	0	0	0 .38	.00	.93						
	LOCA																
050	S&B	FW9018HL5007															
	WT1		4397	0	0	0	0	0	0 .00	.00	1.00						
	TIMEL1		5703	0	0	0	0	0	0 .00	.00	1.00						
	TIMEL2		3855	0	0	0	0	0	0 .00	.00	1.00						
	TIMEL3		5703	0	0	0	0	0	0 .00	.00	1.00						
	LOCA																

DCP# 96-2843-2, STPP.0 page 1973 of 1

DCN# 9704763 page 28 of 134

2C159RC5037

RESTRAINT LOAD SUMMARY

ME101/W4 QABD/54

(MG4946) 05/22/98 MG4946 PAGE 19

TITLE : FREDWATER "FM" SYSTEM - SG 1D TO MS
 PROJECT NUMBER : 23438003
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE :

DATA TYPE PT	LOAD	TITLE	LOCAL FORCES(LB)			LOCAL MOMENTS (FT-LB)			DIRECTION COSINES								
			FA	FB	FC	MA	MB	MC	COS AX	COS AY	COS AZ	COS BX	COS BY	COS BZ	COS CX	COS CY	COS CZ
058	SND	FM9018HL5008															
		WT1															
		TIME11	5189	0	0	0	0	0	0	1.00	.00	.00					
		TIME12	6422	0	0	0	0	0	0	1.00	.00	.00					
		TIME13	4524	0	0	0	0	0	0	1.00	.00	.00					
		LOCA	6422	0	0	0	0	0	0	1.00	.00	.00					
068	SND	FM9018SS0006															
		WT1															
		TIME11	7609	0	0	0	0	0	0	0	0.00	1.00	.00				
		TIME12	8632	0	0	0	0	0	0	0	0.00	1.00	.00				
		TIME13	6919	0	0	0	0	0	0	0	0.00	1.00	.00				
		LOCA	8632	0	0	0	0	0	0	0	0.00	1.00	.00				
085	SND	FM9018SS0007															
		WT1															
		TIME11	2885	0	0	0	0	0	0	0	-.71	.00	-.71				
		TIME12	3198	0	0	0	0	0	0	0	-.71	.00	-.71				
		TIME13	2784	0	0	0	0	0	0	0	-.71	.00	-.71				
		LOCA	3198	0	0	0	0	0	0	0	-.71	.00	-.71				
092	SND	FM9018HL5003															
		WT1															
		TIME11	1559	0	0	0	0	0	0	0	-.71	.00	.71				
		TIME12	1833	0	0	0	0	0	0	0	-.71	.00	.71				
		TIME13	1312	0	0	0	0	0	0	0	-.71	.00	.71				
		LOCA	1833	0	0	0	0	0	0	0	-.71	.00	.71				
097	SND	FM9018HL5006															
		WT1															
		TIME11	1001	0	0	0	0	0	0	0	0.00	0.00	1.00				
		TIME12	1182	0	0	0	0	0	0	0	0.00	0.00	1.00				
		TIME13	968	0	0	0	0	0	0	0	0.00	0.00	1.00				
		LOCA	1182	0	0	0	0	0	0	0	0.00	0.00	1.00				



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438001SUBJECT FW-PIPING FROM S.G. 1D To MSORIGINATOR PANI -CRDATE 3/1/983/1/98CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____CHK. WSS
DCP# 96-2843-2, SUPP. 0 page 175 of

DCN# 9704763

Page 100 of 134

ATTACHMENT 3.0 HELB STRESS SUMMARY

TOTAL NO OF SHEETS

7

2C159RC5037 ALL PIPE BREAK LOCATIONS

NE101/M4 GAZU/S4

(S03406) 10/28/97 S03406 PAGE

41

TITLE : FEEDWATER "FW" SYSTEM - EG 1D TO XS
 PROJECT NUMBER : 23438001
 PROBLEM NUMBER : 2C159RC5037
 USER : PAMI
 LOAD CASE : ALL

CODE SC3W75, CLASS 2

ELEMENT FROM TO	TYPE TITLE	EQN 9		SUM 9+10		ALLOW PSI
		EQN 9 PSI	EQN 10 PSI	9+10 PSI	16	
002	TNGT	12	11	23	48600	
001		16	20	36		
002	TNGT	7563	9928	17491	48600	
N02		7149	14378	21527		
N02	BEND	7490	17273	24763	39468	
005 M	BEND	7159	17626	24785	39468	
005 E	BEND	6824	17409	24229		
005 E	TNGT	6466	9646	16122	39468	
006 B	TNGT	5873	9304	15177		
006 B	BEND	6022	16708	22810	39468	
006 M	BEND	6205	15568	21773		
006 M	BEND	6206	16568	21773	39468	
006 E	BEND	6314	13223	19537		
006 E	TNGT	6089	7405	13494	32400	
006A	TNGT	6174	5153	11327	32400	
007	TNGT	6420	11672	18092	32400	
007	TNGT	6358	9282	15640	32400	
07G	TNGT	6358	9282	15640	32400	
07GA	TNGT	6349	7465	13814		
07GA	TNGT	6349	7465	13814	32400	
07H	TNGT	6565	9085	18650	32400	
009	TNGT	6157	5914	12071		

** EXCEEDED ALLOWABLE

DCP# 96-2843-2, STPP.0 page 191 of 16DCN# 9704763 page 101 of 134

2C159RC5037

ALL PIPE BREAK LOCATIONS

ME101/N4 GABU/S4

(803406) 10/28/97 803406 PAGE

42

CODE SC3W75, CLASS 2

ELEMENT FROM TO	TYPE TITLE	EQN 9 PSI	EQN 10 PSI	SUM 9+10 PSI	ALLOW PSI
009	TNGT	6157	5914	12071	32400
09A B		6193	5638	11831	
09A B	BEND	6454	10227	16681	32400
09A M		6489	8662	15152	
09A M	BEND	6489	8662	15152	32400
09A E		6361	7674	14036	
09B E	TNGT	6124	4253	10377	32400
09B B		6225	4063	10288	
09B B	BEND	6498	7331	13829	32400
09B M		6680	6465	13145	
09B M	BEND	6680	6465	13145	32400
09B E		6753	5258	12011	
09B E	TNGT	6415	2912	9327	32400
09C		6332	2889	9221	
09C	TNGT	6726	6428	13154	32400
010					
010	TNGT	6435	4561	10996	32400
011		6094	2719	8812	
011	TNGT	6094	2719	8812	32400
012		6074	2951	9025	
012	TNGT	6074	2951	9025	32400
12A		6041	3380	9421	
12A	TNGT	6041	3380	9421	32400
013		6016	3828	9844	
013	TNGT	5990	4631	10621	32400
014 B					
014 B	BEND	6161	8429	14590	32400
014 M		6134	9528	15662	
014 M	BEND	6134	9528	15662	32400
014 E		6393	9397	15790	
014 E	TNGT	6162	5162	11324	32400
015		6279	5051	11322	

** EXCEEDED ALLOWABLE

DCP# 96-2843-2, SUPP. 0 page 111 of 1DCN# 970473 page 102 of 134

2C159RCS037

ALL PIPES BREAK LOCATIONS

ME101/W4 GAEU/S4

(803406) 10/28/97 803406 PAGE

43

DCP# 96-2843-2, SUPP.0 page 178 of —DCN# 9704763 page 103 of 134

CODE SC3W75, CLASS 2

ELEMENT FROM TO	TYPE TITLE	EQN 9 PSI	EQN 10 PSI	SUM 9+10 PSI	ALLOW PSI
015 030	TNGT	6279 6571	5053 4977	11332 11548	32400
030 028	TNGT	6571 6420	4977 4965	11548 11385	32400
028 029	TNGT	6420 6333	4965 4974	11385 11306	32400
029 032	TNGT	6333 6281	4973 5002	11305 11283	32400
032 035	TNOT	6281 6549	5002 5033	11283 11582	32400
035 035A	TNGT	6549 6551	5033 4974	11582 11525	32400
035A 040	TNGT	6551 6555	4974 4918	11525 11473	32400
040 045 B	TNGT	6555 6539	4918 4490	11473 11029	32400
045 B 045 M	BEND	6908 6941	8174 7826	15081 14807	32400
045 M 045 E	BEND	6981 6937	7826 6916	14807 13813	32400
045 E 050	TNGT	6530 7443	3796 5841	10326 13326	32400
050 050A	TNOT	7443 6826	5841 2636	13324 9462	32400
050A 055	TNGT	6826 6937	2636 2547	9462 9485	32400
055 060 B	TNOT	6937 6730	2547 2554	9485 9292	32400
060 B 060 M	BEND	7180 6673	4669 5041	11829 11714	32400
060 M 060 Z	BEND	6673 6446	5041 5364	11714 11610	32400

** EXCEEDED ALLOWABLE

2C159RC5037 ALL PIPE BREAK LOCATIONS NE101/H4 GARD/S4 (S03606) 10/28/97 S03606 PAGE 44

CODE SC3W78, CLASS 2

FROM	ELEMENT TO	TYPE TITLE	EQN 9 PSI	EQN 10 PSI	SUM 9+10 PSI	ALLOW PSI
060 E		TNGT	6201	2946	9147	32400
065			6299	3016	9315	
065		TNGT	6299	3016	9315	32400
067			6695	3158	9853	
067A		TNGT	6695	3158	9853	32400
067A			6873	3217	10091	
067A		TNGT	6873	3217	10091	32400
070			7060	3277	10337	
070		TNGT	7060	3277	10337	32400
071			6702	3672	10374	
071A		TNGT	6702	3672	10374	32400
071A			6473	4222	10694	
072		TNGT	6473	4222	10694	32400
072			6432	4779	11212	
072A		TNGT	6432	4779	11212	32400
072A			6328	5240	11568	
072A		TNGT	6328	5240	11568	32400
075			6403	5710	12112	
080 B		TNGT	6403	5710	12112	32400
080 M		BEND	6174	9567	15741	32400
080 M			6183	9406	15589	
080 M		BEND	6183	9406	15589	32400
080 X			6371	9507	15878	
080 E		TNGT	6146	5222	11368	32400
085			6223	5274	11497	
085		TNGT	6223	5274	11497	32400
086			6207	5376	11583	
086A		TNGT	6160	5703	11863	32400
086A			6130	6178	12308	

** EXCEEDED ALLOWABLE

DCP# 96-2843-2, SUPP. 0 page 1919 of _____

DCN# 9704763 page 104 of 134

2C159BC5037 ALL

PIPE BREAK LOCATIONS

ME101/H4 GAZU/54

(803406) 10/28/97 803406 PAGE

45

DCP# 96-2843-2, SUPP.0 page 1070 of —DCN# 9704763 page 105 of 134

CODE SC3W75, CLASS 2

ELEMENT FROM TYPE TO TITLE		EON 9 PSI	EON 10 PSI	SUM 9+10 PSI	ALLOW PSI
087	TNGT	6130	6178	12308	32400
090 B		6127	6258	12385	
090 B	BEND	6345	11394	17739	32400
090 M		6334	12100	18435	
090 M	BEND	6334	12100	18435	32400
090 E		6324	11728	18053	
090 E	TNGT	6112	6442	12554	32400
090A		6362	5273	11635	
090A	TNGT	6362	5273	11635	32400
094		7245	4209	11454	
094A	TNGT	7100	4014	11113	32400
094A		6970	3819	10790	
092	TNGT	6970	3819	10790	32400
092A		6450	2098	8548	
092A	TNGT	6450	2098	8548	32400
095 B		6785	882	7666	
095 B	BEND	7243	1605	8848	32400
095 M		7206	1612	8818	
095 M	BEND	7206	1612	8818	32400
095 E		7142	1574	8716	
095 E	TNGT	6711	864	7575	32400
097		7211	1445	8656	
097A	TNGT	6197	682	6879	32400
097A		6670	1024	7694	
099	TNGT	6670	1024	7694	32400
100 B		6552	964	7515	
100 B	BEND	6925	1755	8679	32400
100 M		6801	2111	8912	

** EXCEEDED ALLOWABLE

2C159RC5037 ALL

PIPE BREAK LOCATIONS

ME101/N6 GABU/54

(S03406) 10/28/97 S03406 PAGE

46

CODE SC3W76, CLASS 2

ELEMENT FROM TO	TYPE TITLE	EQN 9 PSI	EQN 10 PSI	SUM 9+10 PSI	ALLOW PSI
100 W	BEND	6801	2111	8912	32400
100 Z		6833	3237	10070	
100 E	TNGT	6484	1778	8262	32400
101		6535	2271	8806	
101	TNGT	6535	2271	8806	32400
11A		6573	2629	9202	
11B	TNGT	6573	2629	9202	32400
11B		6590	4001	10591	
11B	TNGT	6590	4001	10591	32400
102 B	BEND	6980	9845	16826	32400
102 M		6968	14473	21441	
102 M	BEND	6968	14473	21441	32400
102 E		6979	16168	23148	
102 E	TNGT	6591	8881	15472	32400
10A		6679	8714	15393	
105	TNGT	6679	8714	15393	32400
105		8098	9992	18090	
110	TNGT	8098	9992	18090	32400
110		8190	9936	18126	

** EXCEEDED ALLOWABLE

DCP# 96-2843-2, SUPP. 0 page 187 of 187DCN# 9704763 page 106 of 134



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438001SUBJECT FW-PIPING FROM S.G. 1D TO MSCALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____ORIGINATOR PANI

DATE

3/1/98CHK, VSEDCP# 96-2843-2, SUPP. 0 page 181 of

DCN# 9704763

Page 107 of 134

ATTACHMENT 4.0 STRESS ISOMETRICS

TOTAL NO OF SHEETS

4

LARGE DOCUMENT CROSS REFERENCE

THE FOLLOWING IMAGES(S)
RELATED TO STI 30486219

PG #	DIN #
108	28928834
109	28929062
110	28929222

DIN # already in Oracle 5-9-00

WILL BE AVAILABLE IN HARDCOPY UNTIL IMAGE
LOCATION IS UPDATED ON ORACLE.

CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438001

OBJECT FW-PIPING FROM S.G. 1D TO M5

ORIGINATOR PANI GB

DATE 3/1/98

3/1/98

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

DCP# 96-2843-2, SUPP. 0 page 1 of 134

DCN# 9704763

Page 111 of 134

ATTACHMENT 5.0 LOCAL STRESS EVALUATIONS FOR IWAS TOTAL NO OF SHEETS

4



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438001

SUBJECT FW-PIPING FROM S.G. 1D TO PEN. # M-5

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE _____

DCP# 96-2843-2, SUPP. 0 page 1 of 134

DCN# 9704763

Page 112 of 134

NOTES FOR LOCAL STRESS EVALUATIONS AT INTEGRAL WELDED ATTACHMENTS (IWAs) :

1. THE FOLLOWING 3 CASES APPLY FOR EACH IWA EVALUATION

DESCRIPTION	LOADINGS CONSIDERED	ALLOWABLE STRESS
CASE 1 (PRIMARY UPSET)	WT + OBEI	1.5 Sm
CASE 2 (PRIMARY PLTD.)	WT + HIGHER OF (SSEI; LOCA; JET; DBA; WAT. HAMMER)	3.0 Sm
CASE 3 (PRIM. + SECY. UPSET)	WT + THRM + OBEI + OBESAM	3.0 Sm

2. REDUCED PIPE WALL THICKNESS TO CORRESPOND TO $D_m/(2T) = 5$ USED CONSERVATIVELY IF $D_m/(2T)$ IS LESS THAN 5.
3. REDUCED ATTACHMENT DIAMETER USED CONSERVATIVELY FOR CIRCULAR ATTACHMENTS TO CORRESPOND TO $d_o/D_o = 0.7$ IF ACTUAL $d_o/D_o > 0.7$

REDUCED ATTACHMENT DIMENSIONS USED CONSERVATIVELY FOR SQUARE ATTACHMENTS TO CORRESPOND TO C_1/D_m OR $C_2/D_m = 0.7$ IF THE ACTUAL RATIOS ARE > 0.7

REDUCED ATTACHMENT DIMENSIONS USED CONSERVATIVELY FOR RECTANGULAR ATTACHMENTS TO CORRESPOND TO C_1/D_m OR $C_2/D_m = 0.5$ IF THE ACTUAL RATIOS ARE > 0.5

4. FOR IWAs WITH WRAPPER PLATES, EVALUATIONS ARE MADE FOR PIPE-PAD INTERFACE AS WELL AS PAD-ATTACHMENT INTERFACE.
5. THE SH AND SA VALUES ARE ADJUSTED FOR ME101LS PROGRAM PURPOSES ONLY TO CORRESPOND WITH THE USE OF 1.5Sm FOR PRIMARY UPSET & 3Sm FOR PRIMARY FAULTED AS WELL AS PRIMARY PLUS SECONDARY UPSET.
 $SH=1.5Sm/1.2$; $SA=3Sm-(1.5/1.2)Sm=1.75Sm$.

REF: Calc. No. JC-FW-9018-HL5006 Rev. 3

Calc. No. JC-FW-9018-HL5007 Rev. 1

Calc. No. JC-FW-1018-HL5014 Rev. 0

LOCAL STRESS ANALYSIS FOR PIPING SYSTEM

ME101/E4 GAEU/S4

06/25/98 11:53:10 PAGE 1

I N P U T I N A C S

```

-----1-----2-----3-----4-----5-----6-----7-----8

1  STPI SGR-IWAB MFND:DP 050 HL5007; 097 HL5006; 009 HL5014
2  LDC
3  VD=17.063,VT=0.937,C1=12.600,C2=12.600,SHA=CIR,
4  CAS+UP,PR1=7.4830,SEC=5.8410,SE=21.625,SA=30.275,
5  P=00000..VC=2094.00,VL=000..MT=000000,NC=24539.,ML=000.00;
6  LDC
7  VD=17.063,VT=0.937,C1=12.600,C2=12.600,SHA=CIR,
8  CAS+PA,PR1=31.088,SEC=5.8410,SE=21.625,SA=30.275,
9  P=00000..VC=45493.0,VL=000..MT=000000,NC=33293,ML=000.00;
10 LDC
11 VD=17.063,VT=0.937,C1=12.600,C2=12.600,SHA=CIR,
12 CAS+PS,PR1=7.4830,SEC=5.8410,SE=21.625,SA=30.275,
13 P=00000..VC=2197.00,VL=000..MT=000000,NC=25746.,ML=000.00,
14 LDC
15 VD=17.063,VT=0.937,C1=10.750,C2=10.750,SHA=CIR,
16 CAS+UP,PR1=7.2110,SEC=1.4450,SE=21.625,SA=30.275,
17 P=2390..VC=00000.00,VL=000..MT=000000,NC=000000..ML=000.00,
18 LDC
19 VD=17.063,VT=0.937,C1=10.750,C2=10.750,SHA=CIR,
20 CAS+PA,PR1=15.726,SEC=1.4450,SE=21.625,SA=30.275,
21 P=37349..VC=00000.00,VL=000..MT=000000,NC=000000..ML=000.00,
22 LDC
23 VD=17.063,VT=0.937,C1=10.750,C2=10.750,SHA=CIR,
24 CAS+PS,PR1=7.2110,SEC=1.4450,SE=21.625,SA=30.275,
25 P=33999..VC=00000.00,VL=000..MT=000000,NC=000000..ML=000.00,
26 LDC
27 VD=15.157,VT=0.843,C1=1.5000,C2=6.0000,SHA=REC,
28 CAS+UP,PR1=6.1570,SEC=5.9140,SE=21.625,SA=30.275,
29 P=00000..VC=00000.00,VL=6700..MT=000000,NC=000000..ML=10050.,
30 LDC
31 VD=15.157,VT=0.843,C1=1.5000,C2=6.0000,SHA=REC,
32 CAS+PA,PR1=13.488,SEC=5.9140,SE=21.625,SA=30.275,
33 P=00000..VC=00000.00,VL=6700..MT=000000,NC=000000..ML=10050.,
34 LDC
35 VD=15.157,VT=0.843,C1=1.5000,C2=6.0000,SHA=REC,
36 CAS+PS,PR1=6.1570,SEC=5.9140,SE=21.625,SA=30.275,
37 P=00000..VC=00000.00,VL=6700..MT=000000,NC=000000..ML=10050..

```

HL5007
(050)HL5006
(097)HL5014
(009)

NOTE: LOADS & GENERAL PIPING STRESSES USED IN LOCAL STRESS ANALYSIS
 VS - ACTUAL VALUES ARE NOT SIGNIFICANTLY DIFFERENT.
 .. No Impact.

Tebaharungi 7/14/98

Allison Sam 7/21/98

LOCAL STRESS ANALYSIS FOR PIPING SYSTEM

ME101/W4 GAEU/S4

06/25/98 PIS310 PAGE 2

DCP# 96-2843-2, SUPP. 0 page 139 of —DCN# 9704763 page 114 of 134SUMMARY TABLE
(KSI)

CASE	PIPING		LOCAL		COMBINED	ALLOWABLE	MAX SHEAR	ALLOWABLE
	PRIMARY	SECONDARY	PRIMARY	SECONDARY + PRIMARY				
1	7.5	.0	.6	.0	8.1	26.0	.0	.0
2	31.1	.0	13.8	.0	44.9	51.9	.0	.0
3	7.3	5.1	.0	2.5	18.8	51.9	.0	.0
4	7.3	.0	.4	.0	7.6	26.0	.0	.0
5	15.7	.0	5.4	.0	21.1	51.9	.0	.0
6	7.3	3.1	.0	1.3	10.0	51.9	.0	.0
7	6.2	.0	1.3	.0	7.5	26.0	.0	.0
8	13.5	.0	1.3	.0	14.8	51.9	.0	.0
9	6.2	5.9	.0	2.9	14.9	51.9	.0	.0

{ HL5007 (050)
 { HL5006 (057)
 { HL5014 (009)



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438001SUBJECT FW-PIPING FROM S.G. 1D TO M5ORIGINATOR PANI -EB
CHK. INSSDATE 3/1/983/1/98CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

DCP# 96-2843-2, SUPP. 0 page 190 of

DCN# 9704763

Page 115 of 134

ATTACHMENT 6.C EVALUATION OF GENERIC IWA CALCULATION

TOTAL NO OF SHEETS

12

Attachment 6

Title: EVALUATION OF GENERIC IWA CALCULATION

This evaluation is to assess the fatigue effects on new and existing IWAs for the main feedwater (MFW) lines (4 loops). The pipe stress calculation revision is due to the SGR pipe modifications and the evaluation is in accordance with the commitments and requirements of reference 2.

The fatigue effects on piping systems are evaluated with EQ10 and EQ11 of ASME Section III NB3600 (see reference 2, 3 & 4) based on thermal range and OBE range loads.
(Below)

Based on a review of all the supports with IWAs (see attached tables) and a comparison of thermal/ OBE loads and stresses between:

- a. the existing analysis (pre-SGR)
- b. the new analysis (post-SGR)
- c. the loads for feedwater support FW-9012-HL5010 selected in reference 1 for fatigue evaluation (see reference 1);

the following two supports of Loop A are selected for evaluation: HL5001 and HL5006.

Based on the results of this evaluation, it is concluded that the modifications made to the MFW (4 loops) due to the SGR modifications have no significant impact on the generic calculation (reference 1) performed to comply with the commitment made in reference 2, in regard to the elimination of arbitrary intermediate breaks.

Note: The evaluation for design loads (weight, SSE, water hammer, etc.) has been performed for all supports with IWAs. See attachment 5, "Local Stress Evaluation for IWAs".

References:

1. Calculation 2L029RC-9585, Rev 0; Fatigue Analysis for ASME 2/3 Piping with Integral Attachments.
2. SER NUREG 0781.
3. ASME B&PV Code Case N-122, 1983.
4. ASME B&PV Code Case N-391, 1983.
5. ASME B&PV Code Case N-318-4, 1989.
6. ASME B&PV Code Case N-392-1, 1989.

Supp. O
DCP# 96-2843-2; page 191 of _____
Originator: C.Basavaraju Date: _____

DCN# 9704763 ; page 117 of 134

EVALUATION OF GENERIC IWA CALCULATION

Support No.: HL5006 (Data Point 85)
Code Case N-391 Methodology

Pipe/ Stanchion Properties

$$D_o := 18.0 \text{-in}$$

$$T := 0.937 \text{-in}$$

Pipe OD & thickness

$$d_o := 8.625 \text{-in}$$

$$t := 0.5 \text{-in}$$

Stanchion OD & thickness

$$h := 8.968 \text{-in}$$

Moment arm length

$$r_o := \frac{d_o}{2} \quad r_i := \frac{d_o - 2t}{2}$$

Stanchion outside & inside radius

$$A_T := \frac{\pi}{2} (r_o^2 - r_i^2)$$

$$A_T = 6.381 \text{-in}^2$$

$$Z_T := \frac{\pi}{4} \frac{(r_o^4 - r_i^4)}{r_o}$$

$$Z_T = 24.5 \text{-in}^3$$

Calculate C_N coefficient

$$\gamma := \frac{D_o}{2 \cdot T} \quad \gamma = 9.605$$

$$\tau := \frac{t}{T}$$

$$\tau = 0.534$$

$$\beta := \frac{d_o}{D_o} \quad \beta = 0.479$$

$$A_{op} := 0.51 \quad n_1 := 1.01 \quad n_2 := 0.79 \quad n_3 := 0.89 \quad \text{Run pipe properties}$$

$$C_{N\text{pipe}} := A_{op} \cdot (2 \cdot \gamma)^{n_1} \cdot \beta^{n_2} \cdot \tau^{n_3} \quad C_{N\text{pipe}} = 3.227$$

$$A_{oa} := 0.84 \quad n_1 := 0.85 \quad n_2 := 0.80 \quad n_3 := 0.54 \quad \text{Stanchion properties}$$

$$C_{N\text{att}} := A_{oa} \cdot (2 \cdot \gamma)^{n_1} \cdot \beta^{n_2} \cdot \tau^{n_3} \quad C_{N\text{att}} = 4.096$$

$$C_N := 4.096 \quad \text{Maximum of 2 values}$$

Based on Reanalysis

Support Loads

$$R_1 := 7725 \text{-lbf} \quad \text{Thermal positive load}$$

Pipe Stresses

$$S_{10} := 8840 \text{-psi} \quad \left(i \cdot \frac{M}{Z} \right) \quad \text{Thermal + SAM range}$$

$$R_2 := -11909 \text{-lbf} \quad \text{Thermal negative load}$$

(EQ10 with SIF=1.0)

$$R_{obe} := 1833 \text{-lbf} \quad \text{OBE load}$$

$$S_{th} := 6856 \text{-psi} \quad \left(i \cdot \frac{M}{Z} \right) \quad \text{Thermal Normal}$$

(with SIF=1.0)

$$R_{sam} := 328 \text{-lbf} \quad \text{SAM load}$$

$$S_9 := 1062 \text{-psi} \quad \left(i \cdot \frac{2 \cdot M}{Z} \right) \quad \text{OBE range}$$

(with SIF=1.0)

Supp. O
 DCP# 96-2843-2; page 113 of _____
 Originator: C.Basavaraju Date: _____

DCN# 9704763 ; page 118 of 134

EVALUATION OF GENERIC IWA CALCULATION
 Support No.: HL5006 (Data Point 85)
Code Case N-391 Methodology

EQ10: Reference 1, page 152 & 153
 Reference 4

$$S_n = \frac{C_1 \cdot P_o \cdot D_o}{2 \cdot T} + C_2 \cdot \frac{D_o}{2 \cdot I} \cdot M_i + S_{NT}$$

$$S_{NT} = \frac{Q_1}{A_T} + \frac{C_N M_N}{Z_T} + 1.7 \cdot E \cdot \alpha \cdot |T_T - T_W|$$

$$\frac{C_1 \cdot P_o \cdot D_o}{2 \cdot T} = 4985 \text{ psi} \quad \text{Not affected, use same value}$$

$$1.7 \cdot E \cdot \alpha \cdot (T_T - T_W) = 32071 \text{ psi} \quad \text{Conservative, use same value}$$

$$C_2 \cdot \frac{D_o}{2 \cdot I} \cdot M_i = S_{10} + S_g = 8840 \text{ psi} + 1062 \text{ psi} = 9902 \text{ psi}$$

$$Q_1 := \left[\frac{(R_1 - R_2) + 2 \cdot (R_{obe} + R_{sam})}{2} \right] \quad Q_1 = 11978 \text{ lbf}$$

$$M_N := Q_1 \cdot h \quad M_N = 107419 \text{ in-lbf}$$

$$\frac{Q_1}{A_T} = 1877 \text{ psi}$$

$$\frac{C_N M_N}{Z_T} = 17948 \text{ psi}$$

$$S_n := 4985 \text{ psi} + 32071 \text{ psi} + 9902 \text{ psi} + 1877 \text{ psi} + 17948 \text{ psi} \quad S_n = 66783 \text{ psi} > 3S_m = 51900 \text{ psi}$$

EQ12:

$$C_2 \cdot \frac{D_o}{2 \cdot I} \cdot M_i = S_{10} = 8840 \text{ psi} < 3S_m - \text{O.K.}$$

EQ13:

$$\frac{C_1 \cdot P_o \cdot D_o}{2 \cdot T} + C_2 \cdot \frac{D_o}{2 \cdot I} \cdot M_i = 4985 \text{ psi} + S_g = 4985 \text{ psi} + 1062 \text{ psi} = 6047 \text{ psi} < 3S_m - \text{O.K.}$$

$$\Delta T \leq \frac{y \cdot S_y}{0.7 \cdot E \cdot \alpha} \cdot C_u \quad \text{Check for ratcheting}$$

$$164.7 \leq \frac{0.8 \cdot 29000}{0.7 \cdot 28.607} \cdot 1.1 = 214.5 - \text{O.K.}$$

DCP# 96-2843-2; page 1994 of
 Originator: C.Basavaraju Date:

DCN# 9704763 ; page 119 of 134

EVALUATION OF GENERIC IWA CALCULATION
 Support No.: HL5006 (Data Point 85)
Code Case N-391 Methodology

EQ11 (Calculated for load pair 2:4, Highest usage factor)

Reference 1, page 153 - 155

Reference 4

$$S_P = \frac{K_1 \cdot C_1 \cdot P_o \cdot D_o}{2 \cdot T} + \left(K_2 \cdot C_2 \cdot \frac{D_o}{2 \cdot I} \cdot M_i \right) + \frac{1}{2 \cdot (1 - v)} \cdot K_3 \cdot E_a \cdot |\Delta T_1| + \frac{1}{1 - v} \cdot E \cdot \alpha \cdot |\Delta T_2| + S_{PT}$$

$$S_{NT} = \frac{Q_1}{A} + \frac{C_N \cdot M_N}{Z_T} - 1.7 \cdot E \cdot \alpha \cdot |T_T - T_w|$$

$$S_{PT} = K_T \cdot S_{NT}$$

$$\frac{K_1 \cdot C_1 \cdot P_o \cdot D_o}{2 \cdot T} = 1172 \text{psi Not affected, use same value}$$

$$\frac{1}{2 \cdot (1 - v)} \cdot K_3 \cdot E_a \cdot |\Delta T_1| = 7284 \text{psi Conservative, use same value}$$

$$\frac{1}{1 - v} \cdot E \cdot \alpha \cdot |\Delta T_2| = 2719 \text{psi Conservative, use same value}$$

$$1.7 \cdot E \cdot \alpha \cdot (T_T - T_w) = 11846 \text{psi Conservative, use same value}$$

$$K_2 \cdot C_2 \cdot \frac{D_o}{2 \cdot I} \cdot M_i = 0.76 S_{th} = 0.76(6856 \text{psi}) = 5211 \text{psi}$$

{0.76 = [(440 - 300)/(440 - 70)]^2 : load factor for transient for pair 2:4}

$$Q_1 := 0.76 \cdot \frac{R_1}{2} \quad Q_1 = 2936 \text{lbf}$$

$$M_N := Q_1 \cdot h \quad M_N = 26326 \text{in-lbf}$$

$$\frac{Q_1}{A_T} = 460 \text{psi}$$

$$\frac{C_N \cdot M_N}{Z_T} = 4399 \text{psi}$$

$$S_{NT} = \frac{Q_1}{A_T} + \frac{C_N \cdot M_N}{Z_T} + 1.7 \cdot E \cdot \alpha \cdot (T_T - T_w) = 460 \text{psi} + 4399 \text{psi} + 11846 \text{psi} = 16705 \text{psi}$$

$$K_T := 2.0$$

$$S_{PT} = K_T \cdot S_{NT} \quad S_{PT} = 2.0 \cdot 16705 \text{psi} \quad S_{PT} = 33412 \text{psi}$$

$$S_P := 1172 \cdot \text{psi} + 7284 \cdot \text{psi} + 2719 \cdot \text{psi} + 5211 \cdot \text{psi} + 33412 \cdot \text{psi} \quad S_P = 49798 \text{psi}$$

$$S_{ALT} = \frac{K_e}{2} \cdot (S_P) \quad S_{ALT} := \frac{1.0}{2} \cdot (49798 \cdot \text{psi}) \quad S_{ALT} = 24899 \text{psi} < 30809 \text{psi from Ref 1, sheet 155}$$

Usage factor < 0.635

Supp. O
DCP# 96-2843-2; page 1995 of _____
Originator: C.Basavaraju Date: _____

DCN# 9704763 ; page 120 of 134

EVALUATION OF GENERIC IWA CALCULATION

Support No.: HL5001 (Data Point 95B)

Code Case N-122 Methodology

Pipe/ Rectangular Attachment Properties

$$D_o := 18.0 \text{-in} \quad t := 0.937 \text{-in} \quad \text{Pipe OD & thickness}$$

$$r := \frac{D_o - t}{2} \quad r = 8.532 \text{-in} \quad \text{Mean pipe radius}$$

$$L_1 := \frac{9.5}{2} \text{-in} \quad L_1 = 4.75 \text{-in}$$

$$L_2 := \frac{8}{2} \text{-in} \quad L_2 = 4 \text{-in} \quad \text{Dimensions for } 5/8" \times 8" \times 9.5" \text{ Wrapper Plate}$$

Calculate C_T coefficient

$$\gamma := \frac{r}{t} \quad \gamma = 9.105 \quad \beta_2 := \frac{L_2}{r} \quad \beta_2 = 0.469 \quad \beta_1 := \frac{L_1}{r} \quad \beta_1 = 0.557$$

$$\beta_1 \cdot \beta_2 = 0.261 > 0.075 \quad \beta_1 \times \beta_2 < 0.075 : \text{Calculate reduced } L_1, L_2$$

$$\beta_1 := \sqrt{0.075} \quad \beta_1 = 0.274 \quad \beta_2 := \beta_1$$

$$L_1 := \beta_1 \cdot r \quad L_1 = 2.336 \text{-in} \quad L_2 := \beta_2 \cdot r \quad L_2 = 2.336 \text{-in}$$

$$A_o := 2.2 \quad \theta := 40 \text{-deg} \quad X_o := 0 \quad Y_o := 0.05 \quad \text{Thrust load constants}$$

$$Y_1 := Y_o + \log(\beta_2) \quad Y_1 = -0.512$$

$$X_1 := X_o + \log(\beta_1) \quad X_1 = -0.562$$

$$\eta := - (X_1 \cdot \cos(\theta) + Y_1 \cdot \sin(\theta)) - \frac{1}{A_o} \cdot (X_1 \cdot \sin(\theta) - Y_1 \cdot \cos(\theta))^2 \quad \eta = 0.76$$

$$C_T := 7.64 \cdot \gamma^{1.64} \cdot \beta_1 \cdot \beta_2 \cdot \eta^{1.54} \quad C_T = 14.051$$

$$A_1 := 4 \cdot L_1 \cdot L_2 \quad A_1 = 21.836 \text{-in}^2$$

Based on Reanalysis

Support Loads

$$R_1 := 17511 \text{-lbf} \quad \text{Thermal maximum load}$$

$$R_2 := 8418 \text{-lbf} \quad \text{Thermal minimum load}$$

$$R_{obe} := 3702 \text{-lbf} \quad \text{OBE load}$$

$$R_{sam} := 4244 \text{-lbf} \quad \text{SAM load}$$

Pipe Stresses

$$S_{10} := 5549 \text{-psi} \quad \left(i \cdot \frac{M}{Z} \right) \quad \text{Thermal + SAM range}$$

(EQ10 with SIF=1.0)

$$S_{th} := 2913 \text{-psi} \quad \left(i \cdot \frac{M}{Z} \right) \quad \text{Thermal Normal}$$

(with SIF=1.0)

$$S_9 := 886 \text{-psi} \quad \left(i \cdot \frac{2 \cdot M}{Z} \right) \quad \text{OBE range}$$

(with SIF=1.0)

Supt. D
DCP# 96-2843-2; page 1996 of _____
Originator: C.Basavaraju Date: _____

DCN# 9704763 ; page 121 of 134

EVALUATION OF GENERIC IWA CALCULATION

Support No.: HL5001 (Data Point 95B)
Code Case N-122 Methodology

EQ10: Reference 1, page 152, 153 & 161, 162
Reference 3

$$S_n = \frac{C_1 \cdot P_o \cdot D_o}{2 \cdot T} + C_2 \cdot \frac{D_o}{2 \cdot I} \cdot M_i + S_{nl}$$

$$S_{nl} = \frac{C_T \cdot W}{A_1}$$

$$\frac{C_1 \cdot P_o \cdot D_o}{2 \cdot T} = 4985 \text{ psi} \quad \text{Not affected, use same value}$$

$$C_2 \cdot \frac{D_o}{2 \cdot I} \cdot M_i = S_{10} + S_g = 5549 \text{ psi} + 886 \text{ psi} = 6435 \text{ psi}$$

$$W := [(R_1 - R_2) + 2 \cdot (R_{obe} + R_{sam})] \quad W = 24985 \text{ lbf}$$

$$S_{nl} = \frac{C_T \cdot W}{A_1} = 16077 \text{ psi}$$

$$S_n := 4985 \text{ psi} + 6435 \text{ psi} - 16077 \text{ psi}$$

$$S_n = 27497 \text{ psi} < 3Sm = 51900 \text{ psi}$$

O.K.

DCP# 96-2843-2; page 199 of _____
 Originator: C.Basavaraju Date: _____

DCN# 9704763; page 122 of 134

EVALUATION OF GENERIC IWA CALCULATION
 Support No.: HL5001 (Data Point 95B)
Code Case N-122 Methodology

EQ11 (Calculated for load pair 2:4, Highest usage factor)

Reference 1, page 152, 153 & 161, 162

Reference 3

$$S_p = \frac{K_1 \cdot C_1 \cdot P_o \cdot D_o}{2 \cdot T} + \left(K_2 \cdot C_2 \cdot \frac{D_o}{2 \cdot I} \cdot M_i \right) + \frac{1}{2 \cdot (1 - v)} \cdot K_3 \cdot E_a \cdot |\Delta T_1| + \frac{1}{1 - v} \cdot E \cdot \alpha \cdot |\Delta T_2| + S_{pl}$$

$$S_{pl} = [K_1 \cdot (1.5 + 0.537 \cdot \beta_1 \cdot \beta_2 \cdot \gamma) - 1] \cdot P_o \cdot \frac{D_o}{2 \cdot t} + K_1 \cdot (S_{nl}) + K_1 \cdot E \cdot \alpha \cdot |T_1 - T_w|$$

$$\frac{K_1 \cdot C_1 \cdot P_o \cdot D_o}{2 \cdot T} = 1172 \text{ psi} \quad \text{Not affected, use same value}$$

$$\frac{1}{2 \cdot (1 - v)} \cdot K_3 \cdot E_a \cdot |\Delta T_1| = 7284 \text{ psi} \quad \text{Conservative, use same value}$$

$$\frac{1}{1 - v} \cdot E \cdot \alpha \cdot |\Delta T_2| = 2719 \text{ psi} \quad \text{Conservative, use same value}$$

$$E \cdot \alpha \cdot |T_1 - T_w| = \frac{11846 \text{ psi}}{1.7} = 6968 \text{ psi} \quad \text{Conservative, use same value}$$

$$K_2 \cdot C_2 \cdot \frac{D_o}{2 \cdot I} \cdot M_i = 0.76 S_{th} = 0.76(2913 \text{ psi}) = 2214 \text{ psi}$$

$\{0.76 = [(440 - 300)/(440 - 70)]^2 : \text{load factor for transient for pair 2:4}\}$

$K_1 := 2.0$ for fillet weld on four sides (as-welded)

$$[K_1 \cdot (1.5 + 0.537 \cdot \beta_1 \cdot \beta_2 \cdot \gamma) - 1] \cdot P_o \cdot \frac{D_o}{2 \cdot t}$$

$$[K_1 \cdot (1.5 + 0.537 \cdot \beta_1 \cdot \beta_2 \cdot \gamma) - 1] \cdot 1172 \cdot \text{psi} = 3204 \cdot \text{psi}$$

$$W := 0.76 \cdot R_1 \quad W = 13308 \cdot \text{lbf}$$

$$S_{nl} = \frac{C_T \cdot W}{A_I} \approx 8564 \cdot \text{psi}$$

$$K_1 \cdot \frac{C_T \cdot W}{A_I} = 17127 \cdot \text{psi}$$

$$K_1 \cdot E \cdot \alpha \cdot |T_1 - T_w| = 2 \times 6968 \text{ psi} = 13936 \text{ psi}$$

$$S_p := 1172 \cdot \text{psi} + 2214 \cdot \text{psi} + 7284 \cdot \text{psi} + 2719 \cdot \text{psi} + 3204 \cdot \text{psi} + 17127 \cdot \text{psi} + 13936 \cdot \text{psi} \quad S_p = 47656 \cdot \text{psi}$$

$$S_{ALT} = \frac{K_e}{2} \cdot (S_p) \quad S_{ALT} := \frac{1.0}{2} \cdot (47656 \cdot \text{psi}) \quad S_{ALT} = 23828 \cdot \text{psi} < 30809 \text{ psi from Ref 1, sheet 155}$$

Usage factor < 0.635






DCP# 96-2843-2, SUPP.O, page 1998d DCN#9704763 page 123 of 134
 STP-I SGR ASSESSMENT OF IMPACT ON IWA GENERIC CALC. # RC9585
 MFW SYSTEM: MFWA

IWA#	CASE	PREVIOUS	NEW	CASE	PREVIOUS	NEW	COMMENT
		LOADS	LOADS		STRESS	STRESS	
		LB	LB		PSI	PSI	
HL5006 Y RGD)	WT	-4364	-5824	EQ.8	6413	18563*	18"φ, SCH 80 8"φ, SCH 80 (TYP) ALL AROUND
	THMAX	1612	7725*	EQ.10/11	14712		
	THMIN	1475	-11909*				
	OEESAM	419	328				
	OEE	1594	1833	EQ.9B	6531	7202	
HL5001 (95B X RGD)	WT	-595	-976	EQ.8	5765	6926	6"φ, SCH. 80 18"φ SCH. 80 5/8" x 8" x 9 1/2" ALL AROUND
	THMAX	11745	17511*	EQ.10/11	6906	11652	
	THMIN	-6186	8418*				
	OEESAM	4173	4244				
	OEE	3971	3702	EQ.9B	7680		
HL5010 (10A ZRGD)	WT	-224	-276	EQ.8	6292	20608	18"φ, SCH. 80 12"φ, SCH. 80 ALL AROUND
	THMAX	11289	5714	EQ.10/11	19617		
	THMIN	1808	1336				
	OEESAM	2902	3600				
	OEE	2914	3008	EQ.9B	6563	6938	
HL5002 (50 X SNB)	WT			EQ.8	5687	12202*	18"φ, SCH. 80 5/8" x 10 1/2" TS. 6"φ, SCH. 60 ALL AROUND
	THMAX			EQ.10/11	7061		
	THMIN						
	OEESAM	1569	1380				
	OEE	1561	2110	EQ.9B	6523	6310	
HL5005 (80 Z SNB) INCLUDED IN GENERIC STUDY CALC# RC9585	WT			EQ.8	6140	16371	18"φ, SCH. 80 8" x 8 1/2" TS. 5/8" x 10 1/2" TS. ALL AROUND
	THMAX			EQ.10/11	13882		
	THMIN						
	OEESAM	1668	1257				
	OEE	2974	2634	EQ.9B	6531	7014	

DCP# 96-2843-2, SUPPL. O page 1999 of

DCN# 9704763 page 124 of 134

MFW SYSTEM: MI WB


IWA#	CASE	PREVIOUS	NEW	CASE	PREVIOUS	NEW	COMMENT
		LOADS	LOADS		STRESS	STRESS	
		LB	LB		PSI	PSI	
HL5011 (10A Z RGD)	WT	-211	101	EQ.8		5798	
	THMAX	-1599	651	EQ.10/11	9500	9916	
	THMIN	-9213	-10023				
	OEESAM	2085	3312				
	OEE	2415	2308	EQ.9B	6096	6288	
HL5012 (027 SK SNB)	WT			EQ.8		5650	
	THMAX			EQ.10/11	11254	10382	
	THMIN						
	OEESAM	756	499				
	OEE	1003	1622	EQ.9B	6364	6724	
HL5001 (050 X SNB)	WT			EQ.8		6022	
	THMAX			EQ.10/11	5404	5615	
	THMIN						
	OEESAM	1516	1493				
	OEE	1957	2977	EQ.9B	6594	7212	
HL5003 (080 Z SNB)	WT			EQ.8		5781	
	THMAX			EQ.10/11	13775	14797	
	THMIN						
	OEESAM	1222	1245				
	OEE	2951	2581	EQ.9B	6643	7014	
HL5014 (009 Y SPD)	WT	-14523	EQ.8		6328	16"Ø, SCH 80	
	THMAX		EQ.10/11		6360		
	THMIN						
NEW IWA	OEE		EQ.9B		6516		

DCP# 96-2843-2, S4PP.0 page 2600 of

DCN#9704763 page 125 of 134

MFW SYSTEM: MFWC




IWA#	CASE	PREVIOUS LOADS		CASE	PREVIOUS STRESS		COMMENT
		LB	LB		PSI	PSI	
HLS012 (102 X RGD)	WT	155	773	EQ.8		6290	12"Ø, SCH.40
	THMAX	23809	18872	EQ.10/11	3031	2850	18"Ø, SCH.80
	THMIN	7315	3136				
	OBSAM	4075	3820				
	OBE	2463	2523	EQ.9B	6485	6719	3/4" x 21" x 28 1/4" ALL AROUND



DCP# 96-2843-2, SURP. O page 2001 of

DCN#9704763 page 426 of 134

MFW SYSTEM: MFWD

IWA#	CASE	PREVIOUS	NEW	CASE	PREVIOUS	NEW	COMMENT
		LOADS	LOADS	CASE	STRESS	STRESS	
		LB	LB		PSI	PSI	
HL5007 (050 Z SNB)	WT			EQ.8		6106	 ALL AXIALLY
	THMAX			EQ.10/11	2442	5841*	
	THMIN						
	OBESAM	693	207	EQ.9B	6523	7483	
	OBE	2015	4187*				
HL5006 (097 Z SNB)	WT			EQ.8		6469	 ALL AXIALLY
	THMAX			EQ.10/11	2396	1445	
	THMIN						
	OBESAM	2318	1409	EQ.9B	6506	7211	
	OBE	2084	2590				
HL5014 (009 Y SPD)	WT	-9528		EQ.8		5689	 1 1/2"x1/2"x6" (4 LUGS)
NEW IWA	THMAX			EQ.10/11		5914	
	THMIN						
	OBE			EQ.9B		6157	

* : INCREASES

THMAX & THMIN : MAX. OR MIN. OF NORMAL & UPSET THERMALS ONLY (THRMI,2,3,4,&7)



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438001SUBJECT FW-PIPING FROM S.G. 1D TO M5CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____ORIGINATOR PANI

DATE

3/1/98CHK. LVSS

DCP# 96-2843-2, SUPP. 0 page 201 of

DCN# 9704763

Page 127 of 134

ATTACHMENT 7.0 FIUEDHEAD PENETRATION LOADINGS AND EVALUATION

TOTAL NO OF SHEETS

4



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438001

SUBJECT FW-PIPING FROM S.G. 1D TO M5

CALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____

ORIGINATOR PANI

DATE _____

DCP# 96-2843-2, SUPP. 0 page 103 of

DCN# 9704763

Page 128 of 134

ASSESSMENT OF IMPACT OF SGR MODIFICATION ON FLUED HEAD PENETRATION LOADS:

FLUED HEAD PENETRATION (M-5): (LOOP -D)

CASES WHERE ALLOWABLES ARE EXCEEDED ARE SUMMARIZED BELOW WITH JUSTIFICATION.

		ACTUAL/ ALLOWABLE	PREVIOUSLY JUSTIFIED ENVELOPED LOADINGS **	COMMENT
(NORMAL PRIM)				
FA LB	856/600*	725 ***	OK	
V LB	5065/7447	6302		
MA FT LB	336/6962*	15311		
MB FT LB	11594/42130	25871		
(NORM PRI+SEC)				
FA LB	28029/41846	31298	OK	
V LB	20660/18263*	23609		
MA FT LB	8318/40976	46230		
MB FT LB	115090/260446	185309		
(UPSET PRIM)				
FA LB	16025/8517*	16660	OK	
V LB	8445/20458	11768		
MA FT LB	13887/28295	30408		
MB FT LB	39417/178058	63763		

* EXCEEDED COMPONENT

** RESULTS ACCEPTABILITY BASED ON ENVELOPED LOADINGS USED IN
CALC# 2L469RC9962 REV. 2*** SCALING THE FEA STRESS RESULTS: NORMAL PRIMARY MAX STRESS INTENSITY
 $12166(856/725) = 14364 \text{ PSI} < 17800 \text{ PSI ALLOWABLE}$

PENETRATION LOAD SUMMARY
PENETRATION NO. M-5

LOADING	OUTS DE CTMT LOADS							
	FA	FB	FC	MA	MB	MC		
	LB	LB	LB	FT LB	FT LB	FT LB		
DW	-29	-1985	0	8453	-5	10996		
TE +	3002	108	134	0	2757	0		
TE-	-278	0	0	0	0	-3292		
OBEI	13264	2634	1576	8470	10942	18349		
SSEI	26299	4314	3139	18052	21248	27963		
OBE SAM	50	445	1122	0	17128	7138		
BLD SETL	270	1784	798	0	24412	54120		
WAT HAM	39832	5307	2693	2210	11608	27948		
DBA	0	0	0	0	0	0		
LOCA	0	0	0	0	0	0		
WIND	904	2	4	0	78	35		
JET	0	0	0	0	0	0		
RUPTURE	220200	43268	43268	151400	222917	222917		
 INSIDE CTMT LOADS								
LOADING	FA	FB	FC	MA	MB	MC		
	LB	LB	LB	FT LB	FT LB	FT LB		
	DW	-827	-3080	-52	-8789	-10	-22590	
TE +	0	8593	2389	0	0	0	69315	
TE-	-27165	0	-21144	-7982	-13882	0		
OBEI	1001	350	169	5081	1581	7368		
SSEI	2408	762	414	11223	3305	16297		
OBE SAM	4266	242	9148	724	45224	2251		
BLD SETL	0	0	0	0	0	0		
WAT HAM	271747	7882	20442	36556	64210	63793		
DBA	21341	-14280	-5511	32563	95328	-112848		
LOCA	466	78	64	1761	346	1814		
WIND	0	0	0	0	0	0		
JET	0	0	0	0	0	0		
RUPTURE	0	0	0	0	0	0		
 INSIDE+OUTSIDE LOADS								
LOADING	FA	FB	FC	MA	MB	MC	V	MBR
	LB	LB	LB	FT LB	FT LB	FT LB	LB	FT LB
	DW	-856	-5065	-52	-336	-15	-11594	5065
TE +	3002	8701	2523	0	2757	69315	9059	69370
TE-	-27443	0	-21144	-7982	-13882	-3292	21144	14287
OBEI	14265	3184	1745	13551	12523	25715	3631	28602
SSEI	28707	5076	3553	27275	24553	44260	6196	50614
OBE SAM	4316	687	10270	724	63352	9389	10293	64044
BLD SETL	270	1784	798	0	24412	54120	1954	59371
WAT HAM	311579	13169	23135	38766	75818	91741	26620	118016
DBA	21341	-14280	-5511	32563	95328	-112848	15307	147722
LOCA	466	78	64	1761	346	1814	101	1847
WIND	904	2	4	0	76	35	4	84
JET	0	0	0	0	0	0	0	0
RUPTURE	220200	43268	43268	151400	222917	222917	61190	315252
D	-856	-5065	-52	-336	-15	-11594	5065	11594
D+TEP+BS	2416	5420	3269	-336	27154	111841	6330	115090
D+TEN+BS	-23029	-3281	-20398	-8318	10515	39234	20660	40819
D+OI+WND	13025	8251	1801	13887	12814	37344	8445	39417
D+OI+WND+TEP+BS	17585	8608	5018	13887	39753	137591	9962	143219
D+OI+WND+TEN+BS	43198	6467	22147	21869	23114	64984	23072	68972
D+SI+WND+WH+LO	362141	37670	32319	100029	196106	262290	49634	327496

* SEE JUSTIFICATION FOR EXCEEDANCES

PENETRATION LOAD SUMMARY
PENETRATION NO. M-6

D+SI+R	249763	53409	46873	179011	247485	278771	71061	372776
PENETRATION ALLOWABLES								
	FAA			MAA			VA	MBA
	LB			FT-LB			LB	FT-LB
D	600			6962			7447	42130
D+TEP+BS	41846			40976			18263	260446
D+TEN+BS	41846			40976			18263	260446
D+OI+WND	8517			28295			20458	178058
D+OI+WND+TEP+BS	64839			63829			34815	406829
D+OI+WND+TEN+BS	64839			63829			34815	406829
D+SI+WND+WH+LO	488016			788831			496685	946739
D+SI+R	488016			788831			496685	946739
ACTUAL TO ALLOWABLES RATIO								
	FA/FAA			MA/MAA			V/VA	MBR/MBA
D	* 1.427			0.048			0.680	0.275
D+TEP+BS	3.058			0.008			0.347	0.442
D+TEN+BS	3.870			0.203			* 1.131	0.156
D+OI+WND	* 1.882			0.491			0.413	0.221
D+OI+WND+TEP+BS	3.271			0.218			0.288	0.352
D+OI+WND+TEN+BS	3.668			0.343			0.667	0.170
D+SI+WND+WH+LO	3.742			0.127			0.100	0.346
D+SI+R	3.512			0.228			0.143	0.394

CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438001

OBJECT FW-PIPING FROM S.G. 1D TO MS

ORIGINATOR PANI T:13
CHK. WSS

DATE 3/1/98 CALC NO RC5037-P-400 R0
3/1/98 SHEET NO _____
SHEET REV _____

DCP# 96-2843-2, SUPP. 0 page 1006 of

DCN# 9704763

Page 131. of 134

ATTACHMENT 8.0 OTHER INFORMATION

TOTAL NO OF SHEETS

1

**100% REVIEW DRAFT
CALCULATION SHEET**

DCP 96-2843-2 Supp. 0 Page of
DCN 9800456 Page of

PROJECT South Texas Project
SGRP
JOB NUMBER 23438-100

SUBJECT Hydraulic Transient Analysis of Feedwater Line Break in Conjunction with
Check Valve Slam

BY J. M. Gilmer

DATE 7/17/98 SHEET NO.

SHEET REV.

9.4 MFW, Loop D Results




FIGURE 11-49. LOOP D REACTION FORCE DIAGRAM

NOT TO SCALE
FORCE IN KIPS

FEEDWATER PIPE WATERHAMMER REANALYSIS LOAD RECONCILIATION
(BETWEEN 75% AND 100%)

ATTACHMENT 1 (SHEET1-1)

BY: *H. S. G.* Date: 7-17-98
CHK'D: *A. H. K.* Date: 7-17-98

LOOP D (UNIT1)

SUPPORT MK #	DATA PT.	NEW FAULTED LOAD (Q) (DW+THERM+WH)	DESIGN LOAD (Q) (EXIST P. S. CALC.) (SEE NOTE 2)	REF. PIPE SUPPORT CALC NO.	REV. NO. DCN	COMMENTS
FW-9018-HL5002	084	+28.056/-36.853	+/-48.026	JC-FW-9018-HL5002	6 9704712	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-HL5001	086	33.804/-24.386	+/-36.2	JC-FW-9018-HL5001	4 9704713	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-HL5013 (LOWER STRUT)	11A	+70.812/-44.549	+/-118.8	JC-FW-9018-HL5013	6 9704715	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-HL5013 (UPPER STRUT)	101	+87.805/-83.276	+/-178.72	JC-FW-9018-HL5013	6 9704715	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-SS0001	015	+/- 18.086	+/-24.582	JC-FW-9018-SS0001	3 9704717	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-HL5009	035	+/- 75.21	+/-78.098	JC-FW-9018-HL5009	3 9704718	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-HL5007	050	+91.399/-89.53	+/-118	JC-FW-9018-HL5007	5 9704720	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-HL5008	055	+/- 106.633	+/-143.3	JC-FW-9018-HL5008	4 9704721	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-SS0006	065	+/- 75.981	+/-77.41	JC-FW-9018-SS0006	4 9704722	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-SS0007	085	+/- 85.825	+/-101.5	JC-FW-9018-SS0007	6 9704723	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-HL5003	092	+/- 52.336	+/-44.06	JC-FW-9018-HL5003	4 9704724	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-HL5006	097	+/- 37.873	+/-104.129	JC-FW-9018-HL5006	5 9704725	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-1018-HL5014	009	-9.528	-9.528	JC-FW-1018-HL5014	0	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-SH0001	030	-8.136	-8.136	JC-FW-9018-SH0001	3 9704726	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-9018-SH0002	070	-8.836	-8.836	JC-FW-9018-SH0002	3 9704727	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD
FW-1018-HL5016	007	+28.6/-36.7	+/-36.779	JC-FW-1018-HL5016	0	O.K. DESIGN LOAD > NEW FAULTED (WH) LOAD

NOTES:

1. CHANGE IN MOVEMENTS DUE TO REVISED WATER HAMMER TRANSIENT ANALYSIS FROM 75% TO 100% IS NEGLIGIBLE AND DOES NOT IMPACT THE EXISTING PIPE SUPPORT DESIGN.

2. MAXIMUM LOAD FOR WHICH THE PIPE SUPPORT IS QUALIFIED IS LISTED. IT IS EITHER THE LOAD FOR WHICH THE SUPPORT WAS QUALIFIED PRIOR TO 6GR OR THE 75% ANALYSIS LOAD WHICH WAS USED TO REVISE THE CALCULATION.

3. SUPPORTS NOT LISTED ABOVE HAVE BEEN REVISED TO INCORPORATE THE 100% ANALYSIS LOADS.

Attachment No. <u>9</u>
Calc. No. <u>RC5037-P-400 Rev. O</u>
Sheet No. _____



CALCULATION SHEET

PROJECT STP-SGR
JOB NO 23438001SUBJECT FW-PIPING FROM S.G. 1DCALC NO RC5037-P-400 R0
SHEET NO _____
SHEET REV _____ORIGINATOR PANI

DATE _____

DCP# 96-2843-2, SUPP. 0 page 209 of

DCN# 9704763

Page 134 of 134

ATTACHMENT 0.0.0 MICROFICHE FILES LOG

File # 1, Computer Output: FLEXIBILITY (MFWD5),
File # 2, Computer Output: WATER HAMMER (MFWDW),
File # 3, Computer Output: LOCA (MFWDL),
File # 4, Computer Output: WATER HAMMER (MFWDW7) -