

June 6, 2005

MEMORANDUM TO: Biweekly Notice Coordinator

FROM: Harold K. Chernoff, Project Manager, Section 1 /RA/
Project Directorate III
Division of Licensing Project Management

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE -
NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE (TAC NOS. MC4926 AND MC4927)

Nuclear Management Company, LLC, Docket Nos. 50-266 and 50-301, Point Beach
Nuclear Plant, Units 1 and 2, Town of Two Creeks, Manitowoc County, Wisconsin

Date of application for amendments: October 15, 2004

Brief description of amendments: The amendments revised Technical Specifications related to the reactor coolant pump flywheel inspection program by increasing the inspection interval to 20 years.

Date of issuance: June 6, 2005

Effective date: As of the date of issuance and shall be implemented within 45 days.

Amendment Nos.: 218,223

Facility Operating License Nos. DPR-24 and DPR-27: Amendments revised the Technical Specifications.

Date of initial notice in *Federal Register*: March 29, 2005 (70 FR 15945).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 6, 2005.

No significant hazards consideration comments received: No.

June 6, 2005

MEMORANDUM TO: Biweekly Notice Coordinator

FROM: Harold K. Chernoff, Project Manager, Section 1 /RA/
Project Directorate III
Division of Licensing Project Management

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE -
NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE (TAC NOS. MC4926 AND MC4927)

Nuclear Management Company, LLC, Docket Nos. 50-266 and 50-301, Point Beach

Nuclear Plant, Units 1 and 2, Town of Two Creeks, Manitowoc County, Wisconsin

Date of application for amendments: October 15, 2004

Brief description of amendments: The amendments revised Technical Specifications related to the reactor coolant pump flywheel inspection program by increasing the inspection interval to 20 years.

Date of issuance: June 6, 2005

Effective date: As of the date of issuance and shall be implemented within 45 days.

Amendment Nos.: 218, 223

Facility Operating License Nos. DPR-24 and DPR-27: Amendments revised the Technical Specifications.

Date of initial notice in *Federal Register*: March 29, 2005 (70 FR 15945).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated June 6, 2005.

No significant hazards consideration comments received: No.

DISTRIBUTION

Non-PUBLIC PDIII-1 Reading LRaghavan
HChernoff DClarke

ADAMS Accession Number: **ML051450561**

OFFICE	CLIP LPM	PDIII-1/PM	PDIII-1/LA	PDIII-1/SC
NAME	WReckley	HChernoff	DClarke	LRaghavan
DATE	05/20/05	06/02/05	05/26/05	06/02/05

OFFICIAL RECORD COPY