

9

DCS No.: 05000423041705

Date: April 18, 2005

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-I-05-17

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility

Millstone Unit 3 Power Station
Waterford, CT
Docket: 50-423

Licensee Emergency Classification

- Notification of Unusual Event
- Alert
- Site Area Emergency
- General Emergency
- Not Applicable

SUBJECT: ALERT DECLARED AT MILLSTONE 3 DUE TO A MAIN STEAM SAFETY VALVE NOT RESEATING AFTER AN SI ACTUATION ON LOW MAIN STEAM LINE PRESSURE

On April 17, 2005, at 8:29 a.m. Millstone Unit 3 experienced a reactor trip from full power. In addition to the reactor trip, one of two trains of the Safety Injection (SI) and Main Steam Isolation (MSI) subsystems actuated. Control room operators manually initiated a full SI and MSI. There were also indications that multiple main steam line safety valves (MSSVs) opened with at least one MSSV that appeared to remain open. As a result, at 8:42 a.m., Dominion Nuclear Connecticut (DNC) declared an Alert due the failure of one MSSV to close. The response of the MSSVs is under further review.

The SI and MSI signals were initially attributed to a sensed low steam line pressure on one of four steam generators. Auxiliary Feedwater (AFW) automatically actuated during the event. However, the turbine-driven AFW pump initially tripped and was successfully reset locally and restarted. Both motor-driven AFW pumps operated as expected to maintain steam generator levels. Due to the additional inventory added during the SI, the pressurizer filled and an overpressure condition caused pressurizer valves to lift and reseal. Operators responded to these conditions, stabilized the plant in Hot Standby and began a cooldown. Subsequently, the plant entered hot shutdown at 7:03 p.m. and DNC terminated the Alert at 7:05 p.m. The facts of this PN were verified with the Site Vice President - Millstone.

NRC resident inspectors responded to site, the NRC entered "monitoring" mode at 9:53 a.m., and activated the RI incident response center. The NRC, including on-site inspectors, monitored DNC's activities to stabilize the plant throughout the event including actions to place the plant in a hot shutdown condition.

DNC has established an event review team to review the root causes, extent of condition, and actions taken to address the event. The NRC staff is assessing event follow up per NRC Management Directive 8.3. Additional NRC inspection is planned to review DNC's actions including their root cause determination, safety system response including any identified equipment issues, and actions taken to mitigate the consequences of the event.

A/7

The Region I Public Affairs Office issued a press release and has responded to media inquiries. DNC issued three press releases during the event. The States of Connecticut and New York have been informed.

ADAMS Accession Number: ML051080484

CONTACT: Paul Krohn
(610) 337-5120

DISTRIBUTION: (PN Recipient List)

OWFN

Chairman Diaz
 Comm. Lyons
 Comm. Jazcko
 Comm. McGaffigan Jr.
 Comm. Merrifield

TWFN

IRO
 NMSS
 ACRS
 OIG
 RES
 NSIR

LST

PDR

OIP
 OCA
 OGC
 OPA
 EDO
 OE
 NRR
 SECY
 Regional Offices

By Fax:

DOT:Trans

INPO

NSAC

RI Resident Office

Licensee: _____

ADAMS Accession Number: ML051080484

SISP Review Complete: PGK (Reviewer's Initials)

DOCUMENT NAME: G:\DRP\BRANCH6\PNs\PNO-I-05-17 MS3 Alert - Low SG Press Sl.wpd

After declaring this document "An Official Agency Record" it will be released to the Public.
 To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRP		RI/DRP	RI/ORA		RI/DRP		RI/DRP	
NAME	SBarber/ GSB		RBores/ RJB	DScrenci/ DPS		PKrohn/ PGK		ABlough/ ARB	
DATE	04/18/05		04/18/05	04/18/05		04/18/05		04/18/05	

OFFICIAL RECORD COPY