

4/19

(16)

Lamborn / Holian - Nothing.
No announcement, yellow. Absolutely.
No cards. 4/29 last day.
Appreciate notes.

Nimitz

- 1) 1st 45 min no concern, RWST water
& low activity
- 2) T+45 to VCT, max 200 used on
floor. In area of cube.
Covered 24' elevation.
Operator & HP Tech slight foot cont
4' contaminated also.
Brown localized crud
- 3) 30K still left in cube.
Overall, 3 cont.
No intakes, local grab sampler negative.
- 4) No occupational exposure
No Iodine
No Noble gas.
Cont. on floor.

Effluent release

- 1) Stack, TB gaseous monitors showed
nothing.

A/11

2) Low level Xe^{135} 3×10^{-10} $\mu\text{Ci}/\text{ft}^3$ in
SLCRS.

400 to 500 gals to floor

265 gal RCS inv to floor

200 μCi Xe^{135} } worst case 10^{-7} μrem
35 μCi Kr^{85} } exposure

3) Tritium migrates to 20, ^{assum} all S/G's volume
14 μCi Tritium \sim -10 μrem range