

Nuclear Power Business Unit
RADIATION WORK PERMIT

CO

Revision: 0

RWP Number: 04-141

Controlling Work Document: Various RG 1.16 Class: 2 Estimated Dose: 4.320 Rem

Job Title: Nozzle Dam Install/Remove

Job Location: U1 Containment

Job Description: Remove/ Install Nozzle Dams in Steam Generators

Radiological Assessment of Work

Significant increase in radiation levels is likely? Yes No Reason: Removal of Shielding (ie, Manways, ALARA doors.)

Significant increase in contamination levels is likely? Yes No Reason: Removing nozzle dams after use.

Potential for internal dose? Yes No Reason: Removing nozzle dams after use.

RWP Tasks

Task 1: Remove and Install Nozzle Dams

Task 2:

Task 3:

Task 4:

Task 5:

Task 6:

Task 7:

Task 8:

Task 9:

Task 10:


Task 11:

Task 12:

RWP Review and Approval

Prepared By: CD 2/24/04
Initials Date

ALARA Review By: WWL 2-24-04 ALARA Review No.: N/A 2004-0017
Initials Date

Approved By:  3-28-04
RP Supervisor Date

Terminated By: _____
RP Supervisor Date

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 4, 5
FOIA/PA-2004-0282 L-4
Page 1 of 4

Nuclear Power Business Unit
RADIATION WORK PERMIT

Revision: 0



RWP Number: 04-141

TASK 1: Remove and Install Nozzle Dams

Radiation Protection personnel are authorized to suspend work activities in the event of a change in job scope, changes in radiological conditions, or a failure of personnel working under the RWP to abide by the RWP conditions.

Stop Work Dose Rate: 30,000 mr/hr ED Dose Rate Alarm: 25,000 mr/hr ED Dose Alarm: 904mrem

Radiation Protection Hold Points: N/A
No entries into the S/G Channelhead without RP approval.
Contact RP before entering any HRA's

Authorized Radiological Work Areas: Any RWP permits entry into RCA(s), RMA, and RA.

HRA LHRA VHRA Ctmt, Reactor Critical
 CA HCA HPCA Airborne Radioactivity Area

Expected Radiological Conditions: Data From: Current Survey Historical Data Estimated

Radiation: GA 500 to 10,000 mrem/hr Contact: 10,000 to 20,000 mrem/hr

Contamination: 10,000 to > 1E6 dpm/100 cm² Internal Contamination: 10,000 to > 1E6 dpm/100 cm² (estimated)

Airborne Radioactivity: <.25 DAC P I₂ NG ³H (Estimated / Actual DAC)

RP Job Coverage: Routine Direct Start of Job System Breach Pre-Job Briefing Required

Special Instructions: Direct RP Coverage required for all entries into the S/G Channelhead. See Job files 132, 133.

Radiological Survey Requirements:

A. Radiation: Prior to/Start of Work System Breach Other

Special Instructions: Verification Platform/Channel Head surveys required.
Hot particle surveys required for all worker's every 2 hours and immediately after exit from the S/G Channelhead.
Loop Area surveys performed per RP based on job evolution.

B. Contamination: Prior to/Start of Work System Breach Other

Special Instructions: Verify conditions prior to entry.

C. Airborne: Prior to/Start of Work System Breach Other

Special Instructions: Shiftly Platform Air Samples required during S/G work. Grab samples required based on job evolution and radiological conditions.

Nuclear Power Business Unit
RADIATION WORK PERMIT

Revision: 0

CO-2

RWP Number: 04-141

III. Dose Assessment: TLD and EPD required.

Special Instructions: Special multiple dosimetry packs required for full body/half body entries into channelhead IAW HPIP 1.66. RP to relocate WB Dosimetry to area expected to receive the highest exposure. Extremity Dosimetry required as per HPIP 1.66. Perform time keeping on personnel making whole body entries into the channelhead. Rescue team does not require multiple dosimetry and should wear dosimetry on the chest.

IV. Protective Clothing

- Coveralls, Booties, and Rubber Gloves (Minimum requirements for entering a contaminated area)
- Labcoat, Booties, and Rubber Gloves may be used only with RP permission.
- Coveralls, Double Booties or Booties and Rubber Totes/Boots, and Double Rubber Gloves to enter HCA.
- Double coveralls, Double Rubber gloves, Double Booties, Rubber Totes/Boots.⁽¹⁾
- Plastic suit, Double Rubber Gloves, Double Booties, Rubber Totes/Boots.⁽¹⁾
- Surgeon's Gloves may be substituted for Rubber Gloves with RP permission.
- Hood and Face Shield required as per RP.
- Other: See Special Instructions ⁽¹⁾ Safety review may be required for additional coveralls or plastics.

Special Instructions: Additional Dress requirements as per RP. Plastic suit for all entries into the S/G Channelhead.

V. Respiratory Protection: N/A TEDE ALARA Review:

Special Instructions: Bubble Hoods to be used for whole body entries. Reach-ins require a face shield.

VI. Engineering Controls:

Special Instructions: HEPA ventilation required on opposite leg for reach-ins and full jumps as much as practicable.

Ex 5

J

Nuclear Power Business Unit
RADIATION WORK PERMIT

Revision: 0

RWP Number: 04-141

VII. ALARA Requirements:

COP

See ALARA Review

LDWA: To be identified by RP.

Special Instructions: Prejob briefing to cover all items in the ALARA Review.
ALARA Doors to be shut when not actively working in S/G Channelhead
RP to monitor for Hot Particles at a minimum of once every two hours and immediately upon exit.

RP TO SURVEY ALL ITEMS EXITING THE STEAM GENERATOR.

Ensure ventilation is running on 1 channelhead at all times.
RP to be present when opening bags or equipment boxes on the 8'.

DO NOT HANDLE ITEMS FROM CHANNELHEAD WITHOUT RP APPROVAL!!!

Foreign debris found within the S/G channel head may be highly radioactive and shall not be handled without RP permission.

- When working in these areas or handling equipment from these areas (such as refueling tools) workers shall monitor at least every two hours.
- Contact RP immediately if, during monitoring of protective clothing, the worker discovers >10,000 cpm above bkg using a frisker or >5 mRem/hr above bkg using an open window beta instrument.
- Contact RP immediately if, during monitoring of skin, personal clothing, or modesty garments any contamination above bkg is discovered.

Point Beach Nuclear Plant
Level 3 Pre-Job ALARA Review

COPY

ALARA Review Number:	2004-0017 U1R28	Estimated dose:	4.320	Rem
----------------------	-----------------	-----------------	-------	-----

Part 1: Job Description	
A. Job Description (Attach work list if appropriate)	Install and Remove S/G Primary Nozzle Dams
B. Controlling job procedures.	Scientech Document No. 83A7564 and the job specific RWP
C. Job History/O.E./Lessons Learned	See the attached INPO Just-in Time Operating Experience report. Lessons learned during U2R26 concerning the stainless steel brush use are to be implemented (the drills that will be used for the hole cleaning evolutions will be taped so they can only be operated in the correct direction).
D. Dose history.	Nozzle Dams were installed during U2R26 using 2.038 rem. Dose estimate calculations are on page 3.
Part 2: ALARA Checklist	
NOTE: The following exposure reduction measures should be considered during job planning.	
Section 1: Pre-Job Planning/	
E. Designated low dose waiting/staging areas.	Low dose areas on the platforms will be out of the shine from the manways, near the top of the platform access ladder and also on the 8' el. of containment. See the attached survey maps of the S/G platforms, the 10' platforms and the 8' G.A.'s.
F. Remote job coverage equipment.	Audio and video equipment will be used. Teledosimetry use is also recommended. EIS
G. Communication devices used.	Westinghouse comm. gear will be used.
H. Services required. (lighting, air, electrical)	Grade D breathing air will be required.
I. Designated work area access/exit points.	Access to the generators will be at the entrance to the 10' platforms, then to the manway platform ladders.
J. Coordination with other groups.	Coordination between Scientech, RP and Operations will be required.
K. Work performed outside of radiation areas: Prefabrication Disassembly Assembly	Set-up and assemble as much of the nozzle dam equipment as possible outside of the loop areas.
L. Post-job cleanup requirements.	An inspection of the S/G bowls after installation of the dams will be required. Also the S/G manway platform will need to be deconned prior to the eddy current equipment setup.

Point Beach Nuclear Plant
Level 3 Pre-Job ALARA Review

COPY

ALARA Review Number:	2004-0017 U1R28	Estimated dose:	4.320	Rem
----------------------	-----------------	-----------------	-------	-----

M. Special tools/equipment used to minimize time and exposure. (Use contaminated tools when practicable)	None
N. Radwaste minimization.	Survey and decon all tools and equipment as required.
O. Work activities/equipment status that could result in significant interruption of job or changes in radiological conditions.	Loss of S/G channel head ventilation will interrupt the job. <i>Interrupting</i> <i>↳ stop work condition?</i> It

Section 2: Radiological Controls	
P. Describe temporary shielding to be used.	Shielding package #'s 94 and 95 are to be installed on the "A" S/G manway platform. Shielding package #'s 15, 63 and 64 are to be installed on the "B" S/G manway platform.
Q. What systems/components will be filled with water or flushed to reduce job area dose rates?	N/A
R. Engineering controls to control airborne activity. (HEPA filters, glove bags, etc.)	Use of the channel head HEPA/ventilation system.
S. Attach applicable survey data.	All current survey data will be attached and discussed during the pre-job briefings.

Section 3: Worker Preparation and Training	
T. Consider the following: <ul style="list-style-type: none"> Experienced workers selected. Special training, photos, drawings, video tapes available Rehearsal Mock-up training Use of fewer workers evaluated Method of shift turnovers 	Experienced workers will be utilized. Mock-up training will be performed with all necessary personnel involved.

ALARA-As Low As Reasonably Achievable
RWP-Radiation Work Permit
HEPA-High Efficiency Particulate Air

Point Beach Nuclear Plant
Level 3 Pre-Job ALARA Review

COPY

ALARA Review Number: 2004-0017 UIR28	Estimated dose: 4320 Rem
--------------------------------------	--------------------------

Dose calculations for Nozzle Dam Installation/Removal

Two minutes for installing and one minute for removal of each nozzle dam is assumed.

- "A" S/G Hot Leg Max dose rate is 15 R/hr or 300 mrem/min x 3 min. = 900 mrem
= 250 mR/min
- "A" S/G Cold Leg Max dose rate is 20 R/hr or 400 mrem/min x 3 min. = 1200 mrem
= 333 mrem/min
- "B" S/G Hot Leg Max dose rate is 15 R/hr or 300 mrem/min x 3 min. = 900 mrem
- "B" S/G Cold Leg Max dose rate is 16 R/hr or 320 mrem/min x 3 min. = 960 mrem
= 266 mrem/min

Conservatively incorrect conversion from R/hr to mrem/min.

There will be 3 men on the platform. 1 RP and 2 Scientech

The average dose on the platform is ~ 80 mR/hr

Using 2 mR/min x 3 men x 30 min. = 360 mrem

Total Dose 4320 mrem

Basis (2/3 install, 1/3 removal)

These dose rates being used are from historical data, current survey data will be used to update this estimate if necessary.

Completed By: W.W. Lemerond	Date: 9-22-03
Approved By: <i>[Signature]</i>	Date: 4/2/04

Point Beach Nuclear Plant
In-Progress ALARA Review/Assessment

COPY

ALARA Review Number:	2004-0017	Date:	4-11-04
----------------------	-----------	-------	---------

Review Purpose:

- In-Progress ALARA Review (No pre-job ALARA Review Performed)
- In-Progress ALARA Assessment (Dose Adjustment)
- In-Progress ALARA Assessment (Job at 50% of Original Dose Estimate)

Part 1: Job Description

A. Job Description (Attach work list if appropriate)	Install and Remove S/G Primary Nozzle Dams
B. Controlling job procedures.	Scientech Document No. 83A7564 and the job specific RWP
C. Job History/O.E./Lessons Learned	See the attached INPO Just-in Time Operating Experience report. Lessons learned during U2R26 concerning the stainless steel brush use are to be implemented (the drills that will be used for the hole cleaning evolutions will be taped so they can only be operated in the correct direction).
D. Dose history.	Nozzle Dams were installed during U2R26 using 2.038 rem.

Part 2: Person-Rem Radiation Dose Evaluation

Date	Current Dose Estimate (Rem)	Dose Expended to Date (Rem)	% of Current Estimate	% of Job Completed	Revised Dose Estimate (Rem)
4-11-04	4.32 rem	4.442 rem	1.03 %	66 %	6.002 rem

Part 3: Dose Effectiveness Evaluation

1. Check one or more of the items listed below which may have contributed to higher than expected RWP Person-Rem accumulation. Provide an explanation for all items checked.	
<input type="checkbox"/> a. Job scope changed/expanded.	
<input type="checkbox"/> b. Job site radiation levels different/changed.	
<input type="checkbox"/> c. Encountered scheduling/coordination difficulties.	
<input type="checkbox"/> d. Work extended due to tool/equipment failure.	
<input type="checkbox"/> e. Work extended due to wrong or unavailable parts/tools/material.	
<input type="checkbox"/> f. Work extended due to unplanned job site preparation requirements.	

Point Beach Nuclear Plant
In-Progress ALARA Review/Assessment

COPY

<input type="checkbox"/> g. Work extended due to interruptions/interferences caused by other work activities.	
<input type="checkbox"/> h. Inadequate compliance with radiological controls/requirements.	
<input type="checkbox"/> i. Inadequate consideration of Pre-Job ALARA Worksheet items.	
<input type="checkbox"/> j. Inadequate shielding.	
<input checked="" type="checkbox"/> k. Other.	<p>Currently all four dams are installed; total dose expended to accomplish this was 4.442 rem, 67mRem of that total was for equipment set-up. There were numerous difficulties during the installation process. These included service air supply for the bubble hoods, which increased time on the platforms. A bolt could not be installed on the "A" hot leg (was eventually resolved by chasing the threads). But the biggest impact was having to remove the "A" hot leg dam and then installing it again once a vent path for the RCS was established. Additionally a proper jump platform was not available on the "A" S/G platform. See the attached AR. Also when making the original dose estimate, nothing was allotted for the camera installation and nozzle dam verification, which was at least 140 mRem plus the RP support dose.</p> <p>The new estimate is for one minute in each bowl for dam removal. Which is 1.32 rem, plus 0.120 rem for S/G platform support and .120 rem for removing cameras and S/G close-out inspections added to the current total of 4.442 for a total of 6.002 rem.</p> <p><i>Dose cost... In CAP ≈ 900 mrem</i> →</p>
2. Exposure Reduction Action to Be Implemented (If Applicable).	Install a proper jump platform on the "A" S/G manway platform prior to nozzle dam removal.
3. AR Generated: <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes AR Number:	CAP055587

Completed By: W. W. Lemerond	Date: 4-11-04
Approved By:	Date:

COPY

TEDE ALARA EVALUATION

RWP 04-141

DESCRIBE THE WORK TO BE PERFORMED (DOSE RATES, EST. AVERAGE AIR CONCENTRATIONS, CONTAMINATION LEVELS):

Steam generator nozzle dam installation/removal - The work involves installation and removal of the steam generator nozzle dams. The work area is a confined area and entry/exit through the manway will abrasively scrub exposed surfaces. Dose rates in the work area is 20 R/hr based on historical data. Expected contamination levels are 200 mrad/hr beta/gamma. From historical data, highest measured alpha contamination was 600 dpm/100 cm². Long-lived alpha contamination levels are unknown. Estimated work duration is 3 minutes per worker. The estimated beta/gamma DAC fraction from HPIP 4.40 for work in a confined area is 450 DAC beta/gamma and 10 DAC for alpha.

DESCRIBE THE ENVIRONMENTAL CONDITIONS AND EFFECTS ON PERSONNEL SAFETY: The environmental conditions in the work area are typical refueling temperature and humidity conditions (i.e, approximately 80 °F and 50 % humidity).

DESCRIBE PROCESS AND ENGINEERING CONTROLS TO BE USED: Steam generator channelhead ventilation will be operating during the entry.

DESCRIBE THE PROTECTIVE EQUIPMENT AND CLOTHING, INCLUDING THE RESPIRATOR, TO BE USED AND THEIR EFFECTS ON WORKER EFFICIENCY: The protective clothing that will be worn is the standard protective clothing requirement for work in a contaminated area (coveralls, booties, cotton liners, rubber gloves). Additionally, the standard protective clothing will be augmented with plastic coveralls and additional sets of booties and rubber gloves. An airline/hood is planned for respiratory protection.

DESCRIBE POTENTIAL POST-ACTIVITY NEGATIVE IMPACTS (E.G., PERSONNEL DECONTAMINATION AND SKIN DOSE ASSESSMENTS, PORTAL MONITOR ALARMS): Potential post-activity negative impacts include facial contamination and uptakes without the use of respiratory protective equipment. Additional time and energy will be spent responding to portal monitor alarms, documenting the contamination and uptake, and assessing the dose impacts.

DOSE WITHOUT RESPIRATORY PROTECTION:

[Time (hrs) x Dose rate (mR/h)]	0.05 x 20000	=	1000	mrem, external dose
[Time (hrs) x DAC fraction x 2.5 mR/DAC-h]	0.05 x 460 x 2.5	=	60	mrem, internal dose
Est. dose for implementing engineering or process controls		=	0	mrem
Total		=	1060	mrem

DOSE WITH RESPIRATORY PROTECTION:

[Time (hrs) x Dose rate (mR/h)]	0.05 x 1.15 x 20000	=	1150	mrem, external dose
[Time (hrs) x DAC fraction x 2.5 mR/DAC-h / Respirator PF]	0.058 x 460 x 2.5 / 50	=	1	mrem, internal dose
Est. dose for implementing engineering or process controls		=	0	mrem
Total		=	1151	mrem

Note: Time value should reflect worker efficiency impact due to respirator use. Work time increased by 15 percent per HPIP 4.40.

ALARA RECOMMENDATIONS:

<input type="checkbox"/>	Without respirator	Type:	<input type="checkbox"/> Negative Pressure/PAPR	<input checked="" type="checkbox"/> Airline/Hood	<input type="checkbox"/> SCBA
<input checked="" type="checkbox"/>	With respirator				
<input type="checkbox"/>	As indicated below				

Justification/Comments: This evaluation determines that the use of an airline/hood for this work is not ALARA. However, the increase in dose due to the use of the airline/hood does not negate its use when accounting for the additional time and energy needed to address the effects of external and internal contamination that will result when the airline/hood is not used.

Preparer (Name/Date): Carl Onesti 4-3-04
 Approver (Name/Date): [Signature] 4-3-04

Handwritten notes on the right side of the page, including "Ex 5" and "Ex 3" with arrows pointing to specific sections of the form.

Isotope??

IODINE ACTIVITY CONCENTRATIONS

LOCATION: Unit A 5/6 Hot leg RWP No. 04-104

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME, (cc)	SAMPLER NUMBER	INITIALS
	DATE	TIME	DATE	TIME			
30-109	4-8-04	1830	4-8-04	1845	1.65 EG	HUS-22	DM

Sample start flow 110 Lpm Total sample time (min) 15m
 Sample stop flow _____ Flow correction factor _____
 Average sample flow ↓ Remarks _____

ANALYSIS DATA:

Isotopic Analysis

MECDOS (for DAC data)

S.I. # _____

Date	Time	Isotope	*Concentration (μCi/cc)	By Initials	Date	Time	Isotope	Concentration (μCi/cc)	By Initials
4/8/04	2022	I-131	2.66E-10	GW	4/8/04	2022	Cl-38	<MDDA	GW
↓	↓	I-132	6.09E-9	↓	↓	↓	Br-82	↓	↓
↓	↓	I-133		↓	↓	↓		↓	↓
↓	↓	I-134		↓	↓	↓		↓	↓
↓	↓	I-135		↓	↓	↓		↓	↓
↓	↓	Total Iodine	6.36E-9	↓	↓	↓	Total Additional	↓	↓

Total Iodine Concentration + Total Additional Concentration = 6.36E-9 μCi/cc By (Initials) GW

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

This form should be used for all radioiodine analysis results.

*RELEASE ACCOUNTABILITY - (for release paths only)

If the concentration of total for radioiodines exceeds 2.25E-09 μCi/cc, follow steps outlined in RAM 5.2. Save the charcoal filter until the investigation is completed.

Approved by: [Signature] Date: 4/9/04

RADIOLOGICAL SURVEYS

LOCATION: "A" Loop - w "A" Steam Generator


DATE 4-8-04
 TIME 1100
 MONITOR J Perantka

INSTRUMENT TYPE ABCS / ROZA
 SERIAL NO. 2457091, 9684 / 4551
 COUNTED BY R. Wichayk / R

PURPOSE: Daily Survey Pre-RWP
 RWP # Other Follow up
 REVIEWED BY: [Signature]

NO.	MREM/HR	β DPM/100 CM ²	α DPM/100 CM ²	REMARKS
1	N/A	650	52	
2		371		
3		720		
4		2470		manway bolts-box
5		2280	52	
6		1762		manway bolts-box
7		537	176	
8		1676		
9		11470		drain line

8' Follow up to personnel contamination
 POSTED: HRA, NRP



Area IC-9

PBF-4021
 Revision 0 01/01/93
 HP 1.9

- Notes:
- 1) All readings in mrem/hr
 - 2) *Designates hot spots
 - 3) ⊗ Designates routinely updated posting
 - 4) "Potential Hazards" identified are indicated on map


RADIOLOGICAL SURVEYS

LOCATION: "A" Loop - Below "A" Steam Generator

COP

DATE	4-8-04	INSTRUMENT TYPE	R3050 AMTACS/RM14	PURPOSE:	<input type="checkbox"/> Daily Survey	<input type="checkbox"/> Pre-RWP
TIME	15:30	SERIAL NO.	7626 9684 / 7698	RWP #	04-140	<input checked="" type="checkbox"/> Other
MONITOR	FONIT WICHART/AA	COUNTED BY	FONIT WICHART/AA	REVIEWED BY:	[Signature]	

NO.	MREM/HR	By DPM/100 CM ²	aDPM/100 CM ²	REMARKS
1		46K	<MDA	Floor
2		50K	<MDA	Floor
3		35K	<MDA	strapsack
4		20K	1/2	Floor
5		35K		Floor
6		20K		Floor
7		100K		Floor Under #2
8		500K		strapsack
9		1300 mRad		11/2 Manway
10		1500 mRad		0/2 Manway



Notes: 1) All readings in mrem/hr
2) *Designates hot spots
3) ⊙ Designates routinely updated posting
4) "Potential Hazards" identified are indicated on map


RADIOLOGICAL SURVEYS

LOCATION: "A" Loop - Low "A" Steam Generator

COPY

DATE 4-9-04 INSTRUMENT TYPE RSC5 / ABACUS / RM14 PURPOSE: Daily Survey Pre-RWP
 TIME 1530 SERIAL NO. 7377 / 9684 / 17698 RWP # CH-141 Other _____
 MONITOR PETER SATENIM COUNTED BY PETER SATENIM REVIEWED BY: [Signature]

NO.	MREM/HR	β DPM/100 CM ²	α DPM/100 CM ²	REMARKS
1		31K	4MDA	FLOOR
2		21K	4MDA	
3		41K	4MDA	
4		51K	4MDA	
5		41K	4MDA	
6		152K		
7		70K		
8		100K		
9		41K		
10		51K		
11		101K		
12		21K	4MDA	
13		11K	4MDA	
14		21K	4MDA	
15		10K 100K		
16		100K		STRONG BARR
17		200K		
18		40K		
19		200K		
20		20K		



PBF-4021
 Revision 0 01/01/93
 HP 1.9

- Notes:
- 1) All readings in mrem/hr
 - 2) *Designates hot spots
 - 3) ⊗ Designates routinely updated posting
 - 4) "Potential Hazards" identified are indicated on map


COP

POINT BE: NUCLEAR PLANT
RADIOLOGICAL SURVEYS

LOCATION: UNIT ~~XXXXXX~~ STEAM GENERATOR CHANNEL HEAD

DATE: 4-8-04 INSTRUMENT TYPE: R5050 / TELEMET PURPOSE: Routine Daily Survey
 TIME: 1530 SERIAL NO.: 7626 / 2865 CRWP # 04-1413 Other
 MONITOR: BCN WICHAYK, ZCN COUNTED BY: HA REVIEWED BY: [Signature]

NO.	LOCATION	DOSE RATE (mrem/hr)
INLET CHANNEL (HOTLEG)		
1	Midpoint of tube sheet	8,000
2	Channel head center	8,000
3	Center divider head	10,000
4	Bottom of channel head	10,000
5	Manway entrance	1,900
6	1' from manway	1,100
7	3' from manway	350
8	Center of diaphragm	700 JC 1500 BC 2000 BC
OUTLET CHANNEL (COLDLEG)		
9	Midpoint of tube sheet	1,100
10	Channel head center	900
11	Center divider plate	10,000
12	Bottom of channel head	10,000
13	Manway entrance	2,000
14	1' from manway	1,000
15	3' from manway	300
16	Center of diaphragm	1500 JC 500 BC 2000 BC
HOT SPOTS (DESCRIBE LOCATION)		
17		
18		
19		
20		



Ventilation Operational Check

RAD DOORS INSTALLED (YES / NO)	VENTILATION OPERABLE (SAT / UNSAT / NA)
<u>Yes</u>	<u>SAT</u>
Hot Leg	<u>Yes</u>
Cold Leg	<u>Yes</u>

INLET DIAPHRAGM		OUTLET DIAPHRAGM	
8A - 0°	1300 mrem/hr	16A - 0°	900 mrem/hr
8B - 90°	1300	16B - 90°	1000
8C - 180°	1500	16C - 180°	1300
8D - 270°	1500	16D - 270°	900

*TAKE DIAPHRAGM SURVEY BEFORE REMOVAL

AREA C-1

- Notes:
- 1) All readings in mrem/hr
 - 2) *Designates hot spots
 - 3) ⊙ Designates routinely updated posting
 - 4) "Potential Hazards" identified are indicated on map

RADIOLOGICAL SURVEYS

COPY


LOCATION: "A" Loop - Below "A" Steam Generator

DATE: 1-16-88
TIME: 1000
MONITOR: PETER PINGEL

INSTRUMENT TYPE: HX-5/AMACUS/R1114
SERIAL NO.: 7855/9684/7698
COUNTED BY: Peter Pangel

PURPOSE: Daily Survey Pre-RWP
 RWP # 04-143 Other
REVIEWED BY: Bull

NO.	MREM/HR	β g DPM/100 CM ²	α DPM/100 CM ²	REMARKS
	960 mcp	121K		FLOOR
		31K		
		1001K		
		71K	2000A	
		11K	2200B	
		21K	2200B	
		151K		
		31K		
		21K		MANWAY STRAINER
		41K		



Area 1C-9
Shielding

PBF-4021
Revision 0 01/01/93
HP 1.9

- Notes:
- 1) All readings in mrem/hr
 - 2) *Designates hot spots
 - 3) ⊗ Designates routinely updated posting
 - 4) "Potential Hazards" identified are indicated on map

SAMPLE TYPE: AP Gas Other

Point Beach Nuclear Plant

RWP No. _____

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U-1 CTMT ~~Containment Building~~

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-104	NA	NA	4/8/04	1830	7075	NA	RK

Sample Start Flow: NA
 Sample Stop Flow: ↓
 Average Sample Flow: ↓

Total Sample Time (min): NA
 Flow Correction: ↓
 Remarks: _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS

⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc. notify RP supervision. perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc. perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽³⁾	BY INITIALS

⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180. notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date 4/8/04 Time 1853 Spectrum Index No. NIA

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS
Xe 133	3.39E-7	SK			

Record RE-211 and RE-212 readings for all at-power containment air samples:

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Release Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 6.09 μCi/cc. or the total for noble gases exceeds 6.86E-06 μCi/cc. notify the Chemistry lab supervisor and/or the Radiation Protection supervisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C₂/C₁) is greater than the value given in Table 1, and if C₂ is greater than 7.5E-13, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

⁽⁴⁾Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Mult. Factor	Activity (µCi/cc)	LLD ⁽⁴⁾	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁										----	----	
C ₂												
C ₃												
C ₄												
C _{LL}											----	

Reviewed By: _____

RP Supervision

Date: _____

4/5/07

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C₁ At T₄ Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C₂ At T₆ Start second count at least 2 hours after C₁.
- C₃ At T_x Start time dependent upon results of C₂.
- C₄ At T₂₄ Start count 24 hours after C₁.
- C_{LL} At T_{>75} Start count at least 75 hours after T₀.

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF (C_{2,3,4}, ETC.)/C₁ FOR C_{LL} EQUAL TO ZERO

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

- If the ratio of activity (C_{2,3}, etc.)/C₁ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be ≤ 7.5E-13 µCi/cc).
- If C_{LL} is greater than 7.5E-13 µCi/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

- If the C₂/C₁ ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

Point Beach Nuclear Plant

*** NOBLE GAS SKIN EXPOSURE ***

SAMPLE DATE: 04/08/04 18:30
SAMPLE LOCATION: U1 CTMT CHANNEL
REMARKS:

SAMPLE ID: 30-104

TAKEN BY: RLK
ANALYSIS BY: EK

COP

ISOTOPIC ANALYSIS RESULTS

ISOTOPE	NOBLE GAS CONC. ($\mu\text{Ci}/\text{cc}$)	FRACTION	GAMMA WHOLE BODY (mR/hr)	BETA SKIN DOSE (mR/hr)	GAMMA SKIN DOSE (mR/hr)	TOTAL SKIN DOSE (mR/hr)
XE-133	3.390E-07	1.0000	0.01	0.01	0.02	0.03
TOTALS	3.390E-07	1.0000	0.01	0.01	0.02	0.03

Reviewed by: 300

Date: 4/5/04

Point Beach Nuclear Plant

*** RESTRICTED DAC IN AIR CALCULATIONS ***

SAMPLE DATE: 4/8/2004 18:30
SAMPLE LOCATION: U1 CTMT CHANNEL
REMARKS:

SAMPLE ID: 30-104

COP

TAKEN BY: RLK
ANALYSIS BY: EK

ISOTOPIC ANALYSIS RESULTS

ISOTOPE	RESTRICTED DAC ($\mu\text{Ci/cc}$)	CONC ($\mu\text{Ci/cc}$)	FRAC. OF CONC.	% OF DAC
XE-133	1.00E-04	3.39E-07	1.00	0.339
TOTALS		3.39E-07	1.00	0.339

Based on a 40 hour work week, the maximum stay time for the listed concentrations is: 1.2E+04 hours.

Reviewed by: 

Date: 4/9/04

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. 24-140

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U-1 UNIT S/C platform (dephos removal)

Remote containment sampling system used? Yes No NA

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-105	4-8-04	1440	4-8-04	1613	2.7E6	LVS3	RLK

Sample Start Flow 35 lpm
 Sample Stop Flow ↓
 Average Sample Flow ↓

Total Sample Time (min) 93
 Flow Correction 0.83
 Remarks _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm β	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-8-04	1638	Pre-2	121.6	0.6	121	7.2	8.48E-11	RLK

⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm β / NET cpm α ⁽³⁾	BY INITIALS

⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date _____ Time _____ Spectrum Index No. _____

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Release Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 6.0E-09 μCi/cc, or the total for noble gases exceeds 6.0E-06 μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection supervisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C_2/C_1) is greater than the value given in Table 1, and if C_2 is greater than $7.5E-13$, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

⁽¹⁾Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Multi. Factor	Activity ($\mu\text{Ci/cc}$)	LLD ⁽¹⁾	Hours From C_1	Activity Ratio/ C_1	BY INIT.
C_1										----	----	
C_2												
C_3												
C_4												
C_{LL}											----	

Reviewed By: _____
RP Supervision

Date: 4-9-69

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C_1 At T_4 Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C_2 At T_6 Start second count at least 2 hours after C_1 .
- C_3 At T_n Start time dependent upon results of C_2 .
- C_4 At T_{28} Start count 24 hours after C_1 .
- C_{LL} At T_{75} Start count at least 75 hours after T_0 .

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF $(C_{2,3,4} \text{ ETC.})/C_1$ FOR C_{LL} EQUAL TO ZERO

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

- If the ratio of activity $(C_{2,3} \text{ etc.})/C_1$ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be $\leq 7.5E-13 \mu\text{Ci/cc}$).
- If C_{LL} is greater than $7.5E-13 \mu\text{Ci/cc}$, notify RP supervision for review.

Date	Time	C_1	C_2	λ	Δt	C_{LL}	RP Supervision Notified (initials)
				0.0655			

- If the C_4/C_1 ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

1 Where Isotopes?
73 Isotopes?

IODINE ACTIVITY CONCENTRATIONS

LOCATION: U1 CONT 7c PLATFORM - Diaphragm RWP No. 04-140
REMOVAL

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	INITIALS
	DATE	TIME	DATE	TIME			
30-106	4-8-04	1440	4-8-04	1613	2.7 EG#	LU3-3	RLK

Sample start flow 35 LPM Total sample time (min) 93
 Sample stop flow ↓ Flow correction factor 0.83
 Average sample flow ↓ Remarks _____

ANALYSIS DATA:

Isotopic Analysis MECDOS (for DAC data) S.I. # _____

Date	Time	Isotope	*Concentration (μCi/cc)	By Initials	Date	Time	Isotope	Concentration (μCi/cc)	By Initials
4/8/04	1756	I-131	<MDA	EW	4/9/04	1756	Cl-38	<MDA	EW
		I-132					Br-82		
		I-133							
		I-134							
		I-135							
		Total Iodine					Total Additional		

Total Iodine Concentration + Total Additional Concentration = <MDA μCi/cc By (Initials) EW

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

This form should be used for all radioiodine analysis results.
*RELEASE ACCOUNTABILITY - (for release paths only)
If the concentration of total for radioiodines exceeds 2.28E-09 μCi/cc, follow steps outlined in RAM 5.2.
Save the charcoal filter until the investigation is completed.

Approved by: [Signature] Date: 4/9/04

SAMPLE TYPE:
 LAP Gas Other

Point Beach Nuclear Plant

RWP No. 54-171

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: 1.1A 5/6 platform

Remote containment sampling system used? Yes No NA

COPI

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-123	4-8-04	1900	4-9-04	1010	3.02E7	LVS-30	RLK

Sample Start Flow 40 lpm
 Sample Stop Flow _____
 Average Sample Flow ✓

Total Sample Time (min) 910
 Flow Correction 0.43
 Remarks _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-9-04	1030	CAN 8	11117	31.2	14085.8	9.4	1.98E-9	RLK

⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽³⁾	BY INITIALS
9-04	1040	T272	4.8	0.1	44.7	315.1	RLK

⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS

Return to RP by 14.0 hr. for LLA counting.

Date 7-9-04 Time 1101 Spectrum Index No.

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS
Ct-51	3.65E-10 ✓	KL3	Zr-95	1.02E-10 ✓	KL3
Mn-54	5.23E-11 ✓	KL3	Sr-113	6.17E-12 ✓	KL3
Co-57	1.13E-11 ✓	KL3	Sr-117M	4.24E-12 ✓	KL3
Co-58	2.67E-9 ✓	KL3	Sr-125	1.16E-11 ✓	KL3
Fe-59	2.62E-11 ✓	KL3			
Co-60	8.93E-10 ✓	KL3			
Nb-95	1.60E-10 ✓	KL3			

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Please Accountability: For release paths only. If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 5.5E-09 μCi/cc, or the total for noble gases exceeds 6.80E-06 μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection Director. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an air release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C₂/C₁) is greater than the value given in Table 1, and if C₂ is greater than 7.5E-13, perform C_{LL} screening.

Sample Volume (cc): 5.02^{E7} (from Page 1)

¹⁴Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Multi. Factor	Activity (μCi/cc)	LLD ¹⁴	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁	4-9-64	1410	7270	17.8	0.5	17.3	4.25	1.09E-12	7.46E-14	----	----	RLK
C ₂	4-9-64	1610	7270	14.8	0.5	14.3	4.25	9.06E-13	7.46E-14	2	0.832	Rm
C ₃												
C ₄												
C _{LL}											----	

Reviewed By: Rm RP Supervision

Date: 4-11-64

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C₁ At T₄ Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C₂ At T₆ Start second count at least 2 hours after C₁.
- C₃ At T₈ Start time dependent upon results of C₂.
- C₄ At T₂₄ Start count 24 hours after C₁.
- C_{LL} At T₇₅ Start count at least 75 hours after T₀.

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF (C_{2,3,4} ETC.)/C₁ FOR C_{LL} EQUAL TO ZERO

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

- If the ratio of activity (C_{2,3} etc.)/C₁ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be ≤ 7.5E-13 μCi/cc).
- If C_{LL} is greater than 7.5E-13 μCi/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

- If the C₂/C₁ ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. 4-8-04
~~04-104~~
 04-140

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U1 A-5/6 PLATFORM

Remote containment sampling system used? Yes No NA

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-110	4-8-04	1514	4-8-04	1900	0.56 EG	203-3	DM

Sample Start Flow: 3.5 cfm
 Sample Stop Flow: _____
 Average Sample Flow: ✓

Total Sample Time (min): 226
 Flow Correction: 0.83
 Remarks: _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS .cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-8-04	1900	P20-2	70.2	0.6	69.6	4.2	2.61E-11	DM

⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽³⁾	BY INITIALS

⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date _____ Time _____ Spectrum Index No. _____

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Particulate Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 6.0E-09 μCi/cc, or the total for noble gases exceeds 6.0E-06 μCi/cc, notify the Chemistry Lab supervisor and/or the Radiation Protection supervisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C₂/C₁) is greater than the value given in Table 1. and if C₂ is greater than 7.5E-13, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

⁽¹⁾Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Mult. Factor	Activity (μCi/cc)	LLD ⁽¹⁾	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁										----	----	
C ₂												
C ₃												
C ₄												
C _{LL}											----	

Reviewed By: *[Signature]* RP Supervision

Date: 4/9/04

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C₁ At T₀ Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C₂ At T₆ Start second count at least 2 hours after C₁.
- C₃ At T_x Start time dependent upon results of C₂.
- C₄ At T₂₈ Start count 24 hours after C₁.
- C_{LL} At T₇₅ Start count at least 75 hours after T₀.

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF (C_{2,3,4, ETC.)/C₁ FOR C_{LL} EQUAL TO ZERO}

ΔT	ΔT	ΔT	ΔT	ΔT			
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

1. If the ratio of activity (C_{2,3, etc.)/C₁ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be ≤ 7.5E-13 μCi/cc).}
2. If C_{LL} is greater than 7.5E-13 μCi/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

3. If the C₂/C₁ ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. 07-107

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: 111 A S/E Hot Leg

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-108	4-8-04	1830	4-8-04	1845	1.65 cc	HUS-22	RM-DD

Sample Start Flow 110 cfm
 Sample Stop Flow _____
 Average Sample Flow ↓

Total Sample Time (min) 15m
 Flow Correction _____
 Remarks _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-8-04	1853	PRO-2	27.6	0.6	27.0	4.2	3.10 E-11	RM

⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽³⁾	BY INITIALS

⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date _____ Time _____ Spectrum Index No. _____

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Filter Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 6.09 μCi/cc, or the total for noble gases exceeds 6.86E-06 μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection supervisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C₂/C₁) is greater than the value given in Table 1, and if C₂ is greater than 7.5E-13, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

¹⁴¹Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Mult. Factor	Activity (μCi/cc)	LLD ¹⁴¹	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁										----	----	
C ₂												
C ₃												
C ₄												
C _{LL}											----	

Reviewed By: _____ RP Supervision

Date: 4/9/04

COUNTING INFORMATION FOR LONG LIVED ALPHA

- | Count | Time | |
|-----------------|------------------------|--|
| C ₁ | At T ₄ | Start first count 4 hours after sample stop time. (Essentially all radon decayed.) |
| C ₂ | At T ₆ | Start second count at least 2 hours after C ₁ . |
| C ₃ | At T _x | Start time dependent upon results of C ₂ . |
| C ₄ | At T ₂₈ | Start count 24 hours after C ₁ . |
| C _{LL} | At T _{>75} | Start count at least 75 hours after T ₀ . |

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF (C_{2,3,4}, ETC.)/C₁ FOR C_{LL} EQUAL TO ZERO

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

- NOTES:**
- If the ratio of activity (C_{2,3}, etc.)/C₁ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be ≤ 7.5E-13 μCi/cc).
 - If C_{LL} is greater than 7.5E-13 μCi/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

- If the C₄/C₁ ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. 04-138

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U1 A-S/L PLATFORM

Remote containment sampling system used? Yes No NA 

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-107	4-6-04	1100	4-8-04	1440	9.01 E7	-223-3	Rm

Sample Start Flow 35 cpm
 Sample Stop Flow _____
 Average Sample Flow ↓

Total Sample Time (min) 3100
 Flow Correction 0.83
 Remarks _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-8-04	1750	PR0-1	275.2	0.5	274.7	4.1	5.63 E-12	Rm

⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽³⁾	BY INITIALS

⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date _____ Time _____ Spectrum Index No. _____

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Public Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 0.09 μCi/cc, or the total for noble gases exceeds 6.56E-06 μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection supervisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C₂/C₁) is greater than the value given in Table 1. and if C₂ is greater than 7.5E-13, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

¹⁾Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Mult. Factor	Activity (µCi/cc)	LLD ¹⁾	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁										----	----	
C ₂												
C ₃												
C ₄										-		
C _{LL}											----	

Reviewed By: [Signature]
RP Supervision

Date: 4/9/84

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C₁ At T₄ Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C₂ At T₆ Start second count at least 2 hours after C₁.
- C₃ At T_x Start time dependent upon results of C₂.
- C₄ At T₂₄ Start count 24 hours after C₁.
- C_{LL} At T_{>75} Start count at least 75 hours after T₀.

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF (C_{2,3,4}, ETC.)/C₁ FOR C_{LL} EQUAL TO ZERO

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

1. If the ratio of activity (C_{2,3}, etc.)/C₁ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be ≤ 7.5E-13 µCi/cc).
2. If C_{LL} is greater than 7.5E-13 µCi/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

3. If the C₂/C₁ ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

Point Beach Nuclear Plant
*** **RESTRICTED DAC IN AIR CALCULATIONS** ***

SAMPLE DATE: 4/9/2004 10:10
SAMPLE LOCATION: U1 A S/G platform
REMARKS:

SAMPLE ID: 30-123

TAKEN BY: RK
ANALYSIS BY: KCB

COP

ISOTOPIC ANALYSIS RESULTS

ISOTOPE	RESTRICTED DAC (uCi/cc)	CONC (uCi/cc)	FRAC. OF CONC.	% OF DAC
CO-57	3.00E-07	1.13E-11	0.00	0.004
CO-58	3.00E-07	2.67E-09	0.62	0.890
CO-60	1.00E-08	8.93E-10	0.21	8.930
CR-51	8.00E-06	3.65E-10	0.08	0.005
FE-59	1.00E-07	2.62E-11	0.01	0.026
MN-54	3.00E-07	5.23E-11	0.01	0.017
NB-95	5.00E-07	1.60E-10	0.04	0.032
SN-113	5.00E-07	6.17E-12	0.00	0.001
SB-117M	5.00E-07	4.24E-12	0.00	0.001
SB-125	2.00E-07	1.16E-11	0.00	0.006
ZR-95	5.00E-08	1.02E-10	0.02	0.204
TOTALS		4.30E-09	1.00	10.116

Based on a 40 hour work week, the maximum stay time for the listed concentrations is: 395.4 hours.

Reviewed by:  Date: 04-16-04

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. _____

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U-1 "A" S/G PLANT

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
20-129	4-9-04	1010	4-16-04	0940	3.5 FT	205-300	RLK

Sample Start Flow 30 lpm
 Sample Stop Flow _____
 Average Sample Flow _____

Total Sample Time (min) 1410
 Flow Correction 0.83
 Remarks _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm $\beta\gamma$	MULT. FACTOR	SAMPLE ACTIVITY ($\mu\text{Ci/cc}$) ^(1,2)	BY INITIALS
4-16-04	5	6762228	724	255	468.5	0.1	46.85	RLK

- ⁽¹⁾ If sample activity is greater than or equal to $5\text{E}-10 \mu\text{Ci/cc}$, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.
- ⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than $1\text{E}-10 \mu\text{Ci/cc}$, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm $\beta\gamma$ / NET cpm α ⁽¹⁾	BY INITIALS

- ⁽¹⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date _____ Time _____ Spectrum Index No. _____

ISOTOPE	ACTIVITY ($\mu\text{Ci/cc}$)	BY INITIALS	ISOTOPE	ACTIVITY ($\mu\text{Ci/cc}$)	BY INITIALS

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ $\mu\text{Ci/cc}$

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ $\mu\text{Ci/cc}$ SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Release Accountability - For release paths only. If the total concentration for particulates (excluding naturally occurring isotopes) exceeds $5\text{E}-09 \mu\text{Ci/cc}$, or the total for noble gases exceeds $6.86\text{E}-06 \mu\text{Ci/cc}$, notify the Chemistry Lab supervisor and/or the Radiation Protection Division. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C_2/C_1) is greater than the value given in Table 1, and if C_2 is greater than $7.5E-13$, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

¹⁴Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Multi. Factor	Activity (μ Ci/cc)	LLD ¹⁴	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁										----	----	
C ₂												
C ₃												
C ₄												
C _{LL}											----	

Reviewed By: *[Signature]*
RP Supervision

Date: 4.10.04

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C₁ At T₄ Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C₂ At T₆ Start second count at least 2 hours after C₁.
- C₃ At T_x Start time dependent upon results of C₂.
- C₄ At T₂₄ Start count 24 hours after C₁.
- C_{LL} At T_{>75} Start count at least 75 hours after T₀.

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF $(C_{2,3,4, \text{ETC.}})/C_1$ FOR C_{LL} EQUAL TO ZERO

TABLE 1

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

- NOTES:**
- If the ratio of activity $(C_2, \text{ etc.})/C_1$ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be $\leq 7.5E-13 \mu$ Ci/cc).
 - If C_{LL} is greater than $7.5E-13 \mu$ Ci/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

- If the C_2/C_1 ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

Point Beach Nuclear Plant

IODINE ACTIVITY CONCENTRATIONS

LOCATION: U-1 "A" S/E Plat RWP No. _____

Remote containment sampling system used? Yes No NA

COP[®]

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	INITIALS
	DATE	TIME	DATE	TIME			
30-130	4-9-04	1010	4-10-04	0940	3.5E7	2053	RLK

Sample start flow 30 lpm Total sample time (min) 1410
 Sample stop flow ↓ Flow correction factor 0.83
 Average sample flow ↓ Remarks _____

ANALYSIS DATA:

Isotopic Analysis MECDOS (for DAC data) S.I. # _____

Date	Time	Isotope	*Concentration (µCi/cc)	By Initials	Date	Time	Isotope	Concentration (µCi/cc)	By Initials
4-10-04	1529	I-131	4.885-12	KCB			Cl-38		
		I-132					Br-82		
		I-133							
		I-134							
		I-135							
		Total Iodine	4.885-12	KCB			Total Additional	LMPT	KCB

Total Iodine Concentration + Total Additional Concentration = 4.885-12 µCi/cc By (Initials) KCB

Unit 1 Unit 2 RE-211: _____ µCi RE-212: _____ µCi/cc

This form should be used for all radioiodine analysis results.

*RELEASE ACCOUNTABILITY - (for release paths only)

If the concentration of total for radioiodines exceeds 2.25E-09 µCi/cc, follow steps outlined in RAM 5.2.

Save the charcoal filter until the investigation is completed.

Approved by: [Signature] Date: 4/11/04

Point Beach Nuclear Plant
*** RESTRICTED DAC IN AIR CALCULATIONS ***

SAMPLE DATE: 4/10/2004 09:40
SAMPLE LOCATION: U-1 A S/G PLAT
REMARKS:

SAMPLE ID: 30-130

TAKEN BY: RLK
ANALYSIS BY: KCB

COP

ISOTOPIC ANALYSIS RESULTS

ISOTOPE	RESTRICTED DAC (uCi/cc)	CONC (uCi/cc)	FRAC. OF CONC.	% OF DAC
I-131	2.00E-08	4.88E-12	1.00	0.024
TOTALS		4.88E-12	1.00	0.024

Based on a 40 hour work week, the maximum stay time for the listed concentrations is: 1.6E+05 hours.

Reviewed by: RLK Date: 4/11/04

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. 04-148¹⁴²
 7-10-04 Rm

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U11 A 5/6 PLATFORM

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-131	4-10-04	0938	4-10-04	2250	1.9767	203-3	Rm

Sample Start Flow 30 Lpm
 Sample Stop Flow _____
 Average Sample Flow _____

Total Sample Time (min) 792
 Flow Correction 0.83
 Remarks _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-10-04	2250	Pro-1	43.3	1.0	42.3	4.1	4.01E-12 ⁽¹⁾	Rm

⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽³⁾	BY INITIALS

⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date _____ Time _____ Spectrum Index No. _____

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 5 μCi/cc, or the total for noble gases exceeds 6.56E-06 μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection supervisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

Sample Volume (cc): _____ (from Page 1)

If the ratio of (C₂/C₁) is greater than the value given in Table 1, and if C₂ is greater than 7.5E-13, perform C_{LL} screening.

⁴¹Record LLD for the counter being used at each count

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Mult. Factor	Activity (μCi/cc)	LLD ⁴¹	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁										----	----	
C ₂												
C ₃												
C ₄												
C _{LL}											----	

Reviewed By: RP Supervision

Date: 4/11/04

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C₁ At T₄ Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C₂ At T₆ Start second count at least 2 hours after C₁.
- C₃ At T_x Start time dependent upon results of C₂.
- C₄ At T₂₄ Start count 24 hours after C₁.
- C_{LL} At T₇₅ Start count at least 75 hours after T₀.

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta T})}{1 - e^{-\lambda \Delta T}}$$

VALUES OF (C_{2,3,4} ETC.)/C₁ FOR C_{LL} EQUAL TO ZERO

TABLE 1

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

- If the ratio of activity (C_{2,3}, etc.)/C₁ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be ≤ 7.5E-13 μCi/cc).
- If C_{LL} is greater than 7.5E-13 μCi/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

- If the C₄/C₁ ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

Point Beach Nuclear Plant

IODINE ACTIVITY CONCENTRATIONS

LOCATION: U1 A 5/C PLATFORM

RWP No. 04-142
4-10-04 Rn

Remote containment sampling system used? Yes No NA

COPTM

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	INITIALS
	DATE	TIME	DATE	TIME			
30-132	4-10-04	0938	4-10-04	2250	1.97 ± 7	205-3	Rn

Sample start flow 30 LPM
 Sample stop flow _____
 Average sample flow _____

Total sample time (min) 792
 Flow correction factor 0.83
 Remarks _____

ANALYSIS DATA:

Isotopic Analysis

MECDOS (for DAC data)

S.I. # _____

Date	Time	Isotope	*Concentration (µCi/cc)	By Initials	Date	Time	Isotope	Concentration (µCi/cc)	By Initials
4/11/04	0113	I-131	<MDA	Rn	4/11/04	0112	Cl-38	<MDA	Rn
		I-132	↓	↓			Br-82	↓	↓
		I-133	↓	↓				↓	↓
		I-134	↓	↓				↓	↓
		I-135	↓	↓				↓	↓
		Total Iodine	↓	↓			Total Additional	↓	↓

Total Iodine Concentration + Total Additional Concentration = <MDA µCi/cc By (Initials) Rn

Unit 1 Unit 2 RE-211: _____ µCi RE-212: _____ µCi/cc

This form should be used for all radioiodine analysis results.

*RELEASE ACCOUNTABILITY - (for release paths only)

If the concentration of total for radioiodines exceeds 2.28E-09 µCi/cc, follow steps outlined in RAM 5.2.

Save the charcoal filter until the investigation is completed.

Approved by: [Signature] Date: 4/11/04

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. 04-142

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U-1 "A" S/G Plat

Remote containment sampling system used? Yes No NA

COPY

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-137	4-10-04	2250	4-11-04	0845	1.73 ET	440-3	RLK

Sample Start Flow 35 p.m
 Sample Stop Flow ↓
 Average Sample Flow ↓

Total Sample Time (min) 595
 Flow Correction 0.83
 Remarks _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-11-04	1025	CAN 8	371.2	27.8	343.4	9.4	8.4 E-11	RLK

- ⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.
⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽³⁾	BY INITIALS

- ⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date _____ Time _____ Spectrum Index No. _____

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Release Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 7E-09 μCi/cc, or the total for noble gases exceeds 6.86E-06 μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection Advisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C_2/C_1) is greater than the value given in Table 1, and if C_2 is greater than $7.5E-13$, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

⁴¹Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Multi. Factor	Activity ($\mu\text{Ci/cc}$)	LLD ⁴¹	Hours From C_1	Activity Ratio/ C_1	BY INIT.
C_1										----	----	
C_2												
C_3												
C_4												
C_{LL}											----	

Reviewed By: _____
RP Supervision

Date: 4/11/04

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C_1 At T_4 Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C_2 At T_6 Start second count at least 2 hours after C_1 .
- C_3 At T_x Start time dependent upon results of C_2 .
- C_4 At T_{28} Start count 24 hours after C_1 .
- C_{LL} At T_{75} Start count at least 75 hours after T_0 .

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF $(C_{2,3,4} \text{ ETC.})/C_1$ FOR C_{LL} EQUAL TO ZERO

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

- If the ratio of activity ($C_{2,3}$ etc.)/ C_1 is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be $\leq 7.5E-13 \mu\text{Ci/cc}$).
- If C_{LL} is greater than $7.5E-13 \mu\text{Ci/cc}$, notify RP supervision for review.

Date	Time	C_1	C_2	λ	Δt	C_{LL}	RP Supervision Notified (initials)
				0.0655			

- If the C_2/C_1 ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.


COP

POINT BEAM NUCLEAR PLANT RADIOL CAL SURVEYS

LOCATION: UNIT ~~1~~ 2 STEAM GENERATOR CHANNEL HEAD

DATE: <u>4-8-07</u>	INSTRUMENT TYPE: <u>TI / ABACUS /</u>	PURPOSE: <input type="checkbox"/> Routine Daily Survey
TIME: <u>2310</u>	SERIAL NO.: <u>7935 / 9281 /</u>	<input checked="" type="checkbox"/> RWP # <u>1414</u> <input checked="" type="checkbox"/> Other <u>DIAPHRAGM Removal</u>
MONITOR: <u>[Signature]</u>	COUNTED BY: <u>[Signature]</u>	REVIEWED BY: <u>[Signature]</u>

NO.	LOCATION	DOSE RATE (mrem/hr)
INLET CHANNEL (HOTLEG)		
1	Midpoint of tube sheet	8R
2	Channel head center	7R
3	Center divider head	7.8R
4	Bottom of channel head	8R
5	Manway entrance	2.5R
6	1' from manway	1R
7	3' from manway	2.5R
8	Center of diaphragm	3R
OUTLET CHANNEL (COLDLEG)		
9	Midpoint of tube sheet	12R
10	Channel head center	8R
11	Center divider plate	15.5R
12	Bottom of channel head	10R
13	Manway entrance	2.5R
14	1' from manway	1R
15	3' from manway	3R
16	Center of diaphragm	2.8R
HOT SPOTS (DESCRIBE LOCATION)		
17		
18		
19		
20		



Ventilation Operational Check

RAD DOORS INSTALLED (YES / NO)	VENTILATION OPERABLE (SAT / UNSAT / NA)
Hot Leg: <u>Yes</u>	
Cold Leg: _____	

AREA C-1

- Notes:
- 1) All readings in mrem/hr
 - 2) *Designates hot spots
 - 3) ⊙ Designates routinely updated posting
 - 4) "Potential Hazards" identified are indicated on map

POI BEACH NUCLEAR PLANT
RADIOLOGICAL SURVEYS

LOCATION: "B" LOOP - BELOW "B" STEAM GENERATOR


COPY

DATE 4-10-02
TIME 1000
MONITOR REFOR 47E M11

INSTRUMENT TYPE ASCS / ABACUS RM14
SERIAL NO. 7839 / 9684 / 7678
COUNTED BY [Signature]

PURPOSE: Daily Survey Pre-RWP
 RWP # 04-14R Other
REVIEWED BY: [Signature]

NO.	MREM/HR	B γ DPM/100 CM ²	α DPM/100 CM ²	REMARKS
1	100	200	200	7/LOOR
2	100	200	200	
3	100	200	200	
4	100	200	200	
5	100	200	200	
6	100	200	200	
7	100	200	200	
8	100	200	200	
9	100	200	200	
10	100	200	200	
11	100	200	200	
12	100	200	200	
13	100	200	200	
14	100	200	200	
15	100	200	200	
16	100	200	200	
17	100	200	200	
18	100	200	200	
19	100	200	200	
20	100	200	200	



PBF-4021
Revision 0 01/01/93
HP 1.9

- Notes:
- 1) All readings in mrem/hr
 - 2) *Designates hot spots
 - 3) ⊗ Designates routinely updated posting
 - 4) "Potential Hazards" identified are indicated on map

AREA 1C-14
SHIELDING


POINT ACH NUCLEAR PLANT
RADIOLOGICAL SURVEYS

LOCATION: "B" LOOP - BELOW "B" STEAM GENERATOR

COPY

DATE	4-9-94	INSTRUMENT TYPE	RSOS / ANTEUS / RM114	PURPOSE:	<input type="checkbox"/> Daily Survey	<input type="checkbox"/> Pre-RWP
TIME	1500	SERIAL NO.	7337 / 9684 / 7698	<input checked="" type="checkbox"/> RWP #	04-141	<input type="checkbox"/> Other
MONITOR	PETER SATENIM	COUNTED BY	PETER SATENIM	REVIEWED BY:	<i>[Signature]</i>	

NO.	MREM/HR	By DPM/100 CM ²	aDPM/100 CM ²	REMARKS
1		1500	<MDA	FLOOR
2		50K		
3		1K		
4		50K		
5		4K		
6		10K		
7		115	<MDA	
8		21K	=MDA	
9		21K	<MDA	
10		21K	<MDA	
11		21K		
12		41K		
13		50K		
14		1.57K	<MDA	
15		115	<MDA	



PBF-4021
Revision 0 01/01/93
HP 1.9

- Notes:
- 1) All readings in mrem/hr
 - 2) *Designates hot spots
 - 3) Ⓞ Designates routinely updated posting
 - 4) "Potential Hazards" identified are indicated on man

SHIELDING

POINT ACH NUCLEAR PLANT
RADIOLOGICAL SURVEYS


COP

LOCATION: "B" LOOP - BELOW "B" STEAM GENERATOR

DATE 4-9-04
TIME 1330
MONITOR Dan Mihalik

INSTRUMENT TYPE RO-2A/RM-14/560H PURPOSE: Daily Survey Pre-RWP
SERIAL NO. 14310 / 2648 / 9691 RWP # _____ Other Post-ACCID
COUNTED BY D. Mihalik REVIEWED BY: M. [Signature]

NO.	MREM/HR	By DPM/100 CM ²	By DPM/100 CM ²	REMARKS
1	5K			
2	6K			
3	70K			
4	5K			
5	20K			100 m
6	10K			
7	300K		463.6	SEVERE
8	10K		32.8	MANWAY - floor
9	10K		47.8	
10	8K			



PBF-4021
Revision 0 01/01/93
HP 1.9

- Notes: 1) All readings in mrem/hr
2) *Designates hot spots
3) ⊙ Designates routinely updated posting
4) "Potential Hazards" identified are indicated on map

* Contact
1 F +
3 + +


POINT CH NUCLEAR PLANT
RADIOLOGICAL SURVEYS

COP

LOCATION: "B" LOOP - BELOW "B" STEAM GENERATOR

DATE 4-6-04 INSTRUMENT TYPE RS05 / Abacus PURPOSE: Daily Survey Pre-RWP
 TIME 2315 SERIAL NO. 7855 / 9684 RWP # Other
 MONITOR K. Kono COUNTED BY K. Kono REVIEWED BY: [Signature]

NO.	MREM/ HR	β DPM/ 100 CM ²	α DPM/ 100 CM ²	REMARKS
1	N/A	30.2	9.2	Manway (L)
2		499	<24	Griphlon
3		166	<24	Support Beam
4		596	<24	Griphlon
5		130	<24	Manway (HL)
6	✓	365	<24	Grating
ILL. - R 4-7-04				



AREA IC-14

PBF-4021
Revision 0 01/01/93
HP 1.9

- Notes:
- 1) All readings in mrem/hr
 - 2) *Designates hot spots
 - 3) ⊗ Designates routinely updated posting
 - 4) "Potential Hazards" identified are indicated on map


POIN H NUCLEAR PLANT
RADIOLOGICAL SURVEYS

LOCATION: "B" LOOP - BELOW "B" STEAM GENERATOR

COPY

DATE	<u>4/5/69</u>	INSTRUMENT TYPE	<u>ROZA</u>	PURPOSE:	<input type="checkbox"/> Daily Survey	<input type="checkbox"/> Pre-RWP
TIME	<u>2200</u>	SERIAL NO.	<u>A011</u>	<input type="checkbox"/> RWP #	<input checked="" type="checkbox"/> Other <u>See/visit file</u>	
MONITOR	<u>HINCHISON</u>	COUNTED BY	<u>N/A</u>	REVIEWED BY:	<u>Mattews</u>	

NO.	MREM/ HR	$\beta\gamma$ DPM/ 100 CM ²	α DPM/ 100 CM ²	REMARKS
N/A	N/A	N/A	N/A	



PBF-4021
Revision 0 01/01/93
HP 1.9

- Notes:
- 1) All readings in mrem/hr
 - 2) *Designates hot spots
 - 3) ⊙ Designates routinely updated posting
 - 4) "Potential Hazards" identified are indicated on map

POINT H NUCLEAR PLANT
RADIOLOGICAL SURVEYS




LOCATION: "B" LOOP - BELOW "B" STEAM GENERATOR

DATE 4-5-04
TIME 1520
MONITOR PETER STEINM

INSTRUMENT TYPE RCA
SERIAL NO. 7137
COUNTED BY PETER STEINM

PURPOSE: Daily Survey Pre-RWP
 RWP # Other POST SHIELDING
REVIEWED BY: IC-14

NO.	MREM/ HR	B γ DPM/ 100 CM 2	α DPM/ 100 CM 2	REMARKS



*NOTE: SHIELDING @ PIPE NEEDS TO BE MODIFIED
THERE ARE GAPS BETWEEN SHIELDING BLANKETS*

- Notes: 1) All readings in mrem/hr
2) *Designates hot spots
3) @ Designates routinely updated posting
4) "Potential Hazards" identified are indicated on map

PBF-4021
Revision 0 01/01/93
HP 1.9

AREA IC-14
Sample lines
RADIATION SCHEM
1/030, 4-5-04


POINT E H NUCLEAR PLANT
RADIOLOGICAL SURVEYS

COP

LOCATION: "B" LOOP - BELOW "B" STEAM GENERATOR

DATE 4-5-04 INSTRUMENT TYPE ROSA PURPOSE: Daily Survey Pre-RWP
 TIME 1040 SERIAL NO. 7137 RWP # 4-104 Other
 MONITOR MATHEL COUNTED BY _____ REVIEWED BY: [Signature]

NO.	MREM/ HR	$\beta\gamma$ DPM/ 100 CM ²	α DPM/ 100 CM ²	REMARKS



AREA IC-14

PBF-4021
Revision 0 01/01/93
HP 1.9

- Notes: 1) All readings in mrem/hr
 2) *Designates hot spots
 3) ⊗ Designates routinely updated posting
 4) "Potential Hazards" identified are indicated on map


**POINT BEACH NUCLEAR PLANT
RADIOLOGIC SURVEYS**

LOCATION: "B" LOOP - BEL. B" STEAM GENERATOR

DATE <u>4/3/04</u>	INSTRUMENT TYPE <u>Roza / Rm14 / SAC 4</u>	PURPOSE: <input type="checkbox"/> Daily Survey <input type="checkbox"/> Pre-RWP
TIME <u>0320</u>	SERIAL NO. <u>A012 / 7202 / 7172</u>	<input type="checkbox"/> RWP # <u>01-107</u> <input checked="" type="checkbox"/> Other INITIAL
MONITOR <u>Dole / Hinrichsen</u>	COUNTED BY <u>Dole</u> <u>Rm14 Bkgd = 14 cpm</u>	REVIEWED BY: <u>[Signature]</u>

COPY

NO.	MREM/HR	βγ DPM/100 CM ²	αDPM/100 CM ²	REMARKS
1	See map	41K		WALL
2		41K		STRUT
3		3K	422	GRATING
4		5K	422	I-BEAM
5		41K		WALL
6		41K		STRUT
7		4K	422	I-BEAM
8		1K		RAILING
9		8K	33	PIPE INSULATION
10	See map	41K		BECK GATE



#/# = CONTACT / 30cm

- Notes: 1) All readings in mrem/hr
 2) *Designates hot spots
 3) ⊗Designates routinely updated posting
 4) "Potential Hazards" identified are indicated on map

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. 04-140

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U1 B 5/6 PLATFORM

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-111	4-8-04	1342	4-8-04	1855	8.83 cc	LUS-30	Rm

Sample Start Flow: 30 cpm
 Sample Stop Flow: _____
 Average Sample Flow: ↓

Total Sample Time (min): 313
 Flow Correction: 0.94
 Remarks: _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-8-04	2015	PRO-2	23.0	0.6	22.4	4.2	7.80E-12	Rm

⁽¹⁾ If sample activity is greater than or equal to 10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽³⁾	BY INITIALS

⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date _____ Time _____ Spectrum Index No. _____

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

For Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 6.86E-09 μCi/cc, or the total for noble gases exceeds 6.86E-06 μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection supervisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C₂/C₁) is greater than the value given in Table 1, and if C₂ is greater than 7.5E-13, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

⁽¹⁾Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Multi. Factor	Activity (μCi/cc)	LLD ⁽¹⁾	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁										----	----	
C ₂												
C ₃												
C ₄												
C _{LL}											----	

Reviewed By: *[Signature]* RP Supervision

Date: 9/5/84

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C₁ At T₄ Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C₂ At T₆ Start second count at least 2 hours after C₁.
- C₃ At T_x Start time dependent upon results of C₂.
- C₄ At T₂₈ Start count 24 hours after C₁.
- C_{LL} At T_{>75} Start count at least 75 hours after T₀.

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF (C_{2,3,4}, ETC.)/C₁ FOR C_{LL} EQUAL TO ZERO

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

1. If the ratio of activity (C_{2,3}, etc.)/C₁ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be ≤ 7.5E-13 μCi/cc).
2. If C_{LL} is greater than 7.5E-13 μCi/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

3. If the C₂/C₁ ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. 01-140

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U1 B5/G

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-112	—	—	4-8-04	2330	1075	N/A	SM

Sample Start Flow N/A
 Sample Stop Flow N/A
 Average Sample Flow N/A

Total Sample Time (min) N/A
 Flow Correction N/A
 Remarks N/A

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ⁽¹⁾⁽²⁾	BY INITIALS

⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽³⁾	BY INITIALS

⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.
 Date 4/8/04 Time 2353 Spectrum Index No. N/A

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS
 	2 MDA	SM			

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 0.09 μCi/cc, or the total for noble gases exceeds 6.86E-06 μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection supervisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C_2/C_1) is greater than the value given in Table 1. and if C_2 is greater than $7.5E-13$, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

⁽¹⁾Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Mult. Factor	Activity ($\mu\text{Ci/cc}$)	LLD ⁽¹⁾	Hours From C_1	Activity Ratio/ C_1	BY INIT.
C_1										----	----	
C_2												
C_3												
C_4												
C_{LL}											----	

Reviewed By: Zde
 RP Supervision

Date: 4/9/69

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C_1 At T_4 Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C_2 At T_6 Start second count at least 2 hours after C_1 .
- C_3 At T_x Start time dependent upon results of C_2 .
- C_4 At T_{28} Start count 24 hours after C_1 .
- C_{LL} At $T_{>75}$ Start count at least 75 hours after T_0 .

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF ($C_{2,3,4, \text{ ETC.}}/C_1$) FOR C_{LL} EQUAL TO ZERO

TABLE 1

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

1. If the ratio of activity ($C_{2,3, \text{ etc.}}/C_1$) is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be $\leq 7.5E-13 \mu\text{Ci/cc}$).
2. If C_{LL} is greater than $7.5E-13 \mu\text{Ci/cc}$, notify RP supervision for review.

Date	Time	C_1	C_2	λ	Δt	C_{LL}	RP Supervision Notified (initials)
				0.0655			

3. If the C_2/C_1 ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

Point Beach Nuclear Plant

IODINE ACTIVITY CONCENTRATIONS

LOCATION: U1 B 5/2 D.P. Removal RWP No. 04-140

Remote containment sampling system used? Yes No NA

COF

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME, (cc)	SAMPLER NUMBER	INITIALS
	DATE	TIME	DATE	TIME			
30-115	4-8-04	2320	4-8-04	2330	1.13 ϵ^6	HUS-17	DR

Sample start flow 113 LPM Total sample time (min) 10
 Sample stop flow _____ Flow correction factor _____
 Average sample flow ↓ Remarks _____

ANALYSIS DATA:

Isotopic Analysis

MECDOS (for DAC data)

S.I. # _____

Date	Time	Isotope	*Concentration ($\mu\text{Ci/cc}$)	By Initials	Date	Time	Isotope	Concentration ($\mu\text{Ci/cc}$)	By Initials
4/9/04	0141	I-131	$7.45E^{-11}$	W	4/9/04	0141	Cl-38		
↓	↓	I-132	$7.12E^{-10}$	W	↓	↓	Br-82		
↓	↓	I-133	LMDA	W	↓	↓			
↓	↓	I-134	↓	W	↓	↓			
↓	↓	I-135	↓	W	↓	↓			
↓	↓	Total Iodine	$7.87E^{-10}$	W	↓	↓	Total Additional		

Total Iodine Concentration + Total Additional Concentration = $7.87E^{-10}$ $\mu\text{Ci/cc}$ By (Initials) W

[] Unit 1 [] Unit 2 RE-211: _____ μCi RE-212: _____ $\mu\text{Ci/cc}$

This form should be used for all radioiodine analysis results.

*RELEASE ACCOUNTABILITY - (for release paths only)

If the concentration of total for radioiodines exceeds $2.28E^{-09} \mu\text{Ci/cc}$, follow steps outlined in RAM 5.2.

Save the charcoal filter until the investigation is completed.

Approved by: *[Signature]* Date: 4/9/04

Point Beach Nuclear Plant
*** RESTRICTED DAC IN AIR CALCULATIONS ***

SAMPLE DATE: 4/8/2004 23:30
SAMPLE LOCATION: U1 B S/G D.P
REMARKS:

SAMPLE ID: 30-115

TAKEN BY: RM
ANALYSIS BY: EK

COP

ISOTOPIC ANALYSIS RESULTS

ISOTOPE	RESTRICTED DAC (uCi/cc)	CONC (uCi/cc)	FRAC. OF CONC.	% OF DAC
I-131	2.00E-08	7.45E-11	0.09	0.373
I-132	3.00E-06	7.12E-10	0.91	0.024
TOTALS		7.87E-10	1.00	0.396

Based on a 40 hour work week, the maximum stay time for the listed concentrations is: 1.0E+04 hours.

Reviewed by:  Date: 4/9/04

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. 04-140

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U1 B 5/6 PLATFORM

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-116	4-8-04	1855	4-8-04	2340	8,04 EG	203-30	Rm

Sample Start Flow 30 LPM
 Sample Stop Flow _____
 Average Sample Flow ↓

Total Sample Time (min) 285
 Flow Correction 0.94
 Remarks _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-9-04	0022	PRO-2	59.2	0.6	58.6	4.2	1.38E-11	Rm

⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽³⁾	BY INITIALS

⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date _____ Time _____ Spectrum Index No. _____

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 6.0E-09 μCi/cc, or the total for noble gases exceeds 6.0E-06 μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection supervisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C₂/C₁) is greater than the value given in Table 1. and if C₂ is greater than 7.5E-13, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

⁽¹⁾Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Mult. Factor	Activity (µCi/cc)	LLD ⁽¹⁾	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁										----	----	
C ₂												
C ₃												
C ₄												
C _{LL}											----	

Reviewed By: RP Supervision

Date: 4/9/84

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C₁ At T₄ Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C₂ At T₆ Start second count at least 2 hours after C₁.
- C₃ At T_s Start time dependent upon results of C₂.
- C₄ At T₂₄ Start count 24 hours after C₁.
- C_{LL} At T_{>75} Start count at least 75 hours after T₀.

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF (C_{2,3,4}, ETC.)/C₁ FOR C_{LL} EQUAL TO ZERO

TABLE 1

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

1. If the ratio of activity (C_{2,3}, etc.)/C₁ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be ≤ 7.5E-13 µCi/cc).
2. If C_{LL} is greater than 7.5E-13 µCi/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

3. If the C₂/C₁ ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

IODINE ACTIVITY CONCENTRATIONS

LOCATION: U1 B5/E PLATFORM RWP No. 04-140

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME, (cc)	SAMPLER NUMBER	INITIALS
	DATE	TIME	DATE	TIME			
30-117	4-8-04	1855	4-8-04	2340	8.04 EG	LUS-30	Rh

Sample start flow 30 LPM Total sample time (min) 285
 Sample stop flow ↓ Flow correction factor 0.94
 Average sample flow ↓ Remarks ↓

ANALYSIS DATA:

[X] Isotopic Analysis MECDOS (for DAC data) S.I. # _____

Date	Time	Isotope	*Concentration (µCi/cc)	By Initials	Date	Time	Isotope	Concentration (µCi/cc)	By Initials
4/9/04	0104	I-131	5.43E-12	EW	4/9/04	0104	Cl-38	LMPA	EW
↓	↓	I-132	8.15E-11	↓	↓	↓	Br-82	↓	↓
↓	↓	I-133	2MPA	↓	↓	↓		↓	↓
↓	↓	I-134	↓	↓	↓	↓		↓	↓
↓	↓	I-135	↓	↓	↓	↓		↓	↓
↓	↓	Total Iodine	8.69E-11	↓	↓	↓	Total Additional	↓	↓

Total Iodine Concentration + Total Additional Concentration = 8.69E-11 µCi/cc By (Initials) EW

[] Unit 1 [] Unit 2 RE-211: _____ µCi RE-212: _____ µCi/cc

This form should be used for all radioiodine analysis results.
 *RELEASE ACCOUNTABILITY - (for release paths only)
 If the concentration of total for radioiodines exceeds 2.28E-09 µCi/cc, follow steps outlined in RAM 5.2.
 Save the charcoal filter until the investigation is completed.

Approved by: [Signature] Date: 4/9/04

Point Beach Nuclear Plant

*** RESTRICTED DAC IN AIR CALCULATIONS ***

SAMPLE DATE: 4/8/2004 23:40
SAMPLE LOCATION: U1 B S/G PLATFORM
REMARKS:

SAMPLE ID: 30-117

TAKEN BY: RM
ANALYSIS BY: EK

COP

ISOTOPIC ANALYSIS RESULTS

ISOTOPE	RESTRICTED DAC ($\mu\text{Ci/cc}$)	CONC ($\mu\text{Ci/cc}$)	FRAC. OF CONC.	% OF DAC
I-131	2.00E-08	5.43E-12	0.06	0.027
I-132	3.00E-06	8.15E-11	0.94	0.003
TOTALS		8.69E-11	1.00	0.030

Based on a 40 hour work week, the maximum stay time for the listed concentrations is: 1.3E+05 hours.

Reviewed by: zde Date: 4/9/04

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. _____

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U-1 "B" S/C Platform

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-125	4-8-04	2040	4-9-04	1605	2.78E7 2.78E7	2100 LUS-30	RLK

Sample Start Flow: 30 LPM
 Sample Stop Flow: _____
 Average Sample Flow: _____

Total Sample Time (min): 985
 Flow Correction: 0.74
 Remarks: _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-9-04	1650	Pro-2	3355.6	0.1	3555.5	4.2	2.28E-9	Rm

⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽¹⁾	BY INITIALS
4-9-04	1650	Pro-2	14.4	0.0	14.4	246.9	Rm

⁽¹⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date 4/9/04 Time 2:15:21 Spectrum Index No. NIA

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS
Cr 51	2.77E-11	W	Ru103	7.57E-13	W
Mn 54	2.80E-12	W	Sr 113	1.62E-12	W
Co 57	5.39E-13	W	Sr 117M	6.66E-13	W
Co 58	1.05E-10	W	Sb 125	2.58E-12	W
Co 60	2.53E-11	W			
Nb 95	7.38E-11	W			
Zr 95	5.69E-11	W			

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Release Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 5.8E-09 μCi/cc, or the total for noble gases exceeds 6.8E-06 μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection Director. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an air release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C₂/C₁) is greater than the value given in Table 1. - and if C₂ is greater than 7.5E-13, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

⁴¹Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Mult. Factor	Activity (μCi/cc)	LLD ⁴¹	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁										----	----	
C ₂												
C ₃												
C ₄												
C _{LL}											----	

Reviewed By: *[Signature]* RP Supervision

Date: 4/10/04

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C₁ At T₄ Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C₂ At T₆ Start second count at least 2 hours after C₁.
- C₃ At T₈ Start time dependent upon results of C₂.
- C₄ At T₂₄ Start count 24 hours after C₁.
- C_{LL} At T_{>75} Start count at least 75 hours after T₀.

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF (C_{2,3,4} ETC.)/C₁ FOR C_{LL} EQUAL TO ZERO

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

1. If the ratio of activity (C_{2,3} etc.)/C₁ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be ≤ 7.5E-13 μCi/cc).
2. If C_{LL} is greater than 7.5E-13 μCi/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

3. If the C₂/C₁ ratio is greater than that in Table 1, refer to HPIP 5.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

Point Beach Nuclear Plant
 *** RESTRICTED DAC IN AIR CALCULATIONS ***

SAMPLE DATE: 4/9/2004 16:05
 SAMPLE LOCATION: U1 'B' S/G PLATFORM
 REMARKS:

SAMPLE ID: 30-125

TAKEN BY: RLK
 ANALYSIS BY: EK


COP

ISOTOPIC ANALYSIS RESULTS

ISOTOPE	RESTRICTED DAC (uCi/cc)	CONC (uCi/cc)	FRAC. OF CONC.	% OF DAC
CR-51	8.00E-06	2.77E-11	0.09	0.000
MN-54	3.00E-07	2.80E-12	0.01	0.001
CO-57	3.00E-07	5.39E-13	0.00	0.000
CO-58	3.00E-07	1.05E-10	0.35	0.035
CO-60	1.00E-08	2.53E-11	0.08	0.253
NB-95	5.00E-07	7.38E-11	0.25	0.015
ZR-95	5.00E-08	5.69E-11	0.19	0.114
RU-103	3.00E-07	7.57E-13	0.00	0.000
① SN-113	5.00E-07	2.29E-12	0.01	0.000
SB-125	2.00E-07	2.58E-12	0.01	0.001
TOTALS		2.98E-10	1.00	0.420

Based on a 40 hour work week, the maximum stay time for the listed concentrations is: 9.5E+03 hours.

① Sn113 value is actually Sn117M + Sn113 values. Reference
 CAP 055511. gm 4/9/04
 (6.66E-13 µCi/cc) (1.62E-12 µCi/cc)

Reviewed by:  Date: 4/19/04

Point Beach Nuclear Plant

IODINE ACTIVITY CONCENTRATIONS

LOCATION: U-1 "B" S/G Platform RWP No. _____

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	INITIALS
	DATE	TIME	DATE	TIME			
30-126	4-8-04	23:10	4-9-04	16:05	605-30	2	RM

2.78E7

Sample start flow 30 L/min
 Sample stop flow _____
 Average sample flow _____

Total sample time (min) 985
 Flow correction factor 0.97
 Remarks _____

ANALYSIS DATA:

Isotopic Analysis

MECDOS (for DAC data)

S.I. # _____

Date	Time	Isotope	*Concentration (µCi/cc)	By Initials	Date	Time	Isotope	Concentration (µCi/cc)	By Initials
4/9/04	2129	I-131	<MDA	RM	4/9/04	2129	Cl-38	<MDA	RM
		I-132					Br-82		
		I-133							
		I-134							
		I-135							
		Total Iodine					Total Additional		

Total Iodine Concentration + Total Additional Concentration = <MDA µCi/cc By (Initials) RM

Unit 1 Unit 2 RE-211: _____ µCi RE-212: _____ µCi/cc

This form should be used for all radioiodine analysis results.

*RELEASE ACCOUNTABILITY - (for release paths only)

If the concentration of total for radioiodines exceeds 2.25E-09 µCi/cc, follow steps outlined in RAM 5.2. Save the charcoal filter until the investigation is completed.

Approved by: [Signature]

Date: 4/10/04

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. _____

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: J-1 'B' S/G Plat

Remote containment sampling system used? Yes No NA

CO

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-127	4-9-04	1605	4-10-04	0950	3.0 E7	LV5-30	RLK

Sample Start Flow 30 lpm
 Sample Stop Flow ↓
 Average Sample Flow ↓

Total Sample Time (min) 1065
 Flow Correction 0.74
 Remarks _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-11-04	1758	69-6 0229	572	394	178	1.2	3.8 E-12	RLK

- ⁽¹⁾ If sample activity is greater than or equal to $5E-10$ μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.
⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than $1E-10$ μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽³⁾	BY INITIALS

- ⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date _____ Time _____ Spectrum Index No. _____

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Release Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds $6E-09$ μCi/cc, or the total for noble gases exceeds $6.86E-06$ μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection Supervisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C₂/C₁) is greater than the value given in Table 1, and if C₂ is greater than 7.5E-13, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

¹⁴Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Mult. Factor	Activity (μCi/cc)	LLD ¹⁴	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁										----	----	
C ₂												
C ₃												
C ₄										--		
C _{LL}											----	

Reviewed By: *[Signature]* RP Supervision

Date: 4-10-81

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C₁ At T₄ Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C₂ At T₆ Start second count at least 2 hours after C₁.
- C₃ At T_x Start time dependent upon results of C₂.
- C₄ At T₂₈ Start count 24 hours after C₁.
- C_{LL} At T_{>75} Start count at least 75 hours after T₀.

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF (C_{2,3,4} ETC.)/C₁ FOR C_{LL} EQUAL TO ZERO

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

- NOTES:**
- If the ratio of activity (C_{2,3} etc.)/C₁ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be ≤ 7.5E-13 μCi/cc).
 - If C_{LL} is greater than 7.5E-13 μCi/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

- If the C₂/C₁ ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

Point Beach Nuclear Plant

IODINE ACTIVITY CONCENTRATIONS

LOCATION: 1-1-B" S/C Plat RWP No. _____

Remote containment sampling system used? Yes No NA

COP

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	INITIALS
	DATE	TIME	DATE	TIME			
30-128	4-9-04	1605	4-10-04	0950	3.0E7	LV9-30	RLK

Sample start flow 30 lpm
 Sample stop flow ↓
 Average sample flow ↓

Total sample time (min) 1065
 Flow correction factor 0.94
 Remarks _____

ANALYSIS DATA:

Isotopic Analysis MECDOS (for DAC data) S.I. # _____

Date	Time	Isotope	*Concentration (µCi/cc)	By Initials	Date	Time	Isotope	Concentration (µCi/cc)	By Initials
4-10-04	1532	I-131					Cl-38		
		I-132					Br-82		
		I-133							
		I-134							
		I-135							
		Total Iodine	<u>LMQA</u>	<u>KCB</u>			Total Additional	<u>LMQA</u>	<u>KCB</u>

Total Iodine Concentration + Total Additional Concentration = LMQA µCi/cc By (Initials) KCB

Unit 1 Unit 2 RE-211: _____ µCi RE-212: _____ µCi/cc

This form should be used for all radioiodine analysis results.

*RELEASE ACCOUNTABILITY - (for release paths only)

If the concentration of total for radioiodines exceeds 2.28E-09 µCi/cc, follow steps outlined in RAM 5.2.

Save the charcoal filter until the investigation is completed.

Approved by: [Signature] Date: 4/11/04

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. 07-142

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U1 B 3/4 PLATFORM

Remote containment sampling system used? Yes No NA

COPY

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-133	4-10-84	0950	4-10-84	2255	2.71E7	LVS-30	Rm

Sample Start Flow 30 cfm
 Sample Stop Flow _____
 Average Sample Flow ↓

Total Sample Time (min) 785
 Flow Correction 0.97
 Remarks _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm $\beta\gamma$	MULT. FACTOR	SAMPLE ACTIVITY ($\mu\text{Ci/cc}$) ^(1,2)	BY INITIALS
4-10-84	2256	P20 2	31.2	0.8	30.4	4.2	2.60E-12	Rm

⁽¹⁾ If sample activity is greater than or equal to $5E-10 \mu\text{Ci/cc}$, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than $1E-10 \mu\text{Ci/cc}$, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm $\beta\gamma$ / NET cpm α ⁽³⁾	BY INITIALS

⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date _____ Time _____ Spectrum Index No. _____

ISOTOPE	ACTIVITY ($\mu\text{Ci/cc}$)	BY INITIALS	ISOTOPE	ACTIVITY ($\mu\text{Ci/cc}$)	BY INITIALS

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ $\mu\text{Ci/cc}$

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ $\mu\text{Ci/cc}$ SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Release Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds $5.7 \times 10^{-9} \mu\text{Ci/cc}$, or the total for noble gases exceeds $6.86E-06 \mu\text{Ci/cc}$, notify the Chemistry Lab supervisor and/or the Radiation Protection supervisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C_2/C_1) is greater than the value given in Table 1, and if C_2 is greater than $7.5E-13$, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

⁴¹Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Mult. Factor	Activity ($\mu\text{Ci/cc}$)	LLD ⁴¹	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁										----	----	
C ₂												
C ₃										--		
C ₄												
C _{LL}											----	

Reviewed By: _____
 RP Supervision

Date: 4/11/07

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C₁ At T₄ Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C₂ At T₆ Start second count at least 2 hours after C₁.
- C₃ At T_x Start time dependent upon results of C₂.
- C₄ At T₂₈ Start count 24 hours after C₁.
- C_{LL} At T_{>75} Start count at least 75 hours after T₀.

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF $(C_{2,3,4, \text{ETC.}})/C_1$ FOR C_{LL} EQUAL TO ZERO

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

- If the ratio of activity $(C_{2,3, \text{etc.}})/C_1$ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be $\leq 7.5E-13$ $\mu\text{Ci/cc}$).
- If C_{LL} is greater than $7.5E-13$ $\mu\text{Ci/cc}$, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

- If the C_2/C_1 ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

IODINE ACTIVITY CONCENTRATIONS

COP

LOCATION: U1 B7G PLATFORM RWP No. 04-142

Remote containment sampling system used? Yes No NA

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME, (cc)	SAMPLER NUMBER	INITIALS
	DATE	TIME	DATE	TIME			
30-134	4-10-04	0950	4-10-04	2255	2.21 E7	LUS-30	SM

Sample start flow 30 LPM
 Sample stop flow ↓
 Average sample flow ↓

Total sample time (min) 785
 Flow correction factor 0.94
 Remarks _____

ANALYSIS DATA:

Isotopic Analysis

MECDOS (for DAC data)

S.I. # _____

Date	Time	Isotope	*Concentration (µCi/cc)	By Initials	Date	Time	Isotope	Concentration (µCi/cc)	By Initials
4/11/04	0113	I-131	<MDA	GV	4/11/04	0113	Cl-38	<MDA	W
↓	↓	I-132	↓	↓	↓	↓	Br-82	↓	↓
↓	↓	I-133	↓	↓	↓	↓		↓	↓
↓	↓	I-134	↓	↓	↓	↓		↓	↓
↓	↓	I-135	↓	↓	↓	↓		↓	↓
↓	↓	Total Iodine	↓	↓	↓	↓	Total Additional	↓	↓

Total Iodine Concentration + Total Additional Concentration = <MDA µCi/cc By (Initials) GV

Unit 1 Unit 2 RE-211: _____ µCi RE-212: _____ µCi/cc

This form should be used for all radioiodine analysis results.

*RELEASE ACCOUNTABILITY - (for release paths only)

If the concentration of total for radioiodines exceeds 2.25E-09 µCi/cc, follow steps outlined in RAM 5.2. Save the charcoal filter until the investigation is completed.

Approved by: [Signature] Date: 4/11/04

SAMPLE TYPE:
 AP Gas Other

Point Beach Nuclear Plant

RWP No. 04-142

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U-1 B S/C Plat

Remote containment sampling system used? Yes No NA

COPY

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME (cc)	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-138	4-10-04	2255	4-11-04	1017	1.92 E7	245-30	RLK

Sample Start Flow 30 lpm
 Sample Stop Flow ↓
 Average Sample Flow ↓

Total Sample Time (min) 682
 Flow Correction 0.94
 Remarks _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-11-04	1040	CAN-8	67.8	27.8	40	9.4	3768.3	RLK

- ⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.
⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ / NET cpm α ⁽³⁾	BY INITIALS

- ⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by _____ hr. for LLA counting.

Date _____ Time _____ Spectrum Index No. _____

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Release Accountability: (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 0.09 μCi/cc, or the total for noble gases exceeds 6.56E-06 μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection Unit. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C₂/C₁) is greater than the value given in Table 1, and if C₂ is greater than 7.5E-13, perform C_{LL} screening.

Sample Volume (cc): _____ (from Page 1)

⁽¹⁾Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter No.	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Multi. Factor	Activity (μCi/cc)	LLD ⁽¹⁾	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁										----	----	
C ₂												
C ₃												
C ₄												
C _{LL}											----	

Reviewed By: [Signature] RP Supervision

Date: 9/11/64

COUNTING INFORMATION FOR LONG LIVED ALPHA

Count Time

- C₁ At T₄ Start first count 4 hours after sample stop time. (Essentially all radon decayed.)
- C₂ At T₆ Start second count at least 2 hours after C₁.
- C₃ At T_x Start time dependent upon results of C₂.
- C₄ At T₂₄ Start count 24 hours after C₁.
- C_{LL} At T_{>75} Start count at least 75 hours after T₀.

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF (C_{2,3,4} ETC.)/C₁ FOR C_{LL} EQUAL TO ZERO

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

- NOTES:**
- If the ratio of activity (C_{2,3}, etc.)/C₁ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be ≤ 7.5E-13 μCi/cc).
 - If C_{LL} is greater than 7.5E-13 μCi/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
				0.0655			

- If the C₂/C₁ ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

SAMPLE TYPE: AP Gas Other

Point Beach Nuclear Plant

RWP No. 04-140

AIRBORNE RADIOACTIVITY SURVEY

Sample Location: U1 B-3/6 DP Removal

Remote containment sampling system used? Yes No NA

COPY

SAMPLING DATA:

SAMPLE NUMBER	SAMPLE START		SAMPLE STOP		SAMPLE VOLUME <small>(μCi/cc) min</small>	SAMPLER NUMBER	BY INITIALS
	DATE	TIME	DATE	TIME			
30-113	4-8-04	2320	4-8-04	2330	HUS-17	HUS-17	DM

Sample Start Flow: 113 cfm Total Sample Time (min): 10
 Sample Stop Flow: _____ Flow Correction: _____
 Average Sample Flow: _____ Remarks: _____

GROSS BETA-GAMMA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm βγ	MULT. FACTOR	SAMPLE ACTIVITY (μCi/cc) ^(1,2)	BY INITIALS
4-9-04	0011	PR2-1	7397.2	0.5	7396.7	4.1	1.21E-8	DM

⁽¹⁾ If sample activity is greater than or equal to 5E-10 μCi/cc, notify RP supervision, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

⁽²⁾ If sample taken from an area with known alpha contamination (e.g., refueling cavity, spent fuel pool transfer canal, reactor head) and sample activity is greater than 1E-10 μCi/cc, perform gross alpha counting and take or send sample to Chemistry for isotopic analysis.

GROSS ALPHA COUNTING DATA:

DATE	TIME	Counter Number	GROSS cpm	BKGD cpm	NET cpm α	NET cpm βγ/NET cpm α ⁽³⁾	BY INITIALS
4-9-04	0011	PR2-1	7.4	0.0	7.4	799.6	DM

⁽³⁾ If sample activity ratio of net cpm beta-gamma to net cpm alpha is less than 180, notify RP supervision and perform long-lived alpha counting.

Isotopic Analysis NOBLGS DACDOS Return to RP by 0330 hr. for LLA counting.
 Date 4/9/04 Time 0055 Spectrum Index No. N/A

ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS	ISOTOPE	ACTIVITY (μCi/cc)	BY INITIALS
Mn 54	0.62E-12	DM	Bi 214	1.89E-10	DM
Co 57	1.63E-12	DM	Co 58	9.04E-10	DM
Co 59	1.12E-11	DM	Co 60	1.76E-10	DM
Co 60	0.66E-11	DM	Nb 95	6.08E-9	DM
Sr 90	1.52E-11	DM	Zr 95	3.51E-9	DM
Cr 51	3.59E-10	DM	Sr 113	1.95E-10	DM
Mn 54	6.30E-11	DM	Sr 117M	2.02E-11	DM
			Sr 125	5.14E-10	DM

Record RE-211 and RE-212 readings for all at-power containment air samples.

Unit 1 Unit 2 RE-211: _____ μCi RE-212: _____ μCi/cc

Record RE-215 reading and SAE flow for all SAE air samples.

Unit 1 Unit 2 RE-215: _____ μCi/cc SAE Flow: _____ scfm

NOTE: All release path air samples must be counted for long-lived alpha. See back side of form.

Release Accountability - (For release paths only) If the total concentration for particulates (excluding naturally occurring isotopes) exceeds 6.88E-09 μCi/cc, or the total for noble gases exceeds 6.56E-06 μCi/cc, notify the Chemistry lab supervisor and/or the Radiation Protection supervisor. Save the air particulate filter until the investigation is completed. The sample should be investigated to determine its significance as an airborne release.

LONG LIVED ALPHA COUNTING DATA:

If the ratio of (C₂/C₁) is greater than the value given in Table 1, and if C₂ is greater than 7.5E-13, perform C_{LL} screening.

Sample Volume (cc): 1.13 EG (from Page 1)

⁽⁴⁾Record LLD for the counter being used at each count.

COUNT	DATE	TIME	Counter	Gross (cpm)	Bkgd (cpm)	Net (cpm)	Multi. Factor	Activity (μCi/cc)	LLD ⁽⁴⁾	Hours From C ₁	Activity Ratio/C ₁	BY INIT.
C ₁	4-9-04	0330	7272	2.06	0.1	1.96	5.2	3.30 E-12	3.99 E-13	---	---	RM
C ₂	4-9-04	0750	7272	2.14	0.1	2.04	4.3	3.55 E-12	3.99 E-13	4	0.041	RLK
C ₃	4-9-04	1330	7272	1.94	0.1	1.84	4.3	3.15 E-12	3.99 E-13	10	4387	RLK
C ₄	4-10-04	0330	7272	2.16	0.1	2.06	4.3	3.53 E-12	3.99 E-13	24	1.0500	RM
C _{LL}	4-12-04	0230	7272	1.64	0.2	1.44	4.3	2.47 E-12	3.97 E-13	75	---	RM

Reviewed By: _____
RP Supervision

Date: _____

COUNTING INFORMATION FOR LONG LIVED ALPHA

- | | | |
|-----------------|--------------------|--|
| Count | Time | |
| C ₁ | At T ₄ | Start first count 4 hours after sample stop time. (Essentially all radon decayed.) |
| C ₂ | At T ₆ | Start second count at least 2 hours after C ₁ . |
| C ₃ | At T ₈ | Start time dependent upon results of C ₂ . |
| C ₄ | At T ₂₈ | Start count 24 hours after C ₁ . |
| C _{LL} | At T ₇₅ | Start count at least 75 hours after T ₀ . |

$$C_{LL} = \frac{C_2 - (C_1 e^{-\lambda \Delta t})}{1 - e^{-\lambda \Delta t}}$$

VALUES OF (C_{2,3,4} ETC.)/C₁ FOR C_{LL} EQUAL TO ZERO

ΔT		ΔT		ΔT		ΔT	
1	0.9366	5.5	0.6975	9.25	0.5456	13	0.4268
2	0.8772	5.75	0.6862	9.5	0.5367	13.25	0.4198
2.25	0.8630	6	0.6750	9.75	0.5280	13.5	0.4130
2.5	0.8490	6.25	0.6641	10	0.5194	13.75	0.4063
2.75	0.8352	6.5	0.6533	10.25	0.5110	14	0.3997
3	0.8216	6.75	0.6427	10.5	0.5027	16	0.3506
3.25	0.8083	7	0.6322	10.75	0.4945	18	0.3076
3.5	0.7951	7.25	0.6220	11	0.4865	20	0.2698
3.75	0.7822	7.5	0.6119	11.25	0.4786	22	0.236
4	0.7695	7.75	0.6019	11.5	0.4708	23	0.222
4.25	0.7570	8	0.5921	11.75	0.4632	24	0.208
4.5	0.7447	8.25	0.5825	12	0.4557	26	0.182
4.75	0.7326	8.5	0.5731	12.25	0.4483	28	0.160
5	0.7207	8.75	0.5638	12.5	0.4410	30	0.140
5.25	0.7090	9	0.5546	12.75	0.4338		

NOTES:

- If the ratio of activity (C_{2,3}, etc.)/C₁ is equal to or less than that indicated in Table 1, or if the activity of any count is less than LLD, airborne alpha activity will be considered as not present (the LLD must be ≤ 7.5E-13 μCi/cc).
- If C_{LL} is greater than 7.5E-13 μCi/cc, notify RP supervision for review.

Date	Time	C ₁	C ₂	λ	Δt	C _{LL}	RP Supervision Notified (initials)
4-12-04	1615	3.36E-12	3.5E-12	0.0655	4	N/A	

- If the C₂/C₁ ratio is greater than that in Table 1, refer to HPIP 3.53, Counting of Air Samples for Low Level, Long-Lived Radioactive Alpha Particulate Contamination.

Point Beach Nuclear Plant
 *** RESTRICTED DAC IN AIR CALCULATIONS

COPY

SAMPLE DATE: 4/8/2004 23:30
 SAMPLE LOCATION: U1 B S/G D.P
 REMARKS:

SAMPLE ID: 30-113

TAKEN BY: RM
 ANALYSIS BY: EK

ISOTOPIC ANALYSIS RESULTS

ISOTOPE	RESTRICTED DAC (uCi/cc)	CONC (uCi/cc)	FRAC. OF CONC.	% OF DAC
CR-51	8.00E-06	3.59E-10	0.03	0.004
MN-54	3.00E-07	6.30E-11	0.01	0.021
CO-58	3.00E-07	9.04E-10	0.08	0.301
CO-60	1.00E-08	1.76E-10	0.01	1.760
NB-95	5.00E-07	6.08E-09	0.51	1.216
ZR-95	5.00E-08	3.51E-09	0.30	7.020
① SN-113	5.00E-07	2.15E-10	0.02	0.043
SB-125	2.00E-07	5.14E-10	0.04	0.257
TOTALS		4.78E-08	1.00	10.623

Based on a 40 hour work week, the maximum stay time for the listed concentrations is: 376.5 hours.

① sn 113 concentration = Sn 117 M + Sn 113 Activity. *EW*
 4/9/04

Reviewed by: _____ Date: _____

INPO

Just-In-Time Operating Experience

COPY

Ex
4

Ex.
4