

214

From: Ryan Alexander
To: Duane Karjala
Date: 5/12/04 9:53AM
Subject: Re: 30-Day Notifi. from Pt. Beach

Duane, et al.:

<<GroupWise died when I tried to send the first (and very detailed) version of this e-mail. so here's the abbreviated version>>



Any questions, please don't hesitate to call/e-mail me, Ryan

Ex. 5

Ryan D. Alexander
Radiation Specialist - Reactor
U.S. Nuclear Regulatory Commission, Region III
Office: 630-829-9853
Fax: 630-515-1249
E-mail: rda@nrc.gov

>>> Duane Karjala 05/12/2004 7:48:39 AM >>>
Ryan,

We were notified this morning by Licensing Engineer Chuck Krause that Point Beach will be making a 30-day notification that a waste water effluent radiation detector has been taken out of service because of repeated alarms due to low flow. Two CAPs were written, which I will forward in a separate e-mail. Let me know if you need more information.

Also, let me know if you need more information on the contamination found on the inside of a shoe. It is my understanding that the survey of his vehicle and residence identified no radioactive materials.

Duane

CC: Kenneth Riemer; Michael Kunowski; Patrick Loudon; R. Michael Morris

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 5
FOIA/PA-2004-0282

L-26