

INDEX

ADMINISTRATIVE CONTROLS

<u>SECTION</u>	<u>PAGE</u>
<u>6.6 NOT USED</u>	
<u>6.7 NOT USED</u>	
<u>6.8 PROCEDURES AND PROGRAMS</u>	6-14
<u>6.9 REPORTING REQUIREMENTS</u>	6-17
6.9.1 ROUTINE REPORTS.....	6-17
STARTUP REPORT.....	6-17
ANNUAL REPORTS.....	6-17
DELETED	
ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT.....	6-18
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT	6-19
INDUSTRIAL SURVEY OF TOXIC CHEMICALS REPORT	6-20
CORE OPERATING LIMITS REPORT COLR.....	6-20
6.9.2 SPECIAL REPORTS.....	6-20a
<u>6.10 NOT USED</u>	

ADMINISTRATIVE CONTROLS

ANNUAL REPORTS (Continued)

- (1) Reactor power history starting 48 hours prior to the first sample in which the limit was exceeded;
- (2) Results of the last isotopic analysis for radioiodine performed prior to exceeding the limit, results of analysis while limit was exceeded and results of one analysis after the radioiodine activity was reduced to less than limit. Each result should include date and time of sampling and the radioiodine concentrations;
- (3) Clean-up system flow history starting 48 hours prior to the first sample in which the limit was exceeded;
- (4) Graph of the I-131 concentration and one other radioiodine isotope concentration in microcuries per gram as a function of time for the duration of the specific activity above steady-state level; and
- (5) The time duration when the specific activity of the primary coolant exceeded the radioiodine limit.

6.9.1.5 DELETED

|

ADMINISTRATIVE CONTROLS

6.9.1.6 DELETED

ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT

6.9.1.7 The Annual Radiological Environmental Operating Report covering the operation of the unit during the previous calendar year shall be submitted before May 1 of each year. The report shall include summaries, interpretations, and analysis of trends of the results of the Radiological Environmental Monitoring Program for the reporting period. The material provided shall be consistent with the objectives outlined in (1) the ODCM and (2) Sections IV.B.2, IV.B.3, and IV.C of Appendix I to 10 CFR Part 50.