

June 2, 2005

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT PLANT, UNITS 3 AND 4 - REQUEST FOR ADDITIONAL INFORMATION (RAI) RELATED TO GENERIC LETTER 2004-02, "POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON EMERGENCY SUMP RECIRCULATION AT PRESSURIZED-WATER REACTORS" (TAC NOS. MC4725 AND MC4726)

Dear Mr. Stall:

By letter dated March 4, 2005, Florida Power and Light Company (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Turkey Point Plant, Units 3 and 4. The GL requested the licensee perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL.

The NRC staff has completed its preliminary review of your response and has determined it needs additional information requested in the enclosure to complete our review.

This RAI requests additional information about your overall plans and schedules and not any information on detailed plans or extensive analyses. In light of this, please provide the additional information requested in the enclosure within 45 days of receipt of this letter.

If you have any questions, please contact Mr. Jose Arroyo at (301) 415-2149.

Sincerely,
/RA by JArroyo for/

Eva A. Brown, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

Enclosure: Request for Additional Information

cc w/encl: See next page

June 2, 2005

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT PLANT, UNITS 3 AND 4 - REQUEST FOR ADDITIONAL INFORMATION (RAI) RELATED TO GENERIC LETTER 2004-02, "POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON EMERGENCY SUMP RECIRCULATION AT PRESSURIZED-WATER REACTORS" (TAC NOS. MC4725 AND MC4726)

Dear Mr. Stall:

By letter dated March 4, 2005, Florida Power and Light Company (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Turkey Point Plant, Units 3 and 4. The GL requested the licensee perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL.

The NRC staff has completed its preliminary review of your response and has determined it needs additional information requested in the enclosure to complete our review.

This RAI requests additional information about your overall plans and schedules and not any information on detailed plans or extensive analyses. In light of this, please provide the additional information requested in the enclosure within 45 days of receipt of this letter.

If you have any questions, please contact Mr. Jose Arroyo at (301) 415-2149.

Sincerely,
/RA by JArroyo for/

Eva A. Brown, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC PDII-2 R/F RidsOgcRp
RidsAcrsAcnwMailCenter RidsNrrDlpmLpdii2 (MMarshall) RidsNrrPMEBrown
RidsNrrLADBaxley RidsRgnIIIMailCenter DCullison/DSolorio
RidsNrrDlpmDpr RidsNrrDssaDpr MWebb/JArroyo RidsNrrLABClayton

Accession No.: ML051520202 *RAI input from SPLB without any major change

OFFICE	PDIV-1/PM PDIII-2/PM	PDIV-1/LA	DSSA/SPLB/SP	PDII-2/PM	PDIV-1/SC PDIII-2/SC
NAME	MWebb/JHopkins	DBaxley	DCullison/DSolorio*	JArroyo for EBrown	DTerao/GSuh
DATE	6/2/2005	6/2/05	5/23/05	6/2/05	6-2-05

OFFICIAL RECORD COPY

Mr. J. A. Stall
Florida Power & Light Company

TURKEY POINT PLANT

cc:

M. S. Ross, Managing Attorney
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Marjan Mashhadi, Senior Attorney
Florida Power & Light Company
801 Pennsylvania Avenue, NW.
Suite 220
Washington, DC 20004

Michael O. Pearce
Plant General Manager
Turkey Point Nuclear Plant
Florida Power and Light Company
9760 SW. 344th Street
Florida City, FL 33035

T. O. Jones, Site Vice President
Turkey Point Nuclear Plant
Florida Power and Light Company
9760 SW. 344th Street
Florida City, FL 33035

Walter Parker
Licensing Manager
Turkey Point Nuclear Plant
9760 SW 344th Street
Florida City, FL 33035

County Manager
Miami-Dade County
111 Northwest 1 Street, 29th Floor
Miami, Florida 33128

David Moore, Vice President
Nuclear Operations Support
Florida Power and Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Senior Resident Inspector
Turkey Point Nuclear Plant
U.S. Nuclear Regulatory Commission
9762 SW. 344th Street
Florida City, Florida 33035

Mr. Rajiv S. Kundalkar
Vice President - Nuclear Engineering
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Mr. William A. Passetti, Chief
Department of Health
Bureau of Radiation Control
2020 Capital Circle, SE, Bin #C21
Tallahassee, Florida 32399-1741

Mr. Craig Fugate, Director
Division of Emergency Preparedness
Department of Community Affairs
2740 Centerview Drive
Tallahassee, Florida 32399-2100

REQUEST FOR ADDITIONAL INFORMATION
REGARDING GENERIC LETTER 2004-02,
“POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON
EMERGENCY SUMP RECIRCULATION AT PRESSURIZED-WATER REACTORS”
FLORIDA POWER AND LIGHT COMPANY
TURKEY POINT, UNITS 3 AND 4
DOCKET NOS. 50-250 AND 50-251

By letter dated March 4, 2005, Florida Power and Light Company (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Turkey Point Plant, Units 3 and 4. The GL requested that addressees perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL. The staff has completed its preliminary review of your response and has determined it needs the following additional information to complete our review:

In your 90-day response to GL 2004-02, you indicated that you intend to use future test results, industry guidance, and NRC guidance to account for chemical precipitants in your evaluation and their availability will impact the schedule for performing an evaluation. The cooperative NRC-Electric Power Research Institute tests in progress at the University of New Mexico are designed to determine if chemical effects occur, but are not designed to measure head loss associated with any chemical effects. The staff notes that some chemical effects have been observed in the initial three tests.

For addressing chemical effects, you state the evaluation may occur after the September 1, 2005, response due date, depending on the schedule for testing and the availability of industry guidance. This is contrary to the information request in GL 2004-02, which requests that chemical effects be addressed in the September 1, 2005, response. This delay is also contrary to the staff's position that there are sufficient bases to address sump vulnerability to chemical effects and that the September response will be incomplete if the evaluation is incomplete, the design is not complete, or there is no schedule for upgrades. In this light, please discuss your plans and schedule for evaluating chemical effects. In addition, please discuss any plans for performing testing to support your evaluation of this effect.

ENCLOSURE