

June 2, 2005

Mr. Daniel J. Malone  
Site Vice President  
Palisades Nuclear Plant  
Nuclear Management Company, LLC  
27780 Blue Star Memorial Highway  
Covert, MI 49043-9530

SUBJECT: PALISADES PLANT - REQUEST FOR ADDITIONAL INFORMATION (RAI)  
RELATED TO GENERIC LETTER 2004-02, "POTENTIAL IMPACT OF DEBRIS  
BLOCKAGE ON EMERGENCY SUMP RECIRCULATION AT  
PRESSURIZED-WATER REACTORS" (TAC NO. MC4701)

Dear Mr. Malone:

By letter dated March 7, 2005, Nuclear Management Company, LLC, (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Palisades Plant. The GL requested the licensee perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL.

The NRC staff has completed its preliminary review of your response and has determined it needs additional information requested in the enclosure to complete our review.

This RAI requests additional information about your overall plans and schedules and not any information on detailed plans or extensive analyses. In light of this, please provide the additional information requested in the enclosure within 30 days of receipt of this letter.

If you have any questions, please call me at (301) 415-1439.

Sincerely,  
**/RA/**

David H. Jaffe, Acting Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-255

Enclosure: Request for Additional Information

cc w/encl: See next page

June 2, 2005

Mr. Daniel J. Malone  
Site Vice President  
Palisades Nuclear Plant  
Nuclear Management Company, LLC  
27780 Blue Star Memorial Highway  
Covert, MI 49043-9530

SUBJECT: PALISADES PLANT - REQUEST FOR ADDITIONAL INFORMATION (RAI)  
RELATED TO GENERIC LETTER 2004-02, "POTENTIAL IMPACT OF DEBRIS  
BLOCKAGE ON EMERGENCY SUMP RECIRCULATION AT  
PRESSURIZED-WATER REACTORS" (TAC NO. MC4701)

Dear Mr. Malone:

By letter dated March 7, 2005, Nuclear Management Company, LLC, (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Palisades Plant. The GL requested the licensee perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL.

The NRC staff has completed its preliminary review of your response and has determined it needs additional information requested in the enclosure to complete our review.

This RAI requests additional information about your overall plans and schedules and not any information on detailed plans or extensive analyses. In light of this, please provide the additional information requested in the enclosure within 30 days of receipt of this letter.

If you have any questions, please call me at (301) 415-1439.

Sincerely,

**/RAI**

David H. Jaffe, Acting Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-255

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION

PUBLIC

RidsAcrcsAcnwMailCenter  
RidsNrrLADBaxley  
RidsNrrDlpmDpr  
RidsNrrLATHarris

PDIII-1 r/f

RidsNrrDlpmLpdiii2 (LRaghavan)  
RidsRgnIIIMailCenter  
RidsNrrDssaDpr

RidsOgcRp

RidsNrrPMDJaffe  
DCullison/DSolorio  
MWebb

**Accession No.: ML051520321**

\* RAI input from the staff without any major change

OFFICE	PDIV-1/PM PDIII-2/PM	PDIV-1/LA	DSSA/SPLB/SP*	PDIII-1/PM	PDIV-1/SC PDIII-2/SC
NAME	GSuh for MWebb/JHopkins	DBaxley	DCullison/DSolorio	DJaffe	DTerao/GSuh
DATE	6-2-05	6/2/05	5-23-05	6/2/05	6-2-05

**OFFICIAL RECORD COPY**

REQUEST FOR ADDITIONAL INFORMATION  
REGARDING GENERIC LETTER 2004-02,  
“POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON  
EMERGENCY SUMP RECIRCULATION AT PRESSURIZED-WATER REACTORS”  
NUCLEAR MANAGEMENT COMPANY, LLC  
PALISADES PLANT  
DOCKET NO. 50-255

By letter dated March 7, 2005, Nuclear Management Company, LLC, (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Palisades Plant. The GL requested that addressees perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL. The staff has completed its preliminary review of your response and has determined it needs the following additional information to complete our review:

In your 90-day response to GL 2004-02, you indicated that you intend to use future test results, industry guidance, and NRC guidance to account for chemical precipitants in your evaluation and their availability will impact the schedule for performing an evaluation. The cooperative NRC-Electric Power Research Institute tests in progress at the University of New Mexico are designed to determine if chemical effects occur, but are not designed to measure head loss associated with any chemical effects. The staff notes that some chemical effects have been observed in the initial three tests.

In your 90-day response to GL 2004-02, you also indicated that you intend to use industry owners' group guidance and component manufacturer data to evaluate long-term performance degradation of downstream susceptible components caused by debris-laden fluid and their availability will impact the schedule for performing an evaluation.

For both of these issues, you stated the evaluation may occur after the September 1, 2005, response due date, depending on the schedule for testing and the availability of industry guidance. This is contrary to the information request in GL 2004-02, which requests that chemical and downstream effects be addressed in the September 1, 2005, response. This delay is also contrary to the staff's position that there are sufficient bases to address sump vulnerability to chemical effects and that the September response will be incomplete if the evaluation is incomplete, the design is not complete, or there is no schedule for upgrades. In this light, please discuss your plans and schedule for evaluating chemical effects and the long-term downstream effects. In addition, please discuss any plans for performing testing to support your evaluation of these effects.

ENCLOSURE

Palisades Plant

cc:

Robert A. Fenech, Senior Vice President  
Nuclear, Fossil, and Hydro Operations  
Consumers Energy Company  
1945 Parnall Rd.  
Jackson, MI 49201

Arunas T. Udryns, Esquire  
Consumers Energy Company  
1 Energy Plaza  
Jackson, MI 49201

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532-4351

Supervisor  
Covert Township  
P. O. Box 35  
Covert, MI 49043

Office of the Governor  
P. O. Box 30013  
Lansing, MI 48909

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
Palisades Plant  
27782 Blue Star Memorial Highway  
Covert, MI 49043

Michigan Department of Environmental Quality  
Waste and Hazardous Materials Division  
Hazardous Waste and Radiological  
Protection Section  
Nuclear Facilities Unit  
Constitution Hall, Lower-Level North  
525 West Allegan Street  
P.O. Box 30241  
Lansing, MI 48909-7741

Michigan Department of Attorney General  
Special Litigation Division  
525 West Ottawa St.  
Sixth Floor, G. Mennen Williams Building  
Lansing, MI 48913

Manager, Regulatory Affairs  
Nuclear Management Company, LLC  
27780 Blue Star Memorial Highway  
Covert, MI 49043

Director of Nuclear Assets  
Consumers Energy Company  
Palisades Nuclear Plant  
27780 Blue Star Memorial Highway  
Covert, MI 49043

John Paul Cowan  
Executive Vice President & Chief Nuclear  
Officer  
Nuclear Management Company, LLC  
700 First Street  
Hudson, WI 54016

Jonathan Rogoff, Esquire  
Vice President, Counsel & Secretary  
Nuclear Management Company, LLC  
700 First Street  
Hudson, WI 54016

Douglas E. Cooper  
Senior Vice President - Group Operations  
Palisades Nuclear Plant  
Nuclear Management Company, LLC  
27780 Blue Star Memorial Highway  
Covert, MI 49043