



Constellation Energy

Nine Mile Point Nuclear Station

P.O. Box 63
Lycoming, NY 13093

May 24, 2005
NMP1L 1953

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

SUBJECT: Nine Mile Point Unit 1
 Docket No. 50-220
 License No. DPR-63

Special Report, Channel #11 of the Containment Hydrogen Monitoring
System Inoperable for Scheduled Preventive Maintenance

Gentlemen:

In accordance with Action 4.a of Nine Mile Point Unit 1 Technical Specification Table 3.6.11-2, "Accident Monitoring Instrumentation Action Statements," Nine Mile Point Nuclear Station, LLC, is submitting the following Special Report concerning inoperability of Channel #11 of the Containment Hydrogen Monitoring (CHM) System.

Description of Event

On May 11, 2005, at approximately 12:57 hours, operators declared Channel #11 of the CHM System inoperable to perform scheduled preventive maintenance.

The redundant Channel #12 was verified to be operable prior to removal of Channel #11 from service.

Cause of Inoperability

Channel #11 of the CHM System was removed from service to support scheduled preventive maintenance on the circuit breaker that supplies power to the sample and bypass pumps and the analysis and bypass cabinet heaters.


JE22

NMP1L 1953
Page 2

Actions Taken

The circuit breaker preventive maintenance was completed and Channel #11 of the CHM System was restored to operable status on May 12, 2005, at approximately 05:07 hours.

Very truly yours,



Robert C. Godley
Manager Operations

RCG/RF/sac

cc: Mr. S. J. Collins, NRC Regional Administrator, Region I
Mr. G. K. Hunegs, NRC Senior Resident Inspector