

**PRIORITY OF NORTH ANNA/SURRY LICENSING TASKS AT THE NRC**  
**2<sup>nd</sup> Quarter-2005**

1. **\*SPS - Relief Requests SR-38** – Requests alternative acceptance criteria for surface examinations on Class 2 austenitic stainless steel pump casing welds.  
Requested Approval Date: 04/26/05                      NRC Target Date: 05/15/05
  
  2. **\*NAPS Alternate Source Term** - Change licensing basis and TS to take advantage of 10 CFR 50.67, Alternate Source Term.  
Requested Approval Date: N/A                      NRC Target Date: 05/15/05
  
  3. **\*NAPS T- SCR N-029 - Revised PT limits for Units 1 and 2** - These limits will be applicable until renewed license expiration.  
Requested Approval Date:                      NRC Target Date: 07/01/05
  
  4. **SPS - TSCR 379 – Increased Lead Rod Average Burnup Limit** – Proposed License Condition would permit irradiation of Surry fuel assemblies to a lead rod average burnup of 62,000 MWD/MTU.  
Requested Approval Date:                      NRC Target Date: 09/05
  
  5. **\*NAPS - TSCR N-030 - Revise P-4 Surveillance Requirements** - Revise the P-4 interlock surveillance requirements from “once per reactor trip breaker cycle” to “18 months”  
Requested Approval Date: 10/1/05                      NRC Target Date: 10/01/05
  
  6. **NAPS/SPS - Topical Report DOM-NAF-2** - VIPRE reactor core thermal-hydraulics code and qualification of the F-ANP BWU CHF correlations.  
Requested Approval Date:                      NRC Target Date: 09/15/05
  
  7. **\*NAPS - Relief Requests** - ASME Section XI ISI Program, Revision to Snubber Testing Alternatives (CS-3 and CS-1)  
Requested Approval Date:                      NRC Target Date: 12/31/05
  
  8. **\*SPS - Risk Informed Inservice Inspection Program (SPS 2)** – Fourth interval RI-ISI program update.  
Requested Approval Date: N/A                      NRC Target Approval Date: 05/13/05<sup>30</sup>
  
  9. **SPS TSCR 330B – AFW Requirements and Surveillance Revisions\*** - Clarify AFW pump requirements with regard to the operability requirements of TS 3.6.B.1 and 3.6.C versus the action statement of TS 3.6.F.  
Requested Approval Date:                      NRC Target Date: 11/30
  
  10. **NAPS/SPS/MPS - Combined QA Program Description (QAPD) – Topical Report DOM-QA-1** – A new combined QAPD (Dominion QA Topical Report DOM-QA-1) to replace the existing NAPS, SPS, and MPS Quality Assurance Programs.  
Requested Approval Date: 05/05                      NRC Target Approval Date: 06/06/05
- NAPS/SPS/MPS - TSCR Organizational Changes** - These changes are required to support the QA Topical Program change to NQA-1.  
Requested Approval Date: 05/05                      NRC Target Date: 06/30/05

**PRIORITY OF NORTH ANNA/SURRY LICENSING TASKS AT THE NRC**  
**2<sup>nd</sup> Quarter-2005**

**NAPS - ISFSI TSCR - Organizational changes** - These changes are required to support the QA Topical Program change to NQA-1.

Requested Approval Date: 05/05                      NRC Target Date:

11. **SPS - TSCR - Revised PT limits for Units 1 and 2** - These limits will be applicable until renewed license expiration. (Separate Submittals)

Requested Approval Date: N/A                      NRC Target Date: 12/17/05

12. **SPS - TSCR 376 – Change of ASME Code Reference for Inservice Testing Activities** – TS change request updates the ASME IST Code references in the TS from ASME XI to ASME OM Code.

Requested Approval Date: 05/05                      NRC Target Date: 04/05

13. **NAPS - SCR N 025 Fluid System Completion Times** – Plant specific risk informed TS change after NRC rejected the WOG WCAP on fluid systems.

Requested Approval Date: N/A                      NRC Target Date: 12/01/05

14. **NAPS/SPS - TSCR – RCP Flywheel Inspection Frequency** – NRC CLIP reduces the RCP flywheel inspection frequency from once every 10 years to once every 20 years.

Requested Approval Date: 08/05                      NRC Target Date: 08/01/05

15. **SPS - TSCR Change of ASME Code Reference for Inservice Testing Activities** – TS change request updates the ASME IST Code references in the TS from ASME XI to ASME OM Code.

Requested Approval Date: 05/05                      NRC Target Date: 05/01/05

16. **NAPS/SPS - Relief Requests** – Extended Class1 boundary – pressure test at or near the end of the ISI interval for numerous systems

Requested Approval Date: 1/06                      NRC Target Date: 01/01/06

17. **NAPS - ISI Relief Request** - ORS and SI pump casing weld examinations in accordance with 95/95 ASME Code.

Requested Approval Date: N/A                      NRC Target Date:

\*Requested to use during next refueling outage for that Unit.