

Palo Verde



Station Black Out

Presentation

To The

Nuclear Regulatory Commission

May 24, 2005

Palo Verde



Agenda

- Introductions Carl Churchman/
Mel Fields
- Description of Proposed Changes to Station M. Karbassian
Blackout Coping Strategy
- Closing Remarks C. Churchman/
M. Fields

Palo Verde



Background

- APS Power Uprate License Amendment Request
 - Increase Power by 2.94% for U1 & U3
 - 3876 MWt to 3990 MWt
 - Currently being reviewed by NRC Staff
- June 14, 2004 Loss of Off-site Power
 - Unit 1,2 & 3
- NRC RAI to APS
 - SBO Category P3 Plant with 16 hour Coping Strategy

Palo Verde



Purpose

- Identify Actions Necessary to Comply With 16 Hour Coping Strategy

Palo Verde



What is PV's SBO Design Basis

- Alternate AC (AAC) Plant Per Reg Guide 1.155 & NUMARC 87-00
 - Ltr 161-04146-WFC/MEP, dated August 31, 1991
 - SE Dated February 11, 1992 (section 2.2.2)

- Requirement for an AAC Plant
 - Demonstrate Coping W/O Power for 1 Hour
 - 4.2 MW GTG On Line within 1 hour
 - Demonstrate Coping With GTG available for an additional 3 Hours (**Now 16 hours**)

Palo Verde



Existing Strategy (4 hr Coping)

- **Existing Analysis**
 - Assumes 120 GPM RCS Leak Rate
 - Uses ADVs for Heat Removal
 - Start GTG Within 1 hr
 - Load EW/SP/EC/HVAC/Battery Chargers
 - Establish Charging for Inventory Control
 - Maintain Hot Standby Using ADVs
 - Remain @ Hot Standby for the Following 3 Hours

Palo Verde



Credited Future Strategy (16 hr Coping)

- **Revised Analysis**

- Assume 83 GPM RCS Leak Rate
- Minimize Operator Action During 1st hr
- Start GTG, Within 1 hr
- Load EW/SP/EC/HVAC/Battery Chargers
- Use ADV for Heat Removal
- Use HPSI for RCS Inventory Control
- Uses Pressurizer Vent for Pressure Control
- Cool Down to SDC Condition in 16 hrs

Palo Verde




Evaluation of Design Basis RCS Inventory

- 4 hr Coping
 - Core Remains Covered
 - Credits Reflux Boiling
- 16 hr Coping
 - Core Remains Covered
 - Natural Circulation
- Reviewed by NRC
 - February 11, 1992


Palo Verde

Hot Leg Temperatures
(°F)




Palo Verde

Cold Leg Temperatures
(°F)




Palo Verde

Pressurizer Pressure
(PSIA)



Palo Verde


Pressurizer Level
(ft)



Palo Verde



Leak Flow (per RCP)
(lbm/sec)



Palo Verde




Evaluation of Condensate Inventory

- 4 hr Coping
- Required Condensate
 - 156000 gallons
 - Decay Heat
 - Sensible Heat
 - SG Inventory Recovery
- Per NUMARC Guidelines
- Reviewed By NRC
 - February 11, 1992
- 16 hr Coping
- Required Condensate
 - 266000 gallons
 - Decay Heat (ANSI + 2σ)
 - Sensible Heat
 - RSG Inventory Recovery
- Analyzed Using CENTS Code
- Methodology Change

Palo Verde



Integrated AFWS Flow
(lbm)



Palo Verde



Evaluation of Condensate Inventory

- Available Condensate Inventory
 - CST 300,000 gallons (Minimum Tech Spec)
 - RMWT 300,000 gallons Available (Not Tech Spec)

Palo Verde



Evaluation of Class 1E Battery Capacity

- No Effect on Class 1E Battery Capacity From 16 hr Coping
 - Battery Chargers are Loaded on to GTG Within 1 hr
 - Original Analysis Sized the Batteries to Support SBO for 2 Hours
 - Equipment Credited in the First Hour Remains Bounding

Palo Verde



Evaluation of Compressed Air Capacity

- 4 hr Coping
 - ADVs
 - Nitrogen Accumulator
 - RCP Seal Bleedoff
 - Nitrogen Backup
 - 3082 gallon Tank
 - 65000 ft³ HP Cylinder to Support 1 hr Duration
- Reviewed By NRC
 - July 28, 1992
 - April 13, 1994
- 16 hr Coping
 - ADVs
 - Insufficient Margin with Nitrogen Accumulator.
 - Portable Diesel Driven Air Compressor Will be Available for Connection to Instrument Air Header
 - RCP Seal Bleedoff
 - No Change to IA Backup

Palo Verde



Evaluation of Loss of Ventilation Control, AFWP, DC Equip and Battery Rooms

- 4 hr Coping
 - Cooling is Loaded on to GTG for the Following Rooms Within 1 hr.
 - Control Room
 - AFWP Room
 - DC Equipment Room
 - Switchgear Room
 - Battery Room
- 16 hr Coping
 - No Effect on the Heat loads Due to 16 hr Coping or Power Uprate
 - Cooling will Be Loaded on to the GTG within 1 hr.
- Reviewed by the NRC
 - Feb 11, 1992
 - July 28, 1992
- No Effect Due to 16 hr Coping Strategy Change

Palo Verde



Evaluation of Loss of Ventilation Charging Pump Room and MSSS Bldg Upper Elev.

- 4 hr Coping
- No Credit was Given for Room Cooling for the Following:
 - Charging Pump Room
 - MSSS Upper Elevation
- Review by the NRC
 - Feb 11, 1992
 - July 28, 1992
- 16 hr Coping
 - No Credit is Given for Room Cooling for the Identified Rooms,
 - Steady State Temperature in Chg Pump Room & MSSS Building Remains Below Equipment Qualification Temperature Criteria

Palo Verde




Evaluation of Loss of Ventilation Containment

- 4 hr Coping
- Containment
 - In house Code
 - Utilizes NUMARC Criteria
 - Heat Sinks Per NUMARC
 - Perform Temperature Transient Analysis Vs Steady State Solution
 - Results Demonstrate Containment P/T remains bounded by the LOCA P/T
- 16 hr Coping
- Containment
 - COPPATA Code
 - NRC Approved
 - Used for Containment P/T analysis for LOCA
 - Heat Sinks Per UFSAR 6.2
 - Results Demonstrate containment P/T remains bounded by the LOCA
 - Methodology Change

Palo Verde




Comparison of Containment Vapor temperature
SBO and limiting LOCA



Palo Verde



Comparison of Containment pressure
SBO and limiting LOCA



Palo Verde



Evaluation of Containment Isolation

- 4 hr Coping
- Containment Isolation Valves
Were reviewed for the applicability or exclusion to NUMARC 87-00 Criteria and found acceptable
- Located in UFSAR Tables 6.2.4-1 & 6.2.4-2
- Reviewed by the NRC
 - April 13, 1994
- 16 hr Coping
- Will Not Reach RAS at 16 hrs
- No Impact to the Containment Isolation capability due to PUR Or 16 hr Coping

Palo Verde



Evaluation of Communication

- EPABX (Telephone) 8 hr battery
- Plant 2 Way Radio 4 hr battery, Transfer Switch
- Sound Power Phones

Palo Verde



Evaluation of Communication

- 4 hr Coping
- Primary Modes of Communication
 - EPABX Telephone
 - Sound Power Phone
 - Radios
- Reviewed by the NRC
 - April 13, 1994
- 16 hr Coping
- Primary Mode of Communication
 - EPABX Telephone
 - (8 hr Battery back-up)
 - Radios
 - (4 hr Battery back-up)
 - (Transfer Switch)
 - Sound Power Phone
- Sufficient Battery Back-up to Cope for 1 Hour Until GTG Loads the Radio System

Palo Verde



Summary

- Regulatory Guide 1.155 Acceptance Criteria for 16 hr Coping Can Be Successfully Demonstrated
- Methodology Changes Will Be Introduced for Consistency With the Current Safety Analysis Methods
- New Equipment and Procedure Changes Are Necessary for Implementation of the 16 hr Coping Strategy