

June 2, 2005

Mr. Jerald S. Holm
Director, Regulatory Affairs
Attn: Ronnie L. Gardner
3815 Old Forest Rd.
Lynchburg, VA 24501

SUBJECT: DRAFT SAFETY EVALUATION FOR TOPICAL REPORT (TR) BAW-2308,
REVISION 1, "INITIAL RT_{NDT} OF LINDE 80 WELD MATERIALS"
(TAC NO. MB6336)

Dear Mr. Holm:

On July, 26, 2002, Babcock and Wilcox Owners Group (B&WOG) submitted TR BAW-2308, Revision 1, "Intial RT_{NDT} Linde 80 Weld Materials," to the Nuclear Regulatory Commission (NRC) staff for review. Enclosed for the B&WOG review and comment is a copy of the NRC staff's draft safety evaluation (SE) for the TR.

Twenty working days are provided to you to comment on any factual errors or clarity concerns contained in the SE. The final SE will be issued after making any necessary changes and will be made publicly available. The NRC staff's disposition of your comments on the draft SE will be discussed in the final SE.

To facilitate the NRC staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes.

If you have any questions, please contact Mr. Drew G. Holland at 301-415-1436.

Sincerely,

/RA/
Robert A. Gramm, Chief, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Project No. 693

Enclosure: Draft SE

cc w/encl: See next page

June 2, 2005

Mr. Jerald S. Holm
Director, Regulatory Affairs
Attn: Ronnie L. Gardner
3815 Old Forest Rd.
Lynchburg, VA 24501

SUBJECT: DRAFT SAFETY EVALUATION FOR TOPICAL REPORT (TR) BAW-2308,
REVISION 1, "INITIAL RT_{NDT} OF LINDE 80 WELD MATERIALS"
(TAC NO. MB6336)

Dear Mr. Holm:

On July, 26, 2002, Babcock and Wilcox Owners Group (B&WOG) submitted TR BAW-2308, Revision 1, "Intial RT_{NDT} Linde 80 Weld Materials," to the Nuclear Regulatory Commission (NRC) staff for review. Enclosed for the B&WOG review and comment is a copy of the NRC staff's draft safety evaluation (SE) for the TR.

Twenty working days are provided to you to comment on any factual errors or clarity concerns contained in the SE. The final SE will be issued after making any necessary changes and will be made publicly available. The NRC staff's disposition of your comments on the draft SE will be discussed in the final SE.

To facilitate the NRC staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes.

If you have any questions, please contact Mr. Drew G. Holland at 301-415-1436.

Sincerely,

/RA/
Robert A. Gramm, Chief, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Project No. 693
Enclosure: Draft SE
cc w/encl: See next page

DISTRIBUTION:
PUBLIC
PDIV-2 Reading
RidsNrrDlpmLpdiv (HBerkow)
RidsNrrDlpmLpdiv2 (RGramm)
RidsNrrPMDHolland
RidsNrrLADBaxley
RidsOgcRp
RidsAcrsAcnwMailCenter
MMitchell

ADAMS Accession No.: ML051570341

NRR-043

OFFICE	PDIV-1/PM	PDIV-1/LA	EMCB*	PDIV-2/SC	PDIV/D
NAME	DHolland	DBaxley	MMitchell	RGramm	HBerkow
DATE	6/1/05	6/1/05	4-18-05	6/2/05	6/2/05

DOCUMENT NAME: E:\Filenet\ML051570341.wpd

OFFICIAL RECORD

B&W Owners Group

Project No. 693

cc:

Mr. Howard C. Crawford
AmerGen Energy Company
Route 441 South
P.O. Box 480
Middletown, PA 17057-0480

Mr. David J. Firth
Manager, B&W Owners Group Services
Framatome ANP
3315 Old Forest Road
Lynchburg, VA 24501

Mr. W. R. McCollum, Chairman
B&WOG Executive Committee
Duke Energy Corporation
Oconee Nuclear Station
MC ONO 1VP
7800 Rochester Highway
Seneca, SC 29672

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

FOR TOPICAL REPORT (TR) BAW-2308, REVISION 1,

"INITIAL RT_{NDT} OF LINDE 80 WELD MATERIALS"

BABCOCK AND WILCOX OWNERS GROUP

PROJECT NO. 693

1.0 INTRODUCTION

1 By letter dated July 26, 2002 (Agencywide Documents Access and Management System
2 (ADAMS) Accession No. ML022200546), Babcock and Wilcox Owners Group (B&WOG)
3 submitted TR BAW-2308, Revision 0, "Initial RT_{NDT} of Linde 80 Weld Materials," for Nuclear
4 Regulatory Commission (NRC) staff review. The intent of the TR is to establish an alternative
5 method for determining initial, unirradiated material reference temperatures for reactor pressure
6 vessel (RPV) welds manufactured using Linde 80 weld flux (i.e., "Linde 80 welds") and to
7 establish weld wire heat-specific and Linde 80 weld generic values of this reference
8 temperature. These weld wire heat-specific and Linde 80 weld generic values would be used in
9 lieu of the nil-ductility reference temperature (RT_{NDT}) parameter, the determination of which is
10 specified by Paragraph NB-2331 of Section III of the American Society for Mechanical
11 Engineers (ASME) Boiler and Pressure Vessel Code (Code).

12 By facsimile dated April 11, 2003, the NRC staff issued a request for additional information
13 (RAI) regarding BAW-2308. The B&WOG responded to the staff's RAI by letter dated
14 August 19, 2003 (ADAMS Accession No. ML032380449). In the response, the B&WOG
15 withdrew TR BAW-2308, Revision 0, provided answers to the staff's RAI questions, and
16 submitted for review TR BAW-2308, Revision 1, which incorporated the substantive changes
17 resulting from the staff's RAI. In addition, by letters dated June 30, 2004 (ADAMS Accession
18 No. ML041880201) and March 25, 2005 (ADAMS Accession No. ML051320232), B&WOG
19 provided information modifying the proposal outlined in TR BAW-2308, Revision 1.

20 2.0 REGULATORY EVALUATION

21 The determination of RPV material properties impacts regulations associated with the protection
22 of the RPV from brittle failure or ductile rupture. These regulations include Appendix G to Part
23 50 of Title 10 of the *Code of Federal Regulations* (10 CFR) and 10 CFR 50.61, the pressurized
24 thermal shock (PTS) rule. Appendix G to 10 CFR Part 50 and 10 CFR 50.61 require that the
25 initial, unirradiated material reference temperature, RT_{NDT}, be determined in accordance with the
26 provisions of ASME Code, Section III, Paragraph NB-2331. The determination of RT_{NDT} per
27 ASME Code, Section III, Paragraph NB-2331 requires the performance of drop weight testing in
28 accordance with American Society for Testing and Materials (ASTM) Standard Test Method
29 E 208, "Standard Test Method for Conducting Drop-Weight Test to Determine Nil-Ductility
30 Transition Temperature of Ferritic Steels", and Charpy V-notch impact testing in accordance
31 with ASTM Standard Test Method E 23, "Standard Test Methods for Notched Bar Impact
32 Testing of Metallic Materials." Guidance provided in NRC Standard Review Plan Section 5.3.1,

1 “Reactor Vessel Material,” and Branch Technical Position MTEB 5-2, “Fracture Toughness
2 Requirements,” also reflect this dependence on drop weight and Charpy V-notch impact testing.
3 In addition, regarding the implementation of alternatives to the requirements of Appendix G to
4 10 CFR Part 50, 10 CFR 50.60 states, “Proposed alternatives to the described requirements in
5 Appendices G and H of this part or portions thereof may be used when an exemption is granted
6 by the Commission....”

7 3.0 TECHNICAL EVALUATION

8 3.1 B&WOG Evaluation - General Description

9 In TR BAW-2308, Revision 1, the B&WOG proposed to perform fracture toughness testing
10 based on the application of the “Master Curve” evaluation procedure, which permits data
11 obtained from sample sets tested at different temperatures to be combined, as the basis for
12 redefining the initial, unirradiated material properties of Linde 80 welds. Guidelines for the
13 application of the Master Curve evaluation methodology used in TR BAW-2308, Revision 1 were
14 given in the 1997 and 2002 Editions of ASTM Standard Test Method E 1921 (ASTM E 1921)
15 “Standard Test Method for Determination of Reference Temperature, T_0 , for Ferritic Steels in
16 the Transition Range.” Additional guidance on the application of reference temperature values
17 based on Master Curve evaluation to the establishment of RPV material properties for
18 regulatory applications was provided by ASME Code Case N-629, “Use of Fracture Toughness
19 Test Data to Establish Reference Temperature for Pressure Retaining Materials of Section III,
20 Division 1, Class 1.” The B&WOG's motivation for pursuing this option of using a Master
21 Curve-based approach to evaluate Linde 80 welds is related to the fact that, due to their
22 generally low Charpy V-notch upper shelf energy behavior, the testing specified in ASME Code,
23 Section III, Paragraph NB-2331 has been shown to be overly conservative when used to predict
24 the transition from ductile to brittle failure in Linde 80 welds.

25 Fundamentally, the proposal by the B&WOG was that the testing of fracture toughness
26 specimens, including compact tension (CT) specimens ranging in size from 0.5 inch thickness
27 CTs (0.5T-CTs) to 2T-CTs and precracked Charpy-sized bend specimens (PCCS), could be
28 used in lieu of “indirect” tests of fracture toughness (drop weight and Charpy V-notch tests) to
29 establish acceptable initial, unirradiated material properties of Linde 80 welds. A reference
30 temperature, T_0 , would be derived from the testing of sets of 6 or more fracture toughness
31 specimens for a given material, in this case, a Linde 80 weld made from a specific weld wire
32 heat. The value of T_0 would be determined based on the application of ASTM Standard Test
33 Method E 1921, and T_0 would be statistically related to the temperature at which fracture
34 toughness specimens from a given weld wire heat exhibited a median fracture toughness of
35 100 Mega Pascals-square-root-meter (MPa/ m) which is equivalent to 90 thousand pounds per
36 square inch-square-root-inch (ksi/ in). Proposed adjustments to the determined values of T_0 for
37 each weld wire heat were then made to account for loading rate effects and PCCS bend
38 specimen bias, when appropriate. An initial, unirradiated material reference temperature, IRT_{T_0}
39 (initial reference temperature based on T_0), would then be calculated per ASME Code Case
40 N-629 using the adjusted values of T_0 as:

41 [Eqn. 1]
$$IRT_{T_0} = T_0 + 35 EF$$

1 Statistical uncertainty in the values of T_0 (denoted as σ) due to the number of specimens tested
2 was also determined as:

3 [Eqn. 2]
$$\sigma = \beta / N$$

4 where β is implicitly related to the difference between the specimen test temperature and the
5 value of T_0 and N is the number of specimens tested. In addition, contributions to material
6 property uncertainty due to material variation and testing laboratory were evaluated by Monte
7 Carlo simulation. All of the data for a Linde 80 weld wire heat was pooled and sample data sets
8 selected to generate a distribution of T_0 values from which a standard deviation could be
9 defined. The uncertainty contributions based on the sample size calculation and Monte Carlo
10 results were then combined via a square-root-sum-of-squares method to determine a final value
11 (σ_1) for the uncertainty associated with the heat-specific value of IRT_{T_0} .

12 Tests from all available Linde 80 weld wire heats would then be combined to define “generic”
13 values of IRT_{T_0} and σ_1 in a process equivalent to that which was used for each individual
14 Linde 80 weld wire heat. These generic values would be assumed to be applicable for weld wire
15 heats for which no weld wire specific values were generated.

16 A more detailed account of the Master Curve methodology is also given in Appendices A and B
17 of TR BAW-2308, Revision 1.

18 3.2 Framatome ANP Evaluation - Data Analysis

19 Fracture toughness specimen test data from a variety of sources were available for seven
20 Linde 80 weld wire heats: 406L44, 71249, 72105, 821T44, 299L44, 72442, and 72445. The
21 material samples from weld wire heat 406L44 were acquired via the Oconee Nuclear Station
22 (Oconee) Unit 1 and Rancho Seco Nuclear Generating Station reactor vessel surveillance
23 programs. The material samples from weld wire heat 71249 were acquired via the Turkey Point
24 Plant (Turkey Point) Unit 4 reactor vessel surveillance program. The material samples from
25 weld wire heat 72105 were acquired from the beltline and nozzle dropouts from the canceled
26 Midland (Midland) Unit 1. The material samples from weld wire heat 821T44 were acquired via
27 the Davis-Besse Nuclear Power Station reactor vessel surveillance program. The material
28 samples from weld wire heat 299L44 were acquired from Crystal River Nuclear Generating Plant
29 (Crystal River) Unit 3 and Oconee Unit 3 nozzle dropouts as well as the 63W weld fabricated
30 for Oak Ridge National Laboratory. The material samples from weld wire heat 72442 were
31 acquired from Crystal River Unit 3 Nuclear Generating Plant and Midland Unit 1 nozzle
32 dropouts. The material samples from weld wire heat 72445 were acquired from Arkansas
33 Nuclear One Unit 1 nozzle dropouts. An accounting of the number of specimens of varying
34 sizes and types is given in Table 1 below for each weld wire heat. A more detailed list of the
35 available fracture toughness data sets, on a data point-by-data point basis, from the testing of
36 unirradiated samples of Linde 80 welds is given in Appendix C to TR BAW-2308, Revision 1.
37 Generally, the test data for each weld wire heat had been generated at more than one test
38 temperature. Therefore, to make the use of the largest volume of data possible, the B&WOG
39 made use of the “multi-temperature” Master Curve methodology documented in the 2002 Edition
40 of ASTM E 1921, with one exception. The multi-temperature Master Curve methodology
41 permits data from more than one test temperature to be combined in order to determine T_0 for a
42 material. The exception that the B&WOG took to the multi-temperature Master Curve
43 methodology in the 2002 Edition of ASTM E 1921 was with regard to the formula for converting
44 between the fracture toughness parameters J (the J-integral of elastic-plastic fracture

1 mechanics) and K_{Jc} (linear elastic fracture mechanics fracture toughness). The 2002 Edition of
2 ASTM E 1921 permits the use of a plane strain-based formulation for effecting this conversion
3 while the 1997 Edition specifies the use of a slightly more conservative plane stress-based
4 formulation. For TR BAW-2308, Revision 1 analysis, the B&WOG elected to use the plane
5 stress-based conversion from the 1997 Edition of ASTM E 1921.

6 **Table 1 - Distribution of Specimens for Each Linde 80 Weld Wire Heat-**
7 **Table Developed by NRC Staff**

8 Weld Wire Heat	Specimen Type	Number of Specimens	Total Number of Specimens for Weld Wire Heat
9 299L44	0.5T-CT	12	42
	PCCS	30	
10 406L44	0.5T-CT	25	43
	PCCS	18	
11 71249	PCCS	11	11
12 72105	4T-CT	2	148
	2T-CT	14	
	1T-CT	78	
	0.5T-CT	21	
	PCCS	33	
13 72442	PCCS	17	24
	"Various" CTs	7	
14 72445	PCCS	22	22
15 821T44	0.5T-CT	18	24
	PCCS	6	

16 In addition to being generated at different temperatures, the data used in TR BAW-2308,
17 Revision 1 were also generated at various loading rates within the regime classified as
18 "quasi-static testing." The range of loading rates associated with the Linde 80 weld tests was
19 from about 0.21 MPa/ m/s to 2.55 MPa/ m/s. Based upon Master Curve results for a variety of
20 ferritic RPV materials, a linear relationship between T_0 values and the natural logarithm of the
21 loading rate was established to normalize the data to a loading rate of 1 MPa/ m/sec:

22 [Eqn. 3] $T_0 (@ 1 \text{ MPa/ m/s}) = T_0 (@ X \text{ MPa/ m/s}) + 5.33 \ln(1 \text{ MPa/ m/s} \div X \text{ MPa/ m/s})$

23 The B&WOG demonstrated that this relationship could be used to adjust test temperature
24 associated with each data point (test temperature and T_0 are related in such a way as to make
25 this a reasonable method of adjusting for loading rate and other effects) prior to applying the

1 multi-temperature Master Curve to determine final T_0 values for each heat of material. It should
2 be noted, however, that the final RT_{T_0} values recommended by Framatome ANP in BAW-2308,
3 Revision 1 did not include this loading rate correction.

4 A specimen geometry correction was also applied to the fracture toughness data generated
5 from PCCS specimens. A substantial amount of work has been completed recently to compare
6 the Master Curve methodology results obtained from similar sized CT and bend specimens. As
7 noted in a paper presented at the 2000 ASME Pressure Vessel and Piping Conference entitled,
8 “ T_0 Evaluation in Common Specimen Geometries,” by Tregoning and Joyce, there may be a
9 systematic, non-conservative bias in the T_0 values generated by the use of PCCS specimens
10 when compared to those generated by CT specimens. The numerical value of this systematic
11 bias may be about 18 EF. The B&WOG elected to address this bias by again adjusting the test
12 temperature associated with each data point. This adjustment to correct for the use of PCCS
13 specimen data was applied to each data set in a pointwise fashion prior to applying the
14 multi-temperature Master Curve to determine final T_0 values for each heat of material.

15 In addition, by letter dated March 25, 2005, the B&WOG elected to conservatively include an
16 additional 20 EF in the calculation of the Linde 80 weld generic value of IRT_{T_0} to resolve potential
17 concerns over whether this generic value would be adequately bounding. A detailed discussion
18 of the basis for this modification to TR BAW-2308, Revision 1 is provided in the B&WOG’s
19 March 25, 2005, letter.

20 Based on the data analysis procedure outlined above and Eqn. 1, the B&WOG proposed in
21 TR BAW-2308, Revision 1 that the following values be used to characterize the initial properties
22 and associated uncertainties for Linde 80 welds (as modified by the aforementioned March 25,
23 2005 letter):

24 **Table 2 - Proposed IRT_{T_0} and σ_1 Values for Linde 80 Weld Wire Heats**

Linde 80 Weld Wire Heat	IRT_{T_0} (EF)	Initial Margin, σ_1 (EF)
406L44	-103.6	12.1
71249	-62	13
72105	-29.1	13.3
821T44	-90.8	10
299L44	-78.8	12
72442	-37.8	11.9
72445	-73.2	11.9
All Heats (Generic Value)	-47.9 ¹	20.1

33 ¹ Includes additional 20 EF correction proposed in March 25, 2005 letter.
34

35 3.3 Other Elements of the Framatome ANP Methodology

36 Given the method proposed by the B&WOG for determining Linde 80 weld unirradiated, initial
37 material property values, the B&WOG also addressed other issues regarding how these values
38 could be used by licensees. In particular, the B&WOG provided a basis for determining whether
39 it would be appropriate to use material property changes based on the shift in Charpy V-notch
40 30 foot-pound (ft-lb) energy (ΔT_{30}) models with IRT_{T_0} values based on fracture toughness data.
41 This concern arises because, as opposed to the Master Curve-based approach used by

1 Kewaunee Nuclear Power Plant which was approved by the NRC staff in 2001, the B&WOG
2 methodology does not rely on obtaining fracture toughness measurements in the irradiated
3 condition for the purpose of monitoring changes due to irradiation.

4 To begin, the B&WOG cited work performed by the NRC's Office of Nuclear Regulatory
5 Research (RES) which examined a large database of materials for which ΔT_{30} and the shift in
6 Master Curve reference temperature (ΔT_0) existed (data to establish T_0 values based on
7 irradiated Linde 80 weld specimen testing was included in Appendix D of TR BAW-2308,
8 Revision 1). The RES work showed that for welds, including Linde 80 weld data, a linear
9 relationship could be drawn between these two values:

10 [Eqn. 4]
$$\Delta T_0 = 0.99 * \Delta T_{30}$$

11 and the standard deviation of the residuals between the ΔT_0 data and the ΔT_0 vs. ΔT_{30}
12 regression line was 25.6 EF (see Figure 1).

13 The B&WOG performed a similar analysis for 12 Linde 80 weld data pairs. The correlation for
14 the Linde 80 welds (see Figure 2) was:

15 [Eqn. 5]
$$\Delta T_0 = 0.92 * \Delta T_{30}$$


16
17 Therefore in either case, on average, ΔT_{30} test data overpredicted ΔT_0 test data. Based on this
18 information, the B&WOG concluded that the shift models in Regulatory Guide (RG) 1.99,
19 Revision 2, "Radiation Embrittlement of Reactor Vessel Materials," which were developed
20 based on ΔT_{30} , would continue to be adequate when combined with initial properties indexed to
21 Master Curve T_0 values.

22 Finally, the B&WOG examined whether the shift model uncertainty ($\sigma_{\Delta} = 28$ EF) from RG 1.99,
23 Revision 2 was adequate when combined with initial properties based on T_0 values and material
24 property shifts based on the RG 1.99, Revision 2, models. To do this, the B&WOG plotted the
25 ΔT_0 values as a function of fluence for the 13 Linde 80 weld samples which had been tested in
26 the irradiated condition. A RG 1.99, Revision 2 shift trend curve based on a chemistry factor of
27 167 EF (related to the average copper and nickel contents of Linde 80 welds) was plotted, along
28 with curves representing the $+2\sigma_{\Delta}$ and $-2\sigma_{\Delta}$ bounds on the model (see Figure 3). This plot
29 demonstrated that all of the Linde 80 weld ΔT_0 data points were bounded by the $+2\sigma_{\Delta}$ curve.
30 Since the use of the RG 1.99, Revision 2 model with the $+2\sigma_{\Delta}$ margin bounds the Linde 80 weld
31 ΔT_0 data points, B&WOG concluded that it is acceptable to use IRT_{T_0} values with RG 1.99,
32 Revision 2 embrittlement model predictions and a σ_{Δ} value of 28 EF as the "overall method" for
33 implementing TR BAW-2308, Revision 1.

1

2


3



4

Figure 1 - Correspondence of ΔT_0 to $\Delta T_{30 \text{ ft-lbs}}$ (i.e., ΔT_{41J}) for RPV Welds, Plates, and Forgings

1
2




3 Figure 2 - Correspondence of ΔT_0 to $\Delta T_{30 \text{ ft-lbs}}$ For Linde 80 Welds

4 3.4 NRC Staff Evaluation

5 The NRC staff evaluated the methodology proposed by the B&WOG for determining Linde 80
6 weld initial, unirradiated material properties and the uncertainty in those properties. Further, the
7 NRC staff reviewed the "overall method" proposed by the B&WOG for combining: (1) initial,
8 unirradiated material property measurements based on T_0 values, (2) property shifts from
9 models in RG 1.99, Revision 2 which are based on Charpy V-notch impact testing, and (3) a
10 defined margin term to account for uncertainties.

1



2 Figure 3 - Correlation of ΔT_0 data with Regulatory Guide 1.99, Revision 2 Prediction +
3 Margin

4 3.4.1 Evaluation of BAW-2308, Revision 1 Database

5 The NRC staff reviewed the data base of unirradiated and irradiated fracture toughness test
6 data from Linde 80 weld samples. Using an NRC RES database, the staff confirmed that there
7 were no Linde 80 data known to the NRC staff which were not included in the B&WOG's TR
8 BAW-2308, Revision 1 analysis. The NRC staff also confirmed that all of the available data
9 were used in the TR BAW-2308, Revision 1 analysis, as appropriate, to establish Linde 80 weld
10 wire heat-specific values of IRT_{T_0} as well as the Linde 80 generic values of IRT_{T_0} shown in
11 Tables 2 and 3 of this SE. This was consistent with the NRC staff's expectation that the use of
12 all available data will provide the most accurate characterization of RPV material properties.

13 However, the B&WOG stated in their August 19, 2003, RAI response that fracture toughness
14 data from one more heat of Linde 80 weld material are to be obtained (weld wire heat 61782).
15 The NRC staff expects Framatome ANP to evaluate these data to determine whether or not the
16 conclusions of TR BAW-2308, Revision 1 are non-conservative, and to communicate the
17 B&WOG's conclusion to the NRC staff. Non-conservatism in TR BAW-2308, Revision 1 report
18 would be evident if: (1) the IRT_{T_0} value from the to-be-tested Linde 80 weld wire heat turns out

1 to be higher than the generic IRT_{T_0} value approved in this safety evaluation (SE), or (2) if the
2 data from the to-be-tested Linde 80 weld wire heat results in an increase in the Linde 80 generic
3 σ_I value.

4 3.4.2 Evaluation of BAW-2308, Revision 1 Methodology

5 The NRC staff evaluated the B&WOG's methodology for evaluating the available Linde 80 weld
6 fracture toughness data. The NRC staff concluded that the use of the provisions from the 1997
7 and 2002 Editions of ASTM E 1921 as specified in Section 3.2 of this SE was acceptable. The
8 NRC staff also concluded that the B&WOG's decision to apply a correction factor equivalent to a
9 bias of 18 EF to the data obtained from PCCS specimens was consistent with the best current
10 information on the differences between PCCS specimen and CT specimen test results. This
11 bias factor applied to PCCS specimens was conservative (i.e., greater than) when compared to
12 a similar bias factor that the NRC staff required be applied to support approval of the Kewaunee
13 Master Curve-based approach in May 2001. By including this bias term, the NRC staff has
14 concluded that results of the B&WOG analysis will be accurate or conservative with respect to
15 the characterization of RPV weld material properties as far as specimen geometry effects are
16 concerned.

17 The NRC staff evaluated the loading rate correction proposed by the B&WOG to adjust all of the
18 available Linde 80 weld test data to a common loading rate of 1 MPa / m/sec. Based on known
19 principles of fracture toughness testing, an effect of loading rate would be expected when
20 comparing quasi-static and dynamic test data. The data provided by the B&WOG suggest that
21 some loading rate effect does occur based on tests run at loading rates of 1 MPa / m/sec or
22 less (quasi-static) and 10000 MPa / m/sec or more (dynamic) for a variety of materials, with the
23 apparent effect for each tested material being slightly different. However, over the reduced
24 range of loading rates addressed in TR BAW-2308, Revision 1 (0.21 MPa/ m/s to 2.55
25 MPa/ m/s) the staff has determined that the information provided is inconclusive with respect to
26 establishing an unambiguous loading rate correction which should be applied to Linde 80 weld
27 materials. Further, no action has yet been taken by the appropriate consensus codes and
28 standards organizations (ASME, ASTM) to address the need for a loading rate correction over
29 the range of rates applicable to the data in TR BAW-2308, Revision 1.

30 However, the NRC staff also noted that, in general, the application of the loading rate correction
31 proposed by the B&WOG resulted in IRT_{T_0} values which were more conservative than those
32 determined without application of the loading rate correction. Therefore, at this time, the staff
33 concludes that there is reasonable assurance that the use of IRT_{T_0} values for Linde 80 weld
34 materials which were determined using the proposed loading rate correction are acceptable for
35 the purpose of RPV material property determination. These values, along with corresponding σ_I
36 values, are given in Table 3. The staff also expects that action will be pursued within the
37 appropriate consensus codes and standards organizations to address loading rate effects on a
38 more generic basis (or determine that they do not need to be addressed) in the appropriate
39 ASME Code Cases and/or ASTM Standard Test Methods. The staff requests that the B&WOG
40 revise the recommended values in TR BAW-2308, Revision 1 in accordance with Table 3.
41 When consensus codes and standards organizations address loading rate effects on a more
42 generic basis, the staff also expects that the B&WOG will re-evaluate TR BAW-2308, Revision 1
43 to determine whether or not revision of the TR is warranted.

Table 3 - NRC Staff-Accepted IRT_{T_0} and σ_I Values for Linde 80 Weld Wire Heats

Linde 80 Weld Wire Heat	IRT_{T_0} (EF)	Initial Margin, σ_I (EF)
406L44	-94.9	11
71249	-47.4	12.9
72105	-32.7	11.8
821T44	-80.2	9.3
299L44	-81.8	11.6
72442	-30	11.9
72445	-72.5	12.3
All Heats (Generic Value)	-47.61 ¹	17.2

¹ Includes additional 20 EF correction proposed in March 25, 2005 letter.

In summary, the NRC staff determined that the B&WOG methodology, utilizing the provisions from the 1997 and 2002 Editions of ASTM E 1921 as specified in Section 3.2 of this SE, a correction factor equivalent to a bias of 18 EF to the data obtained from PCCS specimens, and the loading rate correction for Linde 80 welds addressed in TR BAW-2308, Revision 1, represents an acceptable methodology for establishing weld wire heat specific and generic IRT_{T_0} values for Linde 80 welds.

3.4.3 Evaluation of Weld Wire Heat Specific and Generic Linde 80 Weld Results

Based on the TR BAW-2308, Revision 1 methodology as summarized in Section 3.4.2 of this SE, the NRC staff reviewed the values given in Table 2 of this SE. Using the TR BAW-2308, Revision 1 methodology, the NRC staff performed a limited number of independent check calculations based on the information provided in TR BAW-2308, Revision 1 and got results which were consistent with those reported by the B&WOG (i.e., within calculational roundoff error). The NRC staff also performed independent calculations to confirm that the B&WOG approach to adjusting the data for loading rate and PCCS bias effects was acceptable (i.e., the NRC staff tried adjusting the data in other ways and concluded that the B&WOG approach resulted in equivalent or conservative results). Based on this assessment, the NRC staff concluded that the Linde 80 weld wire heat specific and generic IRT_{T_0} and σ_I values cited in Table 3 of this SE are acceptable for the purpose of determining unirradiated, initial RPV material properties for the purpose of RPV integrity evaluations.

3.4.4 Evaluation of Other Elements of the B&WOG Methodology

Based on the NRC staff's acceptance of the IRT_{T_0} and σ_I values from Table 3 of this SE, the NRC staff evaluated the approach proposed by the B&WOG for coupling material property changes based on ΔT_{30} models with IRT_{T_0} values based on fracture toughness data. Considering the limited amount of data available for Linde 80 welds shown in Figure 2, the use of ΔT_{30} in lieu of ΔT_0 provides a small amount of additional conservatism based on the slope of the regression line, although this conservatism was not credited by the B&WOG in TR

1 BAW-2308, Revision 1. Based upon the information shown in Figures 1 and 2, the NRC staff
2 concluded that there is sufficient evidence to conclude that for welds in general, and Linde 80
3 welds in particular, the use of models based on ΔT_{30} in lieu of obtaining test data on the shift in
4 the Master Curve T_0 parameter is acceptable, provided that the margins used in the analysis
5 adequately covered the scatter in the ΔT_{30} vs. ΔT_0 correlation.

6 The NRC staff evaluated the information presented in Figures 2 and 3 of this SE to determine if
7 the proposed use of a $\sigma_{\Delta} = 28$ EF was acceptable in conjunction with IRT_{T_0} and σ_I values based
8 on Master Curve testing and shift values based on the RG 1.99, Revision 2 model for welds.
9 When used in the margin term definition given in RG 1.99, Revision 2 and in Section 5 of TR
10 BAW-2308, Revision 1:

11 [Eqn. 6]
$$\text{Margin} = 2 / (\sigma_I^2 + \sigma_{\Delta}^2)$$

12 it is reasonable to consider whether a margin of $2\sigma_{\Delta} = 56$ EF is adequate to bound uncertainty in
13 the assessment of the shift in T_0 due to irradiation. The NRC staff observed that if a parallel line
14 is drawn offset by 56 EF (31 EC) above the one-to-one correlation line given in Figure 2 of this
15 SE (i.e., a parallel line which would represent the 56 EF of margin), that the data points would be
16 conservatively bounded. Further, the NRC staff observed that the data in Figure 3 of this SE
17 demonstrate that the use of a mean trend curve from RG 1.99, Revision 2 based on average
18 Linde 80 weld chemistry plus a $2\sigma_{\Delta}$ margin results in the measured ΔT_0 values being bounded,
19 provided that, at a minimum, a chemistry factor of 167 EF is applied. Based on these
20 observations, the NRC staff concluded that the use of $\sigma_{\Delta} = 28$ EF in conjunction with IRT_{T_0} and
21 σ_I values based on Master Curve testing and material property shifts based on the models in
22 RG 1.99, Revision 2, with a minimum chemistry factor of 167 EF of provides an acceptable basis
23 for RPV Linde 80 weld assessment.

24 The NRC staff has evaluated the issue of the appropriate regulatory process to be used when a
25 licensee incorporates the use of BAW-2308, Revision 1, as modified by this staff SE, within a
26 particular facility's licensing basis. The NRC staff has determined that in order to implement the
27 use of BAW-2308, Revision 1, as modified, for the purpose of supporting RPV integrity
28 evaluations required by 10 CFR 50.61 and 10 CFR Part 50, Appendix G, a licensee must submit
29 exemptions to do so in accordance with 10 CFR 50.12. An exemption is required to address
30 issues related to 10 CFR Part 50, Appendix G per the provisions of 10 CFR 50.60(b). An
31 exemption is required to address issues related to 10 CFR 50.61 inasmuch as the methodology
32 addressed in BAW-2308, Revision 1, as modified, represents a significant change to the
33 methodology specified in 10 CFR 50.61 for determining the pressurized thermal shock reference
34 temperature (RT_{PTS}) value for a Lind8 80 weld material.

35 **4.0 CONCLUSION**

36 In summary, the NRC staff determined that the B&WOG methodology, utilizing the provisions
37 from the 1997 and 2002 Editions of ASTM E 1921 as specified in Section 3.2 of this SE, a
38 correction factor equivalent to a bias of 18 EF to the data obtained from PCCS specimens, and
39 the loading rate correction for Linde 80 welds addressed in TR BAW-2308, Revision 1,
40 represents an acceptable methodology for establishing weld wire heat specific and generic IRT_{T_0}
41 values for Linde 80 welds.

1 5.0 CONDITIONS AND LIMITATIONS

2 Based on the information submitted by the B&WOG in TR BAW-2308, Revision 1, the
3 August 19, 2003, response to an NRC staff RAI, and the B&WOG letter dated March 25, 2005,
4 the NRC staff has concluded:

5 (1) The IRT_{T_0} and σ_I values given in Table 3 of this SE may be used by a licensee to define
6 the initial heat-specific or generic properties of its facility's Linde 80 welds. For those
7 Linde 80 weld wire heats for which heat-specific values are given, those values must be
8 used when applying TR BAW-2308, Revision 1 if the heat-specific IRT_{T_0} value is more
9 conservative than the generic "all heats" IRT_{T_0} value.

10 (2) When the values from Table 3 of this SE are used by a licensee, the methodology of
11 RG 1.99, Revision 2 may be used for the purpose of assessing the shift in initial

12 properties due to irradiation, even though the RG 1.99, Revision 2 methodology is based
13 upon Charpy V-notch 30 ft-lb energy level shift data. However, based on the information
14 in TR BAW-2308, Revision 1 (see Figure 3 of this SE), a minimum chemistry factor of
15 167 EF must be applied when using initial properties given in Table 3 of this SE. A
16 higher chemistry factor may be required if weld wire heat-specific chemical composition
17 or Charpy V-notch surveillance data indicate, via the methodology of RG 1.99, Revision
18 2, that a higher chemistry factor should apply.

19 (3) When the values from Table 3 of this SE are used by a licensee, a value of $\sigma_{\Delta} = 28$ EF
20 must be used to determine the overall margin term, when the margin term per TR
21 BAW-2308, Revision 1 is defined as:

$$\text{Margin} = 2 / (\sigma_I^2 + \sigma_{\Delta}^2)$$

22
23 (4) Any licensee who wants to utilize the methodology of TR BAW-2308, Revision 1 as
24 outlined in items (1) through (3) above, must request an exemption, per 10 CFR 50.12,
25 from the requirements of Appendix G to 10 CFR Part 50 and 10 CFR 50.61 to do so. As
26 part of a licensee's exemption request, the NRC staff expects that the licensee will also
27 submit information which demonstrates what values the licensee proposes to use for
28 ΔRT_{NDT} and the margin term for each Linde 80 weld in its RPV through the end of its
29 facility's current operating license.

30 (5) The B&WOG stated in their August 19, 2003 RAI response that fracture toughness data
31 from one more heat of Linde 80 weld material (weld wire heat 61782) are to be obtained.
32 The NRC staff expects the B&WOG to evaluate these data to determine whether or not
33 the conclusions of TR BAW-2308, Revision 1 and this SE are non-conservative, and to
34 communicate the B&WOG's conclusion to the NRC staff. Non-conservatism in TR
35 BAW-2308, Revision 1 would be evident if: (1) the IRT_{T_0} value from the to-be-tested
36 Linde 80 weld wire heat turns out to be higher than the generic IRT_{T_0} value approved in
37 this SE, or (2) if the data from the to-be-tested Linde 80 weld wire heat results in an
38 increase in the Linde 80 generic σ_I value.

39 (6) Although the NRC staff concludes that there is reasonable assurance that the use of
40 IRT_{T_0} values for Linde 80 weld materials, which were determined using the loading rate

1 correction addressed in TR BAW-2308, Revision 1, is acceptable for the purpose of RPV
2 material property determination, the NRC staff expects that action will be pursued within
3 the appropriate consensus codes and standards organizations to address loading rate
4 effects on a more generic basis (or determine that they do not need to be addressed).
5 The NRC staff also expects that when such action is completed the B&WOG will
6 re-evaluate TR BAW-2308, Revision 1 to determine whether or not revision of the TR is
7 warranted.

- 8 (7) The staff also expects that action will be pursued within the appropriate consensus
9 codes and standards organizations to address loading rate effects on a more generic
10 basis (or determine that they do not need to be addressed) in the appropriate ASME
11 Code Cases and/or ASTM Standard Test Methods. The staff requests that the B&WOG
12 revise the recommended values in TR BAW-2308, Revision 1 in accordance with Table
13 3. When consensus codes and standards organizations address loading rate effects on
14 a more generic basis, the staff also expects that the B&WOG will re-evaluate TR BAW-
15 2308, Revision 1 to determine whether or not revision of the TR is warranted.

16 Principal Contributor: Matthew Mitchell

17 Date: June 2, 2005