

June 7, 2005

Mr. Raymond A. Mosley, Director
Office of the Federal Register
National Archives and Records Administration
Washington, DC 20408

SUBJECT: REQUEST FOR EMERGENCY PUBLICATION

Dear Mr. Mosley:

I am requesting emergency publication of the enclosed exigent notice of consideration in the *Federal Register*. Please publish this notice in the *Federal Register* on June 13, 2005.

This notice is required to support a license amendment to allow the licensee of the Brunswick Steam Electric Plant, Units 1 and 2 to revise the existing Technical Specifications (TS) to replace the existing requirement of TS 3.4.5, "RCS Leakage Detection Instrumentation," Required Action D. 1, to enter Limiting Condition for Operation (LCO) 3.0.3 if required leakage detection systems are inoperable. The TS will be replaced with the requirement to be in Mode 3 within 12 hours and Mode 4 within 36 hours. In accordance with NRC Inspection Manual Part 9900, "Operations - Notices of Enforcement Discretion," exigent processing of the proposed amendment request is a result of the notice of enforcement discretion (NOED) granted by the NRC on May 12, 2005. Therefore, emergency publication of the exigent notice is requested.

Please call Brenda Mozafari at (301) 415-2020 to confirm publication date and to answer any questions you may have.

Sincerely,

/RA/

Douglas V. Pickett, Acting Chief, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Enclosure:
As stated

June 7, 2005

Mr. Raymond A. Mosley, Director
Office of the Federal Register
National Archives and Records Administration
Washington, DC 20408

SUBJECT: REQUEST FOR EMERGENCY PUBLICATION

Dear Mr. Mosley:

I am requesting emergency publication of the enclosed exigent notice of consideration in the *Federal Register*. Please publish this notice in the *Federal Register* on June 13, 2005.

This notice is required to support a license amendment to allow the licensee of the Brunswick Steam Electric Plant, Units 1 and 2 to revise the existing Technical Specifications (TS) to replace the existing requirement of TS 3.4.5, "RCS Leakage Detection Instrumentation," Required Action D. 1, to enter Limiting Condition for Operation (LCO) 3.0.3 if required leakage detection systems are inoperable. The TS will be replaced with the requirement to be in Mode 3 within 12 hours and Mode 4 within 36 hours. In accordance with NRC Inspection Manual Part 9900, "Operations - Notices of Enforcement Discretion," exigent processing of the proposed amendment request is a result of the notice of enforcement discretion (NOED) granted by the NRC on May 12, 2005. Therefore, emergency publication of the exigent notice is requested.

Please call Brenda Mozafari at (301) 415-2020 to confirm publication date and to answer any questions you may have.

Sincerely,

/RA/

Douglas V. Pickett, Acting Chief, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Enclosure:

As stated

DISTRIBUTION:

Non-Public PDII-2 R/F MMarshall BMozafari EDunnington (2) DPickett

ACCESSION NO. ML051580386

NRR-106

OFFICE	PDII-2/PM	PDII-2/LA	PDII-2/SC
NAME	BMozafari	EDunnington	DPickett for MMarshall
DATE	06/07/05	06/07/05	06/07/05

OFFICIAL RECORD COPY