

June 17, 2005

Mr. David A. Christian  
Sr. Vice President and Chief Nuclear Officer  
Dominion Nuclear Connecticut, Inc.  
Innsbrook Technical Center  
5000 Dominion Boulevard  
Glen Allen, VA 23060-6711

SUBJECT: MILLSTONE POWER STATION, UNIT NO. 3 - RESPONSE TO GENERIC  
LETTER 2004-01, "REQUIREMENTS FOR STEAM GENERATOR TUBE  
INSPECTIONS" (TAC NO. MC4830)

Dear Mr. Christian:

On August 30, 2004, the Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2004-01, "Requirements For Steam Generator Tube Inspections." The purpose of GL 2004-01 was to obtain information that would enable the NRC staff to determine whether licensees' steam generator (SG) tube inspection programs comply with the existing tube inspection requirements (the plant technical specifications in conjunction with Appendix B to Title 10 of the *Code of Federal Regulations* Part 50).

By letter dated October 29, 2004, you responded to GL 2004-01 for Millstone Power Station, Unit No. 3. The staff's review of your response to the GL did not identify any concerns with the inspection practices employed at Millstone Power Station, Unit No. 3. The staff, therefore, concludes that your SG tube inspection practices are in compliance with the existing tube inspection requirements.

Sincerely,

*/RA/*

George Wunder, Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-423

cc: See next page

June 17, 2005

Mr. David A. Christian  
Sr. Vice President and Chief Nuclear Officer  
Dominion Nuclear Connecticut, Inc.  
Innsbrook Technical Center  
5000 Dominion Boulevard  
Glen Allen, VA 23060-6711

SUBJECT: MILLSTONE POWER STATION, UNIT NO. 3 - RESPONSE TO GENERIC LETTER 2004-01, "REQUIREMENTS FOR STEAM GENERATOR TUBE INSPECTIONS" (TAC NO. MC4830)

Dear Mr. Christian:

On August 30, 2004, the Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2004-01, "Requirements For Steam Generator Tube Inspections." The purpose of GL 2004-01 was to obtain information that would enable the NRC staff to determine whether licensees' steam generator (SG) tube inspection programs comply with the existing tube inspection requirements (the plant technical specifications in conjunction with Appendix B to Title 10 of the *Code of Federal Regulations* Part 50).

By letter dated October 29, 2004, you responded to GL 2004-01 for Millstone Power Station, Unit No. 3 (Millstone 3). The staff's review of your response to the GL did not identify any concerns with the inspection practices employed at Millstone 3. The staff, therefore, concludes that your SG tube inspection practices are in compliance with the existing tube inspection requirements.

Sincerely,

*/RA/*

George Wunder, Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-423

cc: See next page

DISTRIBUTION:

PUBLIC	OGC	PDI-2 R/F	ACRS	JTerrell
JUhle	CRaynor	CAnderson, RI	MBanerjee	
DRoberts	GWunder	MYoder	PKlein	

DOCUMENT NAME: ML051590003

OFFICE	PDI-2/PM	PDI-2/LA	PDI-2/SC
NAME	GWunder	CRaynor	VNerses for DRoberts
DATE	6/16/05	6/15/05	6/17/05

OFFICIAL RECORD COPY

Millstone Power Station, Unit No. 3

cc:

Lillilan M. Cuoco, Esquire  
Senior Counsel  
Dominion Resources Services, Inc.  
Building 475, 5<sup>th</sup> Floor  
Rope Ferry Road  
Waterford, CT 06385

Edward L. Wilds, Jr., Ph.D.  
Director, Division of Radiation  
Department of Environmental Protection  
79 Elm Street  
Hartford, CT 06106-5127

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

First Selectmen  
Town of Waterford  
15 Rope Ferry Road  
Waterford, CT 06385

Mr. John Markowicz  
Co-Chair  
Nuclear Energy Advisory Council  
9 Susan Terrace  
Waterford, CT 06385

Mr. Evan W. Woollacott  
Co-Chair  
Nuclear Energy Advisory Council  
128 Terry's Plain Road  
Simsbury, CT 06070

Senior Resident Inspector  
Millstone Power Station  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 513  
Niantic, CT 06357

Ms. Nancy Burton  
147 Cross Highway  
Redding Ridge, CT 00870

Mr. Joseph Roy,  
Director of Operations  
Massachusetts Municipal Wholesale  
Electric Company  
Moody Street

P.O. Box 426  
Ludlow, MA 01056

Mr. J. Alan Price  
Site Vice President  
Dominion Nuclear Connecticut, Inc.  
Building 475, 5<sup>th</sup> Floor  
Rope Ferry Road  
Waterford, CT 06385

Mr. Chris Funderburk  
Director, Nuclear Licensing and  
Operations Support  
Dominion Resources Services, Inc.  
5000 Dominion Boulevard  
Glen Allen, VA 23060-6711

Mr. David W. Dodson  
Licensing Supervisor  
Dominion Nuclear Connecticut, Inc.  
Building 475, 5<sup>th</sup> Floor  
Rope Ferry Road  
Waterford, CT 06385