



**UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 400
ARLINGTON, TEXAS 76011-4005**

June 8, 2005

EA-05-038

R. T. Ridenoure
Vice President
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
P.O. Box 550
Fort Calhoun, NE 68023-0550

**SUBJECT: FORT CALHOUN STATION - REPLY TO NOTICE OF VIOLATION
(NRC INSPECTION REPORT 05000285/2005010)**

Dear Mr. Ridenoure:

Thank you for your letter of May 12, 2005, in response to our April 15, 2005, letter and Notice of Violation concerning the failure to promptly identify and correct a condition adverse to quality that resulted in Emergency Diesel Generator 2 being inoperable for approximately 29 days in August and September 2004.

We will review your corrective actions during a supplemental inspection scheduled to be conducted June 13-17, 2005. The inspection will be conducted in accordance with Inspection Procedure 95001, "Inspection for One or Two White Inputs in a Strategic Performance Area."

Sincerely,

/RA/

David N. Graves, Chief
Project Branch E
Division of Reactor Projects

Docket: 50-285
License: DPR-40

cc:
John B. Herman, Manager
Nuclear Licensing
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
P.O. Box 550
Fort Calhoun, NE 68023-0550

David J. Bannister
Manager - Fort Calhoun Station
Omaha Public Power District
Fort Calhoun Station FC-1-1 Plant
P.O. Box 550
Fort Calhoun, NE 68023-0550

James R. Curtiss
Winston & Strawn
1400 L. Street, N.W.
Washington, DC 20005-3502

Chairman
Washington County Board of Supervisors
P.O. Box 466
Blair, NE 68008

Sue Semerena, Section Administrator
Nebraska Health and Human Services System
Division of Public Health Assurance
Consumer Services Section
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
401 SW 7th Street, Suite D
Des Moines, IA 50309

Electronic distribution by RIV:
 Regional Administrator (**BSM1**)
 DRP Director (**ATH**)
 DRS Director (**DDC**)
 DRS Deputy Director (vacant)
 Senior Resident Inspector (**JDH1**)
 Branch Chief, DRP/E (**DNG**)
 Senior Project Engineer, DRP/E (**VGG**)
 Team Leader, DRP/TSS (**RLN1**)
 RITS Coordinator (**KEG**)
RidsNrrDipmlipb
 G. F. Sanborn, D:ACES (**GFS**)
 K. S. Fuller, RC (**KSF**)
 F. J. Congel, OE (**FJC**)
 OE:EA File (**RidsOeMailCenter**)

SISP Review Completed: __dng__ ADAMS: : Yes No Initials: __dng__
 : Publicly Available Non-Publicly Available Sensitive : Non-Sensitive

R:_FCS\2005\FC2005-10AK.wpd

C:DRP/E	D:DRP			
DNGraves;df	ATHowell			
/RA/	AVegel for			
6/7/05	6/8/05			

OFFICIAL RECORD COPY

T=Telephone

E=E-mail

F=Fax