

5.5 Programs and Manuals

---

5.5.5 Component Cyclic or Transient Limit

This program provides controls to track the FSAR, Section 4.1, cyclic and transient occurrences to ensure that components are maintained within the design limits.

5.5.6 Reactor Coolant Pump Flywheel Inspection Program

This program shall provide for the inspection of each reactor coolant pump flywheel per the recommendations of Regulatory Position c.4.b of Regulatory Guide 1.14, Revision 1, August 1975.

In lieu of Position c.4.b(1) and c.4.b(2), a qualified in-place UT examination over the volume from the inner bore of the flywheel to the circle one-half of the outer radius or a surface examination (MT and/or PT) of exposed surfaces of the removed flywheels may be conducted at 20 year intervals.