

Exelon Nuclear Job Performance Measure				
	Assemble th	he Fire Brigade	e	
	JPM Nur	mber: <u>RO A</u>		
	Revision	Number: <u>00</u>		
	Date:	<u>03/11/05</u>		
Developed By:	Instructor		Date	
Validated By:	SME or Instructor		Date	
Review By:	Operations Represen	tative	Date	
Approved By:	Training Department		Date	

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

<u>NOTE</u>: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

- Task description and number, JPM description and number are identified.
 - 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- 4. Initial setup conditions are identified.
- 5. Initiating and terminating cues are properly identified.
 - 6. Task standards identified and verified by SME review.
 - 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
 - 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure:
 Procedure Rev. ____ Date ____
 - 9. Pilot test the JPM:
 a. verify cues both verbal and visual are free of conflict, and
 b. ensure performance time is accurate.
 - 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
 - 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor	Date
SME/Instructor	Date
SME/Instructor	Date

Revision Record (Summary)

1. **Revision 00,** This JPM was developed for ILT NRC Exam 03-01 IAW NUREG 1021, Rev 9.

SIMULATOR SETUP INSTRUCTIONS

- 1. ANY IC may be used for this JPM, provided that it is verified to be compatible with this and the other JPMs that are scheduled to be run concurrently.
- 2. When the above steps are completed for this and other JPMs to be run concurrently, then validate the concurrently run JPMs using the JPM Validation Checklist.
- 3. This completes the setup for this JPM.

- Unit 1 is at 100% power. Unit 2 is in Mode 5 with maintenance activities in progress and many systems out of service. Unit 1 has the responsibility for the common panels.
- You are the U1 Assist NSO.
- The emergency telephone (2211) just rang.

INITIATING CUE

Respond to the emergency telephone call.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time:

<u>ELEMENT</u>	STANDARD	SAT	UNSAT	Comment Number
Answers the Emergency Telephone				
CUE: "This is Joe Smith, there is a FIRE in the contractor tool crib at TRACKWAY TWO. I TRIED to put it out with an extinguisher, but I could NOT. There are NO PERSONNEL in the area."				I NEL
Directs caller to stand by in a safe area and direct the Fire Brigade when they arrive.				
I will stand by in a safe area and dir	rect the Fire Brigade."			
Obtain QCOA 0010-12, Fire Explosion,				
ATOR: When QCOA 0010-12 is loo procedure.	cated, provide the candidate with a o	copy of	f the	
•Dispatches Fire Brigade Leader to the scene to assess the incident and to determine if Offsite Fire Department assistance is needed. •	Uses telephone or radio to contact Fire Brigade Leader (Field Supervisor)			
As the Field Supervisor (Brigade Les I and report back on the initial asse Department assistance is needed.	ader), tell the candidate that you wil ssment of the fire, AND whether or	ll go to not Of	Track fsite Fi	way ire
The PLANT SIREN in the Simulat	or does NOT provide audible feedba	ack.		
•Sounds the fire siren for approximately 10 seconds•	Depresses the START pushbutton below the word FIRE (right side) on the FIRE / ASSEMBLY Alarm Panel.			
After approximately 10 seconds, stops fire siren	Depresses the STOP pushbutton below the word FIRE (right side) on the FIRE / ASSEMBLY Alarm Panel.			
	ELEMENT Answers the Emergency Telephone This is Joe Smith, there is a FIRE in TRIED to put it out with an extinguin in the area." Directs caller to stand by in a safe area and direct the Fire Brigade when they arrive. I will stand by in a safe area and dir Obtain QCOA 0010-12, Fire Explosion, IATOR: When QCOA 0010-12 is low procedure. Dispatches Fire Brigade Leader to the scene to assess the incident and to determine if Offsite Fire Department assistance is needed. • As the Field Supervisor (Brigade Leader Department assistance is needed. • The PLANT SIREN in the Simular •Sounds the fire siren for approximately 10 seconds, stops fire siren	ELEMENTSTANDARDAnswers the Emergency Telephone	ELEMENTSTANDARD5Answers the Emergency TelephoneThis is Joe Smith, there is a FIRE in the contractor tool crib at TRACKWAY RIED to put it out with an extinguisher, but I could NOT. There are NUPER In the area."Directs caller to stand by in a safe area and direct the Fire Brigade when they arrive.Image: Could NOT. There are NUPER Image: Could NOT. There are NUPR Image: Could NUPR <b< td=""><td>ELEMENTSTANDARDImage: Standard s</td></b<>	ELEMENTSTANDARDImage: Standard s

					nt	
			L	ISAT	mmen mber	
<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SA	n	Co Nu	
NOTE:	NOTE: The plant PA system can be accessed by using one of the Giatronic® handsets in the Main Control Room, OR by dialing telephone extension 4747.					
D.4.b*	•Announces over the PA system the fire location and directs the Fire Brigade to respond. •	Makes announcement on PA. Wording similar to: "Attention in the plant, a fire has been reported in the Turbine Building at Trackway II in the Contractor's tool crib. (Repeats) Fire Brigade to respond."				
D.4.c	Re-sounds the fire siren for approximately 30 seconds.	Depresses the START pushbutton below the word FIRE (right side) on the FIRE / ASSEMBLY Alarm Panel.				
D.4.c	After approximately 30 seconds, stops fire siren	Depresses the STOP pushbutton below the word FIRE (right side) on the FIRE / ASSEMBLY Alarm Panel.				
NOTE:	The CentraCom [®] radio console on candidate chooses the DGT-9000 r candidate to NOT ACTUALLY TI	the Simulator Center Desk is non-fr adio on the NSO or ANSO desk, INI RANSMIT.	unctior FORM	nal. IF the	the	
D.5	Uses the Center Desk radio console to inform the Fire Brigade, Radiation Protection, and Security of the location of the fire.					
CUE: IF asked, point to the Memory Mode yellow LED and indicate that it is LIT.						
D.5.a*	•Depresses MULTI-SEL 1/MEMORY button to enter the Multi-Select mode.•	Prepares radio console for making announcement.				
CUE: F	Point to the GREEN LED and state	that it is LIT.				

			AT	NSAT	omment umber
<u>STEP</u>	ELEMENT	<u>STANDARD</u>	Š	U	υz
D.5.b*	•Selects OPS AND EMERGENCY modules. • De-selects all other modules.	Prepares radio console for making announcement.			
CUE: I a I	Point to the SELECT LIGHT on the are LIT. Point to the select light on A EXTINGUISHED.	OPS and SECURITY Modules and ALL OTHER modules and indicate	state t they a	that the re	ey
D.5.c	Presses the Alert 1 key for approximately 3 seconds	Presses ALERT 1 key for approximately 3 seconds to send attention signal			
D.5.d*	•Presses APB-1 key and describes the location of the fire. •	Makes announcement describing the location of the fire. May use wording similar to earlier announcement: "A fire has been reported in the Turbine Building at Trackway II in the Contractor's tool crib."			
D.5.e	Optional Step to exit Multi-Select mode if desired.	MAY exit Multi-Select mode by depressing the MULTI-SEL 1/MEMORY button (optional)			
CUE: I	F above optional step is performed, hat it is LIT. Point to the Multi-Sel	point to the Memory mode LED (ye ect LED (green) and indicate that it	ellow) a is extin	and ind nguishe	licate ed.
D.5.f	Depresses APB-1 key and directs the Fire Brigade, Rad Protection and Security to report to the Fire Brigade Leader	Makes announcement. May use wording similar to: <i>"Fire Brigade,</i> <i>Radiation Protection and Security</i> <i>are to report to the Fire Brigade</i> <i>Leader."</i>			
D.5.f. (1)	Depresses APB-1 or Transmit on the Ops module and directs all NLO's to switch their radios to EMERGENCY Channel 11.	Make announcement. May use wording similar to: "All Non- Licensed Operators switch radios to emergency channel 11."			

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number	
D.9	Notifies the Shift Manager	Notify the Shift Manager to consider classifying the event as a possible E-Plan condition and initiate Shift Emergency director Checklist as necessary				
CUE: As the Shift Manager, reply to the candidate that you will review the E-Plan and take the appropriate actions.						
CUE: As the Fire Brigade Leader, report that THE FIRE HAS BEEN EXTINGUISHED and that Offsite assistance is NOT required. As the Unit Supervisor, inform the Candidate that you will assign one of the EXTRA NSOs complete all remaining actions in QCOA 0010-12.						
CUE: I	nform the candidate that the JPM i	s complete.				

JPM Stop Time: _____

Operator's Name: Job Title:	□ RO □ SR	0			
JPM Title: JPM Number: Task Number and T Console in all mode HU-AA-101.	Assemble the RO A Citle: SR-9000-P es to transmit and	Fire Brigade 3. Given an operating d receive messages in	Revisio greactor plant, accordance wit	on Number: <u>00</u> operate the Centr h QCOP 9000-04	aCom · and
K/A Number and Ir	mportance: K/A: 2.1.	16 Rating: 2.9	/ 2.8		
Suggested Testing	Environment:	Simulator			
Actual Testing Env	vironment:	Simulator Co	ntrol Room	🗌 In-Plant	
Testing Method:	☐ Simulate⊠ Perform	Alternate Path: SRO Only:	Yes Yes	⊠ No ⊠ No	
Time Critical:	🗌 Yes 🛛	No			
Estimated Time to	Complete: 8 n	ninutes Actual	Time Used: _	minutes	
References: QCOA	0010-12, FIRE	/EXPLOSION			
EVALUATION SU Were all the Critica	U MMARY: l Elements perfo	rmed satisfactorily?	Yes	🗌 No	
The operator's perfe	ormance was eva	aluated against the star Satisfactory	ndards containe	ed in this JPM, an actory	d has
Comments:					
Evaluator's Name:			(Print)	
Evaluator's Signatu	ire:		D	Date:	

A:\QuadCities ROAdmin JPMsAsSubmitted\QuadCities RO Admin A As Submitted.doc Page 10 of 11

- Unit 1 is at 100% power. Unit 2 is in Mode 5 with maintenance activities in progress and many systems out of service. Unit 1 has the responsibility for the common panels.
- You are the U1 Assist NSO.
- The emergency telephone (2211) just rang.

INITIATING CUE

Respond to the emergency telephone call.



Exelon Nuclear				
Job Performance Measure				
Electrical Distrib	ution Surveillan	се		
JPM Num	ber: <u>ROB</u>			
Revision N	Number: <u>00</u>			
Date:	02/16/05			
Instructor		Date		
SME or Instructor		Date		
Operations Represent	ative	Date		
Training Department		Date		
	Job Perform Electrical Distrib JPM Num Revision N Date: Onstructor SME or Instructor Department	Job Performance Mease Electrical Distribution Surveillan JPM Number: RO B Revision Number: 00 Date: 02/16/05	Job Performance Measure Electrical Distribution Surveillance	

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

<u>NOTE</u>: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

- Task description and number, JPM description and number are identified.
 - 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- 4. Initial setup conditions are identified.
- 5. Initiating and terminating cues are properly identified.
 - 6. Task standards identified and verified by SME review.
 - 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
 - Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. ____ Date ____
 - 9. Pilot test the JPM:
 a. verify cues both verbal and visual are free of conflict, and
 b. ensure performance time is accurate.
 - 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
 - 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor	Date
SME/Instructor	Date
SME/Instructor	Date

Revision Record (Summary)

1. **Revision 00,** This JPM was developed for ILT NRC Exam 03-01 IAW NUREG 1021, Rev 9.

SIMULATOR SETUP INSTRUCTIONS

- 1. Reset the simulator to IC <u>21</u> (rst <u>21</u>).
- NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently. The IC used must have the Electric Plant in a NORMAL lineup.
- 2. Override the green light indication OFF (open light out) for the T12 to Bus 14 GCB OFF

• ior lohs1650014051 off

3. Verify a copy of QCOS 0005-08 complete through step D.2.

D.1.a:	Reason for test:	"Normal Surveillance"
D.1.b:	Permission to start test	(signed, date / time "current/current"
D.2	Record Operational Mode:	"1"

4. Verify Attachment D and E of QCOS 0005-08 with ALL STEPS INITIALED AS MET, to be provided to the Candidate DURING the JPM

When the above steps are completed for this and other JPMs to be run concurrently, then validate the concurrently run JPMs using the JPM Validation Checklist.

- Unit 1 and 2 are at rated conditions.
- QCOS 0005-08, ELECTRICAL DISTRIBUTION BREAKER AND VOLTAGE VERIFICATION is scheduled to be performed on your shift.
- You are the Unit 1 Assist NSO.
- The Unit 2 Assist NSO will provide all Unit 2 information as requested.
- An NLO has been dispatched to perform the in-plant sections of the surveillance and provide them to you when they are complete.

INITIATING CUE

Perform the Control Room portion QCOS 0005-08.

Provide the Candidate with a copy of QCOS 0005-08 completed through step D.2

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time:

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
NOTE: The procedure allows steps may be performed in any order. If the can invoke this option, then the sequence below will not be accurate.				hooses	
H.1.a	Determines the number of offsite lines available.	Per attachment A, determines that three offsite line are available.			
H.1.a. (1)	Documents at least two lines available.	Initials step complete.			
H.1.a. (2)	Verifies switchyard voltage > 352 KV.	Check Yard voltage on 912-1 panel. Initials step complete.			
H.1.b	Verifies XFMR 12 to BUS 13 GCB capable of being closed.	Checks light indication for GCB T12 Feed to Bus 13. Initials step.			
H.1.c	Verifies XFMR 12 to Bus 13 GCB is closed.	Initials step H.1.c.(2).			
NOTE: Candidate may check voltage on multiple phases of Bus 13 by operating the v switch on the 901-8 panel, but only one phase is required.					ſ
H.1.d	Verifies Bus 13 voltage 3850 to 4400 VAC by verifying voltmeter select switch is selected to Bus 13 and reading the voltage.	Checks Bus 13 voltage > 3850 and < 4400 VAC. Initials step.			
H.1.e	Verifies Busses 13 AND 13-1 TIE GCBs closed.	Checks CLOSED indicating lights indication for bus 13 and 13-1 GCBs (two sets of lights) are lit on 901-8 panel. Initials steps H.1.e (1) and (2).			
H.1.g*	●Determines that the OPEN light indication for XFMR 12 to bus 14 is NOT LIT.●	Checks indicating lights for XFMR 12 to bus 14 and recognizes that the green light is not lit and is NOT a burnt-out bulb.			
NOTE: 7	The candidate may check the light b	ulb to determine if it is burnt out.			

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
CUE: If Tr Tr Th Th Th Th	 CUE: If the candidate dispatches an Operator to Bus 14 to check the feed breaker from Transformer 12 to Bus 14, report that: There are NO lights lit on the breaker cubicle, The breaker appears to be physically cocked in the cubicle. There is a strong acrid odor coming from the cubicle's upper compartment 				
H.1.g*	•Notifies Unit Supervisor that XFMR 12 feed to bus 14 is NOT available and that the surveillance acceptance criteria are NOT met.•	Reviews acceptance criteria and determines that criteria G.1.a.(2) is NOT met.			
CUE: As	the Unit Supervisor, inform the car tions (if any) are required. Continu	ndidate that you will determine wha e performing the surveillance.	t Tech	Spec	
H.1.h	Verifies XFMR 11 to Bus 14 GCB is closed.	Initials step H.1.h.(1).			
H.1.i	Verifies Bus 14 voltage 3850 to 4400 VAC by verifying voltmeter select switch is selected to Bus 14 and reading the voltage.	Checks Bus 14 voltage > 3850 and < 4400 VAC. Initials step.			
H.1.j	Verifies Busses 14 AND 14-1 TIE GCBs closed.	Checks CLOSED indicating lights indication for bus 14 and 14-1 GCBs (two sets of lights) are lit on 901-8 panel. Initials steps H.1.j (1) and (2).			
H.1.k	Verifies Bus 14-1 voltage 3850 to 4400 VAC by verifying voltmeter select switch is selected to Bus 14-1 and reading the voltage.	Initials step.		_	
H.1.1	Verifies (with information provided by U2 Assist NSO below) that at least ONE of the following sets of conditions is met: H.1.1.(1), (2), (3), or (4).	H.1.1.(1) is NOT met H.1.1.(2) IS met H.1.1.(3) is NOT met H.1.1.(4) IS met			

<u>STEP</u>		<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number		
CUE:			I			1		
As the U2	2 Assist NS	O, provide the following	Unit 2 information as requested:					
H.	1.l.(1)	Step (a) is NOT met.						
		Steps (b, c, d, e and g) ARE met.						
		Step (f) is on Unit 1 and	l should be checked by the candidate	e				
H.	1.l.(2)	Steps (a, b, c, d, and f) a	re met					
		Step (e) is on Unit 1 and should be checked by the candidate.						
H.	1.1.(3)	Step (a) is NOT met.						
		Steps (b, c, d, e and g) ARE met.						
		Step (f) is on Unit 1 and should be checked by the candidate						
H.	1.1.(4)	Steps (a, b, c, d, and f) are met						
		Step (e) is on Unit 1 and should be checked by the candidate.						
H.1.m Verifies (with information provided by U2 Assist NSO below) that Bus 29 is energized to meet the opposite unit requirements by verifying at least ONE of the following sets of conditions is met. H.1.m.(1), (2) (3), or (4).		with information by U2 Assist NSO below) 29 is energized to meet ite unit requirements by at least ONE of the sets of conditions is met. b, (2) (3), or (4).	Requests U2 Assist NSO to provide information for step H.1.m.					
CUE:								
As the U2 Assist NSO, provide the following Unit 2 information as requested:								
H.1.m.(1) ALL sub steps ARE MET.								
H.1.m.(2) ALL sub steps ARE MET.								
H.	H.1.m (3) is NOT MET (Transformer 21 NOT on backfeed)							
H.1.m.(4) is NOT MET (Transformer 21 NOT on backfeed)								

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
H.2	Determines that step H.2 is NOT applicable.	H.2 not applicable because Unit 1 is in Mode 1.			
H.3.a. (1)	(a) Checks Bus 13-1 to Bus 18 breaker (on Bus 13-1) CLOSED.	Initials step.			
H.3.a. (1)	(b) Checks Bus 13-1 to Bus 18 breaker (on bus 18) CLOSED.	Initials step.			
H.3.a. (1)	(c) Verifies Bus 18 voltage 435 to 515 VAC by verifying voltmeter select switch is selected to Bus 18 and reading the voltage.	Initials step.			
H.3.a. (2)	(a) Checks Bus 14-1 to Bus 19 breaker (on Bus 14-1) CLOSED.	Initials step.			
H.3.a. (2)	(b) Checks Bus 14-1 to Bus 19 breaker (on bus 19) CLOSED.	Initials step.			
H.3.a. (2)	(c) Verifies Bus 19 voltage 435 to 515 VAC by verifying voltmeter select switch is selected to Bus 18 and reading the voltage.	Initials step.			
H.3.a. (3)	Verifies Opposite unit AC distribution system.				
CUE: As	the U2 Assist NSO, provide the foll	owing Unit 2 information as reques	ted:		
H.	3.a.(3) ALL sub steps (a, b, c, d) AR	E MET.			
H.3.b	Perform Attachment D.	Verifies that NLO is performing attachment D. Indicates that he will review it when the NLO is complete.			
CUE: Provide the candidate with completed Attachment D AND E (with all steps marked as met).					
H.3.b	Reviews Attachment D and verifies all steps MET.				

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number	
H.4.	Determines that H.4 does NOT apply since surveillance was NOT satisfactory.	Indicates all of step H.4 as N/A.				
Н.5.	Completes step H.5 because surveillance was UNSATISFACTORY.	 (1) Describes deficiency as XFMR 12 feed to Bus 14 is NOT capable of being closed. (2) Signs and dates "performed by" section. 				
CUE: As the Unit Supervisor, inform the candidate that you will initiate the IR and record the number at step H.5.(a).2 AND complete the review at step H.5.b						
NOTE: Candidate should inform examiner that the task is complete.						

JPM Stop Time: _____

Operator's Name: Job Title:	RO SRO		
JPM Title: JPM Number: Task Number and T	Electrical Distribution Survei RO B itle:	llance Revisio	on Number: <u>00</u>
K/A Number and In	portance: K/A: 2.1.31 Rating	: 4.2/3.9	
Suggested Testing	Environment: Simulator		
Actual Testing Env	rironment: 🛛 🖂 Simulator [Control Room	🗌 In-Plant
Testing Method:	□ Simulate Alternate ⊠ Perform SRO	Path: ⊠ Yes Only: □ Yes	□ No ⊠ No
Time Critical:	🗌 Yes 🛛 No		
Estimated Time to	Complete: <u>30</u> minutes A	ctual Time Used:	minutes
References: QCOS	0005-08 Rev. 14		
EVALUATION SU Were all the Critica	MMARY: Elements performed satisfactor	ily? 🗌 Yes	🗌 No
The operator's perfe	ormance was evaluated against the set of the	ne standards containe	d in this JPM, and has ctory
Comments:			
Evaluator's Name:		(Print)
Evaluator's Signatu	re:	D	ate:

- Unit 1 and 2 are at rated conditions.
- QCOS 0005-08, ELECTRICAL DISTRIBUTION BREAKER AND VOLTAGE VERIFICATION is scheduled to be performed on your shift.
- You are the Unit 1 Assist NSO.
- The Unit 2 Assist NSO will provide all Unit 2 information as requested.
- An NLO has been dispatched to perform the in-plant sections of the surveillance and provide them to you when they are complete.

INITIATING CUE

Perform the Control Room portion QCOS 0005-08.



-1

Exelon Nuclear					
Job Performance Measure					
	Determine Isolation Po	ints for a Cleara	nce Order		
	JPM Nun	nber: <u>RO C</u>			
	Revision	Number: <u>00</u>			
	Date:	<u>03/14/05</u>			
Developed By:	Instructor		Date		
Validated By:					
	SME or Instructor		Date		
Review By:	Operations Represent	tative	Date		
Approved By:					
	Training Department		Date		

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

<u>NOTE:</u> All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

- Task description and number, JPM description and number are identified.
- 2. Knowledge and Abilities (K/A) references are included.
- Performance location specified. (in-plant, control room, or simulator)
- 4. Initial setup conditions are identified.
 - 5. Initiating and terminating cues are properly identified.
 - 6. Task standards identified and verified by SME review.
 - Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
 - Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. _____ Date _____
 - Pilot test the JPM:
 a. verify cues both verbal and visual are free of conflict, and
 b. ensure performance time is accurate.
 - 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
 - 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor	Date
SME/Instructor	Date
SME/Instructor	Date

Revision Record (Summary)

1. **Revision 00,** This JPM was developed for ILT NRC Exam 03-01 IAW NUREG 1021, Rev 9.

SIMULATOR SETUP INSTRUCTIONS

- 1. None. This JPM may be completed at any location, provided that the appropriate reference material is available.
- 2. Ensure the following references are available:
 - P&ID's M-33 Sh. 1 & 2 and M-75 Sh. 1 & 2
 - 4E-Prints 1661G, 2661H
 - QOM's 1-6700-T05, 2-6700-T05
- 3. When the above steps are completed for this and other JPMs to be run concurrently, then validate the concurrently run JPMs using the JPM Validation Checklist.
- 4. This completes the setup for this JPM.

- Mechanical Maintenance has an emergent work package to uncouple the ½ RBCCW pump from the motor, for motor replacement. No draining is required.
- Because of computer problems, <u>PASSPORT IS NOT AVAILABLE</u>, but is expected back later on your shift. The Unit Supervisor has directed you to "be ready" to write a C/O when passport becomes available, later in the shift.

INITIATING CUE

DETERMINE the isolation points, which will be required for the preparation of a Clearance Order that will adequately protect Mechanical Maintenance while they UNCOUPLE the ¹/₂-RBCCW pump.

On the <u>attached</u>, <u>worksheet</u>. RECORD the ISOLATION POINT. The required HANG POSITION and any applicable HANG SEQUENCE. Additional will be provided if requested

Give the worksheet to the Unit Supervisor when complete

Provide examinee with: Attached form to document isolation points on.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time:

			ΔT	NSAT	omment umber
<u>STEP</u>	ELEMENT	<u>STANDARD</u>	\mathbf{S}^{t}	Í)	ΣŹ
NOTE:	Isolation points with "•" below mu	st be included for successful comple	tion.		
Selection of ADDITIONAL components would constitute failure ONLY if manipulation of the additional component would cause a plant transient or equipment damage, Examples include, closing the discharge valve on the running RBCCW pump, or opening the drain valve on an un-isolated portion of the system.					
NOTE: critical.	The order in which the candidate <i>l</i> . The SEQUENCE should be used w	<i>ists</i> the isolation points on the attach when determining if critical tasks are	ed for met.	m is no	ot
	Using QOM's, 4E-Prints and P&ID' RBCCW pump. Records isolation p of the following components.	s, selects isolation points for the ½ oints, position and sequence for each			
	¹ / ₂ C RBCCW Bus 19 C/S – PTL.	Sequenced before Bus 19 fuse.			
	¹ / ₂ C RBCCW Bus 29 C/S – PTL.	Sequenced before Bus 29 fuse.			
*	•Control power fuse – Removed.• Fuse XJ	Sequenced •before Bus 19 breaker.•			
*	•Bus 19 breaker – Racked Out.•	Sequenced •before valves.•			
*	• Control power fuse – Removed.• Fuse RW	Sequenced •before Bus 29 breaker.•			
*	•Bus 29 breaker – Racked Out.•	Sequenced •before valves.•			
*	•1-3799-66 – Closed.•	Sequenced •before suction valve, if closed.•			
*	•2-3799-66 – Closed.•	Sequenced •before suction valve, if closed.•			

JPM Stop Time:

Operator's Name:		
JPM Title: Determine Isolation Points for a Cle JPM Number: RO C Task Number and Title:	earance Order Revision	Number: <u>00</u>
K/A Number and Importance: K/A: 2.2.13 Rating: 3.6	/ 3.8	
Suggested Testing Environment: Simulator or Classro	oom	
Actual Testing Environment:	ntrol Room	🗌 In-Plant
Testing Method:□SimulateAlternate Path:⊠PerformSRO Only:	☐ Yes ☐ Yes	⊠ No ⊠ No
Time Critical: 🗌 Yes 🛛 No		
Estimated Time to Complete: minutes Actual	Time Used:	minutes
References:		
EVALUATION SUMMARY: Were all the Critical Elements performed satisfactorily?	☐ Yes	🗌 No
The operator's performance was evaluated against the star been determined to be:	ndards contained	in this JPM, and has ory
Comments:		
Evaluator's Name:	(Pr	int)
Evaluator's Signature:	Dat	e:

- Mechanical Maintenance has an emergent work package to uncouple the ½ RBCCW pump from the motor, for motor replacement. No draining is required.
- Because of computer problems, <u>PASSPORT IS NOT AVAILABLE</u>, but is expected back later on your shift. The Unit Supervisor has directed you to "be ready" to write a C/O when passport becomes available, later in the shift.

INITIATING CUE

DETERMINE the isolation points, which will be required for the preparation of a Clearance Order that will adequately protect Mechanical Maintenance while they UNCOUPLE the ¹/₂-RBCCW pump.

On the <u>attached</u>, <u>worksheet</u>. RECORD the ISOLATION POINT. The required HANG POSITION and any applicable HANG SEQUENCE. Additional will be provided if requested

Give the worksheet to the Unit Supervisor when complete

Clearance Order Worksheet:

FOR EXAMINATION PURPOSES ONLY

Attach additional sheets as necessary

Component Name / EPN	HANG	HANG
• 	position:	sequence:



-1

Exelon Nuclear							
	Job Performa	ance Measu	ure				
Re	view Survey Map and Det	ermine Personi	nel Exposures				
	JPM Numl	ber: <u>RO D</u>					
	Revision Number: 00						
	Date: <u>0</u>	03/14/05					
Developed By:							
Developed by:	Instructor		Date				
Validated By:	SME or Instructor						
	SME or Instructor Date						
Review By:	Operations Representa	tive	Date				
Approved By:							
	Iraining Department		Date				

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

<u>NOTE</u>: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

- Task description and number, JPM description and number are identified.
 - 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- 4. Initial setup conditions are identified.
- 5. Initiating and terminating cues are properly identified.
 - 6. Task standards identified and verified by SME review.
 - 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
 - Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. ____ Date ____
 - 9. Pilot test the JPM:
 a. verify cues both verbal and visual are free of conflict, and
 b. ensure performance time is accurate.
 - 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
 - 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor	Date
SME/Instructor	Date
SME/Instructor	Date

Revision Record (Summary)

1. **Revision 00,** This JPM was developed for ILT NRC Exam 03-01 IAW NUREG 1021, Rev 9.

SIMULATOR SETUP INSTRUCTIONS

- 1. None. This JPM may be completed at any location, provided that the appropriate reference material (listed below) is available.
- 2. Ensure the following reference material is available
 - A copy of RWP #: 10004577 rev. 0.
 - Survey map of the U-1 CLEAN UP HEAT EXCHANGER ROOM with dose rate for these 5 valves AO-1-1239; MO-1201-77; MO-1-1-1201-78; 1-1201-148B; 1-1201-148A at 160 mr/hr and with a dose rate of 120 mr/hr for these valves 1-1201-75; MO-1-1201-133.
 - Survey maps of the U-1 REACTOR BLDG. 2nd floor 623elv. and the U-1 CLEANUP HEAT EXCHANGER ROOM.
- 3. This completes the setup for this JPM.
You are assigned to develop the Pre Job Briefing to be given to NLO's who will perform a Clearance Order in the RWCU Heat Exchanger Room. You need to choose two Non-licensed Operators from the list below to perform this task. No dose extensions will be allowed by the Radiation Protection Dept.

The Radiation Protection Department has provided the attached Survey map and RWP to assist you in your planning and the following dose history for five available Non-licensed Operators:

Name	Annual QCNP TEDE Dose	Annual Non-QCNP TEDE Dose	Previous 24 hours DDE dose from all RWPs
Corbin	587 mrem	0 mrem	0 mrem
Kaitlyn	221 mrem	110 mrem	31 mrem
Tyler	320 mrem	0 mrem	8 mrem
Jaali	186 mrem	200 mrem	75 mrem
Blake	422 mrem	0 mrem	43 mrem

Expected stay time to hang cards on the following five valves is 15 minutes. This time was determined from past job history.

AO-1-1239

MO-1201-77

MO-1-1-1201-78

1-1201-148B

1-1201-148A

Expected stay time to hang cards on the following two valves is 15 minutes. This time was determined from past job history.

1-1201-75

MO-1-1201-133

INITIATING CUE

Review the RWP and Survey maps and select two Non-licensed Operators to perform the task. Notify the Unit 1 Unit Supervisor which Non-licensed Operators you select.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

EVALUATOR: The candidate must determine that dose for the task will be 70 mrem and then select two Operators to perform the task they should select Corbin and Tyler as they are the only Operators that can receive the necessary dose to perform this task. See the table below for projected dose + todays dose for each Operator. The calculation for dose projection is also listed below.

Operator Name	Projected dose for task	Operators dose today	Projected + Todays dose = Total dose
Corbin	70 mrem	0 mrem	70 mrem
Kaitlyn	70 mrem	31 mrem	101 mrem
Tyler	70 mrem	8 mrem	78 mrem
Jaali	70 mrem	75 mrem	145 mrem
Blake	70 mrem	43 mrem	113 mrem

Calculation:

- 5 valve clearance projected dose = 15 min/60 min=1/4 or .25 x 160 mr/hr=40 mrem
- 2 valve clearance projected dose = $15 \min/60 \min=1/4$ or .25 x 120 mr/hr=30mrem
- 40mrem + 30 mrem = 70 mrem projected dose for clearance

JPM Start Time:

STEP	ELEMENT	STANDARD	SAT	UNSAT	Comment Number	
NOTE:		<u> </u>				
• 1	• EVALUATOR: Give the candidate a copy of the following documents:					
•]	• RWP #: 10004577 rev. 0.					
• 5	Survey map of the U-1 CLEAN UP HI	EAT EXCHANGER ROOM				
• \$	Survey map of the U-1 REACTOR BL	LDG. 2 nd floor 623elv				
EVALU	JATOR: The following steps can be	performed in any order.				
	Reviews the RWP to determine approved Dose rates.	Reviews the RWP and determines the ED Dose alarm is set for 80 mrem.				
EVALU determi smeara	JATOR: The next step requires the ine dose rates. The candidate calcula ble contamination count instead of a	candidate to correctly read the surv ations will be wrong if the candidate area dose rate.	vey maj choose	p to es		
	Reviews Survey Maps to determine area dose rates.	Reviews the survey maps and determines area dose rates to be 160 mr for 5 valves and 120 mr for 2 valves.				
EVALUATOR: The candidate will need to perform the following calculation to determine total projected dose the NLOs are expected to receive. This calculation is listed here for your reference:						
• 4	• 5 valve clearance projected dose = $15 \min/60 \min=1/4$ or $.25 \times 160 mr/hr=40mrem$					
• 2 valve clearance projected dose = 15 min/60 min=1/4 or .25 x 120 mr/hr=30mrem						
• 1	• projected dose for clearance - 40mrem + 30 mrem = 70 mrem					
	Calculates the projected dose that will be received for the task.	Determines the NLO's will receive 70 mrem on this task.				

<u>STEP</u>	ELEMEN	<u>T</u>		<u>STANDARD</u>	SAT	UNSAT	Comment Number
EVALUATOR: In the next step the candidate will compare the projected dose for the task (70 mrem) to the list of available operators and adds the dose they already received today and compares this to the allowable dose from the RWP (80 mrem ED Dose Alarm)and determines only Corbin and Tyler can perform the task.							
Note: T as the N	Note: The RWP Dose Approval is 100 mrem/day. This should not be used in planning a job brief as the NLOs must exit the area when the ED Dose Alarm activates at 80 mrem.						
Operate Name	or Projected dose for task	Operators dos today	se	Projected + Todays dose = Tota	ll dose		
Corbin	n 70 mrem	0 mrem		70 mrem			
Kaitlyn	n 70 mrem	31 mrem		101 mrem			
Tyler	70 mrem	8 mrem		78 mrem			
Jaali	70 mrem	75 mrem		145 mrem			
Blake	70 mrem	43 mrem		113 mrem			
	Compares the projecte list of available operat allowable dose from th	rojected dose to the operators and from the RWP. the cor fro Co tas		npares the projected dose to the of available operators and adds dose they already received and npares this to the allowable dose in the RWP and determines only bin and Tyler can perform the			
	Chooses two NLO's to task.	o perform the Select perform		ects Corbin and Tyler to form the task.			
	•Notifies the Unit 1 U Supervisor of NLO's s	Unit Not selected.• Con selected.•		ifies the Unit 1 Unit Supervisor bin and Tyler have been cted to perform the First Hang.			
CUE	Candidate should report the task is complete.						

...

Operator's Name: Job Title:	□NLO □RO []SRO ∏STA [SRO Cert	
JPM Title: JPM Number: Task Number and T	Review Survey M RO D Title:	Map and Determine	e Personnel Exp Revisio	osures n Number: <u>00</u>
K/A Number and Ir	mportance: K/A: 2.3.2	Rating: 2.5/	2.9	
Suggested Testing	Environment: Si	mulator		
Actual Testing Env	vironment:] Simulator 🗌 Cor	ntrol Room	🗌 In-Plant
Testing Method:	☐ Simulate☑ Perform	Alternate Path: SRO Only:	☐ Yes ☐ Yes	⊠ No ⊠ No
Time Critical:	□ Yes □ N	0		
Estimated Time to	Complete: <u>15</u>	minutes Actual	Time Used:	minutes
References: RWP	1004577 provided b	y Rad Protection.		
EVALUATION SU Were all the Critica	U MMARY: l Elements performe	ed satisfactorily?	☐ Yes	🗌 No
The operator's perfe	ormance was evalua be:	ated against the star	ndards containe Unsatisfa	d in this JPM, and has ctory
Comments:				
Evaluator's Nar	ne:		()	Print)
Evaluator's Signatu	ire:		D	ate:

A:\QuadCities ROAdmin JPMsAsSubmitted\QuadCities RO Admin D As Submitted.doc Page 9 of 10

You are assigned to develop the Pre Job Briefing to be given to NLO's who will perform a Clearance Order in the RWCU Heat Exchanger Room. You need to choose two Non-licensed Operators from the list below to perform this task. No dose extensions will be allowed by the Radiation Protection Dept.

The Radiation Protection Department has provided the attached Survey map and RWP to assist you in your planning and the following dose history for five available Non-licensed Operators:

Name	Annual QCNP TEDE Dose	Annual Non-QCNP TEDE Dose	Previous 24 hours DDE dose from all RWPs
Corbin	587 mrem	0 mrem	0 mrem
Kaitlyn	221 mrem	110 mrem	31 mrem
Tyler	320 mrem	0 mrem	8 mrem
Jaali	186 mrem	200 mrem	75 mrem
Blake	422 mrem	0 mrem	43 mrem

Expected stay time to hang cards on the following five valves is 15 minutes. This time was determined from past job history.

AO-1-1239

MO-1201-77

MO-1-1-1201-78

1-1201-148B

1-1201-148A

Expected stay time to hang cards on the following two valves is 15 minutes. This time was determined from past job history.

1-1201-75

MO-1-1201-133

INITIATING CUE

Review the RWP and Survey maps and select two Non-licensed Operators to perform the task. Notify the Unit 1 Unit Supervisor which Non-licensed Operators you select.



	Exelon Nuclear				
	Job Performance Measure				
Initiate	a Fire Impairment Perm	it Requiring Corr	pensatory Actions		
	JPM Nun	nber: <u>SRO A</u>			
	Revision	Number: <u>00</u>			
	Date:	<u>03/15/05</u>			
Developed By:					
	Instructor		Date		
Validated By:	SME or Instructor		Date		
			Duto		
Review By:	Review By: Operations Representative Date				
Approved By:					
	Training Department		Date		

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

<u>NOTE:</u> All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

 1.	Task description and number, JPM description identified.	n and number are		
 2. Knowledge and Abilities (K/A) references are included.				
 3.	Performance location specified. (in-plant, consistent simulator)	trol room, or		
 4.	Initial setup conditions are identified.			
 5.	Initiating and terminating cues are properly ide	entified.		
 6.	Task standards identified and verified by SME	review.		
 7.	Critical steps meet the criteria for critical steps with an asterisk (*).	s and are identified		
 8.	Verify the procedure referenced by this JPM r current revision of that procedure: Procedure Rev Date	natches the most		
 9.	Pilot test the JPM: a. verify cues both verbal and visual are free of b. ensure performance time is accurate.	of conflict, and		
 10). If the JPM cannot be performed as written wit responses, then revise the JPM.	h proper		
 11	. When JPM is revalidated, SME or Instructor s cover page.	ign and date JPM		
SM	IE/Instructor	Date		
SM	IE/Instructor	Date		
SM	IE/Instructor	Date		

Revision Record (Summary)

1. **Revision 00,** This JPM was developed for ILT NRC Exam 03-01 IAW NUREG 1021, Rev 9.

SIMULATOR SETUP INSTRUCTIONS

- 1. Reset the simulator to IC $\underline{21}$ (rst $\underline{21}$).
- NOTE: It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.
- 2. NOTE: This JPM may be conducted in any appropriate setting; i.e. simulator, classroom etc.
- 3. Verify the following for this JPM setup:
 - A current revision of OP-MW-201-007 Attachment 1 "Fire Protection Impairment Permit" is filled out with the following errors:
 - 1) Two detectors that make a detection system inoperable (ref. QCAP 1500-01 Attachment A) and the detection system in turn makes the suppression system inoperable (ref. QCAP 1500-01 Attachment C).
 - 2) Fill out section II. "FIRE MARSHAL REVIEW" of the Fire Protection Impairment Permit as follows:
 - a. Mark None in the Fire Watch Performed By: block.
 - b. Check NO in the box for Additional Compensatory Measures.
 - 3) Fill out another Fire Protection Impairment Permit correctly to provide an example to the Evaluator.
- 4. This completes the setup for this JPM.

- You are the Work Execution Center Senior Reactor Operator.
- An Instrument Maintenance Supervisor has requested a permit to allow testing of smoke detectors in the CRD area. The work will continue into the next shift.

INITIATING CUE

Review Fire Protection Impairment Permit 05-05. Approve the permit OR explain the reason(s) why you cannot.

EVALUATOR: Provide candidate with a copy of fire permit 05-05 and OP-MW-201-007 "FIRE PROTECTION SYSTEM"

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM S	JPM Start Time:				
<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
EVALUATOR: Give the candidate a copy of the Fire Protection Impairment Permit and OP-MW-201-007 "FIRE PROTECTION SYSTEM".					MW-
	Obtains Procedures	Obtains a copy of OP-MW-201- 007 and QCAP 1500-01.			
EVALUA'	FOR: The candidate may perform	the following steps in any order.			
	Reviews Fire Permit.	Reviews Fire Permit to determine what is being impaired. Determines that two detectors will be disconnected (1-4133-101 and 1- 4133-102).			
Att. A page 2	Determines effect of disconnecting detectors.	Reviews QCAP 1500-01 Att. A page 2 and determines the two detectors if removed will make the detection system inoperable (3 or 4 are required).			

EVALUATOR: if the candidate states he cannot approve the permit because of errors, prompt him explain all of the errors on the permit for you.

The following errors are built into the permit:

The Fire Protection Permit was filled out improperly in section II. "FIRE MARSHAL REVIEW" as follows:

- None is marked in the "Fire Watch Required:" block (should be marked "hourly with performed by marked as "IMD")
- NO is checked in the box for "Additional Compensatory Measures" (should be marked "YES" and a Description of the additional Compensatory Measures should be included i.e. "backup suppression established or verified.")

The two detectors that were chosen make a detection system inoperable (ref. QCAP 1500-01 Attachment A page 2), and the detection system *in turn* makes the preaction suppression system inoperable (ref. QCAP 1500-01 Attachment C page2).

STEP	ELEMENT	STANDARD	SAT	UNSAT	Comment Number
Att. C page 2	Determines consequence of making the detection system inoperable.	Reviews QCAP 1500-01 Att. C page 2 (or determines info from QCAP 1500-01 Att. A page 2) and determines that making the <i>detection</i> system inoperable makes the <i>suppression</i> system inoperable.			
*D.1.c.(2) *D.2.c.(2)	•Determines hourly fire watch required.•	Reviews QCAP 1500-01 step D.1.c.(2) and D.2.c.(2) and determines an hourly fire watch must be conducted if this permit is approved.			
D.2.c.(4)	•Determines backup suppression required.•	Reviews step D.2.c.(4) and determines backup suppression will also be required.			
NOTE: T	ne candidate may choose to correct	the provided impairment. This is a	cceptal	ble.	
	•Reviews the permit for accuracy and Notifies the Evaluator of his conclusions •	The candidate reviews the permit for accuracy in accordance with OP-MW-201-007 "FIRE PROTECTION SYSTEM IMPAIRMENT CONTROL" step 4.4 and determines the fire impairment permit cannot be approved as written because the Fire Protection Permit was filled out improperly in section II. "FIRE MARSHAL REVIEW" None is marked in the "Fire Watch Performed By:" block (should be marked "hourly) and NO is checked in the box for "Additional Compensatory Measures" (should be marked "YES" and a Description of the additional Compensatory Measures should be included i.e. "backup suppression required).			

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number		
EVALUATOR: After the candidate explains why he cannot approve the fire permit as written as the IM Supervisor requesting the permit that you will rewrite the permit and bring it back for approval on the next shift.							
EVALUATOR: The JPM is complete.							

JPM Stop Time: _____

Operator's Name: Job Title:	SRO		
JPM Title: JPM Number: Task Number and T	Initiate a Fire SRO A Title:	Impairment Permit Requiring Comp Revisio	ensatory Actions on Number: <u>00</u>
K/A Number and Ir	mportance: K/A: 2.1.25	Rating: 3.1	
Suggested Testing	Environment:	Simulator	
Actual Testing En	vironment:	Simulator Control Room	🗌 In-Plant
Testing Method:	☐ Simulate ⊠ Perform	Alternate Path:□YesSRO Only:⊠Yes	⊠ No □ No
Time Critical:	🗌 Yes 🛛	No	
Estimated Time to	Complete: <u>35</u>	minutes Actual Time Used:	minutes
References: QCAP	• 1500-01 Rev. 2	0 & OP-MW-201-007 Rev. 3	
EVALUATION S Were all the Critica	U MMARY: ll Elements perfo	ormed satisfactorily?	🗆 No
The operator's perf determined to be:	ormance was eva	aluated against the standards containe	d in this JPM, and has been ctory
Comments:			
Evaluator's Nar	ne:	(Print)
Evaluator's Signatu	ıre:	D	ate:

A:\QuadCitiesSROAdminJPMsAsSubmitted \QuadCities SRO Admin A As Submitted.doc Page 9 of 10

- You are the Work Execution Center Senior Reactor Operator.
- An Instrument Maintenance Supervisor has requested a permit to allow testing of smoke detectors in the CRD area. The work will continue into the next shift.

INITIATING CUE

Review Fire Protection Impairment Permit 05-05. Approve the permit OR explain the reason(s) why you cannot.



Exelon Nuclear						
	Job Performance Measure					
	Verify Reactor Mode Cha	nge Requirements				
	JPM Number:	<u>SRO B</u>				
	Revision Number: <u>00</u>					
	Date: <u>03/1</u>	<u>4/05</u>				
Developed Bv:						
	Instructor	Date				
Validated By:	SME or Instructor	Date				
Review By:						
	Operations Representative	Date				
Approved By:	Training Department	Date				

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

 Task description and number, JPM description and number are identified. 				
 2. Knowledge and Abilities (K/A) references are	e included.			
 Performance location specified. (in-plant, cor simulator) 	ntrol room, or			
 4. Initial setup conditions are identified.				
 5. Initiating and terminating cues are properly ic	lentified.			
 6. Task standards identified and verified by SM	E review.			
 Critical steps meet the criteria for critical step with an asterisk (*). 	os and are identified			
 Verify the procedure referenced by this JPM current revision of that procedure: Procedure Rev Date 	matches the most			
 Pilot test the JPM: a. verify cues both verbal and visual are free b. ensure performance time is accurate. 	of conflict, and			
 10. If the JPM cannot be performed as written wi responses, then revise the JPM.	th proper			
 11. When JPM is revalidated, SME or Instructor cover page.	sign and date JPM			
SME/Instructor	Date			
SME/Instructor	Date			
SME/Instructor	Date			

Revision Record (Summary)

1. **Revision 00,** This JPM was modified from JPM ADM-A.1.1-SRO, Quad Cities NRC Exam March, 2000, IAW ILT NRC Exam 03-01, IAW NUREG 1021, Rev 9.

SIMULATOR SETUP INSTRUCTIONS

- 1. None. This JPM may be completed at any location, provided that the appropriate reference material is available.
- 2. Ensure the following references are available
 - QCGP 1-1 page 64, signed off through F.6.ah
 - QCGP 1-1 Attachment E completed as follows:
 - All Unit 1 24 month surveillances dated AFTER May 5, 2003.
 - All Unit 1 92 day surveillances dated AFTER Jan 10, 2005 except as noted below.
 - All Unit 2 surveillances marked "N/A".
 - Unit 1 Division I Low Condenser Vacuum Scram Calibration And Functional Test (N/A for Unit Two) is marked "Jan 8, 2005" (page 143)
 - Unit 1 Division I APRM Downscale Control Rod Block Functional Test (N/A for Unit Two) is marked "N/A" (page 144)
 - A Calendar for 2005.
- 3. This completes the setup for this JPM.

- Today is <u>May 5th, 2005.</u>
- You are the Unit 1 Supervisor. Unit 1 is at 10% reactor power, starting up following an outage. QCGP 1-1 is in progress. All procedure steps up to, and including F.6.ah have been completed.

INITIATING CUE

The Shift Manager has directed you to perform QCGP 1-1 step F.6.ai to VERIFY MODE 1 surveillance requirements met, and report to the Shift Manager when complete.

If MODE 1 surveillance requirements are not met, report to the Shift Manager, any action(s) required, to meet the requirements.

Provide the candidate with a working copy of QCGP 1-1 page 64, completed through step F.6.ah, AND a copy of Attachment E with dates filled in as described in setup.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time:

				-			
<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number		
F.6.ai	Reviews Attachment E to ensure all Mode 2 to Mode 1 surveillance requirements are met						
NOTE: ORDEF Evaluat	There are TWO ERRORS on Atta R which the candidate identifies the or.	chment E that the candidate must ic errors will affect the role-play requi	lentify red of	. The the			
ATT E pg 143*	•Candidate identifies that the Unit 1 Division I Low Condenser Vacuum Scram Calibration And Functional Test was completed on Jan 8, 2004 and that this is TOO LONG AGO, to meet the TS requirement + allowable extension. (92 days + 25%) - 115 days)•	Recognizes that the test should have been completed no longer ago than Jan 10, 2005.					
CUE: IF the e	CUE: IF the error above is reported FIRST: Report, as the Operations Predefine Coordinator, that the date listed is NOT CORRECT. The surveillance was completed on Jan 18, 2005. CHANGE the date to "Jan 18, 2005", <u>INITIAL AND DATE THE CHANGE</u> and INITIAL THE RIGHT COLLUM. If the error above is reported SECOND: Report, as the Operations Predefine Coordinator, that you have verified that the date listed is CORRECT.						
ATT E pg 144*	•Candidate identifies that the Unit 1 Division I APRM Downscale Control Rod Block Functional Test (N/A for Unit Two) is marked "N/A" but should not be.• (page 144)						

STEP	ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number	
CUE:						
IF the e	rror above is reported FIRST:					
]]]]]]]]]]]]]]]]]]]	IF ASKED, report, as the Operations Predefine Coordinator, that the surveillance was last performed on <u>January 20, 2005</u> . CHANGE the "N/A" to "Jan 20, 2005" then <u>INITIAL AND DATE THE CHANGE</u> , and INITIAL THE RIGHT COLLUM. If the error above is reported SECOND: Report, as the Operations Predefine Coordinator, that the surveillance was last completed on Jan 9, 2005					
CUE:						
IF BOT	H errors are reported SIMULTAN	EOUSLY (at the end):				
Only ac	knowledge and repeat back the rep	ort.				
	The candidate reports to the Shift Manager step F.6.ai can NOT be signed off without first completing the required surveillance.					
NOTE: WHICH surveillance is required to be performed will depend on the ORDER that they were reported, and the variable role-play required of the Evaluator. (See above)						
	Candidate reports task complete:					

JPM Stop Time: _____

Operator's Name: Job Title:	SRO					
JPM Title: JPM Number: Task Number and T	Verify Reacto SRO B Fitle:	or Mode Cha	nge Requir	ements Revisi	on Number:	<u>00</u>
K/A Number and Ir	mportance: K/A: 2.1.	12 R at	ing: 4.0			
Suggested Testing	Environment:	Simulator				
Actual Testing En	vironment:	Simulate	or 🗌 Cont	rol Room	🗌 In-Plant	
Testing Method:	☐ Simulate☑ Perform	Alterr SI	ate Path: RO Only:	□ Yes ⊠ Yes	⊠ No □ No	
Time Critical:	🗌 Yes 🛛 🖂	No				
Estimated Time to	Complete: <u>30</u>	minutes	Actual T	ime Used: _	minutes	\$
References:						
EVALUATION S Were all the Critica	U MMARY: Il Elements perfo	ormed satisfac	ctorily?	□ Yes	D No	
The operator's perfe	ormance was eva	aluated again Satisfactory	st the stand	lards contain Unsatisf	ed in this JPM actory	, and has
Comments:						
Evaluator's Nar	me:				(Print)	
Evaluator's Signatu	ıre:			I	Date:	

A:\QuadCitiesSROAdminJPMsAsSubmitted \QuadCities SRO Admin B As Submitted.doc Page 8 of 9

- Today is <u>May 5th, 2005.</u>
- You are the Unit 1 Supervisor. Unit 1 is at 10% reactor power, starting up following an outage. QCGP 1-1 is in progress. All procedure steps up to, and including F.6.ah have been completed.

INITIATING CUE

The Shift Manager has directed you to perform QCGP 1-1 step F.6.ai to VERIFY MODE 1 surveillance requirements met, and report to the Shift Manager when complete.

If MODE 1 surveillance requirements are not met, report to the Shift Manager, any action(s) required, to meet the requirements.



Exelon Nuclear				
	Job Performa	nce Measure	•	
	Review Abnormal Comp	oonent Position S	heet	
	JPM Numbe	er: SRO C		
	Revision N	umber: 0		
	Date: <u>03</u>	/14/05		
Developed By:				
	Instructor	Da	te	
Validated By:	SME or Instructor	 Da	ite	
Review By:				
	Operations Representat	ive Da	ite	
Approved By:	Training Department	Da	ite	

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

<u>NOTE:</u> All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

 Task description and number, JPM des identified. 	cription and number are
 2. Knowledge and Abilities (K/A) reference	es are included.
 Performance location specified. (in-plan simulator) 	nt, control room, or
 4. Initial setup conditions are identified.	
 5. Initiating and terminating cues are prop	erly identified.
 6. Task standards identified and verified b	y SME review.
 Critical steps meet the criteria for critica with an asterisk (*). 	al steps and are identified
 Verify the procedure referenced by this current revision of that procedure: Procedure Rev Date 	JPM matches the most
 Pilot test the JPM: a. verify cues both verbal and visual are b. ensure performance time is accurate 	e free of conflict, and
 10. If the JPM cannot be performed as writ responses, then revise the JPM.	ten with proper
 11. When JPM is revalidated, SME or Instr cover page.	uctor sign and date JPM
SME/Instructor	Date
SME/Instructor	Date
SME/Instructor	Date

Revision Record (Summary)

Revision 00, This JPM was developed for ILT NRC Exam 03-01 IAW NUREG 1021, Rev 9.

QuadCities SRO Admin C As Submitted.doc C SIMULATOR SETUP INSTRUCTIONS

- 1. None. This JPM may be completed at any location, provided that the appropriate reference material (listed below) is available.
- 2. Ensure the following JPM material and references are available
 - OP-AA-108-101 Attachment 2, ACPS 05-05 filled out as follows:

0	ACPS#:	05-05
0	Station:	Quad
0	Unit	Two
0	System	RHRSW
0	Action Required for Removal:	Place CO
0	The following SIX Yes/No questions:	Circle "N"
0	SRO Approval	Signed, Date (today) Time (now)
0	SRO Peer Check	Blank
0	SRO Approval for Restoration:	Blank

EPN	EST Number	Normal Position	Abnormal (Desired) Position
2-1001-1A		Open	Closed
2-1001-3A		Open	Closed
2-1001-4A		Open	Closed
2-1001-186A		Closed	Closed
2-1099-100A		Closed & capped	Uncapped & open

- OP-AA-108-101 Attachment 3, Numbering Log, filled out with 05-01 thru 05-04 completed AND lined out with color highlighter indicating completion. For 05-05 write "Quad Cities, 2, RHRSW, Isolate 2A RHRSW pump seal leak"
- 3. This completes the setup for this JPM.

Unit 2 is Operating at rated power. You are the Unit 2 Supervisor on midnight shift. During rounds, the U2 NLO reported a large seal leak from the 2A RHRSW High Pressure Pump outboard seal. You have declared the 2A RHRSW pump INOPERABLE and directed the NSO to place it in PTL.

ALL Tech Spec required LCO action statements have been entered. This is the ONLY LCO affecting Unit 2.

IR #123456 has been generated, documenting the unplanned LCO entry and requesting Work Request generation to repair the leak.

The Shift Manager has directed the pump isolated, using Equipment Status Tags (EST) until dayshift, when a Clearance Order can be prepared and placed. The Shift Technical Advisor (STA) has prepared Abnormal Component Position Sheet (ACPS) 05-05 per OP-AA-108-101 to isolate the leak. He has also prepared the tags to be hung in the plant. The ACPS needs an SRO Peer Check.

For this exercise, assume that using an APCS and EST tags has been determined to be appropriate, and that Engineering concurs that a 10CFR50.59 review is NOT required. (1st 6 questions are, in fact "No")

INITIATING CUE

Perform the SRO Peer Check of ACPS 05-05 per OP-AA-108-101. If you approve the ACPS, notify the NSO who will coordinate the pre-job brief and dispatch of the Non Licensed Operators. If you do NOT approve, indicate why not.

Provide examinee with:	OP-AA-108-101 Attachment 2 (ACPS 05-05)
	OP-AA-108-101 Attachment 3 (Numbering Log)
	OP-AA-108-101
	M-79

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local

A:\QuadCitiesSROAdminJPMsAsSubmitted\QuadCities SRO Admin C As Submitted.doc

Page 5 of 9

QuadCities SRO Admin C As Submitted.doc C

operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time:

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	TASNU	Comment Number
	Reviews OP-AA-108-101 Attachment 2				
EVALU	JATOR: Candidate may report the	errors and omissions below in ANY	ORDI	ER	
*	•Candidate reports that he / she CAN NOT approve the ACPS•				
*	 Candidate Reports the following omissions and errors The ACPS does not contain the pump •Control Switch•, breaker or control power fuses. Only SOME of the EST tags have the ACPS number (05-05) on them as required. •Tag # 10490 is incorrectly prepared for 2-1001-2A instead of 2-1001-3A• •ACPS incorrectly CLOSES 2-1001-4A & 2-1001-186A which would render the ENTIRE LOOP of RHRSW INOPERABLE, instead of just the A pump• ACPS does not ensure pump depressurization, because ONLY 2-1099-100A is opened. 2-1099-96 must also be opened to provide drain path 				
EVALU	JATOR: WHEN the candidate has i	ndicated ALL the reasons why he / s	she can	not	

authorize the ACPS, indicate that this JPM is complete.

Operator's Name: Job Title:	□NLO □RO [SRO 🗌 STA [SRO Cert		_
JPM Title: JPM Number: Task Number and T	Review Abnorm SRO C Title: LNF-PGCM	al Component Posi - Operational Con	ition Sheet Revis figuration Co	sion Number: <u>0</u> ntrol	
K/A Number and In	nportance: K/A: 2.2.11	Rating: 3.4			
Suggested Testing	Environment: S	imulator			
Actual Testing Env	vironment:	Simulator 🗌 Con	ntrol Room	🗌 In-Plant	
Testing Method:	☐ Simulate☑ Perform	Alternate Path: SRO Only:	$\Box Yes \\ \Box Yes$	⊠ No □ No	
Time Critical:	🗌 Yes 🛛 🕅	ю			
Estimated Time to	Complete: <u>20</u>	minutes Actual	Time Used:	minutes	
References:					
EVALUATION SU Were all the Critica	J MMARY: l Elements perform	ed satisfactorily?	Yes	No No	
The operator's perfo determined to be:	ormance was evalua	ated against the star atisfactory	ndards contair	ned in this JPM, a factory	nd has been
Comments:					
					_
					_
					_
					_
Evaluator's Nan	ne:			(Print)	
Evaluator's Signatu	re:			Date:	_

Unit 2 is Operating at rated power. You are the Unit 2 Supervisor on midnight shift. During rounds, the U2 NLO reported a large seal leak from the 2A RHRSW High Pressure Pump outboard seal. You have declared the 2A RHRSW pump INOPERABLE and directed the NSO to place it in PTL.

ALL Tech Spec required LCO action statements have been entered. This is the ONLY LCO affecting Unit 2.

IR #123456 has been generated, documenting the unplanned LCO entry and requesting Work Request generation to repair the leak.

The Shift Manager has directed the pump isolated, using Equipment Status Tags (EST) until dayshift, when a Clearance Order can be prepared and placed. The Shift Technical Advisor (STA) has prepared Abnormal Component Position Sheet (ACPS) 05-05 per OP-AA-108-101 to isolate the leak. He has also prepared the tags to be hung in the plant. The ACPS needs an SRO Peer Check.

For this exercise, assume that using an APCS and EST tags has been determined to be appropriate, and that Engineering concurs that a 10CFR50.59 review is NOT required. (1st 6 questions are, in fact "No")

INITIATING CUE

Perform the SRO Peer Check of ACPS 05-05 per OP-AA-108-101. If you approve the ACPS, notify the NSO who will coordinate the pre-job brief and dispatch of the Non Licensed Operators. If you do NOT approve, indicate why not.



-1

Exelon Nuclear				
Job Performance Measure				
Review Survey Map and Determine Personnel Exposures				
JPM Number: <u>SRO D</u>				
Revision Number: 00				
Date: 03/14/05				
Developed By:				
Developed by.	Instructor		Date	
Validated By:				
	SME or instructor		Date	
Review By:	Operations Representat	tive	Date	
Approved By:				
	Training Department		Date	
Validated By: Review By: Approved By:	SME or Instructor Operations Representat	tive	Date Date Date	

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

<u>NOTE</u>: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

- Task description and number, JPM description and number are identified.
 - 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- 4. Initial setup conditions are identified.
- 5. Initiating and terminating cues are properly identified.
 - 6. Task standards identified and verified by SME review.
 - 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
 - Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. ____ Date ____
 - 9. Pilot test the JPM:
 a. verify cues both verbal and visual are free of conflict, and
 b. ensure performance time is accurate.
 - 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
 - 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor	Date
SME/Instructor	Date
SME/Instructor	Date
Revision Record (Summary)

1. **Revision 00,** This JPM was developed for ILT NRC Exam 03-01 IAW NUREG 1021, Rev 9.

SIMULATOR SETUP INSTRUCTIONS

- 1. None. This JPM may be completed at any location, provided that the appropriate reference material (listed below) is available.
- 2. Ensure the following reference material is available
 - A copy of RWP #: 10004577 rev. 0.
 - Survey map of the U-1 CLEAN UP HEAT EXCHANGER ROOM with dose rate for these 5 valves AO-1-1239; MO-1201-77; MO-1-1-1201-78; 1-1201-148B; 1-1201-148A at 160 mr/hr and with a dose rate of 120 mr/hr for these valves 1-1201-75; MO-1-1201-133.
 - Survey maps of the U-1 REACTOR BLDG. 2nd floor 623elv. and the U-1 CLEANUP HEAT EXCHANGER ROOM.
- 3. This completes the setup for this JPM.

You are assigned to develop the Pre Job Briefing to be given to NLO's who will perform a Clearance Order in the RWCU Heat Exchanger Room. You need to choose two Non-licensed Operators from the list below to perform this task. No dose extensions will be allowed by the Radiation Protection Dept.

The Radiation Protection Department has provided the attached Survey map and RWP to assist you in your planning and the following dose history for five available Non-licensed Operators:

Name	Annual QCNP TEDE Dose	Annual Non-QCNP TEDE Dose	Previous 24 hours DDE dose from all RWPs
Corbin	587 mrem	0 mrem	0 mrem
Kaitlyn	221 mrem	110 mrem	31 mrem
Tyler	320 mrem	0 mrem	8 mrem
Jaali	186 mrem	200 mrem	75 mrem
Blake	422 mrem	0 mrem	43 mrem

Expected stay time to hang cards on the following five valves is 15 minutes. This time was determined from past job history.

AO-1-1239

MO-1201-77

MO-1-1-1201-78

1-1201-148B

1-1201-148A

Expected stay time to hang cards on the following two valves is 15 minutes. This time was determined from past job history.

1-1201-75

MO-1-1201-133

INITIATING CUE

Review the RWP and Survey maps and select two Non-licensed Operators to perform the task. Notify the Unit 1 Unit Supervisor which Non-licensed Operators you select.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

Information For Evaluator's Use:

UNSAT requires written comments on respective step.

- * Denotes critical steps.
- Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

EVALUATOR: The candidate must determine that dose for the task will be 70 mrem and then select two Operators to perform the task they should select Corbin and Tyler as they are the only Operators that can receive the necessary dose to perform this task. See the table below for projected dose + todays dose for each Operator. The calculation for dose projection is also listed below.

Operator Name	Projected dose for task	Operators dose today	Projected + Todays dose = Total dose
Corbin	70 mrem	0 mrem	70 mrem
Kaitlyn	70 mrem	31 mrem	101 mrem
Tyler	70 mrem	8 mrem	78 mrem
Jaali	70 mrem	75 mrem	145 mrem
Blake	70 mrem	43 mrem	113 mrem

Calculation:

- 5 valve clearance projected dose = 15 min/60 min=1/4 or .25 x 160 mr/hr=40 mrem
- 2 valve clearance projected dose = $15 \min/60 \min=1/4$ or .25 x 120 mr/hr=30mrem
- 40mrem + 30 mrem = 70 mrem projected dose for clearance

JPM Start Time:

STEP	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number	
NOTE:	L	L	<u> </u>		<u> </u>	
•]	EVALUATOR: Give the candidate	a copy of the following documents:				
•]	• RWP #: 10004577 rev. 0.					
• 5	• Survey map of the U-1 CLEAN UP HEAT EXCHANGER ROOM					
• 5	Survey map of the U-1 REACTOR BL	DG. 2 nd floor 623elv				
EVALU	JATOR: The following steps can be	performed in any order.			-	
	Reviews the RWP to determine approved Dose rates.	Reviews the RWP and determines the ED Dose alarm is set for 80 mrem.				
EVALU determi smeara	JATOR: The next step requires the ine dose rates. The candidate calcula ble contamination count instead of a	candidate to correctly read the surv ations will be wrong if the candidate area dose rate.	vey maj choose	p to es		
	Reviews Survey Maps to determine area dose rates.	Reviews the survey maps and determines area dose rates to be 160 mr for 5 valves and 120 mr for 2 valves.				
EVALU projecto reference	EVALUATOR: The candidate will need to perform the following calculation to determine total projected dose the NLOs are expected to receive. This calculation is listed here for your reference:					
• 4	• 5 valve clearance projected dose = $15 \min/60 \min=1/4$ or .25 x 160 mr/hr=40mrem					
• 2	• 2 valve clearance projected dose = $15 \text{ min}/60 \text{ min}=1/4 \text{ or } .25 \text{ x } 120 \text{ mr/hr}=30 \text{mrem}$					
• 1	projected dose for clearance - 40mrem	n + 30 mrem = 70 mrem				
	Calculates the projected dose that will be received for the task.	Determines the NLO's will receive 70 mrem on this task.				

STEPELEMENTSTANDARDEVALUATOR: In the next step the candidate will compare the projected dose for the task (70 mrem) to the list of available operators and adds the dose they already received today and compares this to the allowable dose from the RWP (80 mrem ED Dose Alarm)and determines only Corbin and Tyler can perform the task.Note: The RWP Dose Approval is 100 mrem/day. This should not be used in planning a job br as the NLOs must exit the area when the ED Dose Alarm activates at 80 mrem.							Comment Number brief
Operate Name	or Projected dose for task	Operators dos today	se	Projected + Todays dose = Tota	ll dose		
Corbin	n 70 mrem	0 mrem		70 mrem			
Kaitlyn	70 mrem	31 mrem		101 mrem			
Tyler	70 mrem	8 mrem		78 mrem			
Jaali	70 mrem	75 mrem		145 mrem			
Blake	70 mrem	43 mrem		113 mrem			
	Compares the projecte list of available operat allowable dose from th	ed dose to the ors and ne RWP.	Con list the com from Cor task	npares the projected dose to the of available operators and adds dose they already received and apares this to the allowable dose in the RWP and determines only bin and Tyler can perform the			
	Chooses two NLO's to task.	o perform the	Sele perf	ects Corbin and Tyler to form the task.			
	•Notifies the Unit 1 U Supervisor of NLO's s	nit selected.●	Not: Cori sele	ifies the Unit 1 Unit Supervisor bin and Tyler have been cted to perform the First Hang.			
CUE	Candidate should rej	port the task i	s con	ıplete.			

Operator's Name: Job Title:	□NLO □RO	SRO STA	A 🗌 SRO Cert	
JPM Title: JPM Number: Task Number and T	Review Survey SRO D Fitle:	y Map and Detern	nine Personnel E Revis	xposures sion Number: <u>00</u>
K/A Number and Ir	mportance: K/A: 2.3.2	Rating:	2.5/2.9	
Suggested Testing	Environment:	Simulator		
Actual Testing En	vironment:	Simulator	Control Room	🗌 In-Plant
Testing Method:	☐ Simulate ⊠ Perform	Alternate Pa SRO Or	ath: Yes Yes Yes	⊠ No ⊠ No
Time Critical:	☐ Yes □	No		
Estimated Time to	Complete: <u>15</u>	minutes Act	ual Time Used:	minutes
References: RWP	1004577 provided	l by Rad Protectio	on.	
EVALUATION S Were all the Critica	UMMARY: al Elements perfor	med satisfactorily	? 🗌 Yes	🗌 No
The operator's perfe	formance was eval	uated against the Satisfactory	standards contair	ned in this JPM, and has factory
Comments:				
Evaluator's Nar	me:			(Print)
Evaluator's Signatu	ıre:			Date:

You are assigned to develop the Pre Job Briefing to be given to NLO's who will perform a Clearance Order in the RWCU Heat Exchanger Room. You need to choose two Non-licensed Operators from the list below to perform this task. No dose extensions will be allowed by the Radiation Protection Dept.

The Radiation Protection Department has provided the attached Survey map and RWP to assist you in your planning and the following dose history for five available Non-licensed Operators:

Name	Annual QCNP TEDE Dose	Annual Non-QCNP TEDE Dose	Previous 24 hours DDE dose from all RWPs
Corbin	587 mrem	0 mrem	0 mrem
Kaitlyn	221 mrem	110 mrem	31 mrem
Tyler	320 mrem	0 mrem	8 mrem
Jaali	186 mrem	200 mrem	75 mrem
Blake	422 mrem	0 mrem	43 mrem

Expected stay time to hang cards on the following five valves is 15 minutes. This time was determined from past job history.

AO-1-1239

MO-1201-77

MO-1-1-1201-78

1-1201-148B

1-1201-148A

Expected stay time to hang cards on the following two valves is 15 minutes. This time was determined from past job history.

1-1201-75

MO-1-1201-133

INITIATING CUE

Review the RWP and Survey maps and select two Non-licensed Operators to perform the task. Notify the Unit 1 Unit Supervisor which Non-licensed Operators you select.



Exelon Nuclear					
	Job Performance Measure				
C	Determine EP Classificat	tion and Prepare	NARS Form		
	JPM Nur	nber: <u>SRO E</u>			
	Revision Number: <u>00</u>				
	Date:	<u>03/14/05</u>			
Developed By:					
	Instructor		Date		
Validated By:	SME or Instructor		 Date		
Poviow By:					
Review by.	Operations Represen	tative	Date		
Approved By:	Training Department		 Date		

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

<u>NOTE:</u> All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

 1.	Task description and number, JPM descriptio identified.	n and number are
 2.	Knowledge and Abilities (K/A) references are	included.
 3.	Performance location specified. (in-plant, con simulator)	trol room, or
 4.	Initial setup conditions are identified.	
 5.	Initiating and terminating cues are properly id	entified.
 6.	Task standards identified and verified by SME	E review.
 7.	Critical steps meet the criteria for critical step with an asterisk (*).	s and are identified
 8.	Verify the procedure referenced by this JPM r current revision of that procedure: Procedure Rev Date	natches the most
 9.	Pilot test the JPM: a. verify cues both verbal and visual are free b. ensure performance time is accurate.	of conflict, and
 10). If the JPM cannot be performed as written wit responses, then revise the JPM.	h proper
 11	. When JPM is revalidated, SME or Instructor s cover page.	sign and date JPM
SM	IE/Instructor	Date
SM	IE/Instructor	Date
SM	IE/Instructor	Date

Revision Record (Summary)

1. **Revision 00,** This JPM has been modified from SRO-006-I for ILT NRC Exam 03-01 IAW NUREG 1021, Rev 9.

SIMULATOR SETUP INSTRUCTIONS

Candidate to be provided (or have access to) EP-AA-1006, Radiological Emergency Plan Annex for Quad Cites Station (EAL Manual) and a copy of completed Utility Message #1 NARS form.

Page 1 (front)		
Utility Message No. 1		
State Message No. N/A		
Status	[B] Drill/Exercise	
Block #2. Station	[F] Quad Cities	
Block #3. Onsite Condition	.[B] Alert	
Block #4. Accident Classified:	.Time:14:30	
	.Date: today	
	EAL = FA1	
Block #4. Accident Terminated:	.Time:=N/A	
	Date:=N/A	
Block #5. Release Status	.[A] None	
Block #6. Type of Release	[A] Not Applicable	
Block #7. Wind Direction	.74 degrees	
Block #8. Wind Speed:	.[A] Meters/Sec	3.46
	.[B] Miles/Hr	7.64
Block #9. Recommended Actions	.[A] None	
Block #10. Additional Information	.None	
Verified with	.[Joe Sta (or other sign	ature)]
Approved by	.[Mark Jensen (or othe	r signature)]
Block #11	Transmitted By [Joe S	sta (or other)]
Phone Number	.[309-227-2301]	
Time/Date	.[1442 / today]	

Page 2 (back)

In the Quad Cities box check all Initial and Final boxes under NARS Code 43

- Unit 1 was operating at 100% rated power when, at time 1400, a transient occurred that caused an automatic scram. The Emergency Plan was activated and an Alert (FA1) was classified at time 1430 due to high drywell radiation of 140 R/hr.
- NARS notification, Utility Message No. 1 was made at 14:42
- ENS notification is in progress.
- TSC and OSC activation is in progress. The TSC is NOT YET ready to take command and control.
- You are the Shift Emergency Director.
- It is now 1500
 - Drywell radiation is 7500 R/hr.
 - All other containment parameters are normal.

There has been NO CHANGE in release status OR meteorological data, since Utility Message No. 1 was sent.

This is a DRILL, NOT an actual event.

This JPM <u>IS</u> time critical.

INITIATING CUE

As the Shift Emergency Director, DETERMINE if a change in Emergency Classification is required.

- IF a change in classification IS REQUIRED, THEN PREPARE the necessary forms that would allow another SRO to complete the required State and Local Notifications.
- IF a change in classification IS NOT REQUIRED, THEN INDICATE in the space below, what Drywell Radiation Condition changes WOULD require a change in Emergency Classification.

Provide examinee with: Candidate needs to have access to Emergency Plan procedures and blank NARS form as found in the simulator. Copy of EP-MW-114-100 Attachment 1 "Nuclear Accident Reporting System" (NARS) Utility Message #1 form completely filled out for an Alert, as indicated in setup instructions.

Fill in the JPM Start Time when the student declares the new classification.

Information For Evaluator's Use

UNSAT requires written comments on respective step. *Denotes critical steps.

Denotes critical elements of a critical step.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section at the bottom of the page. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

This JPM contains TWO time-critical tasks that are sequential.

The FIRST time critical task is to declare the new EAL classification within 15 minutes after the candidate acknowledges the initiating cue.

The SECOND time critical task is to complete necessary forms to allow notification of state and local agencies to begin within 15 minutes after declaring the new EAL classification.

JPM Start Time:

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number	
	Refers to EP-AA-1006 Quad Cities Annex					
	Determines that the increase in DW radiation requires upgrading the classification to a Site Area Emergency	Recognizes that the conditions for FS1 are met, because Drywell Radiation levels indicate a loss of both fuel cladding (Graph 2.c) and Reactor coolant (Graph 3.c)				
NOTE: T	NOTE: The FIRST time-critical task completes upon declaration of the Site Area Emergency per EAL FS1.					
*	•Declares a Site Area Emergency within 15 minutes•	Drywell Radiation Levels indicate loss of RCS and Fuel Clad but NOT a potential loss of containment. (FS1)				
Record tin	ne of declaration (H	END of <u>1st</u> time-critical task, STAR	Г of <u>2n</u>	<u>d</u>)		
1.3.D	References EP-AA-112-100-F- 01, Shift Emergency Director Checklist	INITIATE required State / Local classification as required per the Notifications procedure.				
	Refers to EP-MW-114-100 MWROG OFFSITE NOTIFICATIONS as necessary to fill out NARS form.					
EVALUA	EVALUATOR: When candidate locates the NARS form (if administered in the simulator, or indicates that he / she needs a NARS form, if administered elsewhere, Give the candidate a blank copy of the NARS form.					
NARS form	Fills out Utility Message Number.	Records Utility Message #2.				
NARS form	Fills out State Message Number.	Records N/A for State Message Number.				
Block #1	Fills out block #1 information regarding Status.	Records [B] Drill/Exercise in block #1.				

			E	SAT	nment nber			
<u>STEP</u>	<u>ELEMENT</u>	STANDARD	SAJ	N	Con Nur			
Block #2	Fills out block #2 information regarding Station.	Records [F] Quad Cities in block #2.						
*Block #3	●Fills out block #3 information regarding onsite condition. ●	Records [C] Site Area Emergency.						
Block #4	Fills out block #4 information regarding Accident Classified & Accident Terminated.	Records Accident Classification as Time= time from above Date= today's date EAL=FS1 Records N/A for Accident Terminated Time and Date.						
*Block #5	●Fills out block #5 information regarding Release Status. ●	Records [A] None.						
*Block #6	●Fills out block #6 information regarding Type of Release. ●	Records [A] N/A.						
EVALUA'	EVALUATOR: Candidate may take information from initial conditions that state "There has been NO Change in release status, or meteorological data" OR they may look up the data on the station computer to complete Blocks #7 and 8. If they choose to look up real data, when they find the real data, give them the following cue "Wind Direction is 74 degrees with speed of 7.64 miles per hour/3.46 meters per second".							
Block #7	Fills out block #7 information regarding Wind Direction.	Records 74 degrees.						
Block #8	Fills out block #8 information regarding Wind Speed.	Records [A] Meters/Sec = 3.46 and [B] Miles/Hr = 7.64						
*Block #9	•Fills out block #9 information regarding Recommended Actions.•	Records [A] None						
Block #10	Fills out block #10 Additional Information.	Records NONE.						
NARS form	•Submits NARS form for verification within 15 minutes•	Submits NARS form for verification.						

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
Evaluator: Record time NARS form submitted for verification (END of second time-critical task.)					
CUE: When candidate submits the NARS form for verification, STATE that the form is acceptable for transmittal (regardless of whether it actually is).					
The	candidate should inform you the	e task is complete.			

JPM Stop Time: _____

Operator's Name: Job Title:	SRO					
JPM Title: JPM Number: Task Number and T	Determine EF SRO E Fitle: S-GSEP-P (organization	P Classification and Pr D1 Given an event, c n in accordance with F	repare NARS Fo Revision lassify the event EP-AA-111 and	rm n Number: <u>00</u> and activate the G EP-AA-112.	SEP	
K/A Number and In	mportance: K/A: 2.4.4	41 Rating:	4.1			
Suggested Testing	Environment:	Simulator				
Actual Testing En	vironment:	Simulator Co	ntrol Room	🗌 In-Plant		
Testing Method:	☐ Simulate☑ Perform	Alternate Path: SRO Only:	I Yes I Yes	⊠ No □ No		
Time Critical: declaration to notif	\boxtimes Yes \square ication of state an	No 15 minutes to no 15 minutes to 15 minutes	o declare, AND	15 minutes from tin	me of	
Estimated Time to	Complete: <u>12</u>	minutes Actual	Time Used:	minutes		
References: EP-AA-111 r9, EP-AA-1006 r19 EP-AA-112-100 r7, EP-MW-114-100 r5,		EMERGENCY CLASSIFICATION AND PROTECTIVE ACTION RECOMMENDATIONS. RADIOLOGICAL EMERGENCY PLAN ANNEX FOR QUAD CITIES STATION (EAL MANUAL) CONTROL ROOM OPERATIONS MIDWEST REGION OFFSITE NOTIFICATIONS				
EVALUATION S Were all the Critica	UMMARY: al Elements perfo	rmed satisfactorily?	☐ Yes	🗌 No		
The operator's perf determined to be:	formance was eva	luated against the star Satisfactory	ndards contained	l in this JPM, and h ctory	as been	
Comments:						
Evaluator's Name:				Print)		
Evaluator's Signature:			Da	Date:		
A:\QuadCitiesSROAdr	ninJPMsAsSubmitte	d\QuadCities SRO Admir	n E As Submitted.de)C		

Page 10 of 11

- Unit 1 was operating at 100% rated power when, at time 1400, a transient occurred that caused an automatic scram. The Emergency Plan was activated and an Alert (FA1) was classified at time 1430 due to high drywell radiation of 140 R/hr.
- NARS notification, Utility Message No. 1 was made at 14:42
- ENS notification is in progress.
- TSC and OSC activation is in progress. The TSC is NOT YET ready to take command and control.
- You are the Shift Emergency Director.
- It is now 1500
 - Drywell radiation is 7500 R/hr.
 - All other containment parameters are normal.

There has been NO CHANGE in release status OR meteorological data, since Utility Message No. 1 was sent.

This is a DRILL, NOT an actual event.

This JPM <u>IS</u> time critical.

INITIATING CUE

As the Shift Emergency Director, DETERMINE if a change in Emergency Classification is required.

- IF a change in classification IS REQUIRED, THEN PREPARE the necessary forms that would allow another SRO to complete the required State and Local Notifications.
- IF a change in classification IS NOT REQUIRED, THEN INDICATE in the space below, what Drywell Radiation Condition changes WOULD require a change in Emergency Classification.