


NOTES:

- 1. Groundwater Levels indicated on the subsurface section were obtained by interpolating between borings with piezometers. Information on actual groundwater levels exist only at boring locations with piezometers.
- It is possible that groundwater levels between borings with piezometers may vary from those indicated.
- 2. The depth and thickness of soil and rock strata indicated on the subsurface section were obtained by interpolating between borings. Information on actual soil and rock conditions exist only at boring locations. It is possible that soil and rock conditions may vary from those indicated.
- 3. The discussion in the text is necessary for proper understanding of the nature of the subsurface materials
- 4. Elevations refer to the USGS Datum

Figure 2.3-15 Near Site Cross Section of Hydrogeologic Units and Piezometric Surfaces



Not to Scale




Figure 2.3-16
Location of Piezometers, CPS
Test Well, and Water Table
in Site Vicinity

Legend

- CPS Test Well
- ▼ Functional Piezometer (As of 12 77)
- Non-Functional Piezometer (As of 12 77)
- Inferred Water Table Contour, Wisconsinan Deposits
- ▼ Piezometer Installed in July/August 2002

Flow Line

NOTES

- 1. Datum is msl.
- 2. Piezometer installation data are listed in Table 2.3-15.

Data Source: CPS, 2002



