

July 19, 2005

Mr. Henry B. Barron
Group Vice President and Chief Executive Officer
Duke Energy Corporation
526 South Church Street
P.O. Box 1006
Charlotte, NC 28201-1006

SUBJECT: CATAWBA NUCLEAR STATION, UNIT 2 - RESPONSE TO NUCLEAR REGULATORY COMMISSION BULLETIN 2003-02, "LEAKAGE FROM REACTOR PRESSURE VESSEL LOWER HEAD PENETRATIONS AND REACTOR COOLANT PRESSURE BOUNDARY INTEGRITY" (TAC NO. MC0529)

Dear Mr. Barron:

On August 21, 2003, the U.S. Nuclear Regulatory Commission (NRC) issued NRC Bulletin 2003-02, "Leakage from Reactor Pressure Vessel Lower Head Penetrations and Reactor Coolant Pressure Boundary Integrity," to the industry. This bulletin informed addressees that current methods of inspecting the reactor pressure vessel (RPV) lower heads may need to be supplemented with bare-metal visual inspections in order to detect reactor coolant pressure boundary leakage. The bulletin also requested for these addressees to provide the NRC with information related to inspections that have been performed to verify the integrity of the RPV lower head penetrations.

The bulletin requested that addressees provide a description of the RPV lower head penetration inspection program that would be implemented at their respective plants during the next and subsequent refueling outages. This description was to include the extent of the inspection, the inspection methods to be used, the qualification standards for the inspection methods, the process used to resolve the source of findings of boric acid deposits or corrosion, the inspection documentation to be generated, and the basis for concluding that their plant satisfied applicable regulatory requirements related to the structural and leakage integrity of the RPV lower head penetrations.

By letter dated September 18, 2003, Duke Energy Corporation (Duke) provided its response to this request for the fall 2004 refueling outage at Catawba Nuclear Station (Catawba), Unit 2. In its response, Duke committed to performing a bare-metal visual inspection of the RPV lower head, including 360-degrees around 100 percent of the RPV lower head penetrations. Duke stated that the information obtained from the inspection findings at Catawba, Units 1 and 2 and industry developments on the RPV lower head penetrations will be used to determine the type of examinations that will be performed during future refueling outages, beyond the fall 2004 refueling outage. The NRC staff notes that there are a number of ongoing industry and NRC staff activities related to developing criteria for RPV lower head penetration inspections. The NRC staff expects that the criteria for these inspections will involve periodic bare-metal visual examinations or their equivalent.

The bulletin also requested that addressees provide a summary of the RPV lower head penetration inspection that was performed at their plants, the extent of the inspection and the methods used, a description of the as-found condition of the lower head, any findings of relevant indications of through-wall leakage, and a summary of the disposition of any findings of boric acid deposits and any corrective actions taken as a result of indications found.

By letter dated December 16, 2004, Duke provided a summary of its inspection results at Catawba, Unit 2. Duke reported it had performed a bare-metal visual inspection of the RPV lower head, including 360-degrees around 100 percent of the RPV lower head penetrations. Duke did not observe any evidence of RPV lower head penetration leakage or RPV lower head wastage. In addition, Duke performed ultrasonic examinations of all 58 RPV lower head penetrations and eddy current examinations on 56 of the 58 penetrations. Equipment problems prevented inspection of the remaining two nozzles. These examinations did not identify any indications.

Based on its review of Duke's responses to NRC Bulletin 2003-02, the NRC staff finds that Duke has met the reporting requirements of the bulletin for Catawba, Unit 2. Accordingly, TAC No. MC0529 is closed for Catawba, Unit 2.

Sincerely,

/RA/

Sean Peters, Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-414

cc: See next page

The bulletin also requested that addressees provide a summary of the RPV lower head penetration inspection that was performed at their plants, the extent of the inspection and the methods used, a description of the as-found condition of the lower head, any findings of relevant indications of through-wall leakage, and a summary of the disposition of any findings of boric acid deposits and any corrective actions taken as a result of indications found.

By letter dated December 16, 2004, Duke provided a summary of its inspection results at Catawba, Unit 2. Duke reported it had performed a bare-metal visual inspection of the RPV lower head, including 360-degrees around 100 percent of the RPV lower head penetrations. Duke did not observe any evidence of RPV lower head penetration leakage or RPV lower head wastage. In addition, Duke performed ultrasonic examinations of all 58 RPV lower head penetrations and eddy current examinations on 56 of the 58 penetrations. Equipment problems prevented inspection of the remaining two nozzles. These examinations did not identify any indications.

Based on its review of Duke's responses to NRC Bulletin 2003-02, the NRC staff finds that Duke has met the reporting requirements of the bulletin for Catawba, Unit 2. Accordingly, TAC No. MC0529 is closed for Catawba, Unit 2.

Sincerely,

/RA/

Sean Peters, Project Manager, Section 1
 Project Directorate II
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket No. 50-414

cc: See next page

Distribution: PUBLIC PDII-1 r/f
 RidsNrrPMSMonarque RidsNrrPMSPeters RidsNrrDlpmLpdii RidsDlpmLpdii1
 RidsNrrDlpmLpdiv2 RidsNrrDlpm ESullivan GCherukenki
 RidsOgcRp RidsRgn2MailCenter RidsAcrcAcnwMailCenter

ADAMS Accession No.: ML051640453

NRR-106

OFFICE	PDII-1/PM	PDII-1/LA	LPM	EMCB	PDII-1/SC
NAME	SPeters	CHawes	SMonarque	ESullivan	EMarinos
DATE	07/12/05	07/12/05	07/12/05	07/13/05	07/19/05

OFFICIAL RECORD COPY

cc:

Mr. Lee Keller, Manager
Regulatory Compliance
Duke Energy Corporation
4800 Concord Road
York, South Carolina 29745

Ms. Lisa F. Vaughn
Duke Energy Corporation
Mail Code - PB05E
422 South Church Street
P.O. Box 1244
Charlotte, North Carolina 28201-1244

Ms. Anne Cottingham, Esquire
Winston and Strawn
1400 L Street, NW
Washington, DC 20005

North Carolina Municipal Power
Agency Number 1
1427 Meadowood Boulevard
P.O. Box 29513
Raleigh, North Carolina 27626

County Manager of York County
York County Courthouse
York, South Carolina 29745

Piedmont Municipal Power Agency
121 Village Drive
Greer, South Carolina 29651

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of Justice
P.O. Box 629
Raleigh, North Carolina 27602

NCEM REP Program Manager
4713 Mail Service Center
Raleigh, North Carolina 27699-4713

North Carolina Electric Membership Corp.
P.O. Box 27306
Raleigh, North Carolina 27611

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
4830 Concord Road
York, South Carolina 29745

Mr. Henry Porter, Assistant Director
Division of Waste Management
Bureau of Land and Waste Management
Dept. of Health and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201-1708

Mr. R.L. Gill, Jr., Manager
Nuclear Regulatory Issues
and Industry Affairs
Duke Energy Corporation
526 South Church Street
Mail Stop EC05P
Charlotte, North Carolina 28202

Saluda River Electric
P.O. Box 929
Laurens, South Carolina 29360

Mr. Peter R. Harden, IV, Vice President
Customer Relations and Sales
Westinghouse Electric Company
6000 Fairview Road
12th Floor
Charlotte, North Carolina 28210

Ms. Mary Olson
Director of the Southeast Office
Nuclear Information and Resource Service
729 Haywood Road, 1-A
P.O. Box 7586
Asheville, North Carolina 28802

cc:

Mr. T. Richard Puryear
Owners Group (NCEMC)
Duke Energy Corporation
4800 Concord Road
York, South Carolina 29745

Mr. Richard M. Fry, Director
Division of Radiation Protection
NC Dept. of Environment, Health,
and Natural Resources
3825 Barrett Drive
Raleigh, North Carolina 27609-7721

Mr. Henry Barron
Group Vice President, Nuclear Generation
and Chief Nuclear Officer
P.O. Box 1006-EC07H
Charlotte, NC 28201-1006

Diane Curran
Harmon, Curran, Spielberg &
Eisenberg, LLP
1726 M Street, NW
Suite 600
Washington, DC 20036