

Official Transcript of Proceedings **ACRST-33/6**

**NUCLEAR REGULATORY COMMISSION**

ORIGINAL

Title: Advisory Committee on Reactor Safeguards  
523rd Meeting

Docket Number: (not applicable)

Location: Rockville, Maryland

Date: Wednesday, June 1, 2005

PROCESS USING ADAMS  
TEMPLATE: ACRS/ACNW-005

**SISP REVIEW COMPLETE**

Work Order No.: NRC-423

Pages 1-358

NEAL R. GROSS AND CO., INC.  
Court Reporters and Transcribers  
1323 Rhode Island Avenue, N.W.  
Washington, D.C. 20005  
(202) 234-4433

TR04

**ACRS OFFICE COPY  
RETAIN FOR THE LIFE OF THE COMMITTEE**

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

June 1, 2005

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on June 1, 2005, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)

+ + + + +

523rd MEETING

+ + + + +

WEDNESDAY

JUNE 1, 2005

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Committee met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B3, 11545 Rockville Pike, at 8:30 a.m., Graham B. Wallis, Chairman, presiding.

MEMBERS PRESENT:

GRAHAM B. WALLIS	Chairman
WILLIAM J. SHACK	Vice Chairman
GEORGE E. APOSTOLAKIS	Member
MARIO V. BONACA	Member
RICHARD S. DENNING	Member
THOMAS S. KRESS	Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

## 1 MEMBERS PRESENT (CONTINUED) :

2 DANA A. POWERS Member  
3 VICTOR H. RANSOM Member  
4 STEPHEN L. ROSEN Member  
5 JOHN D. SIEBER Member-At-Large

## 7 ACRS STAFF PRESENT:

8 JOHN T. LARKINS Executive Director  
9 ASHOK C. THADANI Deputy Executive  
10 Director  
11 RALPH CARUSO  
12 SAM DURAISWAMY  
13 JENNY M. GALLO  
14 CAYATANO SANTOS  
15 MICHAEL L. SCOTT  
16 MICHAEL SNODDERLY

## 18 NRC STAFF PRESENT:

19 MARY DROUIN RES  
20 HOSSEIN HAMZEHEE RES  
21 J. S. HYSLOP RES  
22 JOHN LANE RES  
23 PATRICK LOUDEN Region III  
24 DAVID MATTHEWS NRR  
25 MARTY STUTZKE NRR

## NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



## 1       ALSO PRESENT:

2                   DOUGLAS COOPER               Nuclear Management  
3   Company  
4                   ALAN KOLACZKOWSKI           SAIC, via  
5   teleconference  
6                   GERALDO MARTINEZ           Brookhaven National  
7   Laboratory  
8                   BIJAN NAJAFI                SAIC/EPRI  
9                   STEVEN P. NOWLEN           Sandia National  
10    Laboratory  
11                  JIM SCHWEITZER            Nuclear Management  
12    Company  
13                  BOB YOUNGBLOOD            ISL

14

15

16

17

18

19

20

21

22

23

24

25

## A-G-E-N-D-A

	<u>AGENDA ITEMS</u>	<u>PAGE</u>
1		
2		
3	Opening Remarks, Chairman Graham B. Wallis	5
4	Interim Review of the License Application	
5	for the Point Beach Nuclear Plant,	
6	Units 1 and 2, Member Mario Bonaca	8
7	Mr. David Matthews	11
8	Mr. Douglas Cooper	13
9	Mr. Patrick Loudon	35
10	Draft Commission Paper on Policy Issues	72
11	Related to New Plant Licensing, Member	
12	Thomas S. Kress	
13	Fire Risk Requantification and Probabilistic	
14	Risk Analysis (PRA) Methodology for Nuclear	
15	Power Plants, Member Stephen L. Rosen	173
16	Draft Commission Paper on Proposed Alternatives	
17	to the Existing Single Failure Criterion,	
18	Vice Chairman William J. Shack	257
19		
20		
21		
22		
23		
24		
25		

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P-R-O-C-E-E-D-I-N-G-S

(8:30 a.m.)

CHAIRMAN WALLIS: Good morning. The meeting will now come to order.

This is the first day of the 523rd meeting of the Advisory Committee on Reactor Safeguards. During today's meeting, the Committee will consider the following:

Interim review of the license renewal application for the Point Beach Nuclear Plant, Units 1 and 2, draft Commission paper on policy issues related to new plant licensing, fire risk requantification and probabilistic risk analysis methodology for nuclear power plants, draft Commission paper on proposed alternatives to the existing single-failure criterion, and the preparation of ACRS reports.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act.

Dr. John T. Larkins is the Designated Federal Official for the initial portion of the meeting.

We have received no written comments or requests for time to make oral statements from members

1 of the public regarding today's sessions.

2 A transcript of portions of the meeting is  
3 being kept and it is requested that the speakers use  
4 one of the microphones, identify themselves, and speak  
5 with sufficient clarity and volume so that they can be  
6 readily heard.

7 I will begin with some items of current  
8 interest. John Lamb joined the ACRS staff as a Senior  
9 Staff Engineer on May 16th. John joined the NRC in  
10 June 2000 as a Licensing Project Manager in the Office  
11 of Nuclear Reactor Regulation, Division of Licensing  
12 Project Management.

13 His assignments included being the Lead  
14 Project Manager for Generic Safety Issue 191,  
15 Assessment of Debris Accumulation on Pressurized Water  
16 Reactor Sump Performance and also being the backup  
17 Lead Project Manager for power uprates, both areas of  
18 considerable current interest to the Committee.

19 John just completed a rotational  
20 assignment as a Lead Project Manager for Grid  
21 Reliability in NRR's Division of Engineering.

22 Before joining the NRC, John worked for 15  
23 years for Consolidated Edison Company of New York,  
24 with 12 years at Indian Point Unit 2.

25 He received a bachelor of science degree

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 in mechanical engineering from Villanova University  
2 and a master of science degree from the State  
3 University of New York at Buffalo.

4 This is the last time that Steve Rosen  
5 will join us as a member of the ACRS. Please show  
6 your appreciation of his contributions to the  
7 Committee and of the pleasure we've had in having him  
8 as a colleague over the last four years. Thank you,  
9 Steve.

10 (Applause.)

11 CHAIRMAN WALLIS: I should have also asked  
12 you to welcome John Lamb in the same sort of way.

13 (Applause.)

14 CHAIRMAN WALLIS: There are several SRMs  
15 in the items of interest which has been handed out for  
16 you today. This room got very crowded yesterday when  
17 we were discussing Point Beach. And the meeting in  
18 here is being piped next door. If anyone is feeling  
19 overcrowded here, you can step next door and see what  
20 is going on.

21 It's also being transmitted over Channel  
22 48 in White Flint 1 and 2. So members please note  
23 that you will be on television today. So act  
24 accordingly.

25 (Laughter.)

1 CHAIRMAN WALLIS: Without more ado, I'd  
2 like to move on with the real business. And I'd  
3 invite Dr. Bonaca to lead us through the first item.

4 MEMBER BONACA: Yes, good morning.

5 Yesterday we met as a Subcommittee on  
6 License Renewal to review the application and SER,  
7 interim SER with open items for Point Beach. We  
8 reviewed the SER as we normally do. We noted a number  
9 of open items. We also noted that there are some  
10 scoping issues still to be fully resolved which is  
11 only telling us that maybe the SER could have been  
12 held back for a month or two and probably all of these  
13 issues would have been dealt with.

14 There was not anything noticeable about  
15 this application, you know, different from the others.  
16 The main difference is for the first time we saw a  
17 vessel for Unit 2 that would not be able to meet the  
18 screening criteria for PTS at the end of 20 years of  
19 extended life.

20 And the licensee has opted to choose an  
21 approach where they will manage fluence which will  
22 allow them to go not much more than eight years into  
23 license renewal. By that time they'll have some  
24 options that they can choose to reach 20 years of  
25 extended life.

1                   This is an accepted approach by the NRC.  
2                   We had no specific comment at this stage regarding  
3                   this issue.

4                   The reason for bringing this application  
5                   to the full Committee at this stage is tied to the  
6                   current performance of Point Beach. As you know,  
7                   Point Beach is now in the column 4 of the ROP Action  
8                   Matrix with an open Confirmatory Action Letter that  
9                   identifies several weaknesses of significance in  
10                  current performance.

11                  Now this Committee has consistently been  
12                  supportive of the rule. And the rule does not take  
13                  into consideration current performance. We don't  
14                  intend to change that rule at this stage. I mean we  
15                  don't have a recommendation to do that. We will  
16                  recognize the current performance is not a condition  
17                  of the rule.

18                  We're only concerned about those aspects  
19                  of current performance that may effect one, the proper  
20                  establishment of commitments of the rule, okay. Take,  
21                  for example in this case, human performance. I mean  
22                  human performance is one of the crosscutting issues  
23                  identified that gives us some concern regarding, you  
24                  know, the extent to which inspections done by the NRC  
25                  gives the confidence that these commitments have been

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 properly implemented.

2 The other concern, of course, is with  
3 Corrective Action Program. Corrective Action Program  
4 is the foundation to license renewal. Every program  
5 of license renewal runs through Correct Action Program  
6 either to identify the aging mechanism that you have  
7 to deal with or aging effect and also to correct it.  
8 So, therefore, it's really the cornerstone of license  
9 renewal.

10 And this plant, the first plant will go  
11 into license renewal in five years. So we may  
12 certainly hope that the Corrective Action Program will  
13 be improved by that time. But certainly it would have  
14 been nicer to see it already improved. And so we  
15 wanted to hear from the staff yesterday about, you  
16 know, where did they stand right now with this  
17 program.

18 Again, we're not trying to make them part  
19 of license renewal. But to get the confidence that  
20 these elements which are so important to licensee  
21 renewal will be effective and will be effectively  
22 implemented.

23 With that, we received a presentation from  
24 Region III which was quite effective. So we asked  
25 Region III to come back today and give the whole

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 Committee an overview of those issues we discussed  
2 yesterday. And that's what will happen.

3 Before that, however, we have a brief  
4 presentation from Mr. Cooper of Nuclear Management  
5 Company that manages a number of these units and that  
6 will take probably about ten minutes.

7 And before that, I believe Mr. Matthews of  
8 NRR is going to make some statements, too. So I will  
9 turn the meeting to Mr. Matthews.

10 And then we'll have the other people on  
11 the agenda.

12 MR. MATTHEWS: Thank you, Dr. Bonaca.

13 I'm David Matthews. I'm the Director of  
14 the Regulatory Improvement Programs in the Office of  
15 Nuclear Reactor Regulation. One of those programs is  
16 the license renewal program in addition to the  
17 rulemaking and advance reactor activities that NRR has  
18 responsibility over.

19 These will be very brief remarks. I just  
20 want to acknowledge and thank you for your  
21 consideration of the distinction that does exist in  
22 the regulations with regard to aging management  
23 programs, time-limited aging analysis as being the  
24 principle focus of license renewal.

25 I do understand the statement and the

1 concern with regard to -- I guess I'd put it in the  
2 category of possible anxiety prompted by the  
3 Corrective Action Program deficiencies that have been  
4 identified. And their relationship to any of a number  
5 of programs as we continue forward also into the  
6 period of extended operation.

7 So I mean we have an immediate concern  
8 over the next five to ten years relative to continued  
9 operation of the two units. And we see how those same  
10 concerns would be an issue that the Committee would  
11 want to be reassured on.

12 But as you understand, the licensing  
13 review of aging management, time-limited aging  
14 analysis is the focus of license renewal. And that's  
15 the basis upon which the SER is written.

16 To the extent that the Committee at some  
17 juncture, you know, is going to propose or suggest  
18 based on your collegial view that maybe there be a  
19 consideration with regard to operating programs, that  
20 would constitute the need for a rule change. And we'd  
21 have to, you know, you raise it and we'd have to  
22 address it in front of the Commission.

23 So I think with that, I'll conclude any  
24 comments with regard to what I view the separation of  
25 license renewal and operating history. And I'm

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 pleased that the staff was able to provide some  
2 reassurance for you yesterday. And we're prepared to  
3 address those issues again today for the benefit of  
4 the full Committee.

5 And with that, I think I'd like to turn it  
6 over, I think, to Mr. Cooper.

7 MEMBER BONACA: That's right. Thank you.

8 MR. COOPER: Good morning. Now where do  
9 you prefer me to be at?

10 MEMBER BONACA: Any location at the table.  
11 And please speak in the microphone.

12 MR. COOPER: Yes, sir.

13 First of all, thank you for allowing me to  
14 make a few brief comments. My name is Douglas Cooper.  
15 I'm a Senior Vice President of Group Operations for  
16 Nuclear Management Company. I'm responsible for Point  
17 Beach, Palisades, and Kewanee Nuclear Plants.

18 Yesterday afternoon when I spoke to the  
19 Chairman, he asked me to talk about performance at  
20 Point Beach, specifically relative to where  
21 performance is. And to talk about Corrective Action  
22 Programs and human performance. And I think that's  
23 appropriate.

24 I remember a report issued by the IAEA on  
25 safety culture. And in that report, they say

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 something to the effect of except for what can  
2 legitimately be characterized as acts of God,  
3 performance at all nuclear power plants originate in  
4 some form of human error or human performance. And we  
5 subscribe to that. And that's what our improvement  
6 program is based upon.

7 So today what I'll talk about very  
8 briefly, what have we done specifically to improve  
9 performance and Point Beach? And if we have made  
10 progress. And why do I feel confident that  
11 performance will continue to improve?

12 I was assigned at Point Beach -- or I  
13 picked that up as one of my plants in the fall of  
14 1994. And that was just when the 950003 Inspection  
15 was becoming final. And I don't need to go into these  
16 in great detail. But in that report, it categorized  
17 our findings in terms of five broad areas where we  
18 needed to improve.

19 Point Beach had an Excellence Plan in  
20 place but what that inspection, in addition to some of  
21 our own internal evaluations which were ongoing, told  
22 us was that we needed to do more. And so we took that  
23 Excellence Plan and we actually overhauled it. We did  
24 much more than enhance it.

25 First of all, it needed to be resource-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 loaded. It needed to include more routine monitoring  
2 and updating as things changed. And I'll tell you  
3 based upon our assessments, there were four broad  
4 objectives that had to occur -- or actually three  
5 broad objectives that had to occur. And I'll show you  
6 how those lay out later.

7 But first of all, we had to ensure that we  
8 had the right team in place. So the first task was to  
9 select and retain the right people.

10 The next thing was to communicate what  
11 performance looked like. What was the right picture  
12 of performance? And then we had to put the items in  
13 place to routinely enforce that picture of  
14 performance.

15 And then thirdly, we had to routine --  
16 continuously monitor and verify the effectiveness of  
17 the programs that were in place.

18 Now I'll speak to corrective action. What  
19 I will tell you was the Corrective Action Program was  
20 not the problem. The thing that we had to address was  
21 individual behaviors and how we utilize the Corrective  
22 Action Program.

23 What we have here is what we call the  
24 Picture of Excellence. And this is a structure which  
25 has been put in place and, I believe, ingrained at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Point Beach to allow us to monitor performance and to  
2 enforce this picture.

3 What this tells us, we use it to  
4 communicate first of all what are the right behaviors.  
5 What does it look like when individuals are performing  
6 the way we expect? That's one thing that is  
7 incorporated in here.

8 Secondly, it includes routine performance  
9 indicators. What does it look like in objective terms  
10 when it is done correctly? If you look at the top,  
11 what we call the pillars, which is there on up, we  
12 have attributes and behaviors, and we've done training  
13 for every person on site. There are specific  
14 performance indicators. For instance, under  
15 Organizational Excellence, there are specific  
16 performance indicators for the Corrective Action  
17 Program. What do they look like?

18 MEMBER POWERS: Can I ask you a question?

19 MR. COOPER: Yes, sir.

20 MEMBER POWERS: Everything has got  
21 "excellent" up here. What would be missing if it was  
22 pretty darned good instead of excellent? What takes  
23 you from pretty good to excellent in this list of  
24 things here?

25 MR. COOPER: As far as behaviors, I would

1 tell you nothing. From pretty good to excellent would  
2 be there are specific measures of performance in all  
3 of these. So it is a matter of how high the bar. So  
4 we have the right performance indicators. But it's  
5 what --

6 MEMBER POWERS: Well, I have to have  
7 something quantitative in order to understand what  
8 excellence is here.

9 MR. COOPER: Excellence is in terms of our  
10 performance as measured against our peers.

11 MEMBER APOSTOLAKIS: Are you going to show  
12 us some of the performance indicators?

13 MR. COOPER: No. Based upon the ten -- I  
14 could do that at a later date. But I have ten  
15 minutes. And so I didn't bring the specific  
16 performance indicators.

17 MEMBER APOSTOLAKIS: I'd like to see  
18 those. Who is the engineer? Okay. Thank you.

19 MR. COOPER: Yes.

20 So we have organizational. These  
21 performance indicators are measured at the  
22 organizational level. Also embodied in these  
23 performance indicators we look at are the CAL  
24 indicators. And for the CAL, we have specific  
25 measures of performance which in large part are taken

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 from the performance indicators we already had in  
2 place. And we routinely monitor those.

3 If you go over under Equipment Excellence,  
4 there are things such as corrective maintenance  
5 backlogs, elective maintenance backlog. We have  
6 specific measures of equipment performance that feed  
7 directly -- if done well, they feed directly into the  
8 NRC performance indicators. So they're graduated and  
9 one supports the other.

10 CHAIRMAN WALLIS: Do you have many  
11 measures of improvement in performance over the last  
12 oh, whatever you want to say -- years, months, or  
13 something? Presumably there are measures of these  
14 things. Is there a trend that you could tell us  
15 about?

16 MR. COOPER: Yes. Overall, we have seen  
17 improvement in most trends. Some of the -- I can give  
18 you some specific examples. Corrective maintenance,  
19 Jim, I need your help. When we started a year ago at  
20 the beginning -- or at the beginning of '94, our  
21 corrective maintenance backlog was in the neighborhood  
22 of over 100.

23 MR. SCHWEITZER: Correct.

24 MR. COOPER: But we're currently at about  
25 13 for both units. Elective maintenance was at the



1 tune of over 500 if I --

2 MR. SCHWEITZER: Close to 600.

3 MR. COOPER: -- 600 and now we're in the  
4 neighborhood of 250.

5 MR. SCHWEITZER: Under 250.

6 MR. COOPER: Under 250.

7 MEMBER SIEBER: And how did you do that?  
8 Add more staff? Work overtime? Or eliminate --

9 MR. COOPER: We did not add more staff.

10 MEMBER SIEBER: -- eliminate items from  
11 your list.

12 MR. COOPER: We did not eliminate items.  
13 What we actually did was it was a combination of a  
14 number of things. First of all, we set out specific  
15 performance standards for the staff. One thing that  
16 we will talk about specifically, we worked very hard  
17 on communicating what the right level of performance  
18 is, down to the individual.

19 We communicate and provide feedback to the  
20 individual level and groups. But five days a week at  
21 noon every day, we provide in general -- specifically  
22 how the organization performed in our six elements of  
23 individual excellence. And then routinely we provide  
24 -- so we provided a clear picture of right looks like.  
25 We monitored how we were doing. And we fed back to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the individuals.

2 We did add -- we worked additional  
3 overtime to at least get the backlog -- trimmed it  
4 down. But right now we maintain that backlog with, by  
5 and large, no overtime.

6 So it really goes back to -- what I would  
7 say one thing that is different is we focus  
8 performance at the individual level. We've  
9 communicated how individual performance feeds  
10 organizational performance and excellence above.

11 You might ask why do we talk about  
12 excellence as opposed to just getting it good. What  
13 we found, based on industry experience, is if you set  
14 the bar at just get me good enough, that's where the  
15 staff starts relaxing. You have to go toward  
16 excellence, understanding -- and we understood that  
17 the first thing we had to do was transition through  
18 good enough.

19 MEMBER BONACA: How is, you know, you  
20 correctly said before that human performance is the  
21 key to everything. You can lay down a program and the  
22 program has all the elements. But then humans are the  
23 people.

24 MR. COOPER: Right.

25 MEMBER BONACA: Now this is an old site.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 And I'm sure you have a lot of old-timers there.

2 MR. COOPER: Yes.

3 MEMBER BONACA: Are they accepting the  
4 changes you are making in procedures? In more  
5 detailed prescriptive ways to do business? Or do you  
6 find there is a problem there?

7 MR. COOPER: I would say they are  
8 responding. And across the site, there are different  
9 levels of -- I will say -- you know we get response  
10 from almost everyone. As far as buy-in, it's varying.

11 But what I can tell you is I'll talk about  
12 one specific element on how we're taking performance  
13 to the individual level. Every day every work group  
14 stands down at lunchtime. And we talk about how did  
15 the organization perform on these critical elements  
16 relative to industrial safety, in terms of  
17 radiological dose performance, in terms of nuclear  
18 events, basically errors.

19 We talk about how do we meet commitments  
20 relative not just to meeting the schedule but what we  
21 told others we would do. And what did we tell each  
22 other we would do. So we -- and then we talk about  
23 training and rework. What resulted in rework?

24 MEMBER POWERS: Can I ask you a question?

25 MR. COOPER: Yes, sir.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: You said you do this every  
2 day at noon. You stand down all the workers. That  
3 means there's nobody in the Control Room operating the  
4 plant?

5 MR. COOPER: They're in the Control Room.  
6 Yes, sir. What we do is the Control Room is in place  
7 but they review these parameters during generally over  
8 their turnovers. Jim, that's correct at the beginning  
9 of the staff?

10 MR. SCHWEITZER: That's right. They would  
11 review them during each turnover. They do not have a  
12 specific stand down during the day where they stop  
13 monitoring.

14 MEMBER POWERS: So every worker doesn't  
15 stand down at noon is what you're saying?

16 MR. COOPER: That's correct. That's a  
17 good question. I should have been a lot clearer on  
18 that.

19 But part of that discussion is how did we  
20 do and what do we need to do over the next 24 hours to  
21 ensure that the thumbs are all up? We measure it in  
22 terms of thumbs up or thumbs down. We try to keep it  
23 as easy as we can so it is a very real conversation,  
24 supervisor to individual.

25 Now what I will tell you, back to your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 point, Mr. Chairman, I've sat in a number of these.  
2 Some of the conversations are very good. Others are  
3 toward the minimum. But there is -- in every one,  
4 there is a dialogue on what is our performance and  
5 what do we need to do to go forward.

6 That is what has produced a lot of  
7 progress, specifically if you talk about human error  
8 performance. When we started this picture rollout at  
9 the beginning of '94, I don't remember exactly what we  
10 were between site resets but it was 30 days or less.  
11 Our current average is over 121 days between clock  
12 resets.

13 MEMBER APOSTOLAKIS: I'm a little confused  
14 now. Dr. Bonaca said earlier -- I'm sorry I missed  
15 the supplemental meeting, Dr. Bonaca said that the  
16 plant is now in the fourth column of the action  
17 matrix.

18 MR. COOPER: That is correct.

19 MEMBER APOSTOLAKIS: How can that be after  
20 all this excellence being implemented since 1994?

21 MR. COOPER: Because it takes time. First  
22 of all, and I certainly would, if there is anyone from  
23 the NRC that would like to talk about the regulatory  
24 oversight process, it takes a while to get off. You  
25 don't get off of it from one day to the next.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER APOSTOLAKIS: Off what?

2 MR. COOPER: Off from Column 4 into Column  
3 1.

4 MEMBER APOSTOLAKIS: But how did you ever  
5 get into Column 4? I mean with all this stuff since  
6 1994.

7 MR. COOPER: This was not in place prior  
8 to going to Column 4. This is new since the beginning  
9 of 2004.

10 MEMBER APOSTOLAKIS: Oh, 2004.

11 MR. COOPER: Yes.

12 MEMBER APOSTOLAKIS: I thought you said  
13 1994.

14 MR. COOPER: If I said that, I misspoke.

15 MEMBER APOSTOLAKIS: Oh 2004. Okay.

16 MR. COOPER: 2004. Oh, no. This is what  
17 we've done to improve and to sustain.

18 MEMBER APOSTOLAKIS: All right.

19 MR. COOPER: If I said 1994, I --

20 MEMBER APOSTOLAKIS: That's what I heard.

21 MR. COOPER: So I know the time is  
22 limited. I'll stay here as long as you'd like me to  
23 stay. But what I would say is this structure provides  
24 first of all what are clear expectations in terms of  
25 behavior. What are clear expectations in terms of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 objective measures of performance?

2 And then routine monitoring of the  
3 Excellence Plan. At least monthly, the senior staff  
4 sits down and discusses what do we need to focus on,  
5 what do we need to change, what do we need to do  
6 differently.

7 Next slide. The next thing that was done  
8 between the -- as we enhanced the Excellence Plan, we  
9 -- candidly we had a plan that was probably that  
10 thick. It was thick. And it was beyond the  
11 comprehension of the general worker to say what am I  
12 doing? How does it contribute to achieving success?

13 So part of this Excellence Plan we  
14 established "Six for Success" and we looked out over  
15 the next 18 months. And we said these are critical  
16 things -- now there's other things -- but what are six  
17 things that the workforce can relate to that they know  
18 we have to be successful in?

19 And then we looked at the Excellence Plan  
20 and said what things have to be in place to support  
21 that? And we began with dry fuel storage in the fall  
22 of 2004, the spring refueling outage, of clearly  
23 meeting our commitments to the Confirmatory Action  
24 Letter, the fall outage, we have an operations  
25 training accreditation at the beginning of 2006, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 then the INPO evaluation in 2006.

2 So we keep this before the workforce. We  
3 talk about daily performance. And is what we're doing  
4 today meeting -- contributing to success? Now what I  
5 can tell you is dry fuel storage was completed the  
6 last part of November of 2005. And it was error free.  
7 It was on schedule. And it was quite successful.

8 MEMBER KRESS: Is your spent fuel pool  
9 filled up?

10 MR. COOPER: It's -- Jim? It's not  
11 totally full.

12 MR. SCHWEITZER: No. We have enough room  
13 in the spent fuel pool to allow for a full core  
14 offload. And we have a campaign to continue to load  
15 casks as necessary.

16 PARTICIPANT: You need to use a  
17 microphone.

18 MR. SCHWEITZER: We have enough room in  
19 our spent fuel pool right now for a full core offload  
20 and we have a continuing campaign to continue to load  
21 casks to maintain that.

22 MR. COOPER: So what I've attempted to do  
23 is to lay out what we put in place to improve  
24 performance and what we have in place to sustain  
25 performance.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 The other things I would -- yes, sir?

2 MEMBER KRESS: What is the goal less than  
3 one -- is that half of a radiological event? Or a  
4 fraction of a radiological event?

5 MR. COOPER: None.

6 MEMBER KRESS: That should be none?

7 MR. COOPER: That's correct.

8 MEMBER KRESS: It just seems strange to  
9 put a goal like that -- less than one.

10 MR. COOPER: Yes, I'll take that coaching.  
11 Thanks a lot.

12 CHAIRMAN WALLIS: That's just to give you  
13 something to ask about.

14 MEMBER KRESS: Oh, I see, I see.

15 (Laughter.)

16 MEMBER KRESS: That's what that was for.

17 MR. COOPER: So we talked about what we  
18 have in place. I'd like to -- in case I missed the  
19 point, the first thing we knew we had to do for this  
20 Excellence Plan we had to select and retain the right  
21 people. I will tell you from -- I came on board in  
22 the fall of 2004.

23 Between then and now, of approximately 23  
24 to 24 senior management positions, 70 to 75 percent of  
25 those people are new in position. And that is a mix

1 of bringing in outside folks from outside the NRC  
2 fleet, moving some people from within the fleet to  
3 Point Beach, and then selecting and moving people from  
4 within Point Beach to different jobs. Jim Schweitzer  
5 is an example of a Point Beach person that was moved  
6 into a new position.

7 And we're continuing to evaluate do we  
8 have the right people in position. For instance,  
9 we're going down through the supervisor level. We're  
10 evaluating every person on site for do we have the  
11 right basic skill set to continue improvement and  
12 providing the help or moving if appropriate.

13 The next thing was to communicate and  
14 enforce the right picture. And then thirdly was to  
15 verify that we have the right implementation of the  
16 right processes in place. And then engaging the  
17 workforce.

18 Now let's talk about basically what we've  
19 seen as results. These are the outage goals. And  
20 what we've seen to date relative to outage  
21 performance. And what I can tell you, the change  
22 between last spring's outage and this spring's outage  
23 -- we still have a ways to go but it is remarkable,  
24 particularly -- or, it's good in terms of what we've  
25 done in human performance. And human performance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 actually drives the actual results we've actually  
2 seen.

3 The results to date, I don't need to read  
4 them all to you. I would highlight a couple. We had  
5 our emergency preparedness exercise, which was  
6 conducted in December of 2004. That was clearly  
7 communicated to us from the NRC that we had to be  
8 successful in that venture and we were.

9 Human performance, we talked about the  
10 clock resets are currently -- we're at 121 days. It's  
11 an average between site clock resets. That's a  
12 significant improvement.

13 In the Confirmatory Action Letter, and  
14 this has been an issue that we worked hard on, there  
15 are 143 separate tasks that have to be accomplished to  
16 fulfil the CAL. We're currently at 134 and on track.  
17 We have met 60 of the 65 performance measures. That's  
18 how effective are the actions. And we're on track  
19 with the remaining five. And you can read the rest.

20 The last board I would say is not only do  
21 we just look at performance indicators, but we  
22 routinely assess our own performance and utilize the  
23 performance of outside agencies and organizations to  
24 improve our performance. And all of the outside looks  
25 have shown progress.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER SIEBER: When do you expect to  
2 complete all of the items and meet all of the  
3 parameters in your Confirmatory Action Letter?

4 MR. COOPER: By the end of this year.  
5 We're on track to have most of them done by June of  
6 this year. A couple of them have been -- the  
7 calculation reviews, we have extended into 2006. But  
8 other than that --

9 MEMBER SIEBER: These are engineering  
10 calculations?

11 MR. COOPER: That's correct.

12 MEMBER SIEBER: Okay. Who is doing that?  
13 Your engineers? Or have you hired somebody?

14 MR. COOPER: We're actually utilizing an  
15 outside vendor with oversight from our own engineers.  
16 We're accountability for performance but the bulk of  
17 the work is being done by an outside vendor.

18 MEMBER SIEBER: Have you captured most of  
19 the or all of the engineering records that pertain to  
20 the design and construction of your plant?

21 MR. COOPER: I believe yes but I'm going  
22 to ask Jim Schweitzer who is our Engineering Director  
23 to answer that question.

24 MR. SCHWEITZER: This is Jim Schweitzer  
25 from Point Beach. The question was have we captured

1 all of our design information. For the calculations,  
2 we have gone back and reviewed and we pulled all of  
3 our safety-related and calculations that support  
4 safety-related calcs. There were about 1,400. And we  
5 have done a complete review of those and identified  
6 everything that we need to revise.

7 We also have DBDs, design-basis documents,  
8 in place. And we are going through another review at  
9 this time to do a validation of those. And we're  
10 going through them based on risk significance. We've  
11 completed aux feedwater, which is the most risk-  
12 significant. We're just in the process of completing  
13 service water and fire protection. And then we'll  
14 continue on through the rest of them.

15 MEMBER SIEBER: One final question. When  
16 you did this review, particularly of calcs, did you  
17 find any errors?

18 MR. COOPER: Jim?

19 MR. SCHWEITZER: Yes, we did find some  
20 errors. And all of those errors as we found them  
21 would be entered into our Corrective Action Program  
22 and there were a number of them that we had to  
23 operability determinations on to demonstrate that even  
24 with the error in the calc, that the equipment would  
25 be able to perform its function.

1 And we may still be in some of that  
2 discovery as we step through and do the detailed  
3 revisions. There are about 200 calculations that  
4 we're doing a revision to or either incorporating  
5 other calcs into it and redoing the calc completely.

6 MR. COOPER: And we do have the right  
7 administrative controls in place so that we don't go  
8 and use an unvalidated calc. Correct Jim?

9 MR. SCHWEITZER: That's right. For all  
10 the calcs that have any type of problem, they are on  
11 administrative hold so that if someone picks them up,  
12 we can tell them what the problem is and we'll figure  
13 out how we will address it. But all the calcs with  
14 any issues are on administrative hold.

15 MEMBER ROSEN: You said you had design-  
16 basis documents in place?

17 MR. SCHWEITZER: Yes, we do have design-  
18 basis --

19 MEMBER ROSEN: Does that mean that they're  
20 new or that they were in existence and have been  
21 revised? Which?

22 MR. SCHWEITZER: Design-basis documents  
23 were generated in the 1980s. We have done one  
24 revision to them. And we're doing another -- just  
25 another validation at this time, again to go back and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 look and make sure that we've incorporated all the  
2 latest design items. And also trying to streamline  
3 them to be a little bit more user friendly than they  
4 have been in the past.

5 MEMBER BONACA: To what extent does this  
6 review effect the license renewal team? I mean are  
7 they aware of the changes, the modifications, some of  
8 the errors found? I'm trying to understand what  
9 linkage there is there.

10 MR. SCHWEITZER: Anything that we would  
11 find -- like I said we go through our Corrective  
12 Action Process, that would be -- I think the license  
13 renewal group does take a look at most of the items  
14 that hit into the Correction Action Process. And  
15 we're linked fairly closely also. So they would be  
16 aware of any significant errors or issues that we  
17 would come across.

18 MR. COOPER: It's the expectation as  
19 anything is entered into the Corrective Action  
20 Program, we evaluate for extent of condition and  
21 impact on current operations and future. That's an  
22 expectation.

23 MEMBER BONACA: Okay.

24 MR. COOPER: Last slide. These are the  
25 comments that we've taken from the public meetings

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 with the NRC and the most recent Agency Action Review  
2 Meeting. I would summarize these by saying progress  
3 has been noted in all five areas. We do have some  
4 challenges in the area of the calculation project  
5 because of the volume of that. And it's going to take  
6 careful project management but we are accountable and  
7 committed to make sure we're successful on that.

8 But there has been progress noted both  
9 from outside evaluators and including the NRC in most  
10 recent public meetings.

11 So that's the extent of my comments. And  
12 thank you for the opportunity.

13 MEMBER BONACA: I thank you for the  
14 presentation.

15 I wonder are there questions from the  
16 Members? If not, we can move to the Region's  
17 presentation. I thank you again.

18 MEMBER SIEBER: I think if they are  
19 successful with this, that will be a pretty major  
20 achievement. It's one of the situations where if  
21 you're not successful or you fail or don't finish,  
22 you're probably in as much trouble as you were in had  
23 you not even started.

24 MR. COOPER: Well, I agree with you.  
25 There are a number of sources that tell you once you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 get religion and start going towards it, if you fall  
2 back, you're worse than had you never started.

3 MEMBER SIEBER: That's right. That's  
4 right.

5 MR. COOPER: And I will tell you it's my  
6 job to make sure we don't fall back. And there's a  
7 team of managers that every day are making sure we  
8 don't fall back.

9 MEMBER SIEBER: All right. Thank you.

10 MR. COOPER: Yes, sir. Thank you.

11 MR. LOUDEN: Good morning everyone. My  
12 name is Pat Louden. I'm a Branch Chief in the  
13 Division of Reactor Projects in the Region III Office  
14 in Lisle, Illinois. I'm the Branch Chief for the  
15 region that oversees the inspection activities at  
16 Point Beach.

17 And my presentation today is to provide an  
18 overview, a short background of the red findings and  
19 the placement of Point Beach into Column 4 of the  
20 Action Matrix. And I'll also go over activities that  
21 we've conducted in the region as far as inspection  
22 activities. And also with what the assessment results  
23 have been, particularly I will address the two  
24 specific areas of human performance and the Corrective  
25 Action Program.

1 MEMBER BONACA: Great.

2 MR. LOUDEN: Okay. Next slide. During a  
3 PRA upgrade in 2001, the licensee identified a  
4 potential common mode failure mechanism for the aux  
5 feedwater system during certain transients. This  
6 issue was identified by their PRA staff and was  
7 communicated to the NRC.

8 We responded by conducting a special  
9 inspection which reviewed the circumstances  
10 surrounding the issues associated with the aux  
11 feedwater system.

12 The particular item involved the minimum  
13 recirculation valve, an air-operated valve that would  
14 fail close. And the particular transients that we  
15 were concerned with were those with the loss of  
16 instrument error combined with the need for operators  
17 to throttle back on feeding the steam generators and,  
18 therefore, being more dependent on recirc flow.

19 MEMBER APOSTOLAKIS: How did the PRA team  
20 find this? I mean they were doing the PRA and they  
21 asked questions?

22 MR. LOUDEN: That was a licensee effort.  
23 And I think they would best answer what their team was  
24 doing and how they identified that problem. It was  
25 licensee identified.

1 MEMBER APOSTOLAKIS: Okay.

2 MR. SCHWEITZER: Jim Schweitzer from Point  
3 Beach. What we were doing was a PRA update. And what  
4 it was was including operator actions, operator-  
5 critical actions. So it was looking at the timed  
6 actions.

7 And because the aux feedwater one, we were  
8 relying on the fact that the operators would have to  
9 take actions to assure that we maintained minimum flow  
10 through the aux feedwater pump, it came up high on the  
11 risk assessment. So it was an upgrade, adding actual  
12 operator actions.

13 MEMBER APOSTOLAKIS: And how did you find  
14 the problem? I mean, you know, usually people add the  
15 operator actions and they give a number and everybody  
16 is happy. But you went beyond that. So that's where  
17 I'm missing something.

18 MR. SCHWEITZER: It did go a little  
19 beyond. It went to start looking at what were the  
20 critical actions and how -- and if they were not  
21 performed correctly, what would be the problem. What  
22 we really identified here is that some of these  
23 actions were not procedurally driven so that changed  
24 the factor that was applied for it.

25 MEMBER APOSTOLAKIS: Oh, okay. Okay. So

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 it was not just a matter of probabilities? They had  
2 to take initiatives and do things that were not in the  
3 procedures.

4 MR. SCHWEITZER: That's right. It was  
5 evaluating the probability of performing the correct  
6 human performance action.

7 MEMBER APOSTOLAKIS: Okay.

8 MR. SCHWEITZER: And there's different  
9 levels based on whether it's proceduralized, whether  
10 it's trained, whether --

11 MEMBER APOSTOLAKIS: And you decided to  
12 change the procedures?

13 MR. SCHWEITZER: We did change the  
14 procedures after that, correct.

15 MEMBER APOSTOLAKIS: And that's why you  
16 informed the NRC?

17 MR. SCHWEITZER: Well, we informed the NRC  
18 at the time because we identified that it was a  
19 significant issue associated with the PRA.

20 MEMBER APOSTOLAKIS: See, that's what I  
21 don't understand. What is it that makes it a  
22 significant issue?

23 MR. SCHWEITZER: The calculated core  
24 damage frequency was high enough to put us in --

25 MEMBER APOSTOLAKIS: How high was it?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. SCHWEITZER: I don't remember the  
2 exact number.

3 MEMBER APOSTOLAKIS: Was it ten to the  
4 minus three?

5 MEMBER BONACA: Well, let me just say  
6 that, you know, this -- by throttling back, I mean  
7 there was an issue with the loss of air. And that  
8 effected the auxiliary feedwater system.

9 I understand it effected to PORVs,  
10 therefore effecting the possibility of bleed and feed.  
11 So there was a cascading effect in many parts. I  
12 don't know what the results of the CDF would be.

13 MEMBER APOSTOLAKIS: But my question,  
14 Mario, is at which point did the licensee decide wait,  
15 this is important. We'd better let the regulators  
16 know about it.

17 MEMBER BONACA: Well, I think internally,  
18 they discussed it for about a month.

19 MEMBER APOSTOLAKIS: And why?

20 MEMBER BONACA: Because when you have an  
21 operator action to throttle and the question is will  
22 he throttle correctly, will he succeed, not succeed --

23 MEMBER APOSTOLAKIS: This is not unusual.  
24 I mean I've seen many --

25 MEMBER BONACA: Of course it's not

1 unusual.

2 MEMBER APOSTOLAKIS: -- in a lot of PRAs  
3 they have that problem.

4 MEMBER BONACA: The reason why I think  
5 also it is important to put it in perspective, I think  
6 this issue -- there were many opportunities to  
7 identify it since 1981.

8 MEMBER APOSTOLAKIS: I understand.

9 MEMBER BONACA: There were bulletins of  
10 the NRC specifically addressing the issue of air --

11 MR. LOUDEN: That's correct. Our  
12 inspection that we conducted --

13 MEMBER BONACA: -- requesting the  
14 licensees to review, in fact, the possibilities that  
15 these kinds of things would happen. And that's why,  
16 I believe, the NRC found that this was a severe event  
17 because the opportunities had been there for a long  
18 time.

19 MEMBER APOSTOLAKIS: Is that the event  
20 that put you in the fourth column?

21 MR. LOUDEN: It's one of those.

22 MEMBER APOSTOLAKIS: And would someone  
23 remind us what the fourth column is? I mean we keep  
24 referring to it as the fourth column.

25 MEMBER SIEBER: Multiple degraded

1 cornerstones.

2 MEMBER APOSTOLAKIS: Degraded  
3 cornerstones.

4 MEMBER BONACA: Multiple degraded  
5 cornerstones.

6 MEMBER SIEBER: Multiple degraded  
7 cornerstones.

8 MEMBER APOSTOLAKIS: So which cornerstone  
9 was degraded here?

10 MR. LOUDEN: Well, I mean mitigating  
11 systems would have been --

12 MEMBER SIEBER: A mitigating system is a  
13 big one.

14 MEMBER APOSTOLAKIS: Mitigating system.

15 MR. LOUDEN: The aux feedwater.

16 MEMBER SIEBER: And you had an emergency  
17 plan cornerstone in there, too, someplace.

18 MR. LOUDEN: The particular item -- this  
19 issue it came out red because to qualify to get into  
20 Column 4, you can have multiple or repetitive degraded  
21 cornerstones from various cornerstones or you can have  
22 one red finding.

23 MEMBER SIEBER: Yes.

24 MR. LOUDEN: And the one red finding  
25 category under aux feedwater is what placed the plant

1 in Column 4 on the Action Matrix.

2 MEMBER BONACA: I think for the benefit of  
3 the membership also, later on they made modifications  
4 to the orifices in the auxiliary feedwater system and  
5 the NRC had an inspection and found problems with  
6 that. So there was a compounding effect of inadequate  
7 corrective actions because the issue wasn't solved.  
8 And you had no auxiliary feedwater --

9 MEMBER APOSTOLAKIS: But the core damage  
10 frequency itself did not play any role in this, did  
11 it?

12 MEMBER BONACA: Well, I mean I'm sure that  
13 the number they calculated must have been pretty high.

14 MEMBER APOSTOLAKIS: But that's not why  
15 they put them in the fourth column. It was the  
16 systems.

17 MEMBER BONACA: Well, I would expect a  
18 significant determination would be --

19 MEMBER APOSTOLAKIS: Is that -- the CDF  
20 took you to the red?

21 MR. LOUDEN: Part of what we did during  
22 our process -- evaluating in the significance  
23 determination process is that we went into the various  
24 phases, Phase 2 and Phase 3 of the PRA analyses to see  
25 where the CDF placed this relative to color. And I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 don't have the exact number myself but I do know that  
2 it was above the criteria that would qualify for a  
3 red.

4 MEMBER BONACA: My understanding is that  
5 also the aux feed was effected, the main feed was  
6 effected. Bleed and feed was effected. So you can  
7 draw your conclusions.

8 MEMBER SIEBER: Yes. And even without the  
9 PRA, a system review, which a lot of licensees do,  
10 system by system, would determine that the aux feed  
11 pumps were inoperable which is an action statement  
12 right away under loss of instrument error conditions.

13 MEMBER BONACA: Yes.

14 MEMBER SIEBER: So if you didn't have PRA,  
15 you would still have that issue that you would have to  
16 deal with.

17 MEMBER BONACA: Very significant, yes.

18 MEMBER APOSTOLAKIS: Yes, I don't know  
19 what that means.

20 MEMBER BONACA: What is means that in  
21 licensee space, if you have an efficiency -- even if  
22 the system is likely to work, you call it inoperable.

23 MEMBER APOSTOLAKIS: Now you had the PRA.  
24 You said you were upgrading it. Is that what you  
25 said? And you found this?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. SCHWEITZER: Yes, we were going  
2 through an upgrade to the PRA to include human  
3 factors.

4 MEMBER APOSTOLAKIS: So the first around,  
5 the PRA did not even look at these things?

6 MR. SCHWEITZER: Did not include the human  
7 factors aspect.

8 MEMBER APOSTOLAKIS: Okay. Was that an  
9 IPE or a PRA?

10 MR. SCHWEITZER: I can't -- I'm not  
11 totally sure on that.

12 MEMBER APOSTOLAKIS: Does the licensee get  
13 any credit for the fact that they, themselves, found  
14 it?

15 MEMBER SIEBER: Yes.

16 MR. LOUDEN: Typically, yes you would.  
17 And that's -- from day-to-day events, yes. Our  
18 program is set up such that there is recognition of  
19 licensee-identified activities. That's also countered  
20 with the overall significance. So when you find  
21 yourself in a particular finding of this nature where  
22 you have high significance, it's acknowledged that it  
23 was licensee identified. But nevertheless, it places  
24 -- it falls where it falls. I mean if it came out red  
25 in that area per our program, then that's where it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 would stay.

2 MEMBER APOSTOLAKIS: Okay. Thank you.

3 MEMBER SIEBER: Yes, the color doesn't  
4 change. Where the mitigation might come in is in the  
5 enforcement process. If you were to exact a civil  
6 penalty, the fact that you found it promptly and  
7 corrected it and did, you know, all kinds of good  
8 things might lessen the amount of the fine you would  
9 pay.

10 And conversely, if the NRC found it or  
11 nature found it, self-revealing, and you ended up with  
12 an accident, the civil penalty would go in the other  
13 direction. But that's usually where it would come in  
14 if it comes in at all. The color is the color.

15 MR. LOUDEN: The color is the color. And  
16 then if we were doing the other piece where we were  
17 outside of SDP space, just as you described, over in  
18 the traditional enforcement path, and we were into  
19 escalated enforcement --

20 MEMBER SIEBER: Yes.

21 MR. LOUDEN: -- yes, there are factors,  
22 escalation and mitigating factors that play into this.  
23 And certainly identification credit is one of those.

24 Okay, following our inspection, we issued  
25 a red finding in July of 2002 associated with this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 event. The licensee had requested that we evaluate  
2 the issue against some of our criteria in Manual  
3 Chapter 0305 which applies to old design issues,  
4 meaning an issue that had some legacy to it but was  
5 not necessarily indicative of current performance.

6 So we conducted an inspection starting in  
7 September to review that. And it was as we were  
8 finishing that review that we were informed by the  
9 licensee that the second event, which eventually  
10 became the second event, a second condition occurred  
11 with the modification associated with the flow  
12 orifices in this same recirc line.

13 So at that time, we conducted another  
14 special inspection to review the circumstances  
15 surrounding that. And it was during that time when we  
16 identified that there was design-control issues  
17 associated with that modification and that there were  
18 certainly corrective action elements that could have  
19 played into even resolving the first red issue. So,  
20 therefore, we didn't feel that that old design issue  
21 credit was warranted.

22 It was in the cover letter of that report  
23 that we made the final determination for the red  
24 finding. And informed the plant that they would be  
25 placed in Column 4 of the Action Matrix.

1 And a month or so later, at the conclusion  
2 of the Agency Action Review Meeting in 2003, in the  
3 letter following that meeting is where we informed the  
4 licensee that we would be conducting a 950003  
5 Supplemental Inspection later in the year.

6 Next slide. And I basically covered that.

7 Let's go on to the next slide. The  
8 Supplemental Inspection which was conducted -- the  
9 purpose of the Supplemental Inspection is to be more  
10 diagnostic and to look deeper and broader into the  
11 various areas that have been identified as known  
12 problems. And we also look in areas that were not so  
13 apparent for the specific issue that placed the plant  
14 in Column 4.

15 One example of that would be we did the  
16 Appendix A to the procedure, which looks at the  
17 Emergency Preparedness Program. Early in 2002, we had  
18 identified a white finding associated with I believe  
19 it was exercise critiques. And we had other issues  
20 associated with the Emergency Preparedness Program.

21 So we used that knowledge to include in  
22 our plan for this inspection to do that appendix. And  
23 that resulted in additional findings in the EP area,  
24 which I'll discuss in a moment.

25 We completed this procedure and this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 inspection in three parts. We had three teams, one of  
2 six people, one of five, and another of ten. And the  
3 three areas were the Corrective Action Program, then  
4 the Emergency Preparedness Program, and then the  
5 larger team at the end was an integrated team looking  
6 at Engineering, Operations, and Maintenance, and other  
7 areas.

8 Next slide. The teams were comprised  
9 mainly of inspectors from other regions and from  
10 headquarters. This assists us in getting a different  
11 perspective and a fresher look at some of the areas  
12 that we had been following within the region. And we  
13 found that to be very effective.

14 The results of the 950003 identified  
15 several findings in the various areas. And the  
16 results of that inspection combined with the  
17 observations from our baseline program and our  
18 residents, we resulted in five general areas of  
19 concern.

20 The next slide is -- and Mr. Cooper  
21 referenced these five areas. And I have them there on  
22 this slide in front of you. Human performance and  
23 corrective actions were captured within those five  
24 areas.

25 Next slide. These five areas then formed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the basis for what ultimately lead to the Confirmatory  
2 Action Letter that was issued on April 21st, 2004.  
3 And at the same time, as Mr. Cooper also mentioned in  
4 his presentation, the licensee had been working on an  
5 improvement plan, they called the Excellence Plan, at  
6 their site. And it encompasses a lot of things, both  
7 operationally and business related.

8 What the licensee focused on, they  
9 developed a subset of action plans to address the  
10 specific items within the CAL that were the result of  
11 the 950003 inspection. And that was included in a  
12 commitment letter sent to us in March of 2004 that  
13 included the 143 items that you heard referenced  
14 during Mr. Cooper's presentation.

15 Next slide. Last year as far as  
16 inspections, we did our normal baseline inspections.  
17 Two particular teams noteworthy: the Safety System  
18 Design and Performance Capability Team in June and  
19 then a Problem Identification and Resolution Team in  
20 September.

21 Both of those teams were expanded in  
22 membership beyond the norm, approximately doubling --  
23 we doubled the number of inspectors and the number of  
24 hours that we would normally place on that.

25 The reason we did that was twofold. One,

1 we wanted to ensure that we could get sufficient  
2 sample size that we had an accurate read on the real  
3 state of the programs that we were looking at. And  
4 two, we also wanted to take the opportunity to look at  
5 some of the progress the licensee was making with some  
6 of their 143 items for the particular areas that we  
7 were looking at. So we took advantage of that as  
8 well.

9 We also conducted two special inspections  
10 last year. And the purpose of those special  
11 inspections were to directly look at the progress the  
12 licensee was making in addressing the action items per  
13 the Confirmatory Action Letter.

14 A number of the items are a sequence or in  
15 a series of things that you have to develop or that  
16 they planned to develop. And so some of them offered  
17 themselves to be looked at on interim just to gauge  
18 progress and status and to see if they were proceeding  
19 on track as described in the commitment letter.

20 Next slide. Also to note, within the  
21 normal ROP process, we also identified -- we had  
22 carried the Corrective Action Program and the human  
23 performance area as substantive crosscutting issues  
24 under our ROP. The PI&R area was identified in our  
25 end-of-cycle letter in 2003. And the human



1 performance area we identified in our end-of-cycle  
2 letter in 2004.

3 Next slide. As far as progress on these  
4 two areas and performance to date, human performance,  
5 we have seen improvement in that area, particularly  
6 within the last year. The licensee did experience  
7 some human performance errors during last year's  
8 outage, which was at about this time last year. We've  
9 seen a notable improvement in the last year in the  
10 human performance area.

11 What we're using to gauge that are the  
12 performance indicators the licensee tracks on this.  
13 We also, through our direct observations day to day  
14 with the resident inspectors on site, as we are  
15 looking at activities closely to evaluate not only if  
16 there was an equipment failure or if there was a  
17 technical aspect to the problem, but we also are  
18 looking at it with the eye at was there a human  
19 performance issue here? Or was there something that  
20 was different from before?

21 We were looking for a change. And we're  
22 continuing to look at that, particularly during the  
23 current outage. Again, we wanted to focus on a time  
24 frame when the organization was stressed. Being in an  
25 outage condition certainly would qualify for that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 And we've seen a difference in the human performance  
2 errors, both in the number and the severity of them  
3 during this outage compared to the outage of a year  
4 ago.

5 With regard to the Corrective Action  
6 Program, this slide states -- I wanted to -- I broke  
7 them up a little bit from yesterday's to make it  
8 clearer. The Corrective Action Program, when I  
9 addressed that, the program itself, that being the  
10 procedure, the process, it is sound.

11 It's a fleet-wide process. It's the same  
12 process that is used at -- I believe at all of the NMC  
13 plants. And it has been used effectively. Through  
14 our inspections, we've noted effectively at other NMC  
15 plants.

16 However, the real issue here at Point  
17 Beach with this program is a matter of implementation.  
18 In particular, a piece of the implementation. We're  
19 satisfied with the identification piece of it. And  
20 somewhat with the prioritization of the issues.

21 Where we've had problems in the past and  
22 we still have indications of where areas need to  
23 improve are in the area of timely corrective actions  
24 and long-lasting, effective corrective actions.

25 And really that's -- if you flip to the

1 last slide then -- and I'll go to the second bullet  
2 first. That's the real key of what we're looking at  
3 right now as we're going forward.

4 We understand the elements. We understand  
5 what the licensee has done. We understand that if  
6 they -- from our assessment, if they go through the  
7 plans, that they should be successful. But we're  
8 really focused on sustainability and long-term  
9 effectiveness. And that's what remains to be  
10 evaluated for the remainder of this year.

11 We have seen progress in all of the five  
12 areas. There are varying degrees of how much progress  
13 that has been seen. Certainly some greater than  
14 others. But there has been some progress.

15 And again, our focus for the remainder of  
16 this year, and as the licensee completes their items  
17 for the CAL, we'll be looking at and assessing the  
18 sustainability of those actions.

19 MEMBER POWERS: How many -- or how long of  
20 a period do you generally think it takes -- I mean it  
21 will be different in every case, I understand, before  
22 you can declare something sustainable? I'm looking  
23 for an intuitive number here.

24 MR. LOUDEN: What's that?

25 MEMBER POWERS: I'm looking for your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 intuition here, not some well-honed scientific answer.

2 MR. LOUDEN: I don't know if there is a  
3 well-honed answer. I know it's a real tough question  
4 to answer but I'll try it anyway.

5 You know that was one of the challenges  
6 that we had. We knew going into this that one of the  
7 factors per 0305, I mean when you look at some of our  
8 criteria that we are to evaluate against, one of the  
9 line items right there is sustainability of the  
10 actions that they take.

11 So then how do you -- what do you use as  
12 a measure I believe is your question. And so what we  
13 tried to do when we looked at the commitments that the  
14 licensee provided to us in their commitment letter and  
15 we attached to our CAL, we had extensive dialogue with  
16 them so that we could understand what did these  
17 measures mean and were these measures that could play  
18 into making a decision on sustainability.

19 For example, there are some in there which  
20 it doesn't just, you know, a number can be achieved.  
21 For whatever activity, 25, you hit 25, you check it  
22 off. That doesn't necessarily show sustainability.

23 So what you'll see in here, we tried to  
24 factor in or to have the licensee consider was a  
25 duration to it. You achieve a number over a 90-day

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 rolling period, over a six-month period. And they're  
2 variable. That was the way we're trying to assess it  
3 in a certain sense.

4 And then from a programmatic sense, we're  
5 looking at overall -- as I mentioned with the human  
6 performance piece, are the actions -- are the  
7 frequency of the problems reducing? Are the severity  
8 of them reducing?

9 I mean especially human errors. I mean  
10 they're going to occur. So what we're trying to  
11 assess is does the licensee have a program in place  
12 and are they reinforcing it so that it would provide  
13 you with some assurance that this would be sustainable  
14 long term.

15 MEMBER POWERS: You wouldn't look at  
16 things like is it sustaining through management  
17 turnover?

18 MR. LOUDEN: Sorry.

19 MEMBER POWERS: You wouldn't look at  
20 things like gee does this program continue on its  
21 trend despite a changeover of some particular manager?

22 MR. LOUDEN: Absolutely. It's separate  
23 from the given management at the time. The Corrective  
24 Action Program -- and that's one -- we look at the  
25 Corrective Action Program on a daily basis. I

1 appreciate the sensitivity you have for it for the  
2 topic that we're discussing here today with license  
3 renewal.

4 But it also serves as a foundation that we  
5 look at very closely within the Reactor Oversight  
6 Program and the process. So on a daily basis, the  
7 resident inspectors are looking at how the program and  
8 the process is working separate from -- I mean  
9 certainly management factors could be considered when  
10 you're looking at a change. But once it has been  
11 established, what we're trying to gauge is how is it  
12 working?

13 How is it being -- not only is it being  
14 followed through the process, but how is it being  
15 received? Do the workers in the field who see the  
16 problems, who certainly can identify -- have the  
17 opportunity to identify the problems, are they  
18 reporting the issues?

19 Those are the types of things that we look  
20 at not only on a daily basis but also with our special  
21 inspections that we have and our regional inspections.

22 MEMBER POWERS: I think your answer is  
23 fine. I mean I don't know how I would answer my  
24 question.

25 MR. LOUDEN: That's fine.

1 MEMBER POWERS: And I like yours a lot.  
2 But what I would just comment to the Committee is that  
3 it seems to me when we're thinking about the issues of  
4 safety -- what sometimes gets called safety culture is  
5 this seems to be a particular question that would be  
6 interesting to explore is how do you know some change  
7 is sustainable? And how do you measure the  
8 sustainability here in some objective fashion/

9 Because I think as you've quite accurately  
10 stated here, this is not something that comes with a  
11 label on it, yes, this is sustainable and this other  
12 thing is not. And it would be interesting to explore  
13 that.

14 MEMBER ROSEN: Well, I think the question,  
15 Dana, comes down to monitoring. You have to make a  
16 judgment. I recognize the staff has to do that about  
17 the ability to sustain in order to close the CAL.

18 But then after that, what are you going to  
19 do to monitor that, in fact, your judgment was  
20 correct? That it was sustainable because it is being  
21 sustained?

22 MEMBER BONACA: Yes, that's a good point.

23 MEMBER POWERS: Well, I think that's -- I  
24 see that as confirmatory. What I'm worried about  
25 right now, Steve, yours is a correct thing to worry

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 about, yes. I agree with you.

2 At some point, somebody has to make a  
3 decision yes, this is sustainable. And you can't wait  
4 ten years to say yes, it was sustained. I mean he's  
5 got to do that beforehand. But how does he do that?

6 MEMBER ROSEN: Yes, I understand that.  
7 There are two questions here.

8 MEMBER POWERS: Yes, two questions.

9 MEMBER BONACA: I asked yesterday, Mr.  
10 Loudon, to comment on the quality of root cause  
11 evaluations because I think that they are a window of  
12 sustainability. At least that's an opinion I have.

13 And that's really the process by which you  
14 see -- you test things like questioning attitude,  
15 focus on safety, you know, I mean you reach some root  
16 cause evaluations and you say is this a root cause  
17 evaluation? I mean, you know, even asking that  
18 question it didn't go far enough.

19 And I think when I look back at the  
20 performance on the issues that led to the first red  
21 finding, all through the years, clearly there was no  
22 questioning attitude. I mean because there were very  
23 clear pointers to the loss of air and yet there was no  
24 response to that.

25 So maybe you want to comment on what you



1 see insofar as root cause evaluation because I know  
2 you review them. And you told us yesterday --

3 MR. LOUDEN: We review them and some of  
4 them that we read, we have no issue with. Certainly  
5 some of them we look at, we have questions that take  
6 us back to ask similar questions we would have asked  
7 a year ago. That being what about the extent of  
8 condition? Is the extent of condition adequate? Is  
9 the timeliness -- is the timing of the correction  
10 action appropriate? Those questions still come up.

11 And so in my bullet that I listed on the  
12 slide on the Corrective Action Program of some areas  
13 still needing improvement, those are examples within  
14 the root cause evaluation particularly of what I'm  
15 speaking to.

16 And, again, needing improvement, the way  
17 I'm using it here, is to help us in making the  
18 decision and the determination that you all are  
19 talking about, about sustainable.

20 One question, I believe -- I can try to  
21 answer one question. The program does allow for us  
22 after the plant comes out of Column 4, whenever time  
23 that would be, built in the program, we are allowed --  
24 we are budgeted additional hours, 200 hours, that we  
25 can use and expend to do follow up inspections to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 check certain areas.

2 And certainly the Corrective Action  
3 Program will be one that we will use those hours to  
4 verify and answer the question you asked. Did this  
5 work? Is it sustainable? So the program does allow  
6 for us some budgeted hours for that.

7 VICE CHAIRMAN SHACK: What is the  
8 inspection effort increase associated with the  
9 Confirmatory Action Letter? What do you do in excess  
10 of your normal inspections associated with this?

11 MR. LOUDEN: I'm going to use some hours  
12 that I know and then some maybe FTE estimates -- and  
13 they are estimates. But just to give you a feel.

14 Our baseline program say with the resident  
15 inspectors, and I will use these numbers ballpark, I'm  
16 not sure if I have them exact -- typically, would run  
17 between 1,800 and 2,000 hours a year. For the 950003  
18 inspection, we expended almost 2,000 hours for that  
19 one inspection.

20 And right now, my estimates -- and these  
21 are rough estimates -- but I'm looking at an  
22 additional, so far for follow up about 1,200 hours.  
23 And again, that's just a guess. But it gives you a  
24 feel for -- it is significantly above the norm.

25 MEMBER POWERS: I have a question really

1 not directed to you but perhaps to the previous  
2 speaker. I've had a little chance to examine this  
3 diagram for excellence. And I just have a question or  
4 two about it.

5 It seems to me that the plan is meant --  
6 is focused very much on addressing currently operating  
7 issues. But what we're asking really now -- I mean  
8 what is of primary concern to us, if the commitments  
9 for license renewal actually are going to be met.

10 And when I look at this diagram for  
11 excellence, it's really a map for accomplishments on  
12 what I would call prescribed activities. And I don't  
13 see elements that might be associated with things like  
14 initiative, questioning attitude, having up-to-date  
15 knowledge, technical excellence.

16 And it seems to me that those kinds of  
17 things might be especially important for the  
18 activities associated with license renewal. And I  
19 wonder if you could comment on that.

20 MR. COOPER: Yes, sir. If you look at  
21 that diagram, there are a number of attributes. And  
22 then there's further definition. Looking at that, I  
23 would look at the pillar of site excellence. Then I  
24 would go down to organization excellence. And some of  
25 the attributes have to do with being accountable,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 being predictable. We further define those as doing  
2 what we say we'll do. So --

3 MEMBER POWERS: Well, I mean the truth is  
4 as you sit down now and you say okay, I'm going to do  
5 this, well I would hope that in the course of doing  
6 that, you would look and say well, no I was wrong  
7 about that. I should have done something more.  
8 That's the element that I'm not seeing here.

9 MR. COOPER: You're right. And that is  
10 one of the elements. And it doesn't show on that  
11 picture.

12 One of the things -- on one of the other  
13 slides I talked about is this recurrent -- what I  
14 would call check and adjust or reevaluate. I believe  
15 it was on actually the slide before the Picture of  
16 Excellence.

17 If you go in there, what actually occurs  
18 is on a monthly basis, the senior leadership team  
19 looks down, looks at what is in the Excellence Plan  
20 relative to the challenges that are before them. And  
21 it says they make an evaluation based on current  
22 performance, based on current commitments.

23 Do we have the right priorities? Do we  
24 need to add priorities? Do we need to drop back a  
25 priority? And that makes its way back into the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Excellence Plan.

2 And they look at things like corrective  
3 actions. They look at things like site commitments.  
4 They look at things like current assessments. So  
5 there is this -- at least monthly and sometimes more  
6 frequently, are we putting our resources in the right  
7 place and are they properly integrated? That's going  
8 on in the background. And it's not showing on that  
9 particular picture.

10 Does that answer your question?

11 MEMBER POWERS: Well, it probably  
12 precipitated about five more.

13 I have, however, another one that burns  
14 just a little bit. And it's a problem every manager  
15 faces. You know what you're saying.

16 MR. COOPER: Yes.

17 MEMBER POWERS: Do you know what's being  
18 heard?

19 MR. COOPER: That is a good question. One  
20 thing I've learned as you manage is often what you say  
21 and what people really hear you say are to different  
22 things. And so you have to go out and you have to  
23 validate that the folks are hearing what they say.

24 I'll tell you some of the things that give  
25 me assurance that the people are hearing what I think

1 I'm saying or what the senior manager is saying.

2 First of all, we use the nuclear oversight  
3 organization to periodically pulse and survey the  
4 people. I believe it is -- at least quarterly, they  
5 go out and they do a formal assessment or they do a  
6 questionnaire. We get input from there.

7 We do periodic safety culture evaluations,  
8 which is at least every other year and some of the  
9 sites every year.

10 These daily meetings that I've talked  
11 about where we sit down and talk about performance.  
12 I, when I'm on site, I'm not on that site -- since I  
13 have three sites, I'm not there every day -- I  
14 routinely sit down at these -- what we call D-15s, the  
15 daily 15 meetings, and I listen to what people are  
16 saying. And they have an opportunity to ask me  
17 questions.

18 The senior management team goes out and  
19 does this. So we are periodically going down in the  
20 organization and doing this. Are they hearing what  
21 we're saying? Am I saying the right thing? So we do  
22 that periodic assessment.

23 Now if I was to say does every person in  
24 that organization know exactly what I think, the  
25 answer would be no. But I will tell you, looking at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 an overall preponderance, they understand it. But  
2 that is a challenge and we work on it every day.

3 MEMBER APOSTOLAKIS: I was a little  
4 intrigued by what you said, Mario, at the beginning.  
5 That all this is really irrelevant to the license  
6 renewal process, is it not?

7 MEMBER SIEBER: Yes.

8 MEMBER APOSTOLAKIS: I mean they can have  
9 the worst safety culture in the world, maybe the last  
10 slide from Mr. Loudon would have been -- yes, this is  
11 the worst plant we've ever seen, and still we could  
12 grant the extension.

13 MEMBER BONACA: That's correct. And  
14 that's the way the rule is framed now.

15 MEMBER APOSTOLAKIS: So we could grant the  
16 extension and then shut them down because of those  
17 issues.

18 MEMBER BONACA: Yes.

19 (Laughter.)

20 MEMBER BONACA: That's exactly the  
21 process.

22 MEMBER APOSTOLAKIS: This is the process.

23 MEMBER BONACA: The process is, you know,  
24 that's the future action. I think in this particular  
25 case --

1 MEMBER APOSTOLAKIS: So we're just  
2 granting you an extension to keep you down for a  
3 longer period.

4 MEMBER BONACA: Well, the main concern  
5 that we expressed here, that is the reason why we're  
6 here on this issue, and that's why I tried to focus on  
7 only two of the concerns here, there are many more, is  
8 one is, you know, to what extent are these  
9 deficiencies in the organization are now effecting the  
10 establishment of commitments, et cetera? I mean the  
11 NRC only audits a few of them. You cannot audit all  
12 of them. Many of them are not laid down yet. They're  
13 just promises. So that's the first question.

14 Now if this plant was going through  
15 license renewal in 15 years, I would say well, you  
16 know, 15 years is a long time. And something has to  
17 happen before. But the first plant will go in five  
18 years. And five years is not a very long time  
19 particularly for recovering cultural issues.

20 From experience in seeing older sites, at  
21 times there is success or there is no success in  
22 recovering certain programs. So that's the first  
23 question.

24 The second one is really the nature of  
25 Corrective Action Program. It's so fundamental, as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 you said, Mr. Loudon, to everything that goes on  
2 around the site. But particularly license renewal  
3 would depend for it, you know. And so here we're not  
4 saying that that's a condition. We're only saying we  
5 would like to know.

6 MEMBER APOSTOLAKIS: Yes, okay.

7 MEMBER BONACA: And we would like to see  
8 that, you know, we would like to see that it has been  
9 recovered. That would be the best of all worlds. Or  
10 at least it's on its way.

11 MEMBER ROSEN: Beyond this discussion, Mr.  
12 Matthews earlier mentioned that if we think this is  
13 not the right way to do business, to separate these  
14 things, we have the opportunity to suggest a change to  
15 the regulation. And obviously that's not something  
16 you take too lightly. But this is something that's  
17 there.

18 MEMBER APOSTOLAKIS: That would make us  
19 very popular, Steve.

20 MEMBER BONACA: Well, I mean yes, the  
21 Committee has not discussed this possibility.

22 MEMBER POWERS: Is there any particular  
23 job requirement in our charter that says popularity is  
24 important?

25 (Laughter.)

1 MEMBER APOSTOLAKIS: It's not a  
2 requirement.

3 MEMBER SIEBER: It's no change. We're not  
4 popular.

5 MEMBER POWERS: Is it on our Plan for  
6 Excellence?

7 (Laughter.)

8 CHAIRMAN WALLIS: It's in our criteria for  
9 promoting professors at MIT.

10 (Laughter.)

11 MEMBER BONACA: It seems to me that the  
12 usefulness of this session has been exhausted.

13 (Laughter.)

14 CHAIRMAN WALLIS: Well, I have a question  
15 about that, Mario. We've spent all our time on these  
16 inspection findings and the licensee response. And  
17 the staff evaluation of the licensee response, which  
18 is all very interesting.

19 But the subject of the session is license  
20 renewal. And there are some questions about license  
21 renewal, like the handling of vessel embrittlement and  
22 so on. We just don't have time to do that.

23 MEMBER BONACA: No, this was not our plan  
24 because we did not see -- I mean it is a unique  
25 approach but they are proposing one of the ways the

1 license renewal allows you to use. And so there is  
2 nothing that the Committee has to made a decision on  
3 right now.

4 CHAIRMAN WALLIS: So our letter will not  
5 refer to the license renewal. Just to this particular  
6 aspect of the issues.

7 MEMBER BONACA: Well, I think that we will  
8 deal with those issues when we come to the final SER.

9 CHAIRMAN WALLIS: But I think the  
10 Committee members who weren't here yesterday ought to  
11 have some idea of whether there are license renewal  
12 issues of importance. Maybe you could summarize that?

13 MEMBER BONACA: We cannot identify any  
14 stumbling block at this stage. As I mentioned at the  
15 beginning of this presentation, we didn't any  
16 stumbling block. We felt that the fact if this  
17 application had been presented -- I mean the SER had  
18 been presented a couple of months from now, many of  
19 these issues -- or the issues to do with license  
20 renewal, like scoping would have been dealt with and  
21 closed.

22 And so Mr. Matthews has --

23 MR. MATTHEWS: I just wanted to make a  
24 couple concluding remarks. This does conclude the  
25 staff's presentation, both from the standpoint of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 license renewal activities and also those related to  
2 the safety of existing operations and the implications  
3 for the future.

4 My expectation and I think the staff's  
5 expectation is and our view is that the Committee has  
6 sufficient information to write a letter addressing  
7 the Committee's findings regarding the staff's review  
8 of the applicant's license renewal application with  
9 the focus being on the requirements of Part 5054.

10 And to the extent that it is possible, as  
11 you discuss it among yourselves, segregating those  
12 findings from comments you may wish to make with  
13 regard to the implications of what you've heard  
14 relative to the existing circumstances and performance  
15 for the safety of continued operations for the near  
16 term and also extending through the period of  
17 continued operations, that would be beneficial to the  
18 staff if you were able to segregate your comments in  
19 those regards.

20 I also wanted to add as a second comment  
21 that we, too, would like to say farewell to Mr. Rosen.  
22 But it's because we thought his interactions with the  
23 staff on a range of subjects have been extremely  
24 beneficial. I speak, I think, for the whole staff in  
25 that regard.

1                   They were productive comments and you'll  
2                   be missed. Thank you very much.

3                   MEMBER ROSEN: Thank you very much.

4                   MEMBER BONACA: With regard to the letter,  
5                   you know, we do not write a report until the final SER  
6                   comes because there are so many issues still open.  
7                   And unless we see a measure flaw, okay, or a concern  
8                   that requires some change on the part NRR, so we will  
9                   not comment on the SER until you come up with the  
10                  final SER.

11                  MR. MATTHEWS: I should have prefaced my  
12                  remarks. I meant at the conclusion of the staff's  
13                  review.

14                  MEMBER BONACA: Yes, okay.

15                  MR. MATTHEWS: And thanks for that  
16                  clarification.

17                  MEMBER BONACA: Yes. All right.

18                  Are there any other questions?

19                  (No response.)

20                  MEMBER BONACA: If not, I want to thank  
21                  you very much for your presentations and your time.  
22                  And also Mr. Cooper for that. And with that, I turn  
23                  it over to you, Mr. Chairman.

24                  CHAIRMAN WALLIS: Thank you. We're going  
25                  to take a break. But since you're all here, I'd like

1 to discuss a couple of things off the record. Could  
2 we close the record so we don't have these?

3 (Whereupon, the foregoing matter went off  
4 the record at 9:49 a.m. and went back on the record at  
5 10:07 a.m.)

6 CHAIRMAN WALLIS: The next topic is policy  
7 issues related to new plant licensing. I'll turn to  
8 Dr. Kress to lead us.

9 MEMBER KRESS: Well, thank you.

10 Today we want to welcome Mary Drouin and  
11 her friends back for some of our ongoing collegial  
12 discussions on the technology-neutral framework for  
13 new plant licensing. For this framework, the staff  
14 has identified a number of policy issues, some of  
15 which we've already heard about and talked about, and  
16 some have already been dispositioned.

17 But there are some that still remain, and  
18 today we want to discuss and give Mary the benefit of  
19 our thinking on two of these. One of them is: what  
20 level of safety, or acceptable risk if you want to put  
21 it that way, should we shoot for for new plants? That  
22 is, how do we interpret the Commission's expectation  
23 for a higher level of safety for new plants?

24 And the second issue is one that we've  
25 discussed before. You know, we had a classic letter

1 of on the one hand, and then on the other hand, and  
2 what -- was it Truman that said, "Give me a one-handed  
3 advisor, please"?

4 But anyway, that issue is dealing with  
5 integrated risk at a site versus plant design  
6 parameter risk. And we do expect to have a letter on  
7 this. The staff plans to go to the Commission with  
8 their options and their preferences on the options at  
9 the end of this month I think on --

10 MS. DROUIN: Correct.

11 MEMBER KRESS: So with that as kind of an  
12 introduction, I'll turn it over to Mary to get us  
13 started.

14 MS. DROUIN: Thank you very much. My name  
15 is Mary Drouin from the Office of Research. With me  
16 today is Marty Stutzke from NRR. Also, I want to  
17 acknowledge that this is not just, you know, input and  
18 work from Marty and I, but there is a whole team that  
19 has supported us, other individuals from NRR, also  
20 from Research. With us today is Stu Rubin, my Branch  
21 Chief David Lew, and Jit Singh. We've had support  
22 from OGC that has helped us, EP, etcetera. And  
23 Brookhaven National Labs. I don't want to forget  
24 them.

25 Okay. Why are we here today? As Dr.

1 Kress said, we have two policy issues that we want to  
2 brief you on, and we're asking approval on our  
3 recommendations that are going forward to the  
4 Commission at the end of this month. The two issues  
5 both relate to enhanced safety. When you go back and  
6 look at SECY-03-0047, there were seven policy issues  
7 raised there.

8 The first one was the Commission's  
9 expectation for enhanced safety. The Commission gave  
10 approval for enhanced safety, but now we're at the  
11 next part is -- how do we implement it? Also, though,  
12 the Commission said, you know, they approved our  
13 recommendation. They also wanted to know more about  
14 the integrated risk.

15 Both of these are fundamental to the  
16 framework and also to support preapplication reviews,  
17 which is one of the reasons -- one of the biggest  
18 reasons why we're going forward with these  
19 recommendations now and we're not waiting until the  
20 end of the year -- for those two reasons.

21 Just a little bit of background here, as  
22 I said, you know, SECY-03-0047 talked about seven  
23 policy issues. The first issue was on the expectation  
24 of enhanced safety, and we recommended in 03-0047 that  
25 implementation of enhanced safety, through a process



1 that was similar to the evolutionary LWRs, that that's  
2 what we move forward with.

3 The Commission did give approval for that,  
4 but they did come back and ask us in their SRM to talk  
5 about the options and the impacts of integrated risk,  
6 and so that gave birth to the second issue that we're  
7 going to talk about today is how to treat integrated  
8 risk.

9 CHAIRMAN WALLIS: Now, I don't know what  
10 the first bullet means. I mean, it says  
11 implementation in health safety through a process  
12 similar to that used.

13 MS. DROUIN: I'm going to get into that.

14 CHAIRMAN WALLIS: You're going to get into  
15 that? You're going to explain that?

16 MS. DROUIN: Yes.

17 CHAIRMAN WALLIS: Okay.

18 MS. DROUIN: We then went with SECY-04-  
19 0157.

20 MEMBER ROSEN: Mary, could you go back to  
21 the --

22 MS. DROUIN: Sure.

23 MEMBER ROSEN: -- prior one? Because you  
24 had a sub-bullet there that I want to be sure I  
25 understand. The sub-bullet under the second red

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 bullet. When using probabilistic or risk information,  
2 modular reactive designs should account for the  
3 integrated risk posed by multiple reactors necessary  
4 to achieve the overall electric output. What do you  
5 mean by that?

6 MS. DROUIN: Well, a plant -- they could  
7 come in with this modular reactor concept where a  
8 particular module might be 100 megawatts. I mean, I'm  
9 just making up a number. So to have an equivalent of  
10 today's size, they would have multiple modules. And  
11 how would we treat that? Do we treat each module  
12 individually, or how do we deal with the risk for --

13 MEMBER ROSEN: Well, you haven't told us.  
14 You just said this is just a statement of the problem.

15 MS. DROUIN: That's correct.

16 MEMBER ROSEN: Okay.

17 MS. DROUIN: The Commission came back and  
18 we said we should be considering these things. When  
19 we look at enhanced safety, we need to think about  
20 modular reactors.

21 MEMBER ROSEN: And later on in this  
22 presentation you'll talk more about that bullet?

23 MS. DROUIN: Correct.

24 CHAIRMAN WALLIS: And explain that?

25 Because --

1 MS. DROUIN: I mean, what you'll see is  
2 that we don't differentiate between whether it's a  
3 module or a reactor of typical size. You know, we are  
4 not looking at in our options -- when you look at the  
5 integrated risk across reactors, multiple reactors,  
6 you know, the size of the reactor.

7 MEMBER KRESS: Now, when you say "risk,"  
8 are you talking about the QHOs? Or are you talking  
9 about some version of core damage frequency?

10 MS. DROUIN: When I use the term "risk,"  
11 I'm talking about the consequences, the health  
12 effects.

13 MEMBER KRESS: Good.

14 MS. DROUIN: To me, that's what risk is.

15 MEMBER APOSTOLAKIS: So there are two  
16 comments here that one can make. First of all, I  
17 recommend that you delete the words "when using  
18 probabilistic or risk information." Period. Modular  
19 reactor design should account for the integrated risk.  
20 That's what the statement should be. In other words,  
21 if I choose not to use PRA, I'm not getting out of  
22 this.

23 MS. DROUIN: I understand. These are just  
24 quotes from the paper.

25 MEMBER APOSTOLAKIS: Yes. Whatever.

1 MS. DROUIN: I mean --

2 MEMBER APOSTOLAKIS: So --

3 MS. DROUIN: -- the previous paper is  
4 already written.

5 MEMBER APOSTOLAKIS: Well, we always  
6 learn.

7 MS. DROUIN: Yes. I'm --

8 MEMBER APOSTOLAKIS: So it shouldn't be  
9 there. The second --

10 MEMBER KRESS: Go ahead. I'm sorry. I  
11 thought you were through.

12 MEMBER APOSTOLAKIS: I think you are not  
13 addressing the issue of core damage frequency at all  
14 in the paper I read. You are just talking about, as  
15 you say, the consequences.

16 MS. DROUIN: That is correct.

17 MEMBER APOSTOLAKIS: Is there any reason  
18 why you're avoiding the core damage frequency issue?  
19 I mean, remember, the ACRS was split. That's okay.

20 MS. DROUIN: Without getting into the  
21 details, I mean, there's two primary --

22 MEMBER APOSTOLAKIS: No, it's not a  
23 detail. It's a big thing.

24 MS. DROUIN: No, no, I'm not saying that  
25 it's not a big thing. Without going into the details,

1 there's two primary reasons why we did not look at  
2 that in one of the options is -- there's technical  
3 problems with trying to do it on a technology-neutral  
4 level, trying to say what do you mean by core damage  
5 -- on technology-neutral is -- we're not even sure  
6 it's feasible.

7 MEMBER APOSTOLAKIS: Is it a new thing  
8 now, because I remember Mr. King in one of the  
9 meetings here saying, "Yes, we can define core damage  
10 for all technologies." This is --

11 MS. DROUIN: Well, we had proposed -- we  
12 were not sure at that time that we could, but we were  
13 looking into it. Since then, we've just run into a  
14 lot of difficulties trying to do it. It would take a  
15 lot of time, a lot of resources, and we're not sure at  
16 the end that we would be successful.

17 MEMBER APOSTOLAKIS: I understand that.

18 MS. DROUIN: That's one of the reasons.

19 MEMBER APOSTOLAKIS: No, that's fine. But  
20 it seems to me that even in a technology-neutral  
21 framework, in the name of defense-in-depth, you have  
22 to say something about prevention. I mean, you can't  
23 just have statements only on the risk, which is a  
24 correct statement, I do agree with that. But don't  
25 you think we have to have something about prevention?

1 MS. DROUIN: Well, when you get into the  
2 framework, you will see that the protective strategies  
3 deal with prevention and mitigation. But this is  
4 getting into what -- the level of safety. At a high  
5 level, you know, what do we want to be our minimum  
6 level of safety? To me, those are two very different  
7 answers -- questions.

8 MEMBER APOSTOLAKIS: I mean, damage in the  
9 fuel, for example, is that something -- that's  
10 something we don't want. Can we say something about  
11 it? I mean --

12 MS. DROUIN: Well, I think when you get to  
13 the next level of the framework, you know, in -- in  
14 meeting what your minimum level of safety would be,  
15 you would get into those kinds of questions, and you  
16 would write your requirements to support that.

17 MEMBER KRESS: This is reminiscent of the  
18 time back when ACRS had a letter recommending that  
19 core damage frequency be elevated to a primary goal.  
20 And I think this is the same sort of discussion.  
21 Should it be in the framework, or should it be right  
22 up front as a part of the --

23 MEMBER SIEBER: Well, it's a surrogate.

24 MEMBER APOSTOLAKIS: Maybe you don't need  
25 to call it core damage.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: No. No, you wouldn't call  
2 it that.

3 MEMBER APOSTOLAKIS: But some sort of  
4 prevention or --

5 MEMBER KRESS: Prevention goal of some  
6 kind or --

7 MEMBER APOSTOLAKIS: Yes.

8 MEMBER DENNING: I'm struggling as to why  
9 you consider core damage frequency necessarily to be  
10 a prevention goal. I think it's a surrogate -- it's  
11 used as a surrogate, and it happens to be -- it's  
12 quite different for lightwater reactors and for other  
13 kinds of reactors.

14 And, obviously, when Mary was talking  
15 about for her risk consequences she meant the  
16 frequency of consequences. Implicit in that is the --  
17 is both the prevention and mitigation.

18 MEMBER APOSTOLAKIS: Yes. But the  
19 Commission and the staff for decades now has  
20 determined that the prevention part is about 1,000  
21 times more important than the mitigation, in the sense  
22 that the core damage frequency is  $10^{-4}$  and the LERF  
23 goal is  $10^{-5}$ .

24 So if you say nothing now, you might say,  
25 well, gee, I'm tolerating damage of the fuel and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 release of radioactivity. But as long as I can  
2 contain it successfully, everything is fine. And I  
3 don't think that everything is fine if you do that.  
4 Preventing releases, even within the containment, is  
5 a major goal of this agency.

6 If you look at this strictly speaking, you  
7 know, literally, you don't see anything that tells you  
8 that you have to do that. I agree with Mary that  
9 there may be difficulties defining what that  
10 intermediate --

11 MEMBER KRESS: I think it needs to be --

12 MEMBER APOSTOLAKIS: -- but something  
13 needs to be said, in my view.

14 CHAIRMAN WALLIS: But, George, there might  
15 be a good reactor design which emphasizes containment  
16 more and still has the same risk to the surrounding  
17 population. I don't know why you have to stick with  
18 having core damage frequency with such a large  
19 fraction of --

20 MEMBER APOSTOLAKIS: Because -- well, I'm  
21 not saying it has to be 1,000 to 1. But still, it  
22 seems to me the public would not tolerate these kinds  
23 of incidents.

24 MEMBER KRESS: I'm pretty sure they  
25 wouldn't either. I think it is a goal of the agency

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 and the industry --

2 MEMBER APOSTOLAKIS: No.

3 MEMBER KRESS: -- not to have a damaging  
4 event to the core.

5 MEMBER APOSTOLAKIS: That's right.

6 MEMBER KRESS: Whenever we decide what  
7 that is.

8 MEMBER APOSTOLAKIS: Yes. I agree with  
9 Tom.

10 MEMBER KRESS: And it's much more  
11 important to have that than it is to mitigate.

12 MEMBER APOSTOLAKIS: And the industry, of  
13 course, for the current generation of reactors is  
14 doing the LERF analysis only because we are forcing  
15 them to do it.

16 CHAIRMAN WALLIS: You're saying you --

17 MEMBER APOSTOLAKIS: They don't know  
18 what --

19 CHAIRMAN WALLIS: You think you know what  
20 the public thinks. I mean, I've talked to students  
21 about TMI, a hundred students, non-engineers. And  
22 they say, "What's the big deal? There was a lot of  
23 core damage, but nothing got out." To them, the  
24 containment is the more important part. They don't  
25 care about the core damage.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER APOSTOLAKIS: I don't believe the  
2 majority --

3 CHAIRMAN WALLIS: It's just an accident.

4 MEMBER APOSTOLAKIS: -- of the American  
5 people think that way --

6 CHAIRMAN WALLIS: How do you know? How do  
7 you know?

8 MEMBER APOSTOLAKIS: -- TMI? I don't  
9 believe that. I said I -- I.

10 CHAIRMAN WALLIS: Well, I have a sample  
11 of 100 students. So it's --

12 MEMBER KRESS: You guys are arguing about  
13 what is policy, and policy is set by the Commission  
14 itself, and the Commission has set policy already.  
15 So, you know, it doesn't do us much good. There's a  
16 policy that the --

17 CHAIRMAN WALLIS: But is the staff trying  
18 to describe what kind of policy should be set?

19 MEMBER APOSTOLAKIS: But the Commission  
20 has already set the policy.

21 MEMBER KRESS: There's already a policy.

22 MEMBER APOSTOLAKIS: This 1,001 is not  
23 something that happened randomly.

24 CHAIRMAN WALLIS: Maybe it did.

25 MEMBER SIEBER: Maybe I could change the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 subject a little bit, since we aren't going to solve  
2 this in the next five minutes. Why do you even refer  
3 to the electrical output? You know, if you put out a  
4 lot of electricity, is it okay to be a little riskier?  
5 You know, who cares? Let's make hydrogen --

6 MS. DROUIN: I really apologize that I  
7 quoted from a previous SECY paper here.

8 (Laughter.)

9 MEMBER SIEBER: WE're not blaming you.  
10 Don't take it personally.

11 MS. DROUIN: But, you know, if I can move  
12 on, I think -- thank you.

13 And SECY-157 is when we first noted to the  
14 Commission that in looking at enhanced safety, for new  
15 plant licensing -- that's what we're talking about  
16 here is policy for new plant licensing that -- what  
17 should be the level of safety to be achieved.

18 And I apologize because I -- this is not  
19 the right wording I have here. We're not asking for  
20 a goal. This is not a goal we're saying. We want the  
21 limit.

22 MEMBER KRESS: This is regulatory  
23 acceptance.

24 MS. DROUIN: Yes.

25 MEMBER KRESS: Good. Good for you, Mary.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. DROUIN: We said in SECY -- and I'm  
2 going to come back to these.

3 MEMBER APOSTOLAKIS: The first green goal  
4 you don't want?

5 MEMBER KRESS: It's not a goal. It's --

6 MEMBER APOSTOLAKIS: Which goal don't you  
7 want?

8 MEMBER KRESS: It's not a goal.

9 MS. DROUIN: It's not a goal.

10 MEMBER KRESS: It's an acceptance  
11 criteria.

12 MEMBER APOSTOLAKIS: Wait a minute, wait  
13 a minute, wait a minute. I thought the Commission's  
14 position for years now has been you can't do that.

15 MEMBER KRESS: Well, for the safety goals  
16 that we have, but now we're back to a policy issue for  
17 new plant licensing. And if you're going to do it on  
18 a technology-neutral basis, and do it in a risk-  
19 informed way, your goals are -- once again, they're  
20 not criteria that have to be met.

21 I think they are shooting for criteria  
22 that have to be met for new plants to be licensed. I  
23 applaud them for this, because this business of the  
24 goals has been a burr in my saddle for a long time.

25 MEMBER APOSTOLAKIS: I think it's going to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 be very hard to actually get criteria --

2 MS. DROUIN: What we're saying here is  
3 that when we look at the framework, you know, we're  
4 trying to set the safety -- the level of safety that  
5 we want this framework to achieve, so that when we  
6 develop the criteria and the guidelines, and we  
7 implement these criteria and guidelines and write the  
8 technology-neutral regulations, when the licensee has  
9 met those regulations that risk level, that level of  
10 safety, has been achieved.

11 So it's how it -- how it's going to help  
12 us formulate how we write the regulations. So this  
13 isn't going to be some goal that's going to be out  
14 there for the licensees to go off and achieve. It's  
15 the goal -- it's the target or the limit that we want  
16 to set within our framework, so that when we try and  
17 meet the expectation of enhanced safety, when they've  
18 met these regulations, they have met this level of  
19 safety.

20 MEMBER APOSTOLAKIS: But isn't that the  
21 same thing that we're doing now, that the agency is  
22 saying if you meet our regulations, there's no undue  
23 risk that the -- not disagreement, but the point is  
24 that the agency refuses to say what this undue risk  
25 is. It just says, "If you meet our regulations, there

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 is no undue risk to public health and safety." And I  
2 think you are following the same thinking.

3 MEMBER KRESS: No, I think they're  
4 defining what undue risk is.

5 MEMBER APOSTOLAKIS: Yes. And I just --  
6 I have a problem defining that. We've heard so many  
7 times in this room that the determination of no undue  
8 risk is the result of a long process which uses  
9 quantitative measures, calculations, plus a lot of  
10 judgment. So are you now going to eliminate the  
11 judgment?

12 MEMBER KRESS: Well, not exactly, no. But  
13 we're going to put quantitative values on this undue  
14 risk.

15 MEMBER APOSTOLAKIS: So you're rapidly  
16 galloping towards risk-based regulation.

17 MEMBER KRESS: Oh, no. There will be  
18 defense-in-depth associated with it.

19 MS. DROUIN: No. There's going to be  
20 defense-in-depth in there, there's going to be --

21 MEMBER KRESS: I mean, you can't get away  
22 from the fact --

23 MEMBER APOSTOLAKIS: Why do you think this  
24 is important to do?

25 MEMBER KRESS: Well, personally, I think

1 it would be difficult to write a technology-neutral  
2 framework without something like that as the anchor to  
3 the thing.

4 MEMBER APOSTOLAKIS: It could be easily a  
5 goal.

6 CHAIRMAN WALLIS: But, George, it's also  
7 important I think for the public -- I mean, this  
8 vagueness about, "If you meet the regulations, it's  
9 okay," that could mean anything. But if you say,  
10 "Your risk is so much," you have given them something  
11 definite.

12 MEMBER KRESS: It's time we got away from  
13 that business of --

14 MR. THADANI: Mr. Chairman, if I may  
15 comment on this subject matter. You said meeting the  
16 regulations means no undue risk, but legally what you  
17 would hear would be substantial compliance with  
18 regulations. And now you have to define what you mean  
19 by substantial. And you can see some relationship  
20 now.

21 MEMBER APOSTOLAKIS: But that makes it  
22 even weaker.

23 MS. DROUIN: When we get into the options,  
24 you will see one option is we -- we continue business  
25 as usual. That is one option.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER KRESS: It's always an option.

2 MS. DROUIN: Not the one that we're  
3 recommending.

4 CHAIRMAN WALLIS: I think we have to let  
5 Mary go ahead.

6 MEMBER KRESS: Yes, Mary, go ahead. We --

7 CHAIRMAN WALLIS: She's got a lot to say.

8 MS. DROUIN: In coming up with the options  
9 and guidelines, we follow the same guidelines that  
10 were discussed in SECY-03-0047. There were these six  
11 guidelines that we noted to the Commission. We saw no  
12 reason for coming up with new guidelines. I mean,  
13 these are all related to the same -- all these policy  
14 issues are related, and we thought we should be  
15 consistent.

16 CHAIRMAN WALLIS: Well, how does number 1  
17 fit in with enhanced safety? I mean, it's got the  
18 same risk, but you're doing enhanced safety. How can  
19 you do that?

20 MS. DROUIN: Consistent with the  
21 Commission's policy statement on the safety goals.

22 CHAIRMAN WALLIS: Do you mean the present  
23 risk is not consistent?

24 MS. DROUIN: No, the present --

25 MEMBER SIEBER: For a few plants, it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 true.

2 MS. DROUIN: I'm talking about that when  
3 you look at enhanced safety --

4 CHAIRMAN WALLIS: How can you enhance  
5 safety by keeping the risk the same as it was in '86?

6 MS. DROUIN: I don't think that says that.

7 CHAIRMAN WALLIS: Well, it seems --

8 MS. DROUIN: It says consistent.

9 CHAIRMAN WALLIS: -- it needs to say that.

10 MS. DROUIN: And consistent to me is --  
11 does not mean the same. The same means it's exactly  
12 the same.

13 CHAIRMAN WALLIS: So by enhanced safety,  
14 then you mean the risk is not consistent now? I mean,  
15 I have trouble with the logic, but --

16 VICE CHAIRMAN SHACK: If it's less than it  
17 is now, it's still consistent with the safety goal.

18 MS. DROUIN: It's still consistent.

19 CHAIRMAN WALLIS: Because safety goals are  
20 somewhere way above our present performance?

21 VICE CHAIRMAN SHACK: No. No.

22 CHAIRMAN WALLIS: Well, then, how can you  
23 enhance --

24 VICE CHAIRMAN SHACK: But you're meeting  
25 the goal. If you're much less than the goal, you're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 meeting the goal.

2 MEMBER SIEBER: In space.

3 MS. DROUIN: These are what we're using  
4 for the options we have, and we don't want to propose  
5 an option that's inconsistent --

6 MEMBER KRESS: It's guidance on how  
7 you're --

8 MS. DROUIN: Right.

9 MEMBER KRESS: -- going to go about  
10 formulating your options.

11 MS. DROUIN: That's right. We want it to  
12 be risk-informed, we want it to be performance-based,  
13 we want to use a technology-neutral approach. We want  
14 to use the Commission's performance goals that are in  
15 the strategic plan that deal with safety, efficiency,  
16 effectiveness, openness. We want to consider previous  
17 Commission guidance on these issues. I'm going to get  
18 into those in the next slides.

19 And we want to look at the practicality.  
20 You know, is the approach feasible? You know, what  
21 are the time and resources that it would take to  
22 implement that option? So these were all the things  
23 that we used in formulating and evaluating the  
24 different options we came up with.

25 CHAIRMAN WALLIS: Now, the safety goals

1 are related to the probability of getting cancer or  
2 something like that?

3 MS. DROUIN: You have two safety goals.  
4 You have your early fatalities and your latent  
5 cancers.

6 CHAIRMAN WALLIS: So that as medical  
7 treatment of cancers improves, the safety goals  
8 change.

9 MEMBER APOSTOLAKIS: Or as people quit  
10 smoking.

11 CHAIRMAN WALLIS: Yes.

12 MEMBER APOSTOLAKIS: Yes. These are  
13 questions the agency faced 30 years ago, so --

14 MEMBER KRESS: Yes. They've decided to  
15 look at it at one particular year and fix it there.  
16 You know, both goals change with time, because one of  
17 them has to do with the normal level of accidents,  
18 but --

19 MEMBER POWERS: Why would you do that? I  
20 mean, I agree with you the decision has been made to  
21 do that. But I thought one of the beauties of  
22 defining the goal, as it were, is -- the way they did  
23 was that, in fact, it recognized that as societies  
24 become richer they become more risk-averse.

25 MEMBER DENNING: One problem with those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 goals that I'd like to comment on, though, and that is  
2 their individual goals. They're not well suited  
3 towards cost-benefit plans and considerations. Have  
4 you considered options related to more societal-  
5 related goals rather than these individual-oriented  
6 goals?

7 MS. DROUIN: Can you bear with me as we go  
8 through? I mean, I'm hoping we're going to cover all  
9 of these as we go through each of the options, and  
10 we're going to go through the pros and cons of each  
11 one.

12 MEMBER BONACA: The other question that I  
13 had with regard to the previous slide -- it's  
14 interesting. I mean, there is no definition. However  
15 -- or no consideration of how many plants you may have  
16 in this country at some point in the future.

17 MS. DROUIN: Well, when you look at a  
18 nationwide goal or limit, and you try and set that --  
19 and essentially what you're doing is setting a limit  
20 on the number of plants that could be built, because  
21 as you --

22 MEMBER BONACA: Or setting an objective  
23 for the level of safety of the individual plants. I  
24 mean --

25 MEMBER KRESS: Well, as we argued once

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 before, I think that -- that has to be dealt with with  
2 the equivalent of the core damage frequency.

3 MEMBER APOSTOLAKIS: That's right.

4 MEMBER KRESS: And it ought to be  
5 addressed somewhere in there.

6 MEMBER APOSTOLAKIS: Not here.

7 MEMBER KRESS: Not -- not in here.

8 MS. DROUIN: And you start getting into  
9 legal problems when you look at it.

10 MEMBER BONACA: Well, you're talking about  
11 policy. I asked the question -- there has been some  
12 discussion of -- or the issue I guess -- it became  
13 moot when the construction stopped. At that point --  
14 but certainly when there were objectives of --

15 MEMBER APOSTOLAKIS: But there was an  
16 assumption that there would be something like 1,000  
17 plants.

18 MEMBER BONACA: Yes, you're right. So --

19 MEMBER POWERS: Why would you do that,  
20 Tom? I mean, it seems to me that when we calculate  
21 consequence analyses we carry those out first to 10  
22 miles, and then they go as far as 50, and in some  
23 cases, more for interest than anything else, you carry  
24 them out to 500, though by that time the results are  
25 kind of flaky at that point anyway.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           So if I take an individual wandering  
2 around Knoxville, for instance, he is not susceptible  
3 to the impacts from all of the reactors in the  
4 country. He is only susceptible to those within 25  
5 kilometers or so of him.

6           I mean, it seems to me that it's not the  
7 total number of powerplants in the vicinity -- I mean,  
8 in the nation. It's just those close to it.

9           MEMBER KRESS: Well, I have two minds on  
10 that. One of them is if you're dealing with -- with  
11 the prompt fatalities, latent fatalities, and societal  
12 effects, it does deal with strictly the plants that  
13 are within your vicinity. They don't care about the  
14 plant across the country on there. You set the limits  
15 based on what plants you can be impacted by.

16           The core damage frequency, on the other  
17 hand, is -- is not to me a -- a -- it's a design  
18 parameter that expresses a desire not to have a core  
19 damaging event anywhere in the whole world, because an  
20 accident anywhere is an accident everywhere is the  
21 concept.

22           So it's a -- once again, it's a policy  
23 thing. This is a desire that people have, or the  
24 Commission has, and it may not be logical from the  
25 standpoint of -- of how to protect individuals around

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the plant. But it is, in my mind -- you know, if you  
2 have --

3 MEMBER POWERS: I agree with that, but I  
4 don't quite understand why that translates into a  
5 nationwide or a worldwide consideration in the number  
6 of reactors.

7 MEMBER KRESS: Oh. Well, my feeling is if  
8 you had a -- let's just talk about LWRs, so we know  
9 what we're talking about with the core damage  
10 frequency. If you had a core damage frequency of  $10^{-4}$   
11 per hundred LWRs in this country, there is a certain  
12 expectation of having a core damage event over a given  
13 amount of time of the life.

14 Now, if you had 1,000 reactors, that  
15 expectation is 10 times as high. And, once again,  
16 it's -- what is an acceptable frequency of that is --  
17 is a policy-type thing. But once we decide on what it  
18 is, it is, in my mind, associated with the total  
19 number of reactors, especially in this country and  
20 worldwide, and it's also associated with how long they  
21 exist, both time -- time in which they operate and the  
22 number of them, impacts on whether or not there is a  
23 certain probability of having a core damage event.

24 So in my mind, if you're interested in  
25 limiting that probability, you set a limit on the core

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 damage frequency and that will -- that limit should  
2 depend on the total number of reactors you have and  
3 how long they are expected to exist. This --

4 CHAIRMAN WALLIS: Well, I think, too, you  
5 can't just do it on individual risk. I think a guy  
6 sitting in Vermont would feel very disconcerted if  
7 people in California were killed by an event. It's  
8 not just my risk that's concerned. It's --

9 MEMBER KRESS: Well, that's one reason you  
10 want --

11 MEMBER POWERS: You're extraordinarily  
12 generous. I'm not sure I would --

13 CHAIRMAN WALLIS: I don't know about New  
14 Mexico, but, you know --

15 MEMBER KRESS: Well, I think there would  
16 be hell to pay if we had a risk that had a core damage  
17 event anyway.

18 MEMBER POWERS: You're just gringos over  
19 there. We don't really care.

20 MEMBER KRESS: Yes, let's go on.

21 CHAIRMAN WALLIS: Yes, we've got to move  
22 on. This is a huge --

23 MS. DROUIN: Okay.

24 CHAIRMAN WALLIS: -- topic, really.

25 MS. DROUIN: There's three policy

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 statements that we used quite a bit in coming up with  
2 our options in the evaluation. The first one is on  
3 the advanced nuclear powerplants, and this is the one  
4 where the Commission has given direction and said that  
5 they expect that the advanced reactor designs will  
6 comply with the Commission's safety goal policy  
7 statement.

8 Then, when you look at the policy  
9 statement on several reactor accident, this is -- they  
10 had two comments that are important, where the  
11 Commission has determined that these plants -- and  
12 they're talking about the existing ones -- pose no  
13 undue risk, but they do expect that for your advanced  
14 reactors that you have a higher standard of safety --  
15 severe accident safety performance.

16 MEMBER KRESS: This is real governmentese,  
17 isn't it?

18 MS. DROUIN: Yes. And then, when you look  
19 at the policy statement on the safety goals, again,  
20 the Commission repeated that the current plants are  
21 posing no undue risk, that our regulatory practices  
22 are ensuring that the basic statutory requirements,  
23 adequate protection of the public is met. So --

24 CHAIRMAN WALLIS: Well, saying that  
25 something should be bigger doesn't really say

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 anything. It doesn't say by how much. I mean --

2 MEMBER KRESS: That's why I said it's real  
3 governmentese.

4 MEMBER APOSTOLAKIS: Well, the Commission  
5 can do that.

6 CHAIRMAN WALLIS: Well, how long are they  
7 going to wait until --

8 MEMBER APOSTOLAKIS: The Commission  
9 doesn't have to --

10 CHAIRMAN WALLIS: -- they say by how much?

11 MS. DROUIN: Well, that's what we're  
12 doing.

13 MEMBER KRESS: That's Mary's job. She's  
14 going to --

15 MEMBER APOSTOLAKIS: That's Mary's job.

16 MS. DROUIN: Well, supposing what we --  
17 what we mean by that -- this is our interpretation of  
18 these policy statements.

19 MEMBER KRESS: And it's our job to say  
20 whether we agree or not.

21 MEMBER APOSTOLAKIS: Okay. Let's move on  
22 to the real thing now.

23 (Laughter.)

24 MS. DROUIN: So here are the two issues.  
25 You know, what shall be the minimum level of safety

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that new plants need to meet to achieve the enhanced  
2 safety? We're defining that. And how shall the risk  
3 from the multiple reactors -- you can say multiple or  
4 modular issues. We have more than one reactor,  
5 regardless of its size, at a single site. How should  
6 that integrated risk be accounted for?

7 MEMBER APOSTOLAKIS: Very good.

8 MS. DROUIN: Okay. The first issue -- we  
9 have four options that we have identified. The first  
10 option is we say we're just going to use the current  
11 process, so that we would not explicitly define what  
12 we mean by "minimum level of safety" that you need in  
13 defining enhanced safety. So in a case-by-case  
14 determination, you would be making this.

15 So in the near term, on your ongoing  
16 preapplication reviews, each time you would make --  
17 you would come up with whatever criteria you're going  
18 to come up with to determine what you mean by enhanced  
19 safety.

20 MEMBER KRESS: It sounds like a terrible  
21 option.

22 MS. DROUIN: And it also means that in the  
23 technology-neutral framework, we would not specify it.  
24 So --

25 MEMBER APOSTOLAKIS: I think it's better

1 to say is not quantitatively defined, not explicitly.

2 MS. DROUIN: It's not defined.

3 MEMBER APOSTOLAKIS: Quantitatively.

4 MS. DROUIN: Qualitatively -- we don't  
5 define it now qualitatively.

6 CHAIRMAN WALLIS: How would you do it non-  
7 quantitatively?

8 MEMBER APOSTOLAKIS: I give you five  
9 rules. If you meet them, I have explicitly specified  
10 my level of safety. Meet those five and you're okay.  
11 Now, Ashok makes it a little worse by saying  
12 "substantially." Okay. Meet four out of the five and  
13 you are okay. I am not quantitative, but I'm very  
14 explicit, right?

15 CHAIRMAN WALLIS: But you haven't defined  
16 the level of safety.

17 MEMBER APOSTOLAKIS: Right now, you have  
18 to meet the rules.

19 CHAIRMAN WALLIS: You haven't defined the  
20 level of safety. You've just defined the rules.

21 MEMBER KRESS: I don't think we can dwell  
22 much on option 1, because I don't think anybody is  
23 going to support it.

24 MEMBER APOSTOLAKIS: I think realistically  
25 this is probably the only one that will survive,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       though.

2                   MEMBER ROSEN:   Unless we start talking  
3       about the others, it will.

4                   MEMBER APOSTOLAKIS:   Okay.   Thank you.

5                   MS. DROUIN:   Option 2, this is the one  
6       where you define the minimum level of safety as the  
7       quantitative health objectives.   So the QHOs, as  
8       expressed in the safety goal policy statement, we will  
9       use those to define the minimum level of safety to  
10      demonstrate that enhanced safety has been achieved for  
11      new reactor designs.

12                   The QHOs would be used to assess in the --  
13      for our current reviews under -- our current designs  
14      under review.   We will be using the QHOs right now to  
15      determine that enhanced safety has been met.   This  
16      would be integrated right into the framework at the  
17      very beginning, defining the level of safety.

18                   So,   again,   the   technology-neutral  
19      regulations would be written, you know, such that when  
20      they're met the safety goal level of safety would be  
21      achieved.

22                   MEMBER DENNING:   Mary, how is that  
23      currently interpreted as far as multi-unit plants per  
24      site that have the same boundaries, the same one mile,  
25      the same 10 mile?   Like if you have 10 reactors, does

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that force each one to be one-tenth of the total or --

2 MS. DROUIN: Now you're talking about  
3 integrated risk, and that's the next issue. That's  
4 the next issue.

5 MEMBER DENNING: But today how is that  
6 interpreted? It's just per plant, isn't it? They  
7 don't --

8 MS. DROUIN: This is per plant.

9 MEMBER DENNING: Even though that doesn't  
10 make any sense.

11 MS. DROUIN: It's just per plant. Right  
12 now, you don't have to look at integrated risk.

13 MEMBER APOSTOLAKIS: Let me -- there is a  
14 question here. On slide 5, you said that one of the  
15 general guidelines in assessing options was to be  
16 consistent with the Commission's 1986 policy statement  
17 on safety goals, which you are referring to here.

18 MS. DROUIN: Right.

19 MEMBER APOSTOLAKIS: But it seems to me  
20 you are not consistent, because the Commission never  
21 intended the QHOs to be minimum. They were goals, and  
22 they freely admitted that some of the plants can be  
23 above the goal. You are changing the nature of the  
24 Commission's statement. Is that still consistent with  
25 the Commission's statement?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. DROUIN: I don't think we're changing  
2 the nature.

3 MEMBER APOSTOLAKIS: You are making it  
4 minimum level.

5 MS. DROUIN: We're making it the minimum  
6 level. I think that's consistent.

7 MEMBER APOSTOLAKIS: That's not what they  
8 meant. I mean, in fact, I remember when the IPEs came  
9 out you told us that there were 19 units --

10 MS. DROUIN: That is for current set of  
11 plants.

12 MEMBER KRESS: That's right. The safety  
13 goals were intended strictly to apply to the current.  
14 Now we're going to take something that wasn't intended  
15 for future plants and try to fit it into future  
16 plants.

17 MEMBER APOSTOLAKIS: But we are  
18 interpreting that way. I don't think -- the statement  
19 by the Commission never says that.

20 MEMBER KRESS: Well, they didn't have the  
21 future plants in mind when they --

22 MEMBER APOSTOLAKIS: I'm sure that was --

23 MR. THADANI: Yes. Let me comment, Mary.  
24 Maybe I can help here. Tom is exactly right. Safety  
25 goals were developed and the statement -- policy

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 statement came out in 1986 reflecting current  
2 operating reactors, population of about 100 reactors,  
3 the sort of thinking that went into the development of  
4 that policy.

5 Since then, the Commission has approved,  
6 as you know, three advanced lightwater reactor  
7 designs. Part 52 of our regulations do go beyond what  
8 the current regulations are, and they do refer you to  
9 the issue -- what Mary is talking about.

10 And we have applied this in approval of  
11 the three advanced lightwater reactor designs -- meet  
12 the surrogate objectives as a minimum, and  $10^{-4}$  core  
13 damage frequency and  $10^{-5}$  large early release  
14 frequency. That's all there. That's  
15 reviewed/approved in our safety evaluation reports.

16 The Commission's statement goes beyond in  
17 terms of expectation. They expect these plants to be  
18 substantially safer. The question is: is  $10^{-4}$  still  
19 an appropriate surrogate objective? Are there factors  
20 that have changed since early to mid '80s that would  
21 say, "Let's rethink this policy"? What is happening  
22 worldwide? And have things changed here nationally  
23 that might influence that decision? And that's the  
24 real issue.

25 MEMBER APOSTOLAKIS: Well, I'm not saying



1 that this is wrong. I mean, you are offering a policy  
2 option to the Commission, and they are free to change  
3 if it is inconsistent with the earlier statement.  
4 They are the ones setting the policy, so there's no  
5 problem with that.

6 I'm just wondering whether you have really  
7 -- whether you are sensitive to the fact that this is  
8 not really consistent with the original --

9 CHAIRMAN WALLIS: I think that's a good --  
10 you might want to rewrite the statement on page 5, so  
11 that it lets you do this. So that there doesn't  
12 appear to be this inconsistency.

13 MEMBER APOSTOLAKIS: But it's a policy  
14 proposal, so it can be different. It's a different  
15 interpretation of what they said almost 20 years ago.

16 CHAIRMAN WALLIS: To go back to this page,  
17 Mary, it seems to me that QHOs only refer to dose to  
18 the public, so LERF becomes the only measure. CDF is  
19 unimportant with this option, and you could have a  
20 very good containment and a not so good ECCS system.  
21 LERF is the only measurement, right?

22 MEMBER APOSTOLAKIS: No, not even LERF.

23 CHAIRMAN WALLIS: Well, actually, the  
24 consequences of the LERF are the -- right.

25 MEMBER ROSEN: Or you could have fuel

1 that's so robust that it never lets the fission  
2 products out.

3 CHAIRMAN WALLIS: I just wanted to  
4 clarify, that's what you're saying with this slide.

5 MEMBER ROSEN: It's not just the  
6 discussion of containment.

7 MS. DROUIN: Not exactly. And I'm going  
8 to get back to that when we come into the advantages  
9 and disadvantages.

10 CHAIRMAN WALLIS: Well, that's what it  
11 appears to be saying. CDF is unimportant. You are  
12 looking at dose --

13 MS. DROUIN: That's not what this is  
14 saying.

15 CHAIRMAN WALLIS: Well, that's what it  
16 says to me.

17 MEMBER KRESS: Not necessarily.

18 MS. DROUIN: No. It says that, you know,  
19 at the minimum level we're going to write the  
20 regulations to ensure that people meet both of those  
21 safety goals.

22 MEMBER KRESS: Well, let me reiterate --

23 MS. DROUIN: The early fatalities and the  
24 latent fatalities.

25 MEMBER KRESS: Let me reiterate something

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Rich said, and that is if -- if you look at the  
2 current structure of the regulations, hidden in  
3 various places in there are things having to do with  
4 societal risk. That's total deaths, total cancers,  
5 land contamination. These things are hidden in the  
6 regulations in things like site characteristics and  
7 things to -- they're in there, and they're -- in my  
8 mind, societal risk, although it's implicit to most --  
9 to most extent, is part of adequate protection.

10 Now, if you want to capture the current  
11 regulatory structure in a technology-neutral way, it  
12 seems to me like you have to capture the societal risk  
13 somewhere. QHOs don't do it.

14 Now, my feeling is that you need some --  
15 QHOs are fine. I love them. But you need something  
16 else to capture societal risk, so I think this is an  
17 incomplete statement of the minimum level of safety.  
18 Could you react to that?

19 CHAIRMAN WALLIS: So what you're saying,  
20 Tom, is that you could have an accident which was  
21 slow, late release --

22 MEMBER KRESS: Oh, yes.

23 CHAIRMAN WALLIS: -- and you evacuate  
24 everybody, there's no fatalities, no one has any dose  
25 of any sort --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER KRESS: That's right.

2 CHAIRMAN WALLIS: -- and yet you cannot go  
3 back over 1,000 square miles.

4 MEMBER APOSTOLAKIS: No, you can't do  
5 that, because the QHOs require you to assume that  
6 there is one guy at the perimeter.

7 CHAIRMAN WALLIS: Well, that's a stupid  
8 guy.

9 MEMBER APOSTOLAKIS: You do not evacuate  
10 that guy.

11 (Laughter.)

12 CHAIRMAN WALLIS: That's a very strange  
13 regulation.

14 MEMBER APOSTOLAKIS: Because it's  
15 individual; it's not societal.

16 MEMBER KRESS: That's not true. It's  
17 calculated by looking at the one-mile zone and seeing  
18 how many prompt fatalities you have divided by the  
19 population of that one-mile zone. That has nothing to  
20 do with guy on the --

21 MEMBER APOSTOLAKIS: But you can't say  
22 that if I build a reactor in the middle of a desert  
23 there is nobody around; therefore, I automatically  
24 meet the QHOs.

25 MEMBER KRESS: Yes, you can.

1 MEMBER APOSTOLAKIS: The Commission would  
2 never accept that.

3 MEMBER KRESS: Yes, you can, though.

4 MEMBER APOSTOLAKIS: No.

5 MEMBER KRESS: You can do that.

6 MEMBER APOSTOLAKIS: This is how it's  
7 calculated, guys. I mean, we've had this discussion  
8 before. This is how --

9 MEMBER DENNING: He said the way it was  
10 calculated, not -- you don't put a guy at the  
11 fencepost. That's different. You're talking about --

12 MEMBER KRESS: That's for 10 CFR 100.  
13 That's part of the regulations, but it's not --

14 CHAIRMAN WALLIS: You can buy the reactor  
15 and have as many core damages as you'd like and not  
16 release anything, not hurt anybody, meets the QHOs.

17 MEMBER APOSTOLAKIS: And I still don't  
18 think that's acceptable.

19 CHAIRMAN WALLIS: Why not?

20 MEMBER APOSTOLAKIS: Because you can't  
21 melt the reactor.

22 CHAIRMAN WALLIS: Well, George, you are  
23 always the guy who wants to think outside the box, and  
24 you're giving us all these constraints of how you  
25 can't think about that.

1 MEMBER APOSTOLAKIS: I still stay within  
2 the box there. You don't want the reactor to be  
3 melting -- to melt.

4 CHAIRMAN WALLIS: I know. You're giving  
5 us too many constraints, I think. This would be a  
6 more open conversation.

7 MEMBER ROSEN: I don't want the  
8 conversation to be more open.

9 (Laughter.)

10 CHAIRMAN WALLIS: Well, you're the most  
11 conservative liberal around here.

12 MS. DROUIN: Well, what I really wanted to  
13 try to get was --

14 MEMBER APOSTOLAKIS: Wait a minute.

15 MS. DROUIN: -- these four options, and  
16 then come back and go through the advantages and  
17 disadvantages of each.

18 MEMBER APOSTOLAKIS: I want to understand  
19 this issue. As I recall, the policy statement says  
20 that the individual risk or the guy, you know, within  
21 so many miles will have this probability of death. It  
22 doesn't say that you can take this guy and evacuate  
23 him.

24 Now, when it comes to how we calculate,  
25 maybe if we calculate the total number and divide by

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the number of people --

2 MEMBER KRESS: We don't calculate them  
3 because it's an --

4 MEMBER APOSTOLAKIS: I don't think the  
5 intent of the QHOS was that if there is nobody around  
6 you can melt and do whatever you like. That was never  
7 the intent. And I think this issue has been raised in  
8 the past, and we talked about it and we said, "Well,  
9 this is how it's calculated, really, but the intent  
10 was something else."

11 I think if you go back, it will say the  
12 general accident and probability of death due to  
13 accidents for an individual in the United States is  
14 three  $10^{-4}$ . That individual -- the risk from reactors  
15 should be 1,000 times less. That's what it says.

16 CHAIRMAN WALLIS: So if it's in the  
17 desert --

18 MEMBER APOSTOLAKIS: That doesn't put him  
19 here or put him there.

20 CHAIRMAN WALLIS: So if it's in the  
21 desert, the risk to him is going to be much less.

22 MEMBER APOSTOLAKIS: No, that's not the  
23 intent.

24 MEMBER DENNING: Well, in a sense, George  
25 is right, because if there's somebody effectively

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 there, then he is exposed to the risk. I mean, it is  
2 divided by the number of people. But, you know, the  
3 things like the plume dimension, and stuff like that,  
4 those do reduce the risk to the people within one  
5 mile, and stuff like that.

6 MEMBER APOSTOLAKIS: Absolutely.  
7 Absolutely.

8 MEMBER DENNING: So we're going to move  
9 on, then.

10 MS. DROUIN: Okay.

11 MEMBER KRESS: But still keep in mind this  
12 question of societal risk.

13 MS. DROUIN: Okay. Option 3 is we say  
14 that we would actually define some risk objectives,  
15 some type of surrogate for the minimum level of  
16 safety.

17 MEMBER KRESS: Now that doesn't mean you  
18 might define a societal risk objective. That's just  
19 a surrogate for the QHO.

20 MS. DROUIN: Right. Surrogate --

21 MEMBER KRESS: So this is not the option  
22 I was talking about with 2.

23 MEMBER APOSTOLAKIS: So this is not other  
24 risk objectives. This is a subsidiary objective.

25 CHAIRMAN WALLIS: Other surrogates.



1 MEMBER APOSTOLAKIS: Surrogates.

2 MS. DROUIN: Some type of surrogates.

3 MEMBER APOSTOLAKIS: But it seems to me  
4 that as a result of all these discussions, somewhere  
5 in there, or perhaps in option 2, you should say that  
6 -- define the minimum level of safety as a  
7 quantitatively-held objective, with some option to  
8 enlarge the set.

9 MEMBER KRESS: Yes, that would be my --

10 MEMBER APOSTOLAKIS: I think, you know,  
11 like land contamination or societal risk or something.  
12 I mean, we don't necessarily have to stick to the '86  
13 goals if we are reopening the issue. And let the  
14 Commission decide whether they want to do that.

15 MS. DROUIN: Option 4, develop new QHOs.

16 MEMBER APOSTOLAKIS: You're right. I  
17 should have looked at slide 11.

18 MEMBER KRESS: But, unfortunately, I think  
19 you have in mind there change in the prompt fatality  
20 safety goal and the latent, but we may think those are  
21 all right, but you're going to add something else to  
22 this.

23 MS. DROUIN: No, this --

24 MEMBER ROSEN: I don't want to risk  
25 thinking what she might have in mind.

1 MEMBER KRESS: Okay. Yes, yes.

2 MEMBER ROSEN: I would prefer to know what  
3 she has in mind.

4 MS. DROUIN: There was not anything --  
5 they would be more stringent.

6 MEMBER APOSTOLAKIS: But it wouldn't be  
7 fun here if we didn't try to second guess Mary.

8 MS. DROUIN: It doesn't mean that they  
9 necessarily -- it doesn't mean that they wouldn't be  
10 broader.

11 MEMBER ROSEN: It does not mean that they  
12 would not be broader. It means they could be broader.

13 MS. DROUIN: It could be broader. But  
14 they would be more stringent, because we're trying to  
15 get to enhanced safety.

16 MEMBER ROSEN: So it could include land  
17 contamination.

18 MS. DROUIN: It could include land  
19 contamination.

20 CHAIRMAN WALLIS: So these are called  
21 health objectives. So what you really mean is develop  
22 new quantitative objectives?

23 MS. DROUIN: Yes. That was a -- we should  
24 not have probably put the word "health" there.

25 MEMBER KRESS: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: It seems to me not  
2 unreasonable to take a new look at these objectives  
3 when we've got the chance now, or ask the Commission  
4 to do it.

5 MEMBER APOSTOLAKIS: Are we still looking  
6 into this, by the way? Because the messages we're  
7 getting from the Commission is that this is not going  
8 to continue. I mean, are we really spending a lot of  
9 energy on something that will not continue?

10 I think that Commissioner Merrifield in  
11 particular said at the conference recently that we  
12 don't have money for all this. Nobody is asking for  
13 a new reactor, to build a new reactor, so why spend  
14 any effort on this? Is it something that this is a  
15 continuing effort?

16 MS. DROUIN: Well, all I can tell you is  
17 that I know that the Chairman is going to some  
18 conference -- I don't know if it's in Paris -- or  
19 something pretty recent, and all the topics that were  
20 sent up to the Chairman to select from the Office of  
21 Research to talk about, he picked one topic and it was  
22 on this program.

23 MEMBER APOSTOLAKIS: The new reactor  
24 licensing? Well, that's good.

25 MR. SCOTT: Can I insert something here?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 To clarify what Commissioner Merrifield said -- this  
2 is Mike Scott. Commissioner Merrifield said that --  
3 I think you're referring to his remarks at the RIC,  
4 right, George?

5 MEMBER APOSTOLAKIS: Yes.

6 MR. SCOTT: He was -- my understanding of  
7 what he was saying was that the next generation, the  
8 non-lightwater reactors, he saw as less likely. To  
9 say that they're not spending money on new reactors I  
10 think would be inaccurate. There's an expectation  
11 that a lot of money is going to be spent, because  
12 they're expecting combined license applications near  
13 term.

14 MEMBER APOSTOLAKIS: No, no. I think he  
15 made it very clear that thinking about a new  
16 regulatory system for future reactors is something  
17 that the agency cannot afford right now. It has too  
18 many commitments in terms of license renewal, in terms  
19 of all sorts of things.

20 MEMBER ROSEN: On the other hand, Mary and  
21 Marty are here, so somebody is paying them. Or unless  
22 you are pro bono today.

23 MS. DROUIN: No, we're not pro bono. It's  
24 in our budget. It's in our budget for fiscal year  
25 '06. This is what -- we've had, as you know, a myriad

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of SECY papers that have gone forward to the  
2 Commission. The Commission has not come back and  
3 said, "Don't do this."

4 MEMBER ROSEN: So let's keep on assuming  
5 -- let's go on on the assumption that the --

6 CHAIRMAN WALLIS: Yes. I think if we're  
7 going to write a letter, you're going to have to  
8 convince us of some of these advantages and  
9 disadvantages, so we can make a decision. We need to  
10 move on.

11 MS. DROUIN: Okay. Going back to  
12 option 1, using the current process, you know, we  
13 don't see that there's a lot of advantages there. You  
14 know, you aren't going to have to make any changes to  
15 the way we do business. You know, it provides the  
16 maximum flexibility -- that goes without saying.

17 But when you start looking at the  
18 disadvantages, you know, you -- not necessarily having  
19 a technology-neutral, risk-informed, or performance-  
20 based approach, it's not clear that it's supporting  
21 the Commission's expectations when you talk about  
22 enhanced safety in particular.

23 When you start looking at similar designs,  
24 you could lead to very different results. When you're  
25 doing this on a case-by-case basis, instead of just

1 fundamentally coming in and making it part of your  
2 structure, you're much more likely to be challenged by  
3 stakeholders. We don't think it's very scrutable,  
4 again, because you're doing everything on a case-by-  
5 case basis.

6 It relies a lot on subjective judgment.  
7 You know, I think we're going to get into result  
8 inconsistency and uniformity. One of the biggest  
9 things that the Commission has applauded this agency  
10 on is that with our current regulatory structure we  
11 have predictability and stability.

12 When you start looking for new plants,  
13 when you're doing this on a case by case, you  
14 certainly aren't promoting stability and  
15 predictability.

16 MEMBER APOSTOLAKIS: I would --

17 MS. DROUIN: So we think this one is -- is  
18 very fraught with disadvantages.

19 MEMBER APOSTOLAKIS: I think you went out  
20 of your way to identify disadvantages. It would be a  
21 little more convincing if you eliminated some of  
22 these. For example, reliance on subjective judgment  
23 -- I don't think any regulatory system will ever not  
24 rely on subjective judgment. You clearly don't like  
25 this, and you are beating it.

1 (Laughter.)

2 It's obvious to me. And if I were a  
3 Commissioner, I would send it back to you. I think  
4 you are right, but you should be a little bit more  
5 reserved in your criticism. Could lead to different  
6 results. Come on. Can you ever imagine a regulatory  
7 system that would always lead to the same result?

8 MS. DROUIN: Well, I think --

9 MEMBER APOSTOLAKIS: You have a lot of  
10 good points, though.

11 MS. DROUIN: These are all the same points  
12 we look at for each one of them. We give them all  
13 equal play.

14 MEMBER APOSTOLAKIS: So you're saying in  
15 the future there would be options that will not rely  
16 on subjective judgment.

17 MS. DROUIN: Well, I think when you come  
18 in and you define, "Here's our level of safety," it's  
19 the QHO. That's not subjective anymore, George.

20 MEMBER APOSTOLAKIS: But you have -- it  
21 says -- how do you call it? Ah, geez. On the left of  
22 your figure. Something about defense-in-depth and all  
23 that, and you have administrative stuff. What was the  
24 word that you used?

25 MS. DROUIN: Yes. But we're here at the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 high level, George. What is the minimum level? We're  
2 saying in this option you're not defining that, and  
3 you're going to define it. Each time a new applicant  
4 comes in, you're going to define it. You aren't --

5 MEMBER APOSTOLAKIS: That's right.

6 MS. DROUIN: That's subjective.

7 MEMBER APOSTOLAKIS: That's not --

8 MS. DROUIN: That's subjective.

9 MEMBER POWERS: Mary, I want to ask a  
10 question. Isn't one of the advantages of this that  
11 you can -- because it's a case-by-case decision all  
12 the time, can't you take account better of local  
13 conditions?

14 MS. DROUIN: I'm not sure what you mean  
15 when you say "local conditions."

16 MEMBER POWERS: The actual site where it's  
17 going to be located.

18 MS. DROUIN: Absolutely.

19 MEMBER POWERS: That may be what you mean  
20 by flexibility. I wondered if that doesn't need to  
21 deserve a bullet of its own. I'm not sure you -- I  
22 guess what I'm saying is that maybe you need to expand  
23 a little bit on what you mean by flexibility.

24 MS. DROUIN: There.

25 MEMBER ROSEN: I, for one, know this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 devil. I'd like to hear about the new ones.

2 MS. DROUIN: Okay.

3 CHAIRMAN WALLIS: I would, too, because I  
4 think the current process just cannot be used for some  
5 new designs. It's not a question of using it -- the  
6 advantages. It just doesn't apply.

7 MEMBER POWERS: Could you explain that a  
8 little more?

9 CHAIRMAN WALLIS: That's why they have a  
10 design which has different -- has confinement rather  
11 than containment, has a fuel which is claimed can  
12 never had a core damage accident, and so on. I mean,  
13 how do you apply the present rules to that sort of  
14 thing?

15 MEMBER POWERS: I mean, I don't -- I've  
16 never seen a difficulty with confinement versus  
17 containment, if it's properly implemented. I can't  
18 imagine a core that would be immune to any kind of a  
19 damaging event. I simply can't imagine that.

20 CHAIRMAN WALLIS: Well, except fire.  
21 Let's say fire -- well, but there are so many  
22 regulations now that are specific to lightwater  
23 reactors.

24 MS. DROUIN: This is not saying that when  
25 you look at the -- all this is saying is that when you

1 get in the new design, we're trying to determine if  
2 that new design has achieved enhanced safety. That's  
3 what the issue is here.

4 It's not whether or not what regulation  
5 under the current process applies, you know, because  
6 it -- for the current -- a new design that's going to  
7 come in right now, that's under current review,  
8 they're going to have to make the determination --  
9 right now they're doing it on an ad hoc basis, and  
10 they're going to make the determination based on  
11 something that's not defined -- has that design  
12 achieved enhanced safety?

13 We're saying we want to define what we  
14 mean by that. So the next three options provide a  
15 definition.

16 CHAIRMAN WALLIS: So the disadvantage of  
17 the present system is it does not clearly define the  
18 level of safety.

19 MS. DROUIN: It doesn't define what you  
20 mean by "enhanced safety," what is that minimum safety  
21 that if you reach you have achieved enhanced safety in  
22 that design.

23 CHAIRMAN WALLIS: So option 1 doesn't meet  
24 your requirements right then and there. We have to go  
25 on to this one.

1 MS. DROUIN: Okay.

2 MEMBER SIEBER: And this one doesn't  
3 either.

4 MS. DROUIN: No, this one does. Option 2  
5 does. Enhanced.

6 CHAIRMAN WALLIS: Are we talking about --

7 MEMBER SIEBER: Only by virtue of the fact  
8 that not all existing reactors meet the current set.

9 MS. DROUIN: Well, that's a misleading  
10 statement, because --

11 MEMBER SIEBER: I apologize.

12 (Laughter.)

13 MS. DROUIN: The reason is when you look  
14 at the current set of regulations, and you calculate  
15 the risk based on what they have to do just to meet  
16 the current regulations, there's not a plant that will  
17 meet the safety goals.

18 MEMBER SIEBER: Okay.

19 MS. DROUIN: Because they take credit, and  
20 rightfully so, for things but they -- they don't -- a  
21 BWR, for example, to me that's the easiest plant to  
22 demonstrate it with. They meet the safety goal,  
23 because they take credit for a lot of systems that  
24 they aren't required to have.

25 MEMBER SIEBER: Right. Well, there are --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. DROUIN: Now, if you calculated the  
2 risk and removed the credit for those things, and only  
3 gave credit for what they're required to have to meet  
4 those safety functions, they aren't going to come  
5 close to meeting the safety goals.

6 MEMBER KRESS: You're absolutely right,  
7 Mary.

8 MEMBER SIEBER: And I like this one the  
9 best.

10 MS. DROUIN: So now those things that --

11 MEMBER APOSTOLAKIS: So what is the  
12 conclusion from this argument? I mean, this is a good  
13 argument.

14 MS. DROUIN: I'm saying that when you now  
15 are required to meet the safety goals, which means we  
16 are now going to write the regulations, they would,  
17 for example, have to have -- they'd have to have more  
18 than just their present ECCS.

19 MEMBER APOSTOLAKIS: And why, since they  
20 were not required to have those systems, they  
21 installed them anyway?

22 MS. DROUIN: Well, they didn't install  
23 them for that function.

24 MEMBER KRESS: They were there.

25 MS. DROUIN: They were there.

1 MEMBER KRESS: They had to take advantage  
2 of it.

3 MS. DROUIN: And they're taking advantage  
4 of them. The service water --

5 MEMBER KRESS: Well, like the hydraulic  
6 system that drives the control rods.

7 MEMBER APOSTOLAKIS: Oh, okay.

8 MEMBER SIEBER: And it also puts water in.

9 MS. DROUIN: It always put water in.

10 MEMBER KRESS: Yes. I don't see Level 3  
11 PRA being a disadvantage.

12 (Laughter.)

13 MEMBER DENNING: Be a little more  
14 specific, Mary, in terms of what really meets the goal  
15 in your interpretation? You do a Level 3 PRA that's  
16 got uncertainties. What corresponds now to meeting  
17 the goals, the .1 percent goals? What do you say,  
18 then, makes the -- you meet the goal?

19 You're a plant. Are you saying there's a  
20 regulatory requirement that you have to do a Level 3  
21 PRA and with the median value or the 95th percentile  
22 value? What specifically is this saying that Level 3  
23 PRA has to do?

24 MS. DROUIN: You're going to have to go  
25 and calculate all the way to your Level 3 in your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 consequences.

2 MEMBER DENNING: Okay. And then, what  
3 corresponds -- what says that you've met the .1  
4 percent? What's your level of confidence, then, from  
5 the PRA?

6 MS. DROUIN: Well, that would all have  
7 to -- first of all, that would all have to be worked  
8 out.

9 MEMBER KRESS: If you go by the safety  
10 goals, it would be the mean. And I hope you -- I hope  
11 you get away from that, though.

12 MS. DROUIN: In terms of, you know, the  
13 uncertainties are going to have to be addressed.

14 MEMBER DENNING: Now, is this just  
15 conceptual, or is this every plant then has to do the  
16 Level 3 PRA before it's constructed? And then, what  
17 happens when you construct it and you've got a real  
18 plant, and you no longer satisfy it? You've got to  
19 then make whatever changes are necessary to get you  
20 below the goal? Is that what happens?

21 Because, I mean, you know -- I mean, if  
22 we're talking about a future plant, there's no reality  
23 to that PRA. I mean, if we say there's reality in the  
24 PRAs we do today. I mean, even that has an element of  
25 -- a substantial element of judgment in it, and you do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 it for the plant --

2 MEMBER POWERS: It is, in fact,  
3 metaphysical.

4 MEMBER DENNING: What's that?

5 MEMBER POWERS: It is metaphysical.

6 MEMBER DENNING: Well, it is very much, I  
7 mean, just the concept of what does probability mean.  
8 It's a subjective assessment of the probabilities.  
9 But in any event, I'm just trying to get a feeling as  
10 to, are you really -- is this just conceptual, or is  
11 this -- what you're saying is this is really the basis  
12 of the regulatory framework, that people are going to  
13 have to do this PRA before they've constructed their  
14 plant, and that's really what the term --

15 MS. DROUIN: No.

16 MEMBER DENNING: -- acceptability or is  
17 this just conceptual?

18 MS. DROUIN: No.

19 MR. STUTZKE: This is Marty Stutzke, if I  
20 can jump in. Part 52 requires for design  
21 certification that a design-specific PRA be done.  
22 What we don't have now is the scope of that PRA. Just  
23 is it a Level 1, is it a Level 3, external events?  
24 It's not well specified how much PRA needs to be done  
25 currently.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER APOSTOLAKIS: But it seems to me  
2 there is another issue here. If you -- if the  
3 Commission accepts this, and the industry knows this,  
4 then there will be a lot of work, it seems to me,  
5 defining subsidiary goals, defining even design basis  
6 accidents perhaps, or something else -- the whole  
7 structure with which the designers will have to  
8 comply, and that structure will have as the anchoring  
9 point that the Level 3 PRA will meet whatever goal we  
10 have.

11 And so there will never a case where you  
12 -- you do this thing in the abstract and then you  
13 build a plant and you don't meet it. I mean, there  
14 will be a hell of a lot of requirements emanating from  
15 this that the actual designers will have to meet.

16 MS. DROUIN: that's right.

17 MEMBER ROSEN: It will be a --

18 MEMBER APOSTOLAKIS: And as a result --

19 MEMBER ROSEN: It will be a continuous  
20 touchstone during the design.

21 MEMBER APOSTOLAKIS: There will be  
22 feedback, of course.

23 MEMBER ROSEN: With the iterative use of  
24 the Level 3 PRA as the design matures and evolves.

25 MEMBER APOSTOLAKIS: Yes. So they are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 trying to anchor it somewhat, and there have been --

2 MEMBER ROSEN: It's perfectly reasonable.

3 MS. DROUIN: That's all we're saying.

4 MEMBER KRESS: Level 3 might even use a  
5 fictional site.

6 MEMBER APOSTOLAKIS: But I still think you  
7 are a little unfair. Your columns -- advantages and  
8 disadvantages -- betray your bias. And I think you  
9 will do much better without changing your actual  
10 recommendation by helping these a little bit.

11 CHAIRMAN WALLIS: You want an equal number  
12 on both sides for every one?

13 MEMBER APOSTOLAKIS: I don't know what I  
14 want.

15 (Laughter.)

16 CHAIRMAN WALLIS: Well, thank you.

17 MR. THADANI: Let me comment. Again, this  
18 is Ashok Thadani. I think, Mary, the committee might  
19 actually benefit a great deal in saying, when you talk  
20 about current process, do you mean Part 50 or Part 52?  
21 Because recognize there are additional requirements in  
22 Part 52 regarding -- relating to PRA and relating to  
23 safety goals.

24 CHAIRMAN WALLIS: Yes.

25 MR. THADANI: And so the committee should

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 recognize today's regulations for new reactor designs  
2 do call for certain things.

3 Now, in this proposal, how much further  
4 are we going -- proposing to go -- and the policy  
5 issues as they relate to those differences. I think  
6 it's -- it might help --

7 MS. DROUIN: I understand that, but -- but  
8 it doesn't tell you in Part 52 what is meant by  
9 enhanced safety. And that's why I have to keep  
10 bringing you all back to -- that's what we're talking  
11 about here is: how do we meet -- how do we implement  
12 -- the Commission has told us, and they approved for  
13 enhanced safety. They haven't told us how to  
14 interpret enhanced safety. Part 52 does not tell us,  
15 you know, an interpretation of enhanced safety.

16 MEMBER ROSEN: On the other question, does  
17 Part 52 tell us that they mean a Level 3 PRA?

18 MS. DROUIN: No.

19 MR. THADANI: It does relate to the scope  
20 of the PRA.

21 MEMBER ROSEN: But it doesn't tell us --  
22 I mean, it doesn't say Level 3. It says "all modes"?

23 MR. THADANI: It says "all modes" --  
24 internal, external.

25 MEMBER ROSEN: Right.

1 MR. THADANI: But it does not say Level 3.

2 MEMBER ROSEN: Right. And that's what  
3 this adds.

4 MR. THADANI: I understand. I want to be  
5 sure the committee recognizes that under Part 52 there  
6 are certain requirements in place for new reactor  
7 designs.

8 MEMBER ROSEN: I don't see that Level 3  
9 requirement as being showstopping. It just becomes,  
10 as George says, something that's used from the  
11 beginning 'til the end.

12 MEMBER APOSTOLAKIS: That's right.

13 MEMBER ROSEN: But this is good.

14 MEMBER APOSTOLAKIS: You're not going to  
15 license --

16 MEMBER ROSEN: Just as any other PRA,  
17 without Level 3, in future plants should be used from  
18 beginning to end and was used in the AP1000, and so  
19 on. They used it as a design tool. It's a very good  
20 thing to do.

21 MEMBER SIEBER: So the practice doesn't  
22 change. All you're doing is defining what it is you  
23 want.

24 MEMBER ROSEN: Right. Defining how to do  
25 it in more detail and broadening it somewhat.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER SIEBER: Yes.

2 MS. DROUIN: Okay. Option 3. Now, you  
3 know, we've moved away from using the specific QHOs,  
4 and we would actually define some other --

5 MEMBER SIEBER: Surrogates.

6 MS. DROUIN: -- some kind of surrogates,  
7 some other risk measures.

8 MEMBER APOSTOLAKIS: So this is surrogates  
9 now for the QHOs.

10 MS. DROUIN: Right.

11 MEMBER SIEBER: Which will be different,  
12 depending on the design.

13 MS. DROUIN: Well, that's where -- no, it  
14 would be technology-neutral.

15 MEMBER SIEBER: You would like it to be.

16 MS. DROUIN: Not like it to be. We've  
17 written -- we're creating a technology-neutral  
18 document, you know.

19 MEMBER APOSTOLAKIS: Don't you in your  
20 book, your report, on the new framework promote the  
21 idea of the consequence -- frequency consequence thing  
22 with the dose.

23 MS. DROUIN: Yes.

24 MEMBER APOSTOLAKIS: Well, that would seem  
25 to be a nice surrogate. In fact, that's what your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 report says, that this would apply to all reactors.  
2 So I -- I mean, there are ways -- you don't have to  
3 deal with LERF, which I agree is not always  
4 applicable. But the frequency consequence -- and  
5 then, of course, Dr. Kress has some ideas about what  
6 consequence is.

7 But the staff proposes dose, and it seems  
8 to me that's a reasonable thing to do.

9 MEMBER KRESS: That's not unreasonable.

10 MEMBER APOSTOLAKIS: It's a very  
11 reasonable thing to do. And the uncertainties will  
12 not be as large as in the Level 3, of course. I mean,  
13 here is one instance where it might work.

14 CHAIRMAN WALLIS: Well, one of the major  
15 consequences of a CDF, even if no one has heard --

16 MEMBER APOSTOLAKIS: No, this is not CDF.

17 CHAIRMAN WALLIS: -- it hurts the industry  
18 substantially, it hurts the agency --

19 MEMBER APOSTOLAKIS: Yes.

20 CHAIRMAN WALLIS: -- in all kinds of ways.  
21 That has to fall into the equation somehow.

22 MEMBER KRESS: Why are you switching --

23 MEMBER APOSTOLAKIS: Half an hour ago you  
24 were against --

25 CHAIRMAN WALLIS: Because you seem to be

1 restricting the conversation. We should open it up.  
2 Let her go through all these things.

3 MS. DROUIN: But I don't think that the  
4 frequency consequence -- that's a curve, that's a  
5 continuum. We're trying to set, you know, a limit.  
6 We're trying to come up with a surrogate. I don't  
7 view the frequency consequence curve as a surrogate.

8 MEMBER APOSTOLAKIS: Why not?

9 MS. DROUIN: I mean, it's a way of meeting  
10 a surrogate. But I don't --

11 VICE CHAIRMAN SHACK: Well, I mean, if you  
12 set the frequency consequence curve up, so that you  
13 meet your QHO, it's now a surrogate for the QHO.

14 MEMBER DENNING: What's your dose? How do  
15 you define your dose in that case, in that frequency  
16 consequence? Dose -- is it a population dose or what?

17 MS. DROUIN: We had two different options.  
18 It's been a while since I've thought about it, to be  
19 honest. We had talked about doses, but we had also  
20 talked about -- we had it in our --

21 MEMBER DENNING: Because if it's a  
22 population dose, it's a -- over a large population.  
23 It's not individual risk.

24 MS. DROUIN: I don't remember to be  
25 honest. It's been a while since I've thought about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 it.

2 CHAIRMAN WALLIS: This option 3 would help  
3 a great deal if you had some idea of what these other  
4 risk measures might be.

5 MS. DROUIN: Well, that's the problem.

6 MEMBER KRESS: If the -- I think you'll  
7 find it virtually impossible, on a technology-neutral  
8 basis, to come up with surrogates. We'd better stick  
9 with what we know about -- we'd better stick with  
10 QHOs.

11 CHAIRMAN WALLIS: But then you might need  
12 other ways to -- other surrogates? For certain types  
13 of reactors, you might different surrogates?

14 MEMBER KRESS: No, I don't think so. I  
15 think you stick with QHOs.

16 MEMBER POWERS: I mean, it seems to me  
17 that the surrogates will emerge naturally from -- once  
18 you have a specific design, because you'll define what  
19 is the most critical feature of that particular  
20 design.

21 MEMBER KRESS: Well, the reason LERF ends  
22 up being a relatively decent surrogate for the prompt  
23 fatality safety goal is that when you calculate for  
24 LWRs what magnitude of early release you get, and what  
25 prompt fatalities against that, the variety of sites

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we have now, it turns out that the -- that LERF, if  
2 you -- if you take that that -- the variation in the  
3 prompt fatalities is only a factor of four or five.

4 And so if you take the mean, you don't  
5 miss -- you're going to miss it for a lot of sites.  
6 It's going to be four or five times higher. Some  
7 sites are going to be four or five times lower per  
8 given LERF value that you get out of the plant. But  
9 the --

10 MEMBER POWERS: I will defy --

11 MEMBER KRESS: -- to me, it's because the  
12 sites have been constrained in terms of population by  
13 site suitability characteristics that we have in the  
14 rules. And so the constraints that are in the rules  
15 fix the LERF good enough that it's a -- it's a  
16 relatively good surrogate. To me, we need to get away  
17 from it, though.

18 MEMBER POWERS: I will defy you to do a  
19 calculation of LERF that I cannot just devastate in  
20 criticisms.

21 MEMBER KRESS: Oh, of course.

22 MEMBER POWERS: That's the problem.

23 MEMBER KRESS: This is strictly a Level 3  
24 calculation.

25 MEMBER POWERS: Those that you -- I mean,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 it seems to me that if you had a specific design --  
2 for instance, let's take this hypothetical buried  
3 reactor. It will be the elevator damage frequency  
4 that will quickly become the surrogate.

5 MEMBER APOSTOLAKIS: Which damage  
6 frequency? Elevator.

7 MEMBER ROSEN: Elevator damage frequency.

8 MEMBER POWERS: Sure. Sure. I mean, it  
9 dominates everything.

10 MEMBER ROSEN: I'm not familiar with the  
11 term.

12 MEMBER POWERS: Well, the way you release  
13 radioactivity from an underground site is you fail the  
14 seals on the elevator.

15 MEMBER ROSEN: Okay. And --

16 MEMBER POWERS: And so elevator damage  
17 frequency will quickly become your surrogate, because  
18 it's easy to calculate and it's easy to use and  
19 it's --

20 CHAIRMAN WALLIS: Unless it's a big enough  
21 accident.

22 MEMBER SIEBER: You have to push the "door  
23 close" button.

24 (Laughter.)

25 CHAIRMAN WALLIS: Well, the problem with

1 this is you're not really telling us what these risk  
2 measures are. And you say Level 3 PRA not needed, but  
3 presumably something like it is needed to evaluate  
4 these risk measures which we don't know about. So --

5 MEMBER KRESS: Yes, I think so.

6 CHAIRMAN WALLIS: It's all too academic.  
7 It's not even academic. It's not defined.

8 MEMBER APOSTOLAKIS: So let me understand  
9 this. Defining risk measures means subsidiary, right?  
10 Not expanding. That's option 4.

11 MS. DROUIN: That's option 4.

12 MEMBER APOSTOLAKIS: Okay.

13 MS. DROUIN: And these you would tie to  
14 the QHOs. We haven't defined them, because we haven't  
15 been able to so far. That's why we don't recommend  
16 continuing down this path, because we think that there  
17 is a significant uncertainty in being able to do this.  
18 And trying to do it, we think we'd be expending a lot  
19 of time and resources without any potential success.

20 Even if you could, we think you're going  
21 to need a lot of data and experience from your PRAs.

22 MEMBER APOSTOLAKIS: I think the reason  
23 why we define subsidiary objectives for LWRs is  
24 because we recognize that doing -- basing all the  
25 decisions on a Level 3 PRA and changes at that level

1 is meaningless because of the huge uncertainties.  
2 Huge uncertainties. I mean, if I want to change the  
3 frequency of testing some pump, and I want to see the  
4 impact of that on the QHO, I mean, I'm out of my mind.

5 So we went back and said, "Well, gee. If  
6 you look at CDF, it's easier to calculate," and so on.  
7 So that kind of advantage I guess is hidden there --  
8 when you say Level 3 PRA is not needed, I guess that's  
9 what you mean by that.

10 MS. DROUIN: Right. But also, remember,  
11 we were able to do that because we had all this data  
12 and experience from numerous Level 3 PRAs. That if it  
13 had not existed, we would not have been able to come  
14 up with surrogates for the LWRs.

15 MEMBER APOSTOLAKIS: I don't know about  
16 numerous Level 3. Mary, there are very few of them.  
17 Level 3? There are very few PRAs that are Level 3.  
18 Most of them are out of Southern California.

19 MS. DROUIN: We had a lot of experience,  
20 and we had the NUREG-1150 plants. And when you go and  
21 see how the 1E-4 and the 1E-5, the reason those are  
22 acceptable surrogates is because we were able to show,  
23 based on the data and the experience from these PRAs,  
24 that those were acceptable surrogate numbers.

25 MEMBER APOSTOLAKIS: But let's take your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 example there with the PBMR. I mean, if we ever plan  
2 to build one of those, I really would like to know  
3 what is the frequency of damage in the fuel? I really  
4 want to know that, and I --

5 MEMBER KRESS: You're arguing for another  
6 CDF-like thing.

7 MEMBER APOSTOLAKIS: Yes.

8 VICE CHAIRMAN SHACK: And that is accident  
9 prevention, which doesn't come up in these risk and  
10 safety requirements.

11 MEMBER DENNING: No, there's quite a  
12 difference. What they're defining as their maximum  
13 accident is something that Dana is going to argue  
14 with. In their maximum accident they get a very small  
15 release -- temperature goes up, you get some release,  
16 and they are pebble --

17 MEMBER APOSTOLAKIS: Release where?

18 MEMBER DENNING: Release from the plant.  
19 You get some release from the fuel, from the plant.  
20 But Dana is going to say, "Hey, but what about if you  
21 had steam ingressions," and, you know, or severe air  
22 ingressions? Stuff like that, which they're not  
23 considering as a -- within their domain of  
24 credibility.

25 So what's really -- so they -- in this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 maximum accident they have, they definitely have some  
2 limited core fuel damage. But it's not the level of  
3 Chernobyl or stuff like that. And so the question  
4 still is: well, what really is core damage? Because  
5 in that one case, which is what they would say is  
6 their maximum possible -- you know, you get some  
7 level, and Dana is going to say, "But what if you had  
8 steam?" And then, it could be orders of magnitude  
9 worse.

10 MEMBER ROSEN: It's not just Dana.

11 MEMBER DENNING: Right. I understand.  
12 But I heard --

13 MEMBER ROSEN: It may only need to be  
14 Dana, but there are a lot of people who have --

15 CHAIRMAN WALLIS: Can we move to the next  
16 slide, Mary? Are you ready for that or --

17 MS. DROUIN: I'm --

18 MEMBER APOSTOLAKIS: You haven't sold us  
19 on this one. Could you move us to the next one?

20 MS. DROUIN: Yes.

21 MEMBER KRESS: We've got another whole  
22 issue to deal with.

23 MS. DROUIN: This one is you would define  
24 some new measure.

25 CHAIRMAN WALLIS: That would just be the

1 first step, though. You'd have to then do everything  
2 else.

3 MS. DROUIN: We think that there would be  
4 considerable time and resources. I mean, you know,  
5 all of these, when you look at the quantitative -- the  
6 fact that we would actually -- whether it's option 2,  
7 option 3, or option 4, they have very similar  
8 advantages. It's really on the disadvantages that  
9 becomes on the --

10 CHAIRMAN WALLIS: It doesn't require any  
11 time at all. The Commission can meet and decide to do  
12 it. Then that hasn't changed anything.

13 MS. DROUIN: I'm sorry?

14 CHAIRMAN WALLIS: If you don't use the  
15 QHOs now, they could make the QHOs 10 times as  
16 stringent tomorrow by just a Commission decision.  
17 That doesn't change anything, because it's not used as  
18 a basis for licensing decisions.

19 MEMBER KRESS: You can't do that.

20 MS. DROUIN: I guess I'm not following  
21 what you're saying. Again, we're saying that we are  
22 trying to define what the level of safety would be, so  
23 that you have -- you've shown enhanced safety. Our  
24 option 2 says we're going to use the QHOs. Option 3  
25 says we're going to define some new risk measures.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 And there's two -- remember, there's two  
2 parts to that. It's defining the measure plus what  
3 that quantitative objective is that goes with that  
4 measure.

5 CHAIRMAN WALLIS: Option 4 would have to  
6 be combined with option 2, then. You'd find some more  
7 stringent QHOs, and then follow option 2.

8 MEMBER SIEBER: Right.

9 MS. DROUIN: And then, follow option 2?  
10 I guess I'm not understanding.

11 CHAIRMAN WALLIS: Option 2 says define the  
12 safety level as the QHO.

13 MS. DROUIN: Right.

14 CHAIRMAN WALLIS: And then, if the  
15 Commission decides to have more stringent QHOs, that's  
16 just on top of it. It's not a separate option.

17 VICE CHAIRMAN SHACK: Well, option 2 is  
18 the current QHO. I mean, there's --

19 MS. DROUIN: It's the current --

20 VICE CHAIRMAN SHACK: -- there's an  
21 implicit adjective there.

22 MEMBER KRESS: Yes. I would argue that  
23 those QHOs that we currently have are probably a  
24 pretty good definition of a level of safety. But they  
25 need something more to deal with societal risk. So I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 think -- I think there is a third QHO that's needed,  
2 and it deals with societal risk. And I would -- I  
3 would say my option 2 would be, yes, those QHOs are a  
4 pretty good level, but let's add a third one.

5 MS. DROUIN: I mean, option 4 is brand-new  
6 QHOS.

7 MEMBER KRESS: Yes, I don't want --

8 MS. DROUIN: Option 2 --

9 MEMBER KRESS: I like option 2.

10 MS. DROUIN: -- QHOs as defined in the  
11 safety goal.

12 MEMBER KRESS: I like option 2, though,  
13 with the additional QHO to account for societal risk.  
14 That's part of adequate protection in the current  
15 regulations. And also, I think option 2 ought to  
16 address the prevention metric in some way also.

17 MEMBER APOSTOLAKIS: Address what?

18 MEMBER KRESS: The prevention method, what  
19 would be the equivalent of a CDF.

20 MEMBER APOSTOLAKIS: Oh, all of them would  
21 have that.

22 MEMBER KRESS: Yes.

23 VICE CHAIRMAN SHACK: To me, the  
24 prevention metric, in fact, gives you a societal  
25 metric, too. I mean, if you don't prevent accidents,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 then you don't have societal --

2 MEMBER APOSTOLAKIS: If you don't  
3 remember --

4 VICE CHAIRMAN SHACK: The other way  
5 around, the societal measure doesn't do anything for  
6 you in terms of accident prevention. You can still  
7 build a big containment. The reactor can fail every  
8 week.

9 MEMBER KRESS: I guarantee you, I can  
10 build a reactor with a prevention metric and exceed a  
11 reasonable societal risk. It will not guarantee  
12 you'll meet an appropriate societal risk.

13 VICE CHAIRMAN SHACK: If I make the  
14 accident prevention number low enough --

15 MEMBER KRESS: Yes.

16 MEMBER ROSEN: But to make it low enough,  
17 uncertainties get so large that you don't know.

18 MEMBER KRESS: But then you're really --  
19 yes, I agree, if you make it low enough you can.

20 MEMBER APOSTOLAKIS: Could it be -- would  
21 it be possible, so that you don't have to revise this  
22 completely, to acknowledge whatever option you want to  
23 propose, that in the future there will have to be some  
24 statement regarding the prevention versus mitigation  
25 thing, and leave it at that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. DROUIN: That is inherent -- not  
2 inherent. Explicitly -- I didn't have the -- I don't  
3 have that viewgraph with me, but when you look at the  
4 framework document, you know, and we -- we say, you  
5 know, that we have this hierarchical approach. We  
6 start with the Atomic Energy Act and we say, "Okay.  
7 What's the level of safety we want to meet?"

8 And then, underneath that we come with our  
9 protective strategies. And the protective strategies  
10 -- explicitly we say we're going to have accident  
11 prevention and mitigation.

12 MEMBER APOSTOLAKIS: So that table that I  
13 remember with the prevention and mitigation, and then  
14 the product result,  $10^{-5}$ , and you say that each  
15 sequence has to be one-tenth of that -- does all this  
16 survive?

17 MS. DROUIN: Yes. Yes. Yes. None of  
18 that goes away.

19 MEMBER APOSTOLAKIS: It still though -- it  
20 wouldn't hurt to say, you know, prevention/mitigation  
21 is already covered, or something to that effect.

22 MS. DROUIN: You know, because all we're  
23 trying to say here is, how are we achieving enhanced  
24 safety. That's all -- you know, it's just that little  
25 piece.

1 MEMBER APOSTOLAKIS: I understand that.  
2 But it seems to me it wouldn't hurt to mention that  
3 this is covered already.

4 MS. DROUIN: I mean, there's no problem  
5 with that.

6 MEMBER APOSTOLAKIS: That's all I'm  
7 saying, because prevention is really very important.

8 MEMBER KRESS: We'd better move on to the  
9 next issue, because we're running out of time in a  
10 hurry.

11 CHAIRMAN WALLIS: We may go until 12:00.

12 MEMBER KRESS: Let her at least go through  
13 this issue pretty fast, so we can get a good feel for  
14 what it is without -- because we are running out of  
15 time.

16 CHAIRMAN WALLIS: Well, I think these are  
17 all important matters.

18 MEMBER KRESS: Oh, absolutely.  
19 Absolutely. I think it deserves our time, but I -- I  
20 think this second issue is just as important as the  
21 first one.

22 MEMBER APOSTOLAKIS: Maybe we should have  
23 a subcommittee meeting at some point.

24 MEMBER KRESS: We probably have --

25 MEMBER APOSTOLAKIS: We have to write a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 letter first.

2 MEMBER KRESS: We need a letter. That's  
3 why we --

4 MS. DROUIN: We had a subcommittee meeting  
5 on this.

6 MEMBER KRESS: Yes. Yes, we did.

7 MS. DROUIN: Yes. Okay. Well, I'm going  
8 to give myself a break and let Marty take over. Maybe  
9 he'll get us through faster.

10 MR. STUTZKE: And I was going to suggest,  
11 in the interest of time, we might jump over to slide  
12 number 20.

13 MEMBER KRESS: Good idea.

14 MR. STUTZKE: So to make it clear, when we  
15 talk about integrated risk, we're talking about  
16 collective risk or combined risk of reactors on a  
17 given site. The genesis of this issue was in terms of  
18 modular plants like pebble bed, but we've come to  
19 realize you need to expand it to include all types of  
20 reactors.

21 I think there's been considerable thought  
22 among the staff -- the issue is, if you have 1,000-  
23 megawatt electric plant, is that the same as 10 100-  
24 megawatt plants in risk space? That's what we're  
25 trying to wrestle with is --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: In terms of risk-benefit  
2 space, yes.

3 CHAIRMAN WALLIS: Perhaps yes, perhaps no.  
4 But then, if you get into risk prevention, risk  
5 metrics like core damage frequency, do I divide -- you  
6 know, do I set some target and divide by the number of  
7 modules on site, you get into these sorts of issues.  
8 And it's hard to grapple with.

9 So we've defined three options here. The  
10 option 1 is basically business as usual. There would  
11 be no explicit quantification of integrated risk on  
12 site. We would consider -- continue I guess looking  
13 at the number of modules or something like that in  
14 context of a siting decision.

15 MEMBER KRESS: Siting criteria, some sort  
16 of siting criteria.

17 MR. STUTZKE: Right.

18 CHAIRMAN WALLIS: So each module, no  
19 matter what its power level, would have to have the  
20 same CDF goal, if there is one.

21 MEMBER SIEBER: Not the same.

22 CHAIRMAN WALLIS: The same as the present  
23 ones.

24 MEMBER SIEBER: Individual goal. Develop  
25 it on an individual basis.

1 MEMBER APOSTOLAKIS: I guess you look at  
2 each unit separately.

3 MEMBER SIEBER: Separately.

4 MEMBER APOSTOLAKIS: That's what it says.

5 CHAIRMAN WALLIS: If you have 100 10-  
6 megawatts, it still be  $10^{-4}$  each, which would give you  
7  $10^{-2}$  per site?

8 MR. STUTZKE: That's right.

9 MEMBER APOSTOLAKIS: This is per unit.

10 MR. STUTZKE: That's right.

11 MS. DROUIN: But they would have to meet  
12 whatever gets approved under issue 1.

13 MEMBER KRESS: But that's for CDF. You  
14 would add them up, though, for the LERF.

15 MR. STUTZKE: Yes.

16 MEMBER KRESS: Yes.

17 MEMBER APOSTOLAKIS: What?

18 MEMBER KRESS: You would summate all the  
19 modules for the LERF type issue, but for CDF you  
20 would --

21 MEMBER APOSTOLAKIS: But it says no  
22 quantification of integrated risk by any measure.

23 MR. STUTZKE: We would look at a per  
24 reactor basis and calculate whatever the risk is, and  
25 whatever the total is is whatever the total is.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: That's what this  
2 says.

3 MEMBER KRESS: Yes, okay.

4 MEMBER APOSTOLAKIS: Now, whether you like  
5 it is a different story.

6 MEMBER SIEBER: Let's move on, then.  
7 Let's move to option 2. We don't like option 1.

8 (Laughter.)

9 MEMBER ROSEN: Who is the "we" in that?

10 MEMBER APOSTOLAKIS: I'm tempted to say  
11 that I do.

12 MEMBER KRESS: I don't like option 2,  
13 because I view this -- quantifying the integrated risk  
14 as more of a site selection criteria than anything,  
15 because you aren't going to mess with the plants that  
16 are already there.

17 MR. STUTZKE: Right. Let me summarize.  
18 Option 2 says we would look at integrated risk only of  
19 the new reactors built on a site, and that's in  
20 contrast to option 3 that says we would add in the  
21 existing reactors plus new reactors on site.

22 MEMBER KRESS: I think --

23 CHAIRMAN WALLIS: It won't be on the same  
24 site.

25 MEMBER KRESS: In my mind, you would --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 your view should be the new reactors are going to add  
2 very little to the risk.

3 CHAIRMAN WALLIS: We don't know yet.

4 MEMBER KRESS: Huh?

5 CHAIRMAN WALLIS: We don't know yet. It  
6 might be the same risk as the old one.

7 MEMBER KRESS: It's going to add very  
8 little to the risk. But what you want to do is look  
9 at the sites and the plants that are already on them,  
10 and see what kind of risk they pose, and maybe exclude  
11 some of those sites, even though adding a new one on  
12 there is not going to add much to the risk. It's more  
13 a perceptive thing. You're going -- I don't --

14 MS. DROUIN: That would be option 3.

15 MEMBER KRESS: That's option 3?

16 MR. STUTZKE: That's option 3 --

17 MEMBER KRESS: Okay. That --

18 MR. STUTZKE: -- is to look at the whole  
19 integrated risk.

20 MS. DROUIN: The key to option 2 is that  
21 the Commission has said that your existing plants pose  
22 no undue risk. So, we said, okay, the current plants  
23 pose no undue risk. So in looking at integrated risk,  
24 then we're only going to look at the new stuff that  
25 would be added to the site.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 MEMBER SIEBER: Right.

2 MR. STUTZKE: Except the existing plants.

3 MEMBER SIEBER: So, yes, you'd grandfather  
4 those.

5 MS. DROUIN: That's right.  
6 That's right.

7 MEMBER SIEBER: Yes.

8 MEMBER KRESS: Well, I think --

9 MEMBER SIEBER: That's okay.

10 MEMBER KRESS: Yes, it's okay. But the --  
11 it doesn't get you very far. I want something that  
12 gives you a site characteristic.

13 MEMBER SIEBER: Well, on the other hand,  
14 there are some sites that have existing reactors on it  
15 where when you integrate risk for new modules you may  
16 be real close to the health objectives.

17 MEMBER KRESS: Not likely.

18 MEMBER SIEBER: Well --

19 MS. DROUIN: Well, remember, on this one  
20 -- yes, on this option, the individual reactors would  
21 have to meet whatever level of safety was done --

22 MEMBER SIEBER: For that reactor.

23 MS. DROUIN: -- for the first issue. So  
24 if option 2 got selected, for example, which says, you  
25 know, the QHOs, any new reactor individually would

1 have to meet the QHOs.

2 MEMBER SIEBER: Right.

3 MS. DROUIN: And now we're saying  
4 individually they'd have to meet it, and collectively  
5 they would have to meet it. So those two things  
6 combined, you're adding essentially -- I hate to use  
7 the word "zero," because that becomes a legal term.  
8 But you're not adding any undue risk to the site.

9 MEMBER ROSEN: Let me see if I understand.  
10 In this case, let's say you had a site with two big  
11 reactors on it, and you want to add two more PBF, two  
12 more small reactors. If you just look at the risk of  
13 the two more small reactors, that's -- and you say,  
14 okay, we understand what that is and it's okay, what  
15 if the -- instead, the proposal was to add 20 small --  
16 new small reactors. Now you'd say it might not be  
17 okay, is that right?

18 MS. DROUIN: No.

19 MEMBER ROSEN: Because --

20 MS. DROUIN: No.

21 MEMBER ROSEN: -- the 20 may take the site  
22 above some limit?

23 MS. DROUIN: No. Because individually and  
24 collectively they'd have to meet the QHOs. So whether  
25 you add 1 or 50 or 100, the collective risk cannot

1 exceed the QHOs of all of those combined.

2 MEMBER ROSEN: But if you wanted to add  
3 100, it might have to be a different reactor than if  
4 you wanted to add 10 -- a much safer reactor.

5 MS. DROUIN: Sure.

6 MEMBER APOSTOLAKIS: That's what she's  
7 driving at.

8 MEMBER ROSEN: Well, I just wanted to be  
9 sure I understand.

10 MEMBER APOSTOLAKIS: Yes. If you have  
11 100, you want them to be safer.

12 CHAIRMAN WALLIS: And this risk would  
13 include common cause failures of several of these  
14 modules?

15 MS. DROUIN: Oh, yes. Absolutely.

16 MEMBER APOSTOLAKIS: Everything except  
17 safety conscious.

18 (Laughter.)

19 CHAIRMAN WALLIS: Or risk as risk-benefit,  
20 and I find it rather difficult to divorce the risk  
21 that I tolerate from the benefit I get from the  
22 megawatts.

23 MEMBER KRESS: Well, you just assume  
24 that's already been quantified.

25 CHAIRMAN WALLIS: Well, I'm not sure that

1 it has when you start talking about --

2 MEMBER KRESS: When we talk about .1  
3 percent of the risk it would take, that's saying that  
4 we're willing to accept that risk for the benefits of  
5 nuclear power. That's what that's saying.

6 CHAIRMAN WALLIS: So you accept the same  
7 risk from an MIT research reactor as you would from a  
8 1,000-megawatt plant?

9 MEMBER ROSEN: Well, of course. It's so  
10 much more valuable.

11 MEMBER DENNING: Let me make a quick  
12 comment on Graham, because I think it really is  
13 important, and that is because we're dealing with  
14 these individual risks, that's only people that live  
15 within 10 miles or 1 mile, they're not the people that  
16 get the benefits. You know? So that's where you  
17 really -- if you want to do a tradeoff between cost  
18 and benefits, you need the societal safety goals.

19 CHAIRMAN WALLIS: But that's what all risk  
20 really is. All risk decisions eventually are risk-  
21 benefit decisions.

22 MEMBER DENNING: Well, we can say that,  
23 but these goals do not lend themselves to cost-benefit  
24 analysis. It's just the risk that individuals within  
25 10 miles or 1 mile experience.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER KRESS: That's right. Okay.

2 MR. THADANI: Rich, it's really more than  
3 that, because you're looking at potential cancers. So  
4 you do go out further than 10 miles.

5 MEMBER DENNING: No, wait a second. If  
6 you leave aside the safety goal --

7 MR. THADANI: If you live within a 10-mile  
8 limit --

9 MEMBER DENNING: Not with this  
10 quantitative safety goal. You go to 10 miles, just  
11 the cancers within 10 miles, divided by the population  
12 within 10 miles.

13 MR. THADANI: Right.

14 MEMBER APOSTOLAKIS: How do you divide the  
15 population? Do you mean you take everybody, put them  
16 in the denominator?

17 MEMBER DENNING: Yes, that's what you do.

18 CHAIRMAN WALLIS: So something like a  
19 Chernobyl isn't measurable on this table at all.

20 MEMBER KRESS: Okay.

21 MR. STUTZKE: I wanted to point out  
22 some --

23 CHAIRMAN WALLIS: You going to end up  
24 choosing option 2, and you haven't really told us much  
25 about it. You just said quantification of integrated

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 risk, but you've not said how you're going to do it.  
2 Are you going to tell us how you're going to do that  
3 quantification of integrated risk?

4 MEMBER ROSEN: This is a policy decision.  
5 You don't need to --

6 MEMBER APOSTOLAKIS: Why are we commenting  
7 on policy, by the way? Are we --

8 CHAIRMAN WALLIS: Well, you just have a  
9 policy decision, and you've got to quantify integrated  
10 risk and argue about how to do it. Is that what --

11 MEMBER KRESS: Well, if Mary wants the  
12 benefit of our judgment --

13 MEMBER APOSTOLAKIS: No, but we are  
14 sending -- who are we sending the letter to?

15 MEMBER KRESS: It goes to -- we're sending  
16 it to the Commission, because --

17 MEMBER APOSTOLAKIS: And they told us to  
18 stay away from policy issues.

19 MEMBER KRESS: Ahhh. This is -- they said  
20 for us to get involved in --

21 MEMBER POWERS: Unless they want us to  
22 comment on the policy, George.

23 (Laughter.)

24 MEMBER APOSTOLAKIS: They what?

25 MEMBER POWERS: Unless they want us to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 comment on the policy.

2 MEMBER KRESS: Yes. Stay away, unless we  
3 want you to comment. They want our opinion on this.

4 MEMBER POWERS: They'll let us know  
5 whether they want us to stay away or not.

6 (Laughter.)

7 MEMBER APOSTOLAKIS: I'm serious now.  
8 Maybe our letter should focus only on the technical  
9 merits and demerits of each one.

10 MEMBER KRESS: Well, that's probably all  
11 it will --

12 MEMBER APOSTOLAKIS: Because otherwise  
13 you're going to --

14 MEMBER KRESS: We're going to stick to --

15 MR. STUTZKE: Well, it's true. For both  
16 options 2 and 3, I think there is a substantial effort  
17 to develop suitable methodology for calculating  
18 integrated risk that should not be overlooked. Common  
19 cause between various modules, things like this, there  
20 have been some efforts in the past that I'm aware of,  
21 but this deserves some serious attention on how to do  
22 this.

23 MEMBER APOSTOLAKIS: On the other hand,  
24 Marty, though, if this is a real thing, we can't just  
25 say we're not going to look at it by fiat. Does

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 anybody feel that these common cause failures -- use  
2 that term -- among modules is important?

3 MEMBER KRESS: Yes.

4 CHAIRMAN WALLIS: Yes.

5 MEMBER APOSTOLAKIS: Then we should look  
6 at them. I mean, what is this? We can't legislate  
7 them out.

8 CHAIRMAN WALLIS: Yes. They're going  
9 to --

10 MR. STUTZKE: You would have to look at  
11 the --

12 MEMBER KRESS: What I would do here --

13 MEMBER APOSTOLAKIS: Yes, but we're not  
14 choosing this.

15 MEMBER KRESS: With this option, I would  
16 have put it a different way. I would have said,  
17 "We're going to quantify the integrated risk at a  
18 proposed site for both existing and new reactors."  
19 But what I'm going to do with that quantification is  
20 not the second bullet under advantages. We're not  
21 going to -- we're going to say that the integrated  
22 risk must not -- would not exceed the QHOs.

23 What I would have said is that if -- if  
24 the integrated risk from the current plants on there  
25 already exceed the QHOs, then we're going to exclude

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 that site.

2 MS. DROUIN: Well --

3 MEMBER KRESS: For the new reactors.

4 MS. DROUIN: -- no. No.

5 MEMBER KRESS: We're going to leave that  
6 site alone, because it already has adequate  
7 protection. And we're not going to apply the QHOs to  
8 it.

9 MS. DROUIN: I disagree with that. The  
10 option should be, in my mind -- that's the applicant's  
11 decision. He can decide that he's going to go modify  
12 his current plants. That's a viable option. Why  
13 would we not want him to do that?

14 MEMBER APOSTOLAKIS: Well, that's  
15 consistent with what Tom said.

16 MEMBER KRESS: That's consistent with what  
17 I said. I said if they already received the QHO, I'm  
18 not going to --

19 MEMBER APOSTOLAKIS: They exceed --

20 MEMBER KRESS: -- grant a site permit.  
21 But if they want to go back and change their plant and  
22 still come in, then that's all right.

23 MS. DROUIN: Yes.

24 MEMBER KRESS: I wouldn't say you have to  
25 do that.

1 MS. DROUIN: No. That's an option.

2 VICE CHAIRMAN SHACK: If you want to build  
3 new plants on that site you have to do it.

4 MS. DROUIN: That's right.

5 CHAIRMAN WALLIS: So why does 3 go beyond  
6 the Commission's expectations?

7 MEMBER APOSTOLAKIS: What is this?

8 CHAIRMAN WALLIS: I think option 3 is not  
9 a bad option, really. It excites us.

10 MEMBER APOSTOLAKIS: Because it addresses  
11 existing reactors as well, right?

12 CHAIRMAN WALLIS: Well, only if you want  
13 to add new ones to them.

14 MEMBER KRESS: Yes. It doesn't deal  
15 with --

16 CHAIRMAN WALLIS: It doesn't do anything  
17 to them unless you want to add --

18 MEMBER KRESS: I like 3 better.

19 MEMBER DENNING: Well, I'm not sure that's  
20 true. I think that it does -- I mean, even without  
21 putting any more new reactors on here, we might not  
22 satisfy this today, because we have multiple reactors  
23 on a site, and we're not --

24 MEMBER KRESS: We wouldn't do anything  
25 about that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: It would be  
2 grandfathered.

3 MEMBER KRESS: We'd just grandfather them,  
4 because they already have adequate protection. We're  
5 not going to require them to meet the --

6 MS. DROUIN: You may not require them to  
7 meet it, but you're going to require the licensee to  
8 assess it.

9 MEMBER KRESS: Yes. Okay. That you would  
10 do, yes.

11 MS. DROUIN: That's going beyond the  
12 Commission's expectations for your existing reactors.

13 MEMBER ROSEN: It requires him to assess  
14 it, whether or not he wants to use the site for  
15 additional reactors?

16 MEMBER KRESS: I think you ought to have  
17 to.

18 MS. DROUIN: Well, he has to on this --

19 MEMBER BONACA: Does it mean he has to  
20 perform a Level 3 for each of the units as --

21 MS. DROUIN: I mean, for option 3, since  
22 you have to look at existing reactors, you have to  
23 assess the risk from those reactors.

24 MEMBER ROSEN: Whether or not you intend  
25 to use the sites for new reactors.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER KRESS: No, no. If you're going  
2 to --

3 MS. DROUIN: If you're going to want to  
4 use that site --

5 MEMBER ROSEN: I want to be real sure of  
6 that.

7 MS. DROUIN: Yes. If you aren't  
8 considering that site for a new reactor, it's --

9 MEMBER ROSEN: It depends how you read it.  
10 It's perfectly --

11 VICE CHAIRMAN SHACK: You could well go  
12 back and look at the existing site. You're still  
13 going to have to explain to the public why it's okay  
14 for this site to be over that limit and any other new  
15 site where you want to build a plant you have to be  
16 under that limit.

17 MR. SCOTT: That amounts to option 4.  
18 That's not discussed here. Go back and look at all of  
19 them.

20 CHAIRMAN WALLIS: What I have trouble with  
21 in this whole process, and I wanted to have some sort  
22 of Statement of Considerations, what's the basis for  
23 considering all these options and then establish --

24 MEMBER APOSTOLAKIS: They have a whole  
25 report.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: That's the whole report,  
2 and we're not getting that today.

3 MEMBER KRESS: Well, kind of. She gave  
4 the ground rules.

5 CHAIRMAN WALLIS: Yes.

6 MEMBER KRESS: Basis of one of the slides.

7 CHAIRMAN WALLIS: Yes. But these are the  
8 solutions to a problem. I'd like to have it very  
9 fully defined what this problem is.

10 MEMBER SIEBER: These are the key policy  
11 questions that we're trying to --

12 MEMBER KRESS: I think we're basically  
13 there. Are you done?

14 MR. STUTZKE: I'm done.

15 MEMBER APOSTOLAKIS: In summation.

16 CHAIRMAN WALLIS: What's page 23?

17 MEMBER SIEBER: Two and two.

18 CHAIRMAN WALLIS: But how do you integrate  
19 two and two under the new policy?

20 MS. DROUIN: We're asking for the  
21 Commission to come in and say, "You've approved  
22 enhanced safety. We're going to interpret the  
23 enhanced safety to mean that the level of safety is  
24 the QHOS."

25 CHAIRMAN WALLIS: Essentially it's for

1 both.

2 MS. DROUIN: That's option 2 for issue  
3 number 1. For issue number 2, you know, the  
4 Commission asked us, "Well, how are you going to deal  
5 with integrated risk for new plant licensings?"

6 CHAIRMAN WALLIS: The same way.

7 MS. DROUIN: And we're saying we're going  
8 to do the same way. We're going to look at the QHOs  
9 for just the new plants that come on. We're going to  
10 essentially grandfather the old ones because you've  
11 already said that those pose no undue risk. So since  
12 we're keeping the level of safety for each one to meet  
13 the QHOs, the integrated risk, so that whether you add  
14 two new reactors or 10, or whatever, the combined  
15 collective risk from the new ones also has to meet the  
16 QHOs. That's what we're recommending to the  
17 Commission.

18 If the Commission approves that, then we  
19 will the process of how do we implement that now in  
20 the framework. Now, that's the path we're going down.  
21 We don't want to go and spend all this time creating  
22 a framework based around those two positions, and the  
23 Commission comes back a year a later and says, "Oh, I  
24 don't like this." So we want to be up front --

25 CHAIRMAN WALLIS: We're going to be asked

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to approve recommendations which could have very far-  
2 reaching implications for the agency based on an hour  
3 presentation from you? That's an extraordinary thing  
4 to put on this committee.

5 MS. DROUIN: Well, we have come to the  
6 subcommittee and discussed this in detail.

7 MEMBER KRESS: We've heard this before.

8 MEMBER ROSEN: Not the choices, but the --

9 MEMBER KRESS: Well --

10 MEMBER ROSEN: We've heard about the  
11 issues.

12 CHAIRMAN WALLIS: Well, let's see how it  
13 works out.

14 VICE CHAIRMAN SHACK: I mean, this says  
15 that South Texas, for example, meets the expectations  
16 for new reactors.

17 MEMBER SIEBER: They have enough  
18 mitigating equipment. All they need is another  
19 vessel.

20 MS. DROUIN: I don't think -- why do you  
21 say that South Texas meets this?

22 VICE CHAIRMAN SHACK: You don't think it  
23 meets the current QHOs?

24 MS. DROUIN: I don't know that they do.  
25 If I did a risk assessment strictly at what they're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 required to have --

2 MEMBER SIEBER: No, no, no.

3 MS. DROUIN: But that's what we're talking  
4 about.

5 VICE CHAIRMAN SHACK: Well, that argument  
6 I do find puzzling. I mean, we license a reactor with  
7 systems. You know, whether they're required to have  
8 those systems, or not required to have those systems,  
9 you're licensing a reactor design. He then can't say,  
10 okay, I'm going to take these systems out now that  
11 you've certified my reactor, because I'm not required  
12 to have them.

13 MS. DROUIN: But he's not required to use  
14 them for that function. What he's taking credit for  
15 is analyzing his --

16 VICE CHAIRMAN SHACK: Well, then, you're  
17 going to need an awful lot more detailed regulations  
18 than I think you've got. You know, it sounds to me  
19 like you're going to put the procedures in the  
20 regulations. When the pipe breaks, thou shalt turn on  
21 the ECCS.

22 MS. DROUIN: No, no.

23 MEMBER SIEBER: Yes.

24 CHAIRMAN WALLIS: It might have helped to  
25 keep --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 MEMBER SIEBER: Keep the main feedwater  
2 system running.

3 CHAIRMAN WALLIS: Write the procedure for  
4 the plant.

5 MEMBER APOSTOLAKIS: This doesn't solve  
6 it.

7 CHAIRMAN WALLIS: Tom, are we going to be  
8 finished at quarter to 12:00, do you think?

9 MEMBER KRESS: I think we're through.

10 MEMBER APOSTOLAKIS: We're done.

11 CHAIRMAN WALLIS: I was asking Tom.

12 MEMBER KRESS: I'm about to turn it back  
13 to you, Mr. Chairman.

14 CHAIRMAN WALLIS: I have a meeting at  
15 12:00, okay? So I am done.

16 George, we were asking about whether the  
17 committee is done.

18 MEMBER KRESS: I think we're through.  
19 Well discuss this more. We'll get to the letter  
20 writing.

21 CHAIRMAN WALLIS: So we will take a break,  
22 then, or --

23 MS. DROUIN: Can I ask when you're going  
24 to be discussing this and doing the letter writing?

25 MEMBER KRESS: It's on our agenda to start

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 discussing it --

2 MEMBER SIEBER: This week.

3 MR. SCOTT: Probably about 5:00.

4 MEMBER KRESS: Well, we will probably talk  
5 about the main issues at 5:00, but the real debate I  
6 think will probably come about when we have a draft  
7 letter to talk about, which would be on probably  
8 Thursday. I'm trying to figure out the -- yes,  
9 Thursday at 3:00. Well, I don't know.

10 MEMBER SIEBER: Maybe even 3:30.

11 CHAIRMAN WALLIS: Maybe you'll just have  
12 to stay around.

13 MEMBER KRESS: Yes. I think somewhere  
14 Thursday afternoon we will have a debate about it. It  
15 won't happen tonight.

16 MS. DROUIN: I just wanted to get it on my  
17 calendar, try and be here at that time.

18 CHAIRMAN WALLIS: You may have to be  
19 around --

20 MEMBER ROSEN: Thursday afternoon, bring  
21 your cot.

22 CHAIRMAN WALLIS: Or be available  
23 somewhere where we can call you.

24 All right? We will now take a break.

25 MS. DROUIN: I have a ASME/ANS meeting,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 but we usually finish at 3:00, and then I'll come  
2 straight here.

3 MEMBER KRESS: Well, Mary, thank you all  
4 for bowing up under our intense questioning. Once  
5 again, we appreciate it.

6 MS. DROUIN: Thank you very much.

7 MEMBER KRESS: Back to you now.

8 CHAIRMAN WALLIS: We are through. We're  
9 going to take a break until quarter to 1:00.

10 (Whereupon, at 11:46 a.m., the  
11 proceedings in the foregoing matter went  
12 off the record for a lunch break until  
13 12:45 p.m.)

14 CHAIRMAN WALLIS: We'll come back into  
15 session.

16 The next topic has to do with fire risk  
17 requantification and probabilistic risk analysis, and  
18 Steve Rosen is going to take us through it.

19 MEMBER ROSEN: Thank you, Mr. Chairman.

20 The research part of NRC and EPRI have  
21 collaborate to consolidate recent research in the  
22 state-of-the-art of fire PRA, and these esteemed  
23 gentlemen are here to tell us about that effort, which  
24 as culminated in the publication NUREG-6850, a weighty  
25 document that is much to be admired.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Please --

2 MEMBER POWERS: It leaves much to be  
3 denied?

4 MEMBER ROSEN: That is much to be admired.

5 MEMBER APOSTOLAKIS: For sheer size. It  
6 represents the weight of our efforts.

7 MEMBER POWERS: He who is a spokesman for  
8 PRA ought not complain about the length of a document.

9 MEMBER ROSEN: Please, Mr. Hyslop.

10 MR. HYSLOP: Thank you, Steve.

11 My name is J.S. Hyslop. I'm a senior  
12 reliability and risk analyst in the Office of Nuclear  
13 Regulatory Research.

14 I have two folks who helped work on this  
15 program beside me. Bijan Najafi of SAIC. He was a  
16 technical lead for EPRI in this program. Bob  
17 Kassawara played the role I did for EPRI.

18 Steve Nowlen is also here. Steve is the  
19 technical lead for NRC. He's from Sandia National  
20 Labs.

21 We met with the Subcommittee for half a  
22 day last month, May 4th. So this is the follow-up  
23 presentation to the full Committee.

24 First of all, an MOU on cooperative  
25 nuclear safety research was prepared by Research and

1 EPRI on fire risk. And this is one of several  
2 elements on that MOU. Another example is the V&V of  
3 fire models.

4 Essentially this MOU is a part of a  
5 broader program on fire research.

6 The primary objective of this program,  
7 which I'm talking to you about today, the fire risk  
8 requantification study, is to develop field tests and  
9 document the state-of-the-art.

10 We've briefed the ACRS before, as I said,  
11 the Subcommittee was briefed in May. And so the  
12 purpose is to brief the full Committee on the final  
13 NUREG/CR-6850 EPRI 1008239 entitled "EPRI/NRC Research  
14 Fire PRA Methodology for Nuclear Power Facilities.  
15 And this version addresses public comments.

16 CHAIRMAN WALLIS: Has EPRI really written  
17 a million reports?

18 MEMBER ROSEN: Eight thousand two hundred  
19 and thirty-nine.

20 MEMBER POWERS: It's a little bit like the  
21 year 1, you know.

22 MEMBER ROSEN: Perhaps you could clarify  
23 what it is you want from ACRS?

24 MR. HYSLOP: Well, we're interested in a  
25 letter from the full Committee. We plan to publish in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 August. We'd like to have a letter indicating your  
2 views o this report. So, this -- first of all, later  
3 in my presentation I talk about the role that we hope  
4 this report will play in our regulatory arena; that is  
5 it's currently referenced in the Reg Guide on NFPA  
6 805. And we expect that to be endorsed in part, if not  
7 in full in the Reg Guide later.

8 And also, this is a little bit of a unique  
9 program.

10 MEMBER APOSTOLAKIS: So we are reviewing  
11 the Reg Guide today?

12 MR. HYSLOP: No. What you're doing, I'm  
13 going to tell you about the fire PRA methodology  
14 document. The Reg Guide itself is a different  
15 presentation, and that's being lead by NOR. This is  
16 being lead by Research.

17 MEMBER ROSEN: The Reg Guide and this are,  
18 in that sense, separate, George.

19 MEMBER APOSTOLAKIS: I know.

20 MEMBER ROSEN: You can love the Reg Guide  
21 and hate this or you could hate the Reg Guide and love  
22 this, or any combination thereof.

23 MEMBER APOSTOLAKIS: Or you can hate both.

24 MEMBER ROSEN: Well, yes, possible.

25 MEMBER APOSTOLAKIS: Or love both.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ROSEN: All four.

2 MR. HYSLOP: So the second reason is this  
3 is a project with EPRI and it's the first of the type  
4 that we've had for a while where we've actually done  
5 analyses as opposed to just collecting test data and  
6 going separate ways. And I think a statement in  
7 support of this work would also be in support of the  
8 program that we exercise to carry out the work.

9 Okay. So the roles of the participants.  
10 Research and EPRI developed and tested the methods.  
11 The methodology consists of 16 procedures and  
12 associated appendices. And all procedures were  
13 tested.

14 We had three volunteer pilot plants  
15 support the testing. These procedures were tested for  
16 their viability and effectiveness by these pilot  
17 plants. And three pilot plants were PWRs, Millstone  
18 Unit 3, D.C. Cook and Diablo Canyon.

19 CHAIRMAN WALLIS: They have not yet  
20 finished, is that right?

21 MR. HYSLOP: Two have finished to the  
22 extent they're going to be finished. I'll talk about.

23 Basically two of those plants we performed  
24 demonstration studies with. That is, we tested all the  
25 procedures. However, those plants did not implement

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 our procedures themselves fully in their fire PRA.

2 CHAIRMAN WALLIS: They were not pulled  
3 together into the PRA.

4 MR. HYSLOP: Right. There was a change in  
5 priorities associated with those. However, we have  
6 another pilot plant which we've recently brought on  
7 board, Nine Mile Point Unit 1, the older unit of the  
8 two. And it's our expectation that our methodology  
9 will be applied fully in that plant and so that we can  
10 get plant wide insights, something that we're missing  
11 from the first two pilots.

12 CHAIRMAN WALLIS: And there's something  
13 different about doing the whole job than just testing  
14 pieces.

15 MR. HYSLOP: Agree.

16 CHAIRMAN WALLIS: And I just pointed that  
17 these other two plants didn't finish.

18 MEMBER ROSEN: When do you think Nine Mile  
19 1 will be done? They're just starting now? It's a  
20 multiyear project?

21 MR. HYSLOP: You want to answer that,  
22 Bijan?

23 MR. NAJAFI: They're scheduled to finish  
24 up their results the first quarter of next year. And  
25 I would say, if I had to put an estimate, they're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 about 25 percent into the project?

2 CHAIRMAN WALLIS: That's faster than I  
3 would have anticipated. It's good.

4 MR. HYSLOP: So besides those pilot  
5 plants, other participating licensees provided a peer  
6 review of the methods. We had a presentation in the  
7 Subcommittee, and the lead peer reviewer spoke for the  
8 peer review team and indicated he felt that our work  
9 was a step change progress.

10 MEMBER APOSTOLAKIS: Who is this person?

11 MR. HYSLOP: Dennis Hennecke. Step  
12 change--

13 MEMBER APOSTOLAKIS: Can you explain to  
14 me, first of all, that sentence doesn't seem to have  
15 a verb.

16 MR. HYSLOP: Pardon me.

17 MEMBER APOSTOLAKIS: But anyway, how  
18 different in a step way is this methodology from  
19 design and fire risk assessment of 1981? What does it  
20 do that is really new?

21 MR. NOWLEN: This is Steve Nowlen from  
22 Sandi.

23 I think that's going to bounce right over  
24 to me.

25 I think you'll see a lot of similarities

1 in some aspects of it. For example, the overall  
2 structure of how a fire PRA is conducted will look  
3 very similar.

4 MEMBER APOSTOLAKIS: It's actually the  
5 same.

6 MR. NOWLEN: It's virtually the same. The  
7 overall process, the framework. We did an initial  
8 review and we concluded that the framework that was  
9 used in those early studies works. We had a couple of  
10 other reports that looked at the same question and  
11 again concluded that the overall framework works.

12 What you'll see is, and again and what  
13 Dennis' point was, was that he saw it as a step change  
14 improvement in the process. So you'll see there have  
15 been improvements from relatively incremental  
16 improvements in things like fire frequency. The  
17 overall approach is the same, but we believe that  
18 we've done a better analysis of data, we have more  
19 complete data so we've been able to refine that a bit.

20 On the opposite end you'll see things that  
21 are essentially new. For example, even in those early  
22 studies there was a recognition of the spurious  
23 operation issue. But there was really no concise  
24 structured method for incorporating that  
25 systematically into the PRA. There is now.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 And in other areas, you know, so that sort  
2 of represents the two ends of the spectrum and in  
3 between you'll find a bit of everything.

4 MEMBER APOSTOLAKIS: But the key finding  
5 or innovation the design Indian Point PRAs did that  
6 allowed all this happen is the idea that when  
7 redundant trains come the closest, then you do a heat  
8 transfer calculation with the fires to see whether you  
9 can lose both. This was the key idea which has  
10 survived. Everything else I agree with you is either  
11 improvements or add-ons and so on. And that tends to  
12 be lost in the history of time, so I thought I was  
13 going to bring it up.

14 MR. HYSLOP: And there's another area --

15 CHAIRMAN WALLIS: But the idea came from  
16 UCLA in the time when you were there?

17 MEMBER APOSTOLAKIS: Absolutely.

18 CHAIRMAN WALLIS: All right.

19 MEMBER APOSTOLAKIS: From the Department  
20 of Philosophy. No, I'm serious. This was the key  
21 idea, and it has survived.

22 MR. HYSLOP: So the peer reviewers  
23 reviewed the procedures in many stages. They didn't  
24 participate in the testing or demonstration studies,  
25 but they provided a lot of constructive comment.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 And the peer reviewers were Duke Power,  
2 Florida Power and Light, Exelon, Nuclear Management,  
3 Southern California and CANDU Owners Group.

4 MEMBER APOSTOLAKIS: J.S., why didn't you  
5 have any peer reviewers from the fire safety  
6 community, fire science, or did you have any? Like at  
7 Maryland there are two or three people?

8 MR. NOWLEN: Well, we did bring in a few  
9 individuals in key areas to provide --

10 MEMBER APOSTOLAKIS: You are an expert.  
11 I'm sorry.

12 MR. NOWLEN: No, no.

13 MEMBER APOSTOLAKIS: I mean outsiders.

14 MR. NOWLEN: Yes. We had Ali Mosleh  
15 involved in the project.

16 MEMBER APOSTOLAKIS: A famous fire expert.  
17 Come on, give me --

18 MR. NOWLEN: Statistics. We need a  
19 statistical expert.

20 We brought Dennis Bley in to provide  
21 insights in the area of human reliability analysis.

22 We brought in Andy Ratchford, who is an  
23 Appendix R circuit analysis type to provide us with  
24 review in that area. But fundamentally the way we  
25 structured the project is that the EPRI effort was a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 collaborative effort that certain licensees had paid  
2 money to participate in the project. And as we were  
3 developing the program plan we said well, what role  
4 can these people play? They've paid a price to sit at  
5 the table, in essence. Let's take advantage of it.

6 So what we did is we utilized those  
7 participating utilities who were nonpilots to act as  
8 a peer review team for us. And that's how --

9 MEMBER APOSTOLAKIS: And did you have  
10 anybody from NIST?

11 MR. NOWLEN: No. They were all taken  
12 basically from the non-pilot utility participants.

13 MEMBER APOSTOLAKIS: Don't you think that  
14 is a deficiency? Shouldn't you have somebody?

15 What's the name of this fellow now who  
16 used to be at NIST and he's at --

17 MR. NOWLEN: Quintiere.

18 MEMBER APOSTOLAKIS: Who?

19 MR. NOWLEN: Quintiere?

20 MEMBER APOSTOLAKIS: Yes. Somebody like  
21 that who has published numerous papers on fire science  
22 and all that. I mean, it probably would have been  
23 helpful.

24 MR. NAJAFI: Let me try to respond to  
25 that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           There were some areas of expertise that we  
2           went to ask for peer review to specialized people. An  
3           example, like Steve mentioned, that we have done a lot  
4           of work in this document, more than previous PRA  
5           methodology in the area of the circuit analysis.  
6           That's a big -- the step change. So we went to people  
7           that have traditionally done circuit analysis work for  
8           outside review, like Andy Ratchford.

9           The mention you making from people at NIST  
10          and particularly Jim Quintiere is more applies to the  
11          fire science, an area of fire modeling. This document  
12          when it comes to that area more talks about processes.  
13          It does not say specifically what fire model to use,  
14          what's the theory and science behind those theory of  
15          those models. There is a separate project that is  
16          dealing with these issues of fire science.

17                 MEMBER APOSTOLAKIS: Validation.

18                 MR. NAJAFI: Validation. In those areas we  
19                 do go to NIST, we got to Quintiere, we do go,  
20                 hopefully not yet, maybe people like Hesskesdt. Those  
21                 are more appropriate for those part of it. This is  
22                 what I would say a multi disciplinary layer. So we  
23                 went to HRA outside experts like Dennis Bley. We went  
24                 to statisticians to verify our methods for frequency,  
25                 like Ali Mosleh. We went to when it came to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 circuit, we went there.

2 But to fire science, the depth of it  
3 belongs to other projects. We don't address it in  
4 this document.

5 MR. HYSLOP: So this document that we've  
6 been speaking about, is a consensus document between  
7 EPRI and Research.

8 We had debates, collegial debates, but in  
9 the end we've reached consensus on this entire  
10 document.

11 For the expected use of the methodology,  
12 as I alluded to earlier, we expect this to support the  
13 implementation of the new rule, 10 CFR 50.48 (c).

14 We expect it to support analyses under the  
15 current fire protection regulations,  
16 exemptions/deviations or other plant changes like  
17 risk-informed tech specs.

18 Research is developing review guidance for  
19 the staff for NFPA 805 relates changes.

20 This works currently having a big impact  
21 on the development of the ANS sire risk standard.  
22 Basically Bijan, Steve are writing members of the  
23 standard. They're working on this project and there's  
24 many people working on this project are working on the  
25 standard.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           Also, we expected to support analyses and  
2 reviews of fire protection inspection findings, phase  
3 3s. This work played a large role in development of  
4 the phase 2 SDP. Both the phase 2 SDP revision and  
5 this work was going on at the same time, and so  
6 insights from this program were carried over in the  
7 development of the phase 2 that's in Inspection Manual  
8 Chapter 0609, Appendix F.

9           MEMBER ROSEN: And before you get off  
10 this, I just want to emphasize for the Committee just  
11 how important some of these points are.

12           The one first I would like to mention is  
13 the point on consensus. There were built into this  
14 study a number of features to deal with the lack of  
15 consensus should it arise, because it was a unique  
16 regulator and regulated industry cooperation that was  
17 going on. And those were important to build in up  
18 front. But because of the good work and good spirit  
19 in the work consensus was achieved on every point. I  
20 think that was particularly useful, and a useful  
21 result and needs to be reemphasized. So I just did.

22           The other thing is the first bullet on  
23 this slide support for the new rule 50.48(c).  
24 50.47(c) is risk-informed fire protection program  
25 under NFPA 805. Plants can transition under 50.48(c)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 to a risk-informed fire protection program. But to do  
2 that, they're going to have to do a fire reanalysis.  
3 And to do that, they need this methodology.

4 And so all these are connected. And I  
5 think it is very important to understand those  
6 connections.

7 MEMBER APOSTOLAKIS: Now, we're going to  
8 review the Regulatory Guide tomorrow that deals with  
9 NEI 04-02, which is the implementation of 10 CFR  
10 50.48(c). So I guess you guys would agree then that  
11 if we say that the fire risk assessment is what this  
12 requantification study does, then we would be right.  
13 But the current state-of-the-art in fire risk  
14 assessment is this.

15 MR. HYSLOP: Yes. We believe this is the  
16 best available methodology to get risk insights. This  
17 is the best of it. This is it.

18 MEMBER ROSEN: And it has in it, George,  
19 just because I know your particularly interest in  
20 uncertainty, it has the best compilation of  
21 requirements for uncertainty analysis that I've seen.

22 MEMBER APOSTOLAKIS: Good.

23 MEMBER ROSEN: So some of the key measures  
24 that we would use are I believe here.

25 MEMBER APOSTOLAKIS: Well, it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 interesting though that the Regulatory Guide doesn't  
2 mention it.

3 MR. HYSLOP: Well, the Regulatory Guide  
4 does mention this. It references this document, the  
5 last version I saw. Is that still correct, Paul?

6 MR. LAIN: Yes. Yes, it does.

7 MR. HYSLOP: And getting back to Steve's  
8 point about consensus. Our process specifically  
9 allowed for differences in opinion, translating all  
10 the way to the end and documenting separate positions.  
11 But we just didn't have to go there.

12 So we made improvements in areas important  
13 to fire risk with the consideration of resource  
14 constraints. There were several ways that we advanced  
15 the state of art that Steve recently mentioned.

16 We wrote down best practices, that is  
17 consolidated existing research. We analyzed more  
18 extensive data where appropriate. Modified existing  
19 methods and developed new approaches. And we'll talk  
20 more about that later.

21 So Research has several ongoing analytical  
22 programs. One of which was mentioned earlier is the  
23 V&V of fire models. And, of course, there's a  
24 relationship between a fire PRA and fire model V&V.  
25 The fire modeling tools provide an input to fire PRA,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 determine equipment which is damaged, critical to CDF.

2 This V&V is required for NFPA 805  
3 applications under the new rule.

4 The V&V is a formal extensive process for  
5 verifying the theory and validating the model versus  
6 data.

7 In limited cases we've used empirical  
8 correlations for fire models in our document. We've  
9 used them in a probabilistic model for frequency of  
10 fire damage to the main control board and in  
11 characterizing cable fires as well.

12 And these fire models address cases where  
13 your computational fire models are inadequate. It's  
14 very difficult to get a sophisticated model to model  
15 damage within a cabinet. So that may fill important  
16 gaps that we needed to fill to address all the issues  
17 in fire PRA.

18 This document is not a reference for fire  
19 models. Any V&V for 805 applications is left to the  
20 analyst.

21 We done V&V per ASTM standard on this. We  
22 feel the models are reasonable or best current  
23 practice.

24 I want to note that this NUREG/CR-6850,  
25 however, serves a broader audience than NFPA 805. You

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 don't need V&V for exemptions or deviations, or fire  
2 protection SDP analyses. So, of course, you need  
3 quality but that's going to be determined by the  
4 analyst.

5 MEMBER APOSTOLAKIS: Well, what you're  
6 doing is not competing with NFPA 805? No, not at all.

7 MR. HYSLOP: No. No.

8 MEMBER APOSTOLAKIS: But it's supporting  
9 NFPA 805?

10 MR. HYSLOP: It's supporting it. I'm just  
11 saying the V&V is an 805 issue specifically and there  
12 are many other applications that don't require V&V for  
13 regulatory purposes.

14 MEMBER APOSTOLAKIS: Right.

15 MR. HYSLOP: That's all I'm saying.

16 MR. NAJAFI: I'd like to add also that  
17 this V&V project is also being done jointly by EPRI  
18 and Office of Research and is building on the  
19 precedent established by the fire risk methodology.

20 MEMBER APOSTOLAKIS: Have we ever been  
21 briefed on this?

22 MEMBER ROSEN: Yes, we had a short  
23 discussion of it. But I wouldn't call it a full  
24 briefing. It was just a short, maybe one hour's  
25 worth.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Okay.

2 MEMBER ROSEN: On what is being done, but  
3 not any of the detail.

4 MR. HYSLOP: So for further comments, we  
5 received comments by both industry and consultants;  
6 Duke Power, Florida Power and Light, two consultants  
7 EPM and RDS. We received comments from NRR as well.

8 No public comment required Research and  
9 EPRI to significantly adjust our approach.

10 We had a few comments on the state-of-the-  
11 art limitation. For example, we have one comment  
12 asking us to elaborate on our detailed quantification  
13 guidance. But the detailed HRS was beyond our scope  
14 because of the limitation of the state-of-the-art and  
15 the amount of resources required to address it. I  
16 mentioned that earlier.

17 Other comments were minor clarifications.

18 For millstones, we put out a draft report  
19 for public comment in October of 2004 for 60 days.  
20 We've addressed those comment. We're meeting today  
21 with the full Committee of ACRS.

22 We have a public fire PRA methodology  
23 workshop which is noticed on the website. It's going  
24 to be held in Charlotte, North Carolina from June 14th  
25 to 16th. There has been a lot of interest in this

1 workshop.

2 We intend to publish in August 2005.

3 We have a BWR pilot that we've talked  
4 about. And they've begun. And we hope to get plant-  
5 wide insights from a full implementation of the PRA in  
6 this pilot.

7 Should issues come out from this pilot,  
8 we're holding open the possibility of revision in the  
9 methodology.

10 MEMBER ROSEN: Do you see this as a  
11 limitation of pilot only to a BWR or will you get all  
12 the lessons learned that you need for PWRs as well?

13 MR. HYSLOP: Well, we'll get a lot of the  
14 lessons. Because, you know, a lot of the things are  
15 similar. The plant model might be a little different.  
16 There might be a few circuit issues that we don't run  
17 across.

18 I'm not sure. Have we addressed, would  
19 you say, most of the circuit issues in our PWRs, do  
20 you know? Pretty much?

21 MR. NOWLEN: Well, that's really hard to  
22 say. I mean, you know, because even for the PWRs we  
23 didn't get an exhaustive top to bottom answer. I  
24 can't say with high confidence that we've addressed  
25 all those issues, no. That's one of the reasons we're

1 holding out the possibility of republishing. If we  
2 gain new insights, we want to have that ability to  
3 reflect those in the methodology.

4 Actually, I should let Bijan say this.  
5 But no one plant gives you all the insights you need.

6 MR. HYSLOP: Yes. Yes.

7 MEMBER ROSEN: But I guess you didn't  
8 quite  
9 answer directly my question, which was the difference  
10 between Ps and Bs and whether or not you needed to go  
11 with a P to try to get more of that insight? Are  
12 there things that will specifically come up in a P  
13 that wouldn't come up in a boiling water reactor that  
14 you might need a pressurized water reactor pilot as  
15 well?

16 MR. NAJAFI: When you do these pilot  
17 applications, among other things, there are two kinds  
18 of insights, two categories you're for. One, you're  
19 looking for practicality and applicability of process.  
20 Does it work? Can it be used. The other piece is that  
21 you want to find out what is it going to tell you when  
22 it's done. Would you believe what you see at the end?

23 For the first process, the difference  
24 between Bs and Ps, we have done one in P. We've done  
25 it at Millstone. So we've tested the procedures and

1 they do work.

2 For the second piece, even having one  
3 application of a B and a one application of a P, in my  
4 mind it may give you some insight but it would not be  
5 sufficient. A methodology has to go into public  
6 domain to be used for a few years and get several  
7 plants using it until you gain some substantial  
8 insights.

9 As it's indicated by the IPEEE program, we  
10 gain insights from that because a number of plants  
11 used it. So we gained generic insights of what the  
12 fire has done.

13 So when it comes to the process, we have  
14 to sit in a PWR and it does work. We used it in  
15 Millstone.

16 MEMBER ROSEN: Are you thinking about  
17 ultimately -- well, maybe you should think about  
18 ultimately some sort of a peer review process, like we  
19 do now with internal events PRA. What do you think  
20 about that?

21 MR. NAJAFI: For the long run I think that  
22 is a good idea. In fact, we have even started in the  
23 process for us, at least, to start collecting  
24 information and library from users. There are already  
25 at least three or four plants domestically that even



1 have started using this process or methodology on  
2 their own. And there's one internationally that they  
3 intend to start using that process as early as maybe  
4 this year or next year.

5 We keep close tabs on that. We intend to  
6 get their lessons learned. All their insights  
7 collected. And then feedback into this process. And  
8 when there is need, if there is need, to learn from  
9 those users. Yes, that's something definitely needs  
10 to be done, and we have started the process but it may  
11 take a couple of years.

12 MEMBER ROSEN: Is in the standard, the  
13 fire PRA standard a peer review process?

14 MR. NAJAFI: No. No, no.

15 There is a peer review process for the ANS  
16 standard, yes.

17 MEMBER ROSEN: For the standard itself.

18 MR. NAJAFI: For the standard itself.

19 MEMBER ROSEN: No, I'm not asking. I'm  
20 saying in that standard, in the ANS fire PRA standard  
21 does it require a peer review process to be applied  
22 out of the utilities just like there in the internal  
23 events PRA?

24 MR. NAJAFI: Yes. There is a peer review  
25 process for a fire PRA. Not a fire PRA methodology.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 What we're talking about is to the ANS standard like  
2 ASME standard, has a section about how you peer review  
3 a fire PRA. That's different.

4 What I'm talking about is a review or a  
5 peer review, which George mentioned before, of this  
6 methodology.

7 MEMBER ROSEN: I understand the  
8 distinction.

9 MR. NAJAFI: Yes.

10 MEMBER ROSEN: And I was asking about the  
11 first thing you asked. I think the peer review part  
12 of the ASME standard for internal events is very  
13 valuable and has had a significant impact on the  
14 quality of internal events PRAs in the industry. And  
15 developed a cadre of people who talked to each other,  
16 and all the things that come from that sort of effort.  
17 I think I'm suggesting that a mirror process for fire  
18 PRA be thought about the practitioners.

19 MR. NOWLEN: Yes. The ANS standard does  
20 include a section that specifically references the  
21 broader peer review and recommends or requires that  
22 the same process be applied to your fire PRA with some  
23 specific callouts of the issues that are specific  
24 fire.

25 MEMBER ROSEN: Not there yet, because we

1 don't have a new method yet being used broadly. When  
2 we have a new method and when it's used broadly, I  
3 think it would be very valuable to have that  
4 additional peer review.

5 Go on, J.S.

6 MR. HYSLOP: Basically we had a very  
7 diverse project team and they addressed the areas  
8 critical to fire PRA. A lot of experience, relevant  
9 experience. These people were principal authors of  
10 the fire PRA methods in the U.S. for the past two  
11 decades. Experience with the strengths and  
12 weaknesses. And, again, this document reflect  
13 consensus of the team.

14 MEMBER APOSTOLAKIS: The human reliability  
15 analysis, is that based on ATHEANA?

16 MR. HYSLOP: Alan, can you hear me?

17 MR. KOLACZKOWSKI: Yes, I can.

18 MR. NOWLEN: By the way, just so everyone  
19 knows, Alan Kolaczowski from SAIC who was part of the  
20 NRC Research side team is with us on the telephone.

21 MR. HYSLOP: Did you hear George's  
22 question, Alan?

23 MR. KOLACZKOWSKI: I did.

24 No, the procedure as written does not  
25 specify any specific HRA method. It recognizes that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 licensees may want to use existing methods, whatever  
2 they are; THEARP, HF, CREME, whatever to take their  
3 internal events PRA and extend it to become a fire  
4 PRA. The procedure is flexible enough that any method  
5 can be used as long as you properly account for the  
6 unique fire effects in a fire PRA.

7 MEMBER APOSTOLAKIS: So what this method  
8 does then is it specifies the unique context that a  
9 fire creates and then you go ahead and use a method to  
10 quantify human reliability.

11 MR. KOLACZKOWSKI: That is correct.

12 MEMBER APOSTOLAKIS: Shouldn't that method  
13 be ATHEANA, though?

14 MR. KOLACZKOWSKI: I'm sorry. Could one  
15 of the methods be ATHEANA?

16 MEMBER APOSTOLAKIS: Shouldn't that method  
17 be ATHEANA, not one of the methods? It should be the  
18 method.

19 MR. KOLACZKOWSKI: Well, I think to  
20 specify that everyone should use a method is probably  
21 over prescriptive and probably does not need to be  
22 done. I mean, could ATHEANA certainly be used?  
23 Absolutely. Would it be a good idea? In some cases,  
24 yes. But I don't NRC wants to go to the point of  
25 prescribing a specific method just as it does now not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 prescribe a specific method to do the internal events  
2 PRA.

3 MR. NOWLEN: Yes. I'll jump in with one  
4 additional comment. We mentioned that we reached  
5 consensus in all aspects. I think that perhaps you  
6 could say this is one area where we chickened out just  
7 a little bit. We just decided that it was not  
8 reasonable for us to prescribe ATHEANA. We were also  
9 not willing to go so far as to say any particular  
10 method was acceptable or was considered best current  
11 practice. So in this area we didn't go that. We  
12 rather took a somewhat different view and said "Well,  
13 here are the issues that you need to address that are  
14 specific to the fire analysis. And you have to  
15 provide the justification for what your HRA analysis  
16 does."

17 MEMBER POWERS: Mr. Nowlen, there is a  
18 relatively famous study in which they used a variety  
19 of different HRA methods for a particular problem.  
20 And essentially came up with, say, charitably a broad  
21 spectrum of results. Don't you invite that when you  
22 allow such great flexibility in the choice of HRA  
23 methodology?

24 MR. KOLACZKOWSKI: This is Alan  
25 Kolaczowski again with SAIC.

1 I don't know if we're trying to invite  
2 that. I think on a totally different front but  
3 certainly related to this work there are activities in  
4 place, which I know the ACRS full Committee is very  
5 aware of in which the HRA community is undergoing a  
6 number of activities trying to, if you will, pull  
7 itself together, get formity in the use of the  
8 methods. Yes, I think you're all aware of the Good  
9 Practices document. Of course, the ASME standard  
10 provides some aspects as to what --

11 MEMBER POWERS: Well, not to cut you off,  
12 Alan.

13 MR. KOLACZKOWSKI: -- proper HRA. So I  
14 think on a different but certainly related the HRA  
15 community is attempting to solve the issue that you  
16 brought up, Dana. And I guess we're just trying to  
17 take advantage that, but short of prescribing a  
18 specific --

19 MEMBER POWERS: But you seem not to have.  
20 You seem to have abandoned the field. I mean, you had  
21 the opportunity to take advantage of that and put out  
22 something that you might call best practices. But you  
23 said, no, you'd just use whatever heck you want and  
24 provide some sort of justification of it. I mean, it  
25 seems like you did exactly the opposite of what you

1 said.

2 MR. NOWLEN: It's not quite that dire, I  
3 don't believe. We have provided specific guidance on  
4 screening, for example. And we have provided a fairly  
5 extensive discussions of the factors that needed to be  
6 considered in a HRA analysis. But for us it was a  
7 matter of resources, in effect, that we could not take  
8 on the broader issues of HRA analysis in general that  
9 would need to be addressed before we could get to the  
10 specific issues of HRA for fire. And so we choose not  
11 to expend our resources in that direction.

12 MEMBER POWERS: So what you're saying is  
13 this has all been premature?

14 MR. NOWLEN: No. I would not say that.  
15 This is --

16 MEMBER POWERS: Oh, I'm sure you wouldn't.  
17 But I might.

18 MR. NOWLEN: This is simply an area where  
19 additional work is needed and appropriate. And the  
20 report goes into some detail about this as an area of  
21 additional need.

22 We clearly acknowledge that in a sense you  
23 could say yes, we quit the field to some extent. We  
24 did not tackle this issue headon. We took it as far  
25 as we felt we reasonably could, and then we had to say

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that's as far as we can reasonably go, and that's  
2 where we stopped.

3 MEMBER APOSTOLAKIS: Isn't John Forrester  
4 the guy whose running ATHEANA?

5 MR. NOWLEN: Yes. John Forrester is the  
6 Sandi staff member who is leading the ATHEANA effort.  
7 And he was a strong advocate for ATHEANA. But again,  
8 I don't believe we could have possibly reached  
9 consensus where the industry would agree that the  
10 ATHENA method is the only way to do fire HRA. That  
11 was not reasonable.

12 MEMBER ROSEN: Well, I think we've aired  
13 that subject, J.S.

14 MR. HYSLOP: Okay. So the next slide  
15 shows the PRA process flow chart. It's fairly typical  
16 for fire PRA analysis. It shows one path to perform a  
17 fire PRA, but clearly there are many analysis paths  
18 that could have been taken.

19 Briefly, you parse the plant up. Identify  
20 components for the PRA model, which includes  
21 instrumentation. Because instrumentation often isn't  
22 identified specifically for an internal events PRA, so  
23 it's a little different here.

24 You trace the cables where you need to.

25 MEMBER APOSTOLAKIS: Yes. Let's talk a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 little bit about it, because I agree with you in the  
2 olden days we really focused on task 3, or what you  
3 call task 3 cables. Right?

4 MR. HYSLOP: Yes.

5 MEMBER APOSTOLAKIS: The first PRAs were  
6 cables?

7 MR. HYSLOP: Yes.

8 MEMBER APOSTOLAKIS: Cablecentric.

9 Now, you mentioned instrumentation.

10 MR. HYSLOP: Yes.

11 MEMBER APOSTOLAKIS: I mean, the  
12 instrument itself you're talking about, and what other  
13 components are you talking about?

14 MR. HYSLOP: Well, we're talking about  
15 instrument and cables that could lead to failure of  
16 the instrumentation.

17 MEMBER APOSTOLAKIS: Well, the cables all  
18 right. We understand the cable.

19 MR. HYSLOP: You want it? Go ahead.

20 MR. NOWLEN: Yes. The process started by  
21 picking the components that you want to credit in your  
22 fire PRA. Then based on the components you selected,  
23 which would include key instrumentation, you would  
24 then pick all of the associated cables for each of  
25 those components that you've now selected, which also

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 implies that you at some level then need to trace  
2 those cables.

3 MEMBER APOSTOLAKIS: But then what you're  
4 saying is that I already have a fire, I know what  
5 damage I have and I want to take credit for some  
6 components. And what I'm coming from is there is a  
7 fire in this location, what is it that I have to worry  
8 about.

9 MR. NOWLEN: Yes.

10 MEMBER APOSTOLAKIS: And up until recently  
11 we worried about the cables only. Now you're saying if  
12 there's a pump next to it, I have to worry about  
13 physical damage to the pump or you don't worry about  
14 it yet?

15 MR. NOWLEN: No. We are still in terms of  
16 damage states, very cablecentric. It still dominates.  
17 It's cables, yes.

18 MEMBER APOSTOLAKIS: So I'm talking about  
19 J.S.'s statement or what you have there in yellow,  
20 task 2 fire PRA component selection.

21 MR. NOWLEN: Right.

22 MEMBER APOSTOLAKIS: Is it cables or not?

23 MR. NOWLEN: Task 2 is not cables. Task  
24 2 is credited components that feed down to task 5 --

25 MEMBER APOSTOLAKIS: What do you mean

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 credited? I don't understand.

2 MR. NOWLEN: Do you want to take credit  
3 for a particular pump being operable as a part of your  
4 post-fire safe shutdown process.

5 MEMBER APOSTOLAKIS: So I have already  
6 assumed I have a fire?

7 MR. NOWLEN: Well, okay.

8 MEMBER APOSTOLAKIS: That's where you lose  
9 me. If I start with a fire, I have to worry about its  
10 impact on the plant.

11 MR. NOWLEN: Yes.

12 MEMBER APOSTOLAKIS: I'm an old guy, you  
13 know. I remember the Zion PRA. It was just damage on  
14 the cables. Now J.S. tells me no, it's damage on other  
15 things, too. What other things?

16 MR. NOWLEN: Yes. In that sense, yes. You  
17 are assuming that you are going to have a fire.

18 MEMBER APOSTOLAKIS: Yes.

19 MR. NOWLEN: And now you want to say what  
20 plant components functions, capability am I going to  
21 credit given that I have a fire to achieve safe  
22 shutdown?

23 MEMBER APOSTOLAKIS: But don't I have to  
24 know the damage first before I start blaming credit.

25 MR. NOWLEN: No. No. Because what this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 builds on, is it builds basically on two pieces of  
2 information. You begin with your Appendix R safe  
3 shutdown analysis --

4 MEMBER APOSTOLAKIS: Oh.

5 MR. NOWLEN: -- which has already made  
6 assumptions about what equipment you're going to  
7 credit for post-fire safe shutdown. And you supplement  
8 that with anything that you want to take credit for  
9 from your internal events PRA, which takes credit for  
10 many things beyond the Appendix R system. You merge  
11 those two and reconcile any differences, and you come  
12 up with now a list of fire PRA components that are  
13 going to be taken into the plant safe shutdown model.

14 The cables then are the link between those  
15 systems and the potential damage states.

16 MEMBER ROSEN: Cables and instrumentation?

17 MEMBER APOSTOLAKIS: Yes. But before I  
18 get--

19 MEMBER ROSEN: Not power cables. Just --

20 MR. NOWLEN: No, no. Power cables as well.  
21 Power control instrumentation --

22 MEMBER ROSEN: Power and instrumentation  
23 service.

24 MR. NOWLEN: Absolutely. On any  
25 component. So components would include electrical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 buses. Electrical buses would include the control for  
2 the electrical bus as well as the power cables for the  
3 electrical bus. Pumps would typically have  
4 instrumentation. Your reactor, you know, you've got  
5 key reactor vessel --

6 MEMBER ROSEN: Including circuits that  
7 simply provide indication and information to the  
8 operators?

9 MEMBER APOSTOLAKIS: Yes.

10 MR. NOWLEN: Yes. In some cases those are  
11 picked as well.

12 MEMBER ROSEN: Right.

13 MR. NOWLEN: Critical ones. You wouldn't  
14 necessary model every single --

15 MEMBER ROSEN: Not everything.

16 MR. NOWLEN: Right.

17 MEMBER ROSEN: But if there's a step in  
18 your safe shutdown analysis for an operator to do  
19 something based on some received signal, then that  
20 signal cable has to be available.

21 MR. NOWLEN: Precisely. And that's a very  
22 good example of exactly the way the procedure is  
23 written.

24 MEMBER APOSTOLAKIS: I am not clear.

25 I have a fire in -- and I go and I'm

1 trying to find out kind of initiating event, where am  
2 I entering in the event trees. And I find that I, you  
3 know, by damaging a bunch of cables I end up a small  
4 LOCA. Then I know what I need to mitigate a LOCA and  
5 I can do what you were just saying; I will need these  
6 components. But before I get there, I have to know I  
7 have a small LOCA, which is a result of the damage.  
8 And that damage is damage on cables only, which is not  
9 correct? You don't assume any other damage.

10 MR. KOLACZKOWSKI: This is Alan  
11 Kolaczowski at SAIC. Let me try to answer that.

12 There is a step in the task 2 procedure  
13 that's a little different from the rest of the  
14 procedure in that its focus is to identify the very  
15 thing you're talking about, George. What initiating  
16 event is going to happen for each fire that's  
17 postulated in each compartment. And that is based on  
18 what equipment is in that compartment and/or what  
19 cables pass through that compartment.

20 MEMBER APOSTOLAKIS: But you're not  
21 looking at damage to the equipment. Only to cables?

22 MR. KOLACZKOWSKI: No. Possibly damage to  
23 the equipment. For example, a rather unique case is  
24 there are plants that still have copper tubing as part  
25 of their instrument air system. You could postulate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that the fire melts some of the copper tubing,  
2 therefore you lose your instrument air pressure. And  
3 as far as the plant is concerned, it looks like a loss  
4 of instrument air. That would be the initiating event  
5 postulated for that specific events.

6 MEMBER APOSTOLAKIS: And you are giving  
7 guidance to people how to do these things.

8 MR. KOLACZKOWSKI: Yes.

9 MR. NOWLEN: Yes. Now there are many  
10 physical components that would not be vulnerable to a  
11 fire. And there's a list of those that we recommend  
12 you assume are invulnerable. Check valves, major  
13 piping systems as long they're not soldered joints;  
14 things of that nature.

15 In general, for example, with a pump.  
16 Take a pump. If a pump is in this particular location,  
17 the fire will usually attack the cables leading right  
18 up to the pump. I mean, there's a cable drop. So for  
19 most, even things like valves, pumps, motors it's  
20 usually the cable that's the vulnerable component.  
21 So, yes, in those cases we would attack the cable in  
22 the fire scenario. But there are cases where you may  
23 also attack -- the instrument error is a good example.  
24 Where you could attack certain types of other  
25 components besides cable.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Instrumentation in their main control  
2 board, for example, would be another one. Where the  
3 instrument itself may be more vulnerable to damage  
4 because it's solid state and a cable is relatively  
5 robust compared to a solid state circuit board.

6 MEMBER APOSTOLAKIS: Are you also  
7 including damage due to smoke?

8 MR. NOWLEN: In a qualitative sense, yes.  
9 Quantitatively no because the data's just not there.  
10 But there are recommendations for including a  
11 qualitative judgment as to the extent of where smoke  
12 might cause additional damage.

13 MEMBER APOSTOLAKIS: But that would really  
14 be a step change in the methodology, would it not?

15 MR. NOWLEN: It's a step change, yes.

16 MEMBER APOSTOLAKIS: Yes. Is anybody in  
17 the world independently of nuclear power, outside,  
18 developing models for damage to cables or instruments  
19 due to smoke? Is anybody looking into it?

20 MR. NOWLEN: Not that I'm aware of. The  
21 only industry that I know that was looking at was the  
22 telecommunications industry.

23 MEMBER APOSTOLAKIS: Yes.

24 MR. NOWLEN: Because of the experience  
25 they had with some of their switching center fires.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MEMBER APOSTOLAKIS: Right. Exactly.

2 MR. NOWLEN: I don't know to what extent  
3 that work's underway.

4 Actually, I'll add a second one. The  
5 Navies of the world have been somewhat concerned about  
6 this issue as well. Their focus has generally shifted  
7 towards new cable formulations that would minimize the  
8 hazard of smoke to equipment. So I'm not aware of any  
9 specific equipment vulnerability studies. They're  
10 going after what they call the FRNC, fire-retardant  
11 non-corrosive cables.

12 So there are people out there, you know,  
13 and a lot of this work was fairly active ten years  
14 ago. And the difficulty is it hasn't led to a lot of  
15 quantitative insights. Lots of qualitative insights  
16 available. Not much that you could quantify and, for  
17 example, a fire model.

18 MEMBER APOSTOLAKIS: Okay.

19 MEMBER ROSEN: J.S., please.

20 MR. HYSLOP: Okay. So we'll move on to  
21 quantitative screening and pick up our screening post-  
22 fire HRA that we talked about in the fire model.

23 We perform a scoping fire modeling to  
24 eliminate components from consideration.

25 Then we move on to the more detailed

1 aspect of the fire PRA process, flow chart where we  
2 either perform a probabilistic circuit analysis or  
3 detailed fire modeling, or both. Basically wherever  
4 you get your bang for the buck. If you can refine your  
5 fire modeling estimate and rule out multiple spurious  
6 you do that. On the other hand, you may just want to  
7 quantify low probability circuit analysis issues.

8 Then you quantify, consider uncertainty  
9 and sensitivity and --

10 MEMBER APOSTOLAKIS: Are you coming back  
11 to the quantitative screening? Are you going to say  
12 any more about it?

13 MR. HYSLOP: I wasn't. What's your  
14 question?

15 MEMBER APOSTOLAKIS: You will?

16 MR. HYSLOP: No. I don't have anything  
17 else in presentation.

18 MEMBER APOSTOLAKIS: What is quantitative  
19 screening?

20 MR. HYSLOP: Quantitative screening is the  
21 consideration of fire ignition frequencies. Screening  
22 values of HRA. Your consequence, your CCDP. In the  
23 first stage. In the second stage there's a screening  
24 where you apply simplified fire models at a heat  
25 release rate, a very high percentile heat release rate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and then you eliminate components. There are a couple  
2 of levels of screening.

3 MEMBER APOSTOLAKIS: But are you using the  
4 concept of limiting fire scenario anywhere?

5 MR. HYSLOP: No. No, we're not.

6 MEMBER APOSTOLAKIS: The maximum expected  
7 fire scenario?

8 MR. HYSLOP: The heat release rate that we  
9 use in the case where we actually look at fire damage  
10 from a source, we're using the 98th percentile of our  
11 heat release rate distribution.

12 MEMBER APOSTOLAKIS: Okay.

13 MR. HYSLOP: And that's what we're using.

14 MR. NOWLEN: I'll also add a point that  
15 those two terms, maximum and expected and limiting  
16 fire scenario, are specific to 805, obviously. And as  
17 a team we choose not to attempt to define those terms  
18 because it was beyond the scope of the project in  
19 terms of that's something that really needs to be  
20 debated publicly by the regulatory with industry to  
21 define what those terms mean.

22 So you will not find those terms used in  
23 our document, limiting fire scenario and maximum  
24 expected. We simply did go to that --

25 MEMBER APOSTOLAKIS: Well, maybe the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 reason is is that they are inconsistent with the fire  
2 PRA. And you don't have to answer that.

3 MR. NOWLEN: Within the project, I have to  
4 say I cannot answer that question.

5 MEMBER APOSTOLAKIS: I know you cannot.  
6 I can, though. And they are.

7 Let's go on. Let's on. We're slowing down  
8 so much. J.S., please.

9 MEMBER ROSEN: Okay, J.S.

10 MR. HYSLOP: Okay. We're moving on.

11 I was going to talk in detail about some  
12 of these tasks. We talked a little bit about the fire  
13 PRA component selection. Essentially, some of the  
14 advances over the IPEEE that contribute to important  
15 components are consideration in multiple spurious  
16 actuations and key instrumentation, as we've  
17 indicated. We got some public comments in these  
18 areas. One asked for a search for new scenarios, any  
19 associated components for spurious actuation or other  
20 contributors.

21 One example I can think of is you might  
22 not model SRVs in an internal events model but for  
23 fire it might be necessary because you might fail the  
24 pores. So you have a new consideration.

25 We've added more on unique manual actions,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 including instrumentation needed as well as accounting  
2 for equipment effects.

3 You know, certainly we need to identify  
4 cables for instrumentation where manual actions rely  
5 on a few key indications.

6 We also need to be aware that if the  
7 procedure requires us to de-energize a piece of  
8 equipment like a -- well, you certainly can't count  
9 on for later feed and bleed; things like that. So you  
10 need to be aware that something you do in a procedure  
11 early on can effect you later. That's what that means.

12 So you perform a cable selection for all  
13 the fire PRA components, as we said. And we factor  
14 all of this in our fire-induced risk model in task 5  
15 for purposes of quantitative screening.

16 So for post-fire HRA task 12, we've  
17 developed screening level human error probabilities  
18 and they range from ten times the internal of XPRA,  
19 ATPs to one for extremely challenging circumstances.  
20 We've provided an identification and discussion of  
21 performance shaping factors for detailed analysis.  
22 There, you know, stress, smoke, high temperature  
23 indications are examples. And we try to be as plant  
24 specific and scenario specific as possible in those  
25 applications.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Our procedure does not provide detailed  
2 quantification guidance, as we've indicated.

3 Public comments. The major public comment  
4 caused us to remove discussion of fire specific pre-  
5 initiator HFEs. Basically that could apply to fire  
6 protection systems, barriers, program elements. We  
7 often treat with data, for example. We actually  
8 quantify the unavailability of fire doors with data.  
9 So you certainly wouldn't want to incorporate an HFE  
10 that overlaps or confuses that quantification.

11 This does not preclude plant specific HRA  
12 or fire specific pre-initiator HFEs as long as you  
13 don't double count it in this case.

14 MEMBER APOSTOLAKIS: Why did you remove  
15 these? I'm sorry, I missed it.

16 MR. HYSLOP: We removed them because we  
17 felt like we could treat them with data. Typically  
18 you have data, for example, associated with the  
19 unavailability of fire doors. So if you got that data  
20 in your quantification, then you don't want to add  
21 pre-initiator human failure events that would also  
22 count for the same type of activity that you've  
23 already accounted for in the data.

24 MR. NOWLEN: Yes. The version of the  
25 procedure that went out for public comment had a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 discussion of the incorporation of fire specific pre-  
2 event human failures. And as a result of the comment,  
3 it became clear that there was a little bit of a  
4 disconnect between what was done in other places with  
5 that discussion. So the discussion of specifically  
6 incorporating those into the HRA was removed. And in  
7 its place there's a discussion that says if you want  
8 to do fire specific pre-initiator actions, then you  
9 have to go back and consider that, for example, the  
10 reliability of a fire protection system already  
11 includes human induced failures. For example, the  
12 failure to restore operability after maintenance.  
13 Those are already in the generic reliability.

14 So if you want to do it, you need to go  
15 back and revisit these other values. That was the  
16 change.

17 MR. HYSLOP: So we also added general  
18 guidance on the use existing HRA methods, but no  
19 specific quantification guidance as we got requested  
20 from one comment.

21 As we had, the existing methods may not be  
22 fire-specific, but we talked about a process on how to  
23 modify the PSFs.

24 We made significant improvement in fire  
25 frequencies. Most of our fire sources are now

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 component based. We don't parse equipment, say  
2 cabinets, according to a room. We're now looking at  
3 it more based on plant population. And this allows  
4 for more consistent refined and reasoned compartment  
5 scenario frequencies that reflect plant configuration.

6 We've done an extensive analysis of the  
7 event data. If you remember, IPEEEs took the full  
8 fire frequency and modified it by a severity factor,  
9 which was generic, not very scenario specific.

10 First of all, we've gone through all  
11 events and characterized them as potentially  
12 challenging or not. And our potentially challenging  
13 is a little boarder than has been used in the past.  
14 We look at fires that could be challenging and one  
15 particular configuration, although they might not in  
16 other, so we capture those.

17 And we have also developed severity  
18 profiles which are linked to our fire frequencies. We  
19 basically consider the frequency, the heat release  
20 rate/severity profile and the suppression as a set.  
21 Need to be used as a set. If you do something to one,  
22 you need to look and see if there's an impact on the  
23 other.

24 So we had a lot of discussion and  
25 adjustment during peer review. We went over events

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 several times based on challenges from our peer  
2 reviews on whether or not they were challenging, the  
3 fires were challenging.

4 MEMBER APOSTOLAKIS: Did you include  
5 transient fuels?

6 MR. HYSLOP: Yes, we did.

7 MEMBER APOSTOLAKIS: In which bullet am I  
8 supposed to understand that?

9 MR. HYSLOP: Well, we went over the events  
10 -- well, I didn't say it specifically, so maybe you  
11 aren't.

12 MEMBER APOSTOLAKIS: So there may be, you  
13 know, somebody makes a mistake and leaves a -- you  
14 have allowed for that?

15 MR. HYSLOP: Transient fuels are  
16 considered in a --

17 MEMBER APOSTOLAKIS: Is that a judgmental  
18 kind of thing or do you have actual information? I  
19 know there have been a few instances where people  
20 left, you know, not large but amounts of fuels that  
21 shouldn't be there.

22 MR. HYSLOP: Well, generally, we have an  
23 event reports.

24 MEMBER APOSTOLAKIS: I'm sorry.

25 MR. HYSLOP: We have reports, the event

1 reports--

2 MEMBER APOSTOLAKIS: There are sufficient  
3 number of those?

4 MR. HYSLOP: Yes. To find on the turbine  
5 building, but there are a fair amount.

6 MEMBER APOSTOLAKIS: Yes.

7 MR. NOWLEN: But it also does factor in  
8 the inspection report, insights that were gained back  
9 in the days of the Army studies, for example, where  
10 they looked at these transients that have been  
11 identified. So it incorporates our best current  
12 understanding of what the nature of the transient fire  
13 might be.

14 There is a process for providing a  
15 relative ranking of your fire compartments for the  
16 likelihood and whatnot that a transient fire would  
17 occur in a particular location. And to some extent  
18 that's judgmental. The analyst is asked to assign  
19 weighting factors on three different factors to each  
20 area and then you basically ensure that you  
21 reconstruct the plant wide frequency of transient  
22 fires, which does come from the events.

23 So there's a number of pieces that come  
24 together here, but transients are treated in some  
25 detail.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN WALLIS: A transient fire is a  
2 fire due to some transient fuel being present rather  
3 than a fire which is itself a transient?

4 MR. HYSLOP: Right.

5 MR. NOWLEN: The idea is it's transient  
6 versus situ; things that are fixed in place versus  
7 things that could be found anywhere.

8 MEMBER ROSEN: Fuel.

9 MR. NOWLEN: It's the fuel. The initial  
10 fuel, yes.

11 MR. HYSLOP: I'm going to talk about task  
12 9, which is the detailed circuit analysis. Earlier  
13 for component selection we considered all potential  
14 failure modes. Now we're looking at those failure  
15 modes a little more realistically. This is generally  
16 reserved for cases in which quantitative screening  
17 indicates a clear need in advance for further  
18 analysis.

19 As I say, we're more realistic so we need  
20 to do a detailed failure modes analysis. And the  
21 objective is to screen out cables that cannot impact  
22 the ability of a component to complete its accredit to  
23 the function.

24 This is primarily a deterministic  
25 function, however it's risk-informed. And I'll get to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that in my public comment.

2 One of the public comments was to provide  
3 enhanced risk-informed guidance to focus the analysis  
4 on failure modes on concerns. We basically looked at  
5 those circuit analysis issues that were important top  
6 cut sets. They're deterministic analysis in those  
7 cases.

8 We also incorporated guidance for the  
9 human factors interface. One of the earlier  
10 assumptions was to look at the recovery action and if  
11 it was simple, felt high confidence that we would get  
12 done, the circuit analysis issue would be dropped, not  
13 carried further. Well, we decided to change that.  
14 Now the circuit analysis issues are carried into task  
15 12 on HRA analyses to determine the likelihood of  
16 those and of the manual action.

17 Task 10 is where the probabilities come  
18 in. We've got two methods presented. One uses the  
19 expert panel results, that's the EPRI expert  
20 elicitation. Another is a computational based  
21 analysis. We developed a method for spurious  
22 actuation probability which goes beyond the test  
23 configurations, the NEI test configurations. If you  
24 remember that was a seven conductor cable and there  
25 was one conductor wrapped around it. Well, we now

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 we've got an approach to analyze configurations above  
2 and beyond that.

3 MEMBER ROSEN: Have you published in that  
4 any forum other than in 6850?

5 MR. HYSLOP: No. No. It hasn't been  
6 published. And we also realize that it would be  
7 beneficial to get some data on that and, hopefully,  
8 during the Bin 2 we'll be able pick up a little data.

9 This probabilistic circuit failure mode  
10 likelihood analysis requires a great deal of  
11 knowledge. Circuit design, cable type as whether you  
12 got thermoplastic, theromost, construction, installed  
13 configuration, conduct versus cable tray, etcetera.

14 It's generally reserved --

15 MEMBER POWERS: How many licensees have  
16 all that information?

17 MR. HYSLOP: I don't know. Do you know,  
18 Bijan?

19 MR. NAJAFI: One thing I wanted to  
20 clarify, I guess your question also coming back to  
21 yours, the information about the expert panel results  
22 and some of the computational method, maybe earlier  
23 version of it, were published in two EPRI reports last  
24 year.

25 MEMBER ROSEN: I was thinking of peer

1 review journals. Archival type.

2 MR. NAJAFI: No.

3 MR. HYSLOP: And a question about how many  
4 utilities have all this data available to do the  
5 probabilistic circuit analysis?

6 MR. NAJAFI: Every nuclear power plant in  
7 the United States has access to this data as part of  
8 that EPRI report.

9 MEMBER POWERS: They'd need information  
10 about their plant.

11 MR. NOWLEN: I think I understand the  
12 question. This is one of the areas where we see  
13 there's a significant potential challenge for  
14 licensees to gather all this information to really do  
15 this level of analysis, which is one of the reasons  
16 it's in the flow chart where it is. It's relatively  
17 late in the process, you're in detailed  
18 quantification, there are alternatives to pursue other  
19 types of information. But this gets into the cable.  
20 Tracing, you have to know whether is it in a conduit  
21 or is it in a cable tray. The initial cut is to take  
22 the conservative assumptions for those factors you  
23 don't understand. And if you find that if they're  
24 significant, then you go back and chase more  
25 information. So for those cases where it's having an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 impact on your result, you would chase the  
2 information.

3 MEMBER ROSEN: You haven't answered the  
4 question. Do you know how many by percentage, how  
5 many?

6 MR. NOWLEN: Well, I think given the way  
7 we've written our procedures, I'm not sure there's any  
8 one plant that would have this information for every  
9 cable that they're likely to have interest in in the  
10 PRA. Do they have it for some cables? Absolutely.  
11 Most of their Appendix R cables will be relatively  
12 well documented. They'll know whether they're in  
13 raceways. They know what types of cables they have.  
14 They know how many conductors, that sort of thing.  
15 It's actually the routing information that gets a  
16 little bit more difficult. But when we begin to pick  
17 up other types of systems, there's information  
18 available at the plant but it's never been interpreted  
19 in a fire context.

20 For example, there are electrical analysis  
21 will have identified cable types. They will have done  
22 studies on the cables, for example, so they'll have  
23 information on in general the nature of the raceway  
24 that it's in. They may not know specifically where  
25 it's at. So there's a lot of information available,

1 but bottom line is, no, they are going to be chasing  
2 additional information.

3 MEMBER ROSEN: Do you know a circuit  
4 raceway cable program known as EE 580?

5 MR. NOWLEN: I'm not familiar with that  
6 one, no.

7 MR. NAJAFI: Let me try, now that I can  
8 understand the question and answer.

9 This type of information about the cable  
10 design, cable type and what is in, it is much easier  
11 in every plant to find if the cables are in cable  
12 trays. They generally have much better information in  
13 their cables in the cable trays.

14 In some plants they have cables in the  
15 conduits. So that is a second tier.

16 When it gets even harder is to know a  
17 specific cable type design when it's inside, let's  
18 say, a main control board. That's the hardest part.  
19 To know what's inside, where is it and what circuit  
20 type.

21 But cable trays are easy. Conduits okay.  
22 Inside cabinets are the hardest part.

23 MEMBER SIEBER: I think plants that were  
24 built pretty late, like the late 1980s, they use pull  
25 tickets where you had a ticket for every cable that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 you pulled, where it's terminated, what trays it went  
2 through. And we had that for our latest units, but we  
3 did not have it for the units built in the 1970s.

4 MEMBER ROSEN: And that information was  
5 computerized at some plants.

6 MEMBER SIEBER: Yes. Well, you have to run  
7 a program to actually figure out what's connected to  
8 what and where the cable goes.

9 MR. NOWLEN: Yes. We ran into that issue  
10 with both of our pilots, in fact. They each had older  
11 style cable routing databases. And it was quite a  
12 challenge to translate that into something that you  
13 could query in the context of a PRA.

14 MEMBER SIEBER: That's right.

15 MR. NOWLEN: So, again, it's one of those  
16 resource uncertainties depending on how hard that task  
17 is going to be, that will have a significant impact on  
18 the overall scope of the project. And, yes, a lot of  
19 these older databases are not well suited to our  
20 needs.

21 MEMBER ROSEN: Now in most cases, however,  
22 if you're pushed hard enough you can do a hand-over-  
23 hand tracing in a compartment of where it goes to,  
24 except in cases where the trays have been filed with  
25 some fire retardant material. In that case, you might

1 not be able to anymore.

2 MEMBER SIEBER: Hand-over-hand topped on  
3 a cable tray that's got 75 cables in it.

4 MEMBER ROSEN: Not impossible, but --

5 MR. NOWLEN: It's not impossible. It's a  
6 substantial amount of really unpleasant work. And so,  
7 again --

8 MEMBER SIEBER: Well, they're usually  
9 tagged on the end so if you can find the end, you're  
10 okay.

11 MR. NOWLEN: That's right. They'll  
12 typically -- you know, finding end points. You can  
13 find where it enters a cable tray and you go to the  
14 other, and it comes out the other end so you know it  
15 didn't dive off somewhere strange in between.

16 Yes, you know the cable, the fire  
17 retardant coatings that were applied, complicate the  
18 issue because you can't break in under that coating  
19 anymore. If they're wrapped in fire barrier  
20 materials, you can't just tear the wrap up and go  
21 after it. So there are significant challenges here,  
22 yes.

23 MR. NAJAFI: Also, to add in terms of the  
24 resources. Our experience in the last two plants show  
25 when you get to this task 10, the level of effort is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 almost an order of magnitude less.

2 MEMBER SIEBER: Yes.

3 MR. NAJAFI: What you have to do the most,  
4 it occurs in our task 3 and the majority of it, almost  
5 it could be in some old plants that you'd have to go  
6 through drawings. That task could be 50 percent of  
7 the entire job to do.

8 MEMBER ROSEN: All right, J.S., let's go  
9 on.

10 MR. HYSLOP: Okay.

11 MR. HYSLOP: Okay. So basically this  
12 support the bullet that this was reserved only for  
13 those cases that can't be resolved through other  
14 means.

15 Now for task 10 continuation on the  
16 circuit failure mode likelihood analysis. There's  
17 some key insights here.

18 We feel that we really improved our  
19 knowledge here, but the uncertainties are still high.  
20 The practical implementation is challenging, as was  
21 just stated. It's a challenge to manage your resources  
22 in this circuit analysis work.

23 We also feel that a further analysis of  
24 the existing test data would be beneficial as well as  
25 follow-on tests. Basically, you could analyze the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 data more and get more information fire timing  
2 duration out of it.

3 And then Research also -- but we have  
4 plans to do tests. We have plans to do the Bin 2  
5 test, part of the RIS 2004-03. And so we will be  
6 getting more information.

7 We got comments from the public and peer  
8 review on this. There was some extensive discussions  
9 regarding the most appropriate way to tally spurious  
10 actuation probabilities. I guess in PRA we're  
11 interested whether a valve would change state from a  
12 spurious actuation, whether if it's open it would go  
13 closed or vice versa.

14 The expert elicitation focused on whether  
15 the target conductors for either open or closed would  
16 be contacted by the energized conductor. PRA is only  
17 interested in a single outcome. And fortunately, the  
18 test showed that meltable target conductors were  
19 contacted by an energized conductor during these  
20 tests.

21 I guess the consensus from the team was  
22 that as applied the expert panel values were generally  
23 conservative.

24 We also requested some additional  
25 independent review of the circuit analysis method. We

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 solicited it. It was favorable, but the reviewers  
2 acknowledged there was a fairly high uncertainty in  
3 what we were doing.

4 In the detailed fire modeling, there we  
5 addressed single, multi compartment and main control  
6 room fire scenarios. Approach is traditional.  
7 Identify fire sources, fire growth/spread/damage,  
8 consider detection/suppression and then a CCDP.

9 We also developed some special models to  
10 account for nuclear power plant fire scenarios beyond  
11 the capabilities of existing computational fire  
12 models.

13 Task 11 was a fairly weighty task.  
14 There's a lot in there. I've got a few slides on that.

15 First of all, is the heat release rate in  
16 severity. The IPEEE in many cases used a fixed heat  
17 release rate and single severity factor for an  
18 ignition source. We now have a distribution which  
19 ties heat release rate to severity factor. This  
20 distribution was based on expert judgment and it  
21 captures the high intensity fires that often weren't  
22 captured in the IPEEE.

23 If you look at the diagram on the right,  
24 there's a peek heat release rate distribution versus  
25 probability. Probability versus peek heat release

1 rate. And the vertical lines shows the minimum  
2 tensivity leading to spread and damage, and our severity  
3 factor is at that part of the distribution beyond the  
4 vertical line. So that's how they capture the severity

5 MEMBER POWERS: Are you sure this is a  
6 probability density function?

7 MR. HYSLOP: Yes.

8 MEMBER POWERS: Not probability?

9 MR. HYSLOP: It's normalized. Probability  
10 equals one under there, so it's a true probability.

11 MEMBER POWERS: No, it's a density  
12 function.

13 MR. HYSLOP: Oh, a density function.  
14 Sure. Sure.

15 Basically we used this function for  
16 scoping fire modeling. Because we used the 98th  
17 percentile in scoping fire modeling to determine  
18 whether components are damaged.

19 MEMBER POWERS: What you mean is that you  
20 assumed all density factors are in the top two percent  
21 when you scope and then you find out what gets  
22 damaged?

23 MR. HYSLOP: Yes. And if it's damaged,  
24 then you keep it and you carry it on to refined  
25 modeling.

1           We developed some special models. We  
2       developed a model to address high energy arcing  
3       faults. This is entirely new. It's critical to the  
4       switchgear room. This is an empirical rule set based  
5       on operating experience. It consists of two phases.  
6       There's a high energy phase, kind of an explosive  
7       phase where we have a zone of influence for ignition  
8       of secondary combustibles and physical damage. And in  
9       that phase we don't allow any credit for fixed or  
10      manual suppression, suppression by the --

11           MEMBER POWERS: I'm sorry. Can I go back  
12      to that density function?

13           MR. HYSLOP: Okay.

14           MEMBER POWERS: Why is it not log-normal?

15           MR. HYSLOP: Go ahead.

16           MR. NOWLEN: That's not intended to be  
17      representative of anything. It's just an arbitrary  
18      curve drawn on the figure to illustrate the idea of  
19      having a minimum intensity leading to failure. It's  
20      completely an artificial construct. Most of these  
21      were, in fact, modeled with a log-normal distribution.  
22      I don't know if we used it in all cases. But I know  
23      the vast majority we did with log-normal.

24           This was just an Excel construct.

25           MEMBER POWERS: So if I thought of that as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the log or the P-T release rate, I'd probably be more  
2 right?

3 MR. NOWLEN: You'd probably be closer to  
4 right, yes. Yes.

5 MEMBER POWERS: I'm sorry.

6 MR. HYSLOP: So we have a high energy  
7 phase and then we have a thermal phase or the enduring  
8 fire from the ignition of combustibles. And we treat  
9 that like any other fire source where we allow  
10 suppression versus damage.

11 We have a model for the main control  
12 board. It's critical to control room fire risk and  
13 it's a probabilistic model for the frequency of fire  
14 damage for target sets in the main control board.

15 It's most useful for those main control  
16 boards where there are no dividers and it gives a  
17 sense for determining targets and damage.

18 We've got a cable fire model, critical --

19 MEMBER ROSEN: Hold on. These new efforts  
20 not in any archival journals?

21 MR. HYSLOP: No. These were the first  
22 time these were published. This is it.

23 MEMBER ROSEN: In NUREG 6850?

24 MR. HYSLOP: Yes. Both of those two don't  
25 appear anywhere else. Well, wait. We do have a high

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 energy arcing fault model in the SDP. But it's  
2 simpler. You want to talk about that, Steve?

3 MR. HYSLOP: Yes. The SDP uses a very  
4 similar rule set, but as far as publication goes,  
5 these have been presented at various conferences, but  
6 not a referee journal article yet. So it has been  
7 disseminated both -- and by the way, both within the  
8 general fire protection community and in the nuclear  
9 risk fire group. But it's been more conferences, not  
10 the referee journal article.

11 CHAIRMAN WALLIS: This model for the  
12 propagation inside the main control board. Presumably  
13 that is a framework and someone then has to make it  
14 specific to the particular plant?

15 MR. HYSLOP: Yes.

16 CHAIRMAN WALLIS: So it may not be that  
17 easy to figure out the coefficients and things that go  
18 into the model?

19 MR. NOWLEN: Well, we've got that all  
20 documented and the Appendix discusses that particular  
21 model so that you can recreate our calculation. And  
22 the main factors that go into play is generally the  
23 overall size of your particular main control board,  
24 the overall dimensions. If you have a very small main  
25 control board, then in a sense you're concentrating

1 the main control board fire frequency in a smaller  
2 zone, so you'd end up with higher probabilities for  
3 any one. But it is documented to the point where  
4 someone could with relative easy recreate it.

5 MR. HYSLOP: We have some other special  
6 models. I'll just name them. Several of them are  
7 consolidations. Fire propagation to adjacent  
8 cabinets, passive fire protection features and smoke  
9 damage or consolidation. We have approaches for  
10 hydrogen fires and turbine generator fires. These are  
11 new.

12 We have an approach for detection and  
13 suppression where you have probability of non  
14 suppression, which is a conditional probability that  
15 the first will last long enough to cause a damage.  
16 And the approach is fairly comprehensive. It looks at  
17 prompt detection and suppression, automatic  
18 detection/suppression, manual detection/suppression.  
19 And this is a case where we also analyze more  
20 extensive data. We look at those long duration fires  
21 and we now incorporate those specifically in our  
22 values for suppression reliability.

23 So it's an improvement over previous  
24 methods that we're analyzing more data and we have an  
25 explicit framework for analysis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: But wait. The  
2 probabilities are the result of expert judgment, I  
3 assume. They look at all this stuff, what automatic  
4 detection capability do it I have or manual and so on,  
5 and --

6 MR. HYSLOP: Well, some are based on data.  
7 But there are valves that have been around for  
8 automatic -- based on demand, whether or not an  
9 automatic -- the system is going to go off. And  
10 they're in many books. And they've been around.

11 MEMBER APOSTOLAKIS: But the conditional  
12 probability that the fire last long enough to cause  
13 postulated damage.

14 MR. HYSLOP: Well here --

15 MR. NOWLEN: This is the weighing of  
16 damage time versus time to suppression. So it's  
17 similar to past practice. It's just been --

18 MEMBER APOSTOLAKIS: But it's really a  
19 competition of the two, isn't it?

20 MR. NOWLEN: Precisely. Yes.

21 MR. HYSLOP: Yes.

22 MEMBER APOSTOLAKIS: Here though you're  
23 saying if it takes 23 minutes to damage those cables,  
24 what is the probability that in these 23 minutes I'll  
25 detect and suppress?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. NOWLEN: Right.

2 MR. HYSLOP: Right.

3 MEMBER APOSTOLAKIS: And if it takes ten  
4 minutes, then I'll have a different probability?

5 MR. NOWLEN: Correct.

6 MEMBER APOSTOLAKIS: And is this  
7 probability so sensitive to these minutes?

8 MR. NOWLEN: Yes.

9 MEMBER APOSTOLAKIS: How do you know?

10 MR. NOWLEN: The main piece that's quite  
11 sensitive to the timing is the manual suppression,  
12 which tends to be the most important piece. So, you  
13 know, the likelihood that a fire lasts an hour is very  
14 low, but the main fire -- detection is done using fire  
15 models. We predict the time to detection and fold  
16 that into the overall suppression event tree as a time  
17 factor.

18 The suppression event tree is pretty  
19 typical you come up with end states of how you got to  
20 suppression, whether it was manually detected and  
21 manually suppressed, for example, given failure of  
22 your fixed systems versus actuation of an automatic  
23 system. And each of those has a different time -- a  
24 translation time, basically, of how you got from here  
25 to there. So the combination of the probability that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 you end up on each end state with the transition time  
2 associated with the end state is then weighed against  
3 your prediction of the damage time to estimate the  
4 likelihood that that fire then was either damaging or  
5 not, the probability --

6 MEMBER APOSTOLAKIS: Are you going  
7 separate this in all of this stuff?

8 MR. NOWLEN: There are uncertainties in  
9 some aspects of it, yes. Not in every single rigorous  
10 aspect, but to the extent that you can --

11 MEMBER APOSTOLAKIS: But the important  
12 thing is to have the uncertainty in the final number.  
13 I mean, if you come up with fractions of times that  
14 you are suppressing it or nonsuppressing it, given a  
15 certain period of time, that should be some --

16 MR. NOWLEN: Yes. And, again, it's  
17 primarily driven by the uncertainty of the manual  
18 suppression curves. And those are characterized as a  
19 representative curve with uncertainty bounds.

20 MEMBER APOSTOLAKIS: Yes.

21 MR. NOWLEN: There's also the other part  
22 of uncertainty that's folded into this is this concept  
23 of the distribution of heat release rate. Any one  
24 fire source can give you multiple heat release rates  
25 each having some likelihood of occurrence. So there's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 uncertainty that comes in through the heat release  
2 rate because, obviously, the higher the intensity of  
3 the fire, the shorter the damage --

4 MEMBER APOSTOLAKIS: At least the  
5 principal uncertainty.

6 MR. NOWLEN: Yes. That's the real driver.  
7 Yes. And that one is treated explicitly through our  
8 distribution of heat release rate, which you generally  
9 would -- and treat a certain number of discrete cases  
10 and then refold those back into the final answer.

11 MEMBER ROSEN: We're going to talk about  
12 uncertainty later.

13 MR. HYSLOP: It's coming up.

14 MEMBER ROSEN: But it's soon.

15 MR. HYSLOP: Okay. So we talked about the  
16 V&V of fire models. And how we're treating them. We  
17 got a comment on it.

18 Alan, you there?

19 MR. KOLACZKOWSKI: Yes.

20 MR. HYSLOP: Okay. So this is task 15 the  
21 uncertainty and sensitivity analysis. It addresses the  
22 process for uncertainty and sensitivity analyses, a  
23 process for treating modeling and data uncertainties.

24 MEMBER APOSTOLAKIS: Now that's where you  
25 have to tell us how you do that.

1 MR. HYSLOP: Alan?

2 MR. KOLACZKOWSKI: This is Alan  
3 Kolaczowski, SAIC.

4 The procedure is written to develop --  
5 basically to describe a process for developing the  
6 uncertainties that you're going to quantify or somehow  
7 treat in the analysis. It does not a priori define a  
8 specific -- of uncertainties. However, ones that are  
9 crucial to the final risk are included such as the  
10 ones we've been talking about. We have a distribution  
11 about the heat relates. We have a distribution with  
12 regards to fire detection and suppression frequencies,  
13 those kinds of things. But we do not necessarily  
14 identify the bounds for every item that you might to  
15 specify as being uncertain the fire PRA model.

16 MEMBER APOSTOLAKIS: But there are two  
17 areas, though, where one might want to see some  
18 estimate of the model uncertainty. One is in the code  
19 that might be used for heat transfer calculations to  
20 calculate, for example, the time to damage. And the  
21 second which I understand you're recommending a number  
22 of codes without saying use this one, right? CFAST  
23 and so on.

24 And the other area is the human  
25 reliability analysis, the response to the fire which,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 again, if you use one model you don't know what  
2 another model might produce.

3 Is there any attempt to quantify those  
4 uncertainties?

5 MR. HYSLOP: Well, the V&V approach is the  
6 approach that's addressing the fire models, not this  
7 approach. We're simply saying the model's right there.

8 MEMBER APOSTOLAKIS: But the model itself  
9 may have some uncertainty associated with its  
10 predictions.

11 MR. HYSLOP: Sure.

12 MEMBER APOSTOLAKIS: I mean, do you  
13 recognize that here? You acknowledge it?

14 MR. KOLACZKOWSKI: Yes, to that extent,  
15 George, we do. We do talk about the new possibility  
16 identify sensitivity analyses that we'll use. But you  
17 may postulate, for instance, in the model to how  
18 sensitive the results are to change the model  
19 structure.

20 MEMBER APOSTOLAKIS: Speak closer to the  
21 microphone, Alan. We can't hear you.

22 MR. KOLACZKOWSKI: Okay. It does address  
23 sensitive analyses as being to identify how robust  
24 your answer is to initial changes in your models.

25 MEMBER APOSTOLAKIS: Okay. All right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 Have you done -- not you personally, I mean the  
2 project. Have you done a sensitive analysis that will  
3 tell me what the top five drivers are? We already  
4 identified one, the heat release rate. I agree from  
5 day one, February 1, 1981 it was -- okay.

6 What are the other four?

7 MR. KOLACZKOWSKI: We have not -- while we  
8 have tested the procedures on an individual basis, as  
9 I think as has already been expressed, with the first  
10 two pilot plants we were not able to do an integrated  
11 overall testing of all the procedures all the way  
12 through to the point where we actually had a fire PRA  
13 and results and we could look at what was dominating.

14 MEMBER APOSTOLAKIS: Can you tell us after  
15 you do the pilots what the top five model  
16 uncertainties are or parameter uncertainties so that  
17 someone, you know, in a utility who wants to do this  
18 and doesn't want to be innovative, doesn't want to  
19 change the state-of-the-art, will have some guidance  
20 as to where to pay attention? I think that would be  
21 extremely useful and already we have identified the  
22 first one. If you guys can do that, that will be  
23 great.

24 MEMBER ROSEN: I think the report is  
25 pretty clear in task 15 and this Appendix V, I guess

1 it is, that there are requirements for calculating the  
2 uncertainty. Actually calculating it in the fire  
3 ignition frequency area. But also in the post-fire  
4 human reliability area.

5 The rest of the areas, the 6950 suggests  
6 that there be a quality review. In other words, a  
7 second review, not a quantification which is a  
8 weakness, I think.

9 MR. NOWLEN: It is a combination of those  
10 explicit quantification of uncertainties, sensitivity  
11 studies and in some cases quality reviews for example  
12 to get at completeness of your plant model. You know,  
13 it's typical of the internal events as well. You have  
14 to ask yourself how complete is your model of the  
15 plant. Say, shutdown response we have the same issue.  
16 How complete was your consideration of potential  
17 circuit analysis issues. You have to do a review, and  
18 we've recommended that a peer review is a good process  
19 for doing that to learn from others. Well, we saw  
20 this at our plant, is it possible at yours? Did you  
21 consider it?

22 So I think in some areas the completeness  
23 review based on a peer review is an appropriate way to  
24 deal with that. In other cases, we can quantify and  
25 we recommend that we do quantify.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 In the specific area of the fire models we  
2 make recommendations as to quantifying uncertainties  
3 associated with your fire models. But we did not, for  
4 example, attempt to quantify the uncertainties  
5 associated with CFAST. That was not our job.

6 MEMBER APOSTOLAKIS: But is it something  
7 that in the future must be done?

8 MR. NOWLEN: I believe the V&V effort is  
9 the area where that is being done. And they are  
10 looking at the uncertainties associated with these  
11 models calculations, reliability.

12 MEMBER APOSTOLAKIS: And where is the  
13 uncertainty with respect to smoke impact?

14 MR. NOWLEN: That's another one of those  
15 that is very difficult to quantify.

16 MEMBER APOSTOLAKIS: That's right.

17 MR. NOWLEN: It would be done in the sense  
18 of a sensitivity study. That is, if you were to  
19 assume widespread smoke damage, how would that change  
20 your results? Are you sensitive to the assumption  
21 there? Since we can't really quantify smoke impact,  
22 it's hard to quantify the uncertainty in smoke impact,  
23 as well.

24 MEMBER POWERS: Steve, when you talk about  
25 smoke impact are you talking about immediately during

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the fire or its immediate aftermath?

2 MR. NOWLEN: Yes.

3 MEMBER POWERS: What does the agency do,  
4 probably J.S. is not the right person to ask, but I'll  
5 ask anyway. I mean, the fact is that smoke particles  
6 themselves, fairly acidic typically. And so they go  
7 in and they get onto to connectors and things like  
8 that. They have no trouble today. You have no  
9 trouble tomorrow. Six months from now that connector  
10 is corroded. And now you have troubles. What do you  
11 do about that?

12 MR. NOWLEN: I can't really speak for the  
13 agency, obviously. But, you know, these are fairly  
14 well known phenomena in the fire community. So it is  
15 true, smoke after a fire there is some pretty  
16 extensive cleanup that needs to be done. And, again,  
17 going back to the telecommunications, they've really  
18 pioneered the methods for identifying what needs to be  
19 cleaned up and then going in and actually cleaning up.

20 MEMBER POWERS: And if we regulated the  
21 telecommunications business, we'd be in good shape.  
22 But we don't.

23 MR. NOWLEN: Yes, but those same  
24 technologies have translated directly to nuclear power  
25 industry. And the same techniques apply. So there is

1 a pretty good understanding of what you need to be  
2 aware of, you know, what levels of smoke are a long  
3 term hazard, which in long term it's relatively light  
4 levels of smoke can cause long term problems for a  
5 component.

6 And then the methods for, you know, when  
7 is an object recoverable versus write it off and  
8 replace it. So I think that's a fairly mature  
9 technology that has in fact found it's way directly to  
10 the licensees. It was pioneered, really, by the  
11 telecommunications, but it's now -- you know, you can  
12 pick up a phone book and find services that specialize  
13 in post-fire restoration of electronic equipment, for  
14 example.

15 MEMBER APOSTOLAKIS: Yes, but that doesn't  
16 help you with the analysis.

17 MR. NOWLEN: No. In our analysis we are  
18 limited to the time frame of the fire. We're not  
19 looking at a fire that occurs now and six months later  
20 I have a component failure. That is outside of the  
21 scope of the fire PRA.

22 MEMBER POWERS: But if we're ever going to  
23 integrate fire PRA and normal operations PRA, we've  
24 got to figure out some way to handle that. And, I  
25 mean, that -- this morning we spent some time talking

1 about how we're going to utilize risk in defining  
2 criteria for future plants. And without integrating  
3 these two areas together, that discussion was  
4 essentially a feat.

5 MEMBER APOSTOLAKIS: Can you explain the  
6 first sub bullet under "Some changes were made?"

7 MR. HYSLOP: Yes. Basically there were  
8 discussions on uncertainties for each task, each  
9 procedure. And we got a comment requesting that we  
10 consolidate that under task 15, which is the task for  
11 uncertainty and sensitivity. So we just removed the  
12 discussion to one area as opposed to having it  
13 distributed all among the report.

14 MEMBER APOSTOLAKIS: Well, the thing that  
15 worries me is that years ago I was asked to review a  
16 fire PRA. And when I mentioned the uncertainties,  
17 looked at me as if I was from Mars. They said nobody  
18 does that. Why do you want us to do it? Has the  
19 attitude changed now? Is the industry willing to  
20 actually do uncertainty analysis in the fire area?

21 MR. NAJAFI: Let me try to answer that.

22 The attitude is that way because IPEEE,  
23 which is the biggest experience that industry has, did  
24 not require it. Has that attitude changed? It  
25 remains to be seen. Once this goes out and people do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 new. But it's very clear -- that it states that that  
2 is a critical issue that you need to pay attention to.

3 We have not gone and created a whole new  
4 science for uncertainty. I mean, this document does  
5 not do that. Does not advance the science of  
6 uncertainty in anyway. All it does it makes a list of  
7 these -- are they unique uncertainties due to fire.  
8 Things that are important to fire.

9 Example, fire model uncertainty. These  
10 are things.

11 And also, in addition to that, it says  
12 some can be quantified and should be quantified. Some  
13 needs to be addressed through sensitivities because  
14 you can't come up with distribution, at least for the  
15 current state-of-the-art. There's some that you can't  
16 even do any of it, weakness or whatever. It's just an  
17 acknowledgement. It's there. But we can't tell you  
18 anything to do about it.

19 And the model uncertainty, by the way it's  
20 a good point to bring it up that you said this  
21 document it does not get again get to the depth of the  
22 model uncertainty. It just mentions that as a point.  
23 It says there are -- we talk here about the parameters  
24 that are input to the model and we deal with the  
25 uncertainty of those.

1 For example, did you pick all the right  
2 scenarios? You may have missed some scenarios. But  
3 when you put in, let's see, CFAST, what it comes out  
4 of how you trust the number, that is not here. That's  
5 something that in part V&V project is supposed to  
6 address to say what is the validity or accuracy of the  
7 numbers given a specific set of input.

8 MEMBER ROSEN: All right. Wrap it up, J.S.

9 MR. HYSLOP: All right. I have two more  
10 slides. I'll go through this one quickly.

11 CDF insights. This is compared to the  
12 IPEEE and it's in the author's judgment, since we  
13 haven't applied this throughout an entire PRA.

14 We expect the overall range of CDF --

15 MEMBER ROSEN: Why don't you wrap it up on  
16 that one.

17 MR. HYSLOP: Okay.

18 MEMBER ROSEN: How did you make that  
19 judgment? I mean, is there any basis for that or is  
20 it just --

21 MR. HYSLOP: For what?

22 MEMBER ROSEN: For the first one? To  
23 reflect the overall range of CDF for the fleet of  
24 plants to be maintained.

25 MR. HYSLOP: Well, we looked at the



1 overall range, which is quite broad, from 10 to the  
2 minus 7 -- minus 4. We recognized that our  
3 methodology to have some increases and some decreases.  
4 And so we made a general statement that as far as we  
5 know right now, we don't have any issues that are  
6 going to drive the CDF up tremendously or drive it  
7 down without some competing fashion.

8 MEMBER ROSEN: Okay. I was confused. It's  
9 the second one I have.

10 MR. HYSLOP: Well, let me go to that then.

11 MEMBER ROSEN: Yes.

12 MR. HYSLOP: So we do expect that the  
13 individual risk profile of some plants to change.  
14 There are some plant specific configurations, poor  
15 separation for instance where multiple sprays is  
16 likely to be more important. For example, high energy  
17 arcing faults have the potential to dry things up. On  
18 the other hand, our main control board model allows us  
19 to make more refined determinations of damage. That  
20 could drive us down --

21 MEMBER ROSEN: Well, you're saying things  
22 could move around?

23 MR. HYSLOP: Yes.

24 MEMBER ROSEN: Plants that are pretty good  
25 now might find that they are not so great? Some

1 plants that think they're great or think they're in  
2 poor or might be better than they think.

3 MR. HYSLOP: Yes.

4 MEMBER ROSEN: And that's what I think  
5 will happen.

6 MR. HYSLOP: Yes. That's what I'm saying.  
7 But all in all we feel we feel like this methodology  
8 needs to continue to be applied, continue to get  
9 insights, continue to grow.

10 So however, cable tracing is still going  
11 to be a major resource requirement in circuit  
12 analysis. That hasn't changed. We just have to  
13 address it through screening aspects and hope we don't  
14 get there too often.

15 MEMBER ROSEN: And what you're saying by  
16 addressing it through screening aspects means that not  
17 everybody has to trace everybody cable?

18 MR. HYSLOP: Yes. There's fire damage  
19 estimates that may eliminate components from  
20 consideration, that may eliminate multiple spurious,  
21 so that's what I'm trying to say.

22 MR. NOWLEN: And I would even go further  
23 that no one should have to trace every cable in their  
24 plant. That should not --

25 MEMBER ROSEN: Okay. But there will be

1 cases where it will be beneficial to do so and people  
2 will determine it's possible and it will be helpful,  
3 and people will --

4 MR. NOWLEN: Absolutely.

5 MR. HYSLOP: Okay. We the last slide and  
6 then to wrap up.

7 We feel this is the best available method  
8 to estimate fire risk and obtain insights. You know,  
9 certainly the methodology will continue to evolve in  
10 applications, but this is the best.

11 We feel that improvements will benefit the  
12 state-of-the-art. We talked about spurious actuations,  
13 about some Bin 2 testing and about an equation that  
14 goes beyond the EPRI Research testing configurations.  
15 Certainly more information on those would be helpful.

16 We have screening approach for HRA. A  
17 detailed approach. We need to put some effort into  
18 that.

19 For low power and shutdown operations  
20 there's some differences between low power and  
21 shutdown methodology and full power. Granted, there's  
22 a lot that carries over, but there's frequencies on  
23 availability, plant model, that's a different issue.

24 And then finally for plant specific  
25 assessment of fire fighting, we feel it would be

1 beneficial to capture individual characteristics and  
2 fold that into the fire PRA.

3 Thank you.

4 MEMBER ROSEN: Thank you. It's a very  
5 good presentation, a very good piece of work. It is  
6 imperfect. There's still work to be don. But I think  
7 it's a vast improvement over what we had before in  
8 terms of guidance available to do these things.

9 MEMBER APOSTOLAKIS: Can we have a  
10 detailed presentation in the future of an actual pilot  
11 applications? Not just the insights, the nitty-  
12 gritty, you know. They did this and they did --

13 CHAIRMAN WALLIS: It's all going to be  
14 one, isn't it? It's going to be one pilot, isn't it?

15 MEMBER POWERS: It seems to me that such  
16 a detailed presentation would be in the domain of the  
17 Fire Protection Subcommittee.

18 MEMBER APOSTOLAKIS: Absolutely.  
19 Absolutely.

20 MEMBER POWERS: I would suggest you speak  
21 to the gentleman on your left and he will arrange that  
22 for you.

23 MEMBER APOSTOLAKIS: Okay. Because  
24 usually the Committee does not hear things like that,  
25 even the Subcommittee. They tell you what --

1 MEMBER POWERS: Well the Subcommittee  
2 could hear and figure out if the full Committee needs  
3 to.

4 MEMBER APOSTOLAKIS: But they don't come  
5 into the Subcommittee room --

6 MEMBER POWERS: I mean, it's been  
7 traditional for the Fire Subcommittee to stay on top  
8 of the field. And attend various conferences and  
9 things like that. So it's not necessary to plunge into  
10 details.

11 MR. HYSLOP: I think we might to speak to  
12 the licensee to see if there's any proprietary  
13 information.

14 MEMBER APOSTOLAKIS: Well, we can swear.

15 CHAIRMAN WALLIS: That's something  
16 consider, right?

17 MR. HYSLOP: Well, but it's something that  
18 you need to ask.

19 MR. NOWLEN: Yes, but the way it's  
20 structure right now is that the final analysis belongs  
21 to the licensee. Our parts of it, the demonstration  
22 studies are public. But what the licensee does in the  
23 end is their study. So we wouldn't --

24 CHAIRMAN WALLIS: Maybe if they're very  
25 proud of it, they'll want to present it to us.

1 MR. NOWLEN: They could very well be. But  
2 it would certainly take their --

3 MEMBER APOSTOLAKIS: They can skip the  
4 vulnerabilities.

5 MEMBER ROSEN: All right. Thank you, Mr.  
6 Hyslop.

7 MR. HYSLOP: Thank you.

8 MEMBER ROSEN: Gentlemen.

9 Chairman, back to you early by 18 minutes.

10 CHAIRMAN WALLIS: I think you're late.

11 MEMBER SIEBER: I think you're late.

12 CHAIRMAN WALLIS: You're late. We've lost  
13 some time. We've been using a little bit on every --

14 MEMBER ROSEN: No, no. I think we took  
15 our hour and a half.

16 CHAIRMAN WALLIS: You took an hour and a  
17 half, plus eight minutes.

18 We've been slowly slipping.

19 We will take a break until 20 minutes to,  
20 realizing that we've got a lot to do yet with the next  
21 item.

22 (Whereupon, are 2:34 p.m. a recess until  
23 2:40 p.m.)

24 CHAIRMAN WALLIS: Let us come back into  
25 session. I will hand this over to my colleague, Dr.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       Shack, to lead us through the intricacies of the  
2       single-failure criterion.

3               VICE CHAIRMAN SHACK:   Okay.   We're going  
4       to talk about the evaluation of the broader change to  
5       the single-failure criterion.   The single-failure  
6       criterion arise from the GDC and in the analysis of  
7       design-basis accidents.   In the design criteria, the  
8       objective of the single-failure criterion is to  
9       achieve high safety system reliability.   High  
10      reliability can be achieved in a number of ways.   The  
11      single-failure criterion forces the designer to use  
12      redundancy to achieve high reliability.   We could  
13      refer to this as the structuralist approach to  
14      reliability.   However, we know from experience that  
15      the single-failure criterion is not always sufficient  
16      to assure adequate reliability.

17              PRA methods could be used to provide a  
18      rationalist approach to reliability.   The required  
19      reliability would be a function of the frequency of  
20      the challenge, and it would consider support systems,  
21      as well as safety systems, and it would consider  
22      common cause and other types of multiple failures.  
23      Like all rationalist approaches, it would depend  
24      strongly on the quality of your PRA.

25              In the analysis of design-basis accidents,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the current approach sometimes focuses attention on  
2 events with very low frequency, and with low  
3 probability system failures that may, in fact, have  
4 low risk significance.

5 Sufficiently unlikely, and low risk  
6 significant single-failure sequences could be removed  
7 from design-basis. Design-basis accidents based on  
8 PRA analyses that could include multiple failures, and  
9 would represent a much larger portion of the actual  
10 risk could be added.

11 Although this issue has arisen most  
12 recently in the development of a risk-informed 50.46,  
13 the Staff has been tasked to consider a broader change  
14 single-failure criterion in the regulations, and  
15 they're here today to brief us on their progress in  
16 defining potential alternatives, and the pros and cons  
17 of these alternatives, and Hossein is going to make  
18 this presentation to us.

19 MR. HAMZEHEE: Thank you. Again, my name  
20 is hossein Hamzehee. I'm the Section Chief in PRA  
21 Branch of Office of Nuclear Regulatory Research. Next  
22 to me is John Lane, Senior Risk and Reliability  
23 Engineer of the PRA Branch also, office of Nuclear  
24 Regulatory Research. I would also like to introduce  
25 other team members that are sitting in the back; Bob

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)



1 Youngblood and Scott Newberry of ISL, Incorporated;  
2 and Ted Ginsberg and Gerardo Martinez from Brookhaven  
3 National Lab. So in case there are more detailed  
4 questions that we cannot handle, we'd ask the folks in  
5 the back to help us out.

6 With that, let me just quickly tell you  
7 why we're here, which is consistent with what Dr.  
8 Shack mentioned. The purpose of this presentation is  
9 to provide --

10 CHAIRMAN WALLIS: That's a single-failure.

11 MEMBER SIEBER: I liked it better the  
12 first way.

13 VICE CHAIRMAN SHACK: We notice this is  
14 the high tech presentation.

15 MEMBER ROSEN: You notice it was easy to  
16 fix. If it happened with the computer, you'd have to  
17 wait.

18 MR. HAMZEHEE: Well, the purpose of this  
19 presentation is really to provide a summary of status  
20 of our evaluation of a broader change to single-  
21 failure criterion, and also give you a summary of  
22 planned follow-up activities. And what we would like  
23 the ACRS is to provide some feedback, hopefully via a  
24 letter on the work completed to-date on risk-informed  
25 alternatives, and also the planned follow-up

1 activities that we'll go over shortly.

2 MEMBER APOSTOLAKIS: So no oral feedback.

3 MR. HAMZEHEE: I beg your pardon?

4 MEMBER APOSTOLAKIS: No oral feedback.

5 MR. HAMZEHEE: Hopefully written, but oral  
6 is fine, too.

7 Now I understand we have about no more  
8 than an hour, an hour and 20 minutes, so we would like  
9 to quickly give you some background, and a summary of  
10 technical approach and the work completed to-date.  
11 And then we would also like to provide a summary of  
12 NRR major comments and where we are with those planned  
13 follow-up activities, and quickly go over schedule.  
14 And if time permits, we'll have provided two examples  
15 for each alternative. We can also present those three  
16 examples in a summary fashion.

17 Again, as was mentioned earlier, there was  
18 an SRM on March 31<sup>st</sup>, 2003 that was on the risk-  
19 informed changes to 10 CFR 50.46. And in that SRM,  
20 the Commission approved most of the recommendations  
21 that Staff made on possible changes to LOCA  
22 requirements. And you've seen and heard in the last  
23 few months presentations on proposed rulemaking on  
24 50.46.

25 In the same SRM, the Commission also

1 directed the staff to risk-inform the requirements of  
2 LOCA coincident with loss of off-site power. And in  
3 addition, they directed us to pursue a broader change  
4 to single-failure criterion and inform the commission  
5 of our findings beyond what was considered for the  
6 request for LOCA/LOOP. Now this one was done, mainly  
7 it runs to that directive.

8 Now again, our interpretation of broader  
9 change is to risk-inform alternatives that could apply  
10 to all plant functions, and safety and non-safety  
11 functions and systems, not just to ECCS. And that  
12 could definitely lead to changes that would impact  
13 licensing, programmatic activities such as testing,  
14 inspections, and plant performance marshaling  
15 activities.

16 MEMBER BONACA: So running on any  
17 component, it would be applicable to any component  
18 with respect to whether it is safety-related or not  
19 safety-related.

20 MR. HAMZEHEE: Yes, except that the  
21 single-failure criterion as we speak only apply to  
22 safety-related systems. But when we risk-inform them,  
23 they could apply to non-safety related. That's a  
24 risk-informed approach, but currently it's only for  
25 safety-related, as you know.

1 MEMBER BONACA: Yes. Because, I mean, in  
2 the past application for that condition have led to  
3 significant oversight.

4 MR. HAMZEHEE: Correct. Now before we go  
5 further, let's just make sure we all have a common  
6 understanding of what single-failure means. The term  
7 "single-failure" is defined in 10 CFR Part 50,  
8 Appendix A, as follows: "A single-failure means an  
9 occurrence which could result in loss of capability of  
10 a component to perform its intended safety function."  
11 And then it also talks of "multiple failures that may  
12 result from a single occurrence are considered to be  
13 a single-failure." And a good example is loss of the  
14 support systems, like if you lose a diesel generator,  
15 that's one occurrence, but that could impact four or  
16 five front line systems. So you say this is not a  
17 single failure.

18 MEMBER APOSTOLAKIS: But for years now  
19 people have been saying that the single-failure  
20 criterion does not include common cause --

21 MR. HAMZEHEE: It does not. Common cause  
22 is different.

23 MEMBER APOSTOLAKIS: But wouldn't the  
24 common cause be multiple failure resulting from a  
25 single occurrence?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HAMZEHEE: Yes.

2 MEMBER APOSTOLAKIS: So why isn't it  
3 included?

4 MR. HAMZEHEE: That's the way it is  
5 currently in the design.

6 MEMBER APOSTOLAKIS: Is it because the  
7 focus of this definition is hardware, not causes?

8 MR. HAMZEHEE: Correct.

9 MEMBER APOSTOLAKIS: Okay. So common  
10 cause failure is a single cause.

11 MR. HAMZEHEE: Yes.

12 MEMBER APOSTOLAKIS: But that cause may be  
13 anything.

14 MR. HAMZEHEE: Yes. But when we go over  
15 some of these alternatives where you risk-inform and  
16 common cause failure is a major attribute to risk-  
17 inform those -- because you cannot ignore it any more.

18 MEMBER APOSTOLAKIS: Correct.

19 MR. HAMZEHEE: And that's based on the  
20 risk -- that's all covered. Now we'll talk about them  
21 shortly. And then it says that: "The fluid and  
22 electrical systems are considered to be designed  
23 against an assumed single-failure, if neither a  
24 single-failure of any active component, assuming that  
25 passive components function properly, nor a single-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 failure of a passive component assuming that active  
2 components function properly result in a loss of  
3 capability of a system to perform its intended safety  
4 function." This is the definition in Appendix A of 10  
5 CFR Part 50.

6 CHAIRMAN WALLIS: Only fluid and electric  
7 systems? I mean, how about mechanical systems which  
8 have various components, and have to move and do  
9 something. There's no application to them?

10 MR. HAMZEHEE: Yes. It says fluid and  
11 electrical. Fluid here we mean mechanical systems, as  
12 well.

13 CHAIRMAN WALLIS: Fluid means mechanical?

14 MR. HAMZEHEE: Correct.

15 CHAIRMAN WALLIS: That's new to me. Okay.

16 MR. HAMZEHEE: I believe that's what we  
17 mean by fluid systems are mainly most of the  
18 mechanical systems.

19 MEMBER APOSTOLAKIS: Hossein.

20 MR. HAMZEHEE: Yes, sir.

21 MEMBER APOSTOLAKIS: What is the reason,  
22 if you know, of this one and two, a single-failure of  
23 any active component assuming passive components. I  
24 mean isn't that the whole idea of a single-failure  
25 criterion to assume a single-failure?

1 MR. HAMZEHEE: Correct.

2 MEMBER APOSTOLAKIS: Why does it have to  
3 tell me assuming that the other stuff is working?

4 MR. HAMZEHEE: Because here they want to  
5 emphasize that there are two types of components,  
6 active and passive. And as we go over our  
7 presentation, some of the requirements regarding  
8 passive components are not as clear as for active  
9 components. So here they're saying that for active  
10 components, assuming all your passive components work,  
11 they have to be functional, as well as the other way  
12 around, for clarity purposes. But technically you're  
13 right, either one could precede the purpose of single-  
14 failure criterion.

15 And then there's an associated footnote  
16 that I'm sure Steve remembers. It's been there for  
17 many, many years, that says: "Single failures of  
18 passive components in electrical systems should be  
19 assumed in designing against a single-failure.  
20 However, the conditions under which a single-failure  
21 of a passive component in a fluid system should be  
22 considered in designing the system against a single-  
23 failure or under development. So you see there are  
24 not clear guidelines for passive components to fluid  
25 systems, so you may see some flexibilities, how

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 licensees apply some of these rules --

2 CHAIRMAN WALLIS: Are there guidelines  
3 about what a component is? I mean, almost every  
4 component has sub-components, and how far do you go  
5 down before you come to --

6 MR. HAMZEHEE: The simple definition is a  
7 component is, for instance, an MOV, an AOV, a pump, a  
8 circuit breaker.

9 CHAIRMAN WALLIS: But it's not a  
10 particular part of the pump.

11 MR. HAMZEHEE: Those are sub-components.

12 MEMBER APOSTOLAKIS: But you don't apply  
13 the single-failure criterion to those, I don't think.

14 MR. HAMZEHEE: No, you don't. However, if  
15 they fail, they would impact the functionality of your  
16 component. Then you're talking about the component.

17 CHAIRMAN WALLIS: But there could be  
18 redundancy in those other sub-components.

19 MR. HAMZEHEE: Yes.

20 CHAIRMAN WALLIS: Okay.

21 MEMBER APOSTOLAKIS: I think they're  
22 looking at it the way a PRA would develop, perhaps a  
23 fault tree.

24 CHAIRMAN WALLIS: Yes. It's a component.

25 MEMBER APOSTOLAKIS: You really don't go



1 down to the 2000 sub-components --

2 CHAIRMAN WALLIS: The bolts and all that.

3 VICE CHAIRMAN SHACK: It's sort of tied to  
4 function.

5 MR. HAMZEHEE: That's correct.

6 MEMBER APOSTOLAKIS: But isn't this  
7 footnote essentially negating the second sentence.

8 MR. HAMZEHEE: That's why we have it here.  
9 That's why if you go over alternatives to explain to  
10 you what --

11 MEMBER APOSTOLAKIS: It's always confusing  
12 to me. It says do one or two, but then there's a  
13 footnote that says we cannot do two now.

14 MR. HAMZEHEE: It doesn't say we cannot.  
15 It says --

16 MEMBER APOSTOLAKIS: Guidance.

17 MR. HAMZEHEE: Correct. But that doesn't  
18 mean that you have to ignore them. As I said, if you  
19 go back and look at industry, they have ways of  
20 addressing these things. It's not that they've been  
21 totally ignored.

22 MEMBER APOSTOLAKIS: Okay.

23 MR. HAMZEHEE: Now this is the common  
24 understanding of the single-failures. Now let's go  
25 back and talk a little about some of the background

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 information.

2 CHAIRMAN WALLIS: Wait a minute. This bit  
3 that was under development, that was under development  
4 when this was written?

5 MR. HAMZEHEE: Yes.

6 CHAIRMAN WALLIS: So it's been under  
7 development for two decades or so?

8 MR. HAMZEHEE: For many years.

9 CHAIRMAN WALLIS: Still it's under  
10 development?

11 MR. THADANI: Since 1971.

12 CHAIRMAN WALLIS: Thirty-four years.

13 MR. THADANI: Thirty-four years. And I  
14 might just comment on what Hossein said. I think  
15 George was correct in what he said, in this  
16 historically for design-base accidents, we have  
17 applied single-failure of active components, not  
18 passive components. In other words, you don't  
19 postulate a design-base accident in one pipe, and fail  
20 another pipe. Rather, you fail active single  
21 components.

22 CHAIRMAN WALLIS: But you could fail an  
23 ECCS, some sort of pipe in the ECCS system as a result  
24 of a LOCA somewhere else.

25 MR. THADANI: If it's a consequential

1 failure, you need to consider, but not as an  
2 independent single-failure of a passive component.

3 MR. HAMZEHEE: That's correct, yes. Now  
4 SFC requirements mainly exist in two major contexts,  
5 one is in the general design criteria of 10 CFR 50,  
6 Appendix A, which identifies safety functions and  
7 associates safety systems to which the SFC apply.  
8 There's also a design-basis accident guidance of  
9 Chapter 15 of Reg Guide 1.70 and the Standard Review  
10 Plan. And then it's also important to realize the  
11 single-failure criterion is one element of NRC  
12 defense-in-depth concept.

13 CHAIRMAN WALLIS: In a way it is, but in  
14 another way it's a stop-gap. If you're not doing this  
15 PRA-type analysis of the probability of these  
16 failures, you do the best you can. You assume the  
17 worst single-failure.

18 MR. HAMZEHEE: That's correct.

19 CHAIRMAN WALLIS: Which is sort of a  
20 substitute, rather than a defense-in-depth --

21 MEMBER APOSTOLAKIS: In some sense, in  
22 fact, it limits defense-in-depth.

23 CHAIRMAN WALLIS: Yes, it does, because it  
24 could be something else.

25 MEMBER BONACA: The other point that I was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 making before, I mean, there is a presumption that you  
2 will, first of all, determine the safety-related  
3 components, that you have an understanding of those.  
4 And you don't apply the single-failure to the non-  
5 safety related components. And I point out that in  
6 every transient analysis, they never include the PORVs  
7 before Three Mile Island, and that modeling was  
8 totally neglected because the PORV was not safety-  
9 related; so, therefore, you don't model it. And so,  
10 therefore, you take the single-failure on that one.

11 MEMBER APOSTOLAKIS: I don't think there  
12 is anything profound here. Those smart guys, they  
13 realize they needed low probabilities of failure.  
14 They couldn't quantify that, and they said do this.  
15 This is really the simplest way that you have.

16 CHAIRMAN WALLIS: But it's a kind of  
17 bounding approach, isn't it?

18 MEMBER APOSTOLAKIS: Achieve high  
19 reliability, that's what they wanted.

20 MEMBER ROSEN: It was believed to be a  
21 bounding approach, but it turns out not to be.

22 MEMBER BONACA: Not to be, because there  
23 were instances where this segregation a priori  
24 eliminated elements and you had no basis for doing it  
25 on a --

1 MEMBER APOSTOLAKIS: But that was the  
2 intent.

3 MEMBER BONACA: I understand.

4 MEMBER APOSTOLAKIS: The intent was  
5 deterministic methods to achieve low probabilities of  
6 -- this is the key. At that time, nobody was talking  
7 about common cause failures. Eppler published the  
8 first paper in 1969.

9 MR. HAMZEHEE: Okay. Now back to the  
10 presentation. By the same token, we have to agree  
11 that accomplishment of key safety functions should not  
12 be dependent on a single element of design  
13 construction and operation of nuclear power plants.

14 (Teleconference music.)

15 CHAIRMAN WALLIS: It's going to talk next.

16 VICE CHAIRMAN SHACK: It's in a background  
17 mode.

18 MR. HAMZEHEE: And again, as was mentioned  
19 earlier, single-failure criterion promotes high safety  
20 systems or safety function reliability, but that's not  
21 the only way. That's one of the major elements of  
22 promoting high system reliability. And it's also  
23 important to emphasize that other regulations,  
24 guidelines, and programs with SFC promote highly  
25 reliable system or safety functions. And these are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 programs like QA requirements, tech specs, testing,  
2 inspections, and others.

3 Now based on the experience, we see that  
4 application of single-failure criterion has sometimes  
5 led to redundant system components that may have no  
6 risk significance based on the PRA results. And good  
7 examples are double-ended guillotine break LOCA  
8 coincident with loss of off-site power, and the worse  
9 single-failure, which in this case is diesel  
10 generator. As we've seen in the 50.46, that has a  
11 very low probability.

12 MEMBER APOSTOLAKIS: I guess the English  
13 in the first statement is not quite right, is it? You  
14 mean that the application of the single-failure  
15 criterion--

16 MR. HAMZEHEE: Requires you to have  
17 redundant components that don't have --

18 MEMBER APOSTOLAKIS: That don't have.

19 MR. HAMZEHEE: Yes.

20 MEMBER APOSTOLAKIS: This I think you  
21 could interpret it has led to redundant components  
22 which have low risk significance as a result of the  
23 SFC.

24 MR. HAMZEHEE: That's why I also expand on  
25 it, so that there's no confusion. But we mean is that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 sometimes you require redundancy when they have low  
2 risk significance using PRAs. That's what it means.

3 MEMBER APOSTOLAKIS: Is there in 50.46 the  
4 requirement to assume that you have coincident loss of  
5 power, off-site power? Is that really the result of  
6 the single-failure criterion, or is it even more  
7 stringent than the single-failure criterion?

8 MR. HAMZEHEE: No. The only single-  
9 failure related issue here is the last part of it,  
10 that says you also have to assume one diesel generator  
11 failing. That's part of the design-basis.

12 MEMBER APOSTOLAKIS: Yes, that's what I  
13 would do. But it seems to me that LOOP is the next  
14 recommendation.

15 MR. HAMZEHEE: That's correct.

16 MEMBER ROSEN: And was more unlikely then  
17 than it is now with the deregulation.

18 MR. HAMZEHEE: That's correct.

19 VICE CHAIRMAN SHACK: They were prescient.

20 MEMBER ROSEN: Well, I didn't say it was  
21 very unlikely now. I just said the situation then  
22 with the integrated electric companies meant that they  
23 weren't as severe -- the constraints that we see on  
24 switch yards and electric systems now, which have gone  
25 back the other way making this marginally less remote

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 possibility than it was then, but it's still quite  
2 remote.

3 MR. HAMZEHEE: If you question me too much  
4 about 50.46, I need to turn to NRR folks because I am  
5 not the expert on the proposed rulemaking on 50.46, so  
6 I have to be careful about how much I tell you about  
7 that one.

8 MEMBER ROSEN: But that first line, if you  
9 could do some quick numbers for me, can't you,  
10 Hossein?

11 MR. HAMZEHEE: Yes.

12 MEMBER ROSEN: How low is low? Design-  
13 basis LOCA is what, ten to the minus --

14 MR. HAMZEHEE: One-E minus 5 or 6.

15 MEMBER ROSEN: Let's take 5. And LOOP is  
16 what?

17 MR. HAMZEHEE: One-E minus 2 or 3.

18 MEMBER ROSEN: So that's minus 7 we're at  
19 now.

20 MR. HAMZEHEE: And failure of one diesel  
21 is point one.

22 MEMBER ROSEN: So that's 10 to the minus  
23 8, at least, probably lower.

24 MR. HAMZEHEE: Yes.

25 MEMBER ROSEN: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MEMBER APOSTOLAKIS: Roughly, it's  
2 supposed to be bounding.

3 MR. HAMZEHEE: That's what he was doing,  
4 just some rough estimate. Anyway, let's just focus on  
5 single-failure criterion. And again, the application  
6 of worst single-failure assumption for design-basis  
7 accidents could, in some cases, result in unnecessary  
8 constraint on licensees, and we all know that.

9 CHAIRMAN WALLIS: Well, it doesn't just  
10 affect risk, it affects things like calculating or  
11 Appendix K-type thing. If you change your probability  
12 of successfully calculating your 2200 degrees, you  
13 don't know what effect that has on risk. It's not  
14 comentioned, so you may be doing something which is  
15 not really commensurate with your measuring here,  
16 which is your PRA.

17 MR. HAMZEHEE: Well, again, I think under  
18 proposed rulemaking for 50.46, we went through a lot  
19 of details on this. And what we're saying is some of  
20 those events, if they have very low probability, then  
21 do you need to require the same level of regulatory  
22 oversight and requirements, rather than some minimum  
23 mitigation capabilities; not that you ignore it,  
24 because you need those for uncertainties, for safety  
25 margins, and all those other things that you

1 mentioned.

2 MEMBER POWERS: Steve, could I come back  
3 to your scoping calculation? You came up with ten to  
4 the minus 8, assuming that each of these elements were  
5 independent.

6 MEMBER ROSEN: Right.

7 MEMBER POWERS: But they're not  
8 independent in an earthquake.

9 MEMBER ROSEN: Right. It's possible.  
10 They're intended to be independent by design, because  
11 both the diesels and the piping is supposed to be  
12 seismic-designed.

13 MEMBER POWERS: But if the earthquake  
14 fails the piping, it will assuredly fail everything  
15 else?

16 MEMBER ROSEN: I don't know that. I'm not  
17 expert enough.

18 MEMBER DENNING: It would be an extremely  
19 big earthquake to fail the piping, huge.

20 MEMBER ROSEN: But then you add in --

21 MEMBER DENNING: Yes, but the calculation  
22 was wrong anyway, because we looked at two -- used  
23 loss of off-site power as frequency, and you used LOCA  
24 as a frequency, and what you really have to do is  
25 consider conditional - like you have a LOCA and a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 conditional probability within a short period of time  
2 that independent, you would get an extremely low value  
3 there. The real question is if you have a loss of  
4 coolant accident, is it likely to trigger the loss of  
5 the power. In any event, it's a very low value.

6 MEMBER ROSEN: It would be lower -- if you  
7 did it correctly, the way you suggest, that's even  
8 lower.

9 MEMBER DENNING: It would be very low if  
10 they really are independent.

11 MEMBER ROSEN: That's why I --

12 CHAIRMAN WALLIS: They're teetering on the  
13 edge of instability already, and you suddenly cut out  
14 a reactor, you could set off this --

15 MR. HAMZEHEE: That's right. Sometimes,  
16 as you said, you could have a higher loss of off-site  
17 power frequency if you have a LOCA.

18 MEMBER ROSEN: You can't say that it's  
19 necessarily going to happen, because grids are  
20 designed to lose a single largest --

21 CHAIRMAN WALLIS: No. No. That's a  
22 conditional probability.

23 MR. HAMZEHEE: There could be some  
24 dependencies. We don't know exactly how they're  
25 related.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER ROSEN: It's a subject of current  
2 interest. Right?

3                   MR. HAMZEHEE: Correct. Now again, as we  
4 mentioned, the single-failure criterion has not always  
5 been applied uniformly for the passive components in  
6 the fluid systems, and that's mainly because of the  
7 footnote we reviewed a few minutes ago. And the last  
8 bullet is trying to focus in the areas where the  
9 single-failure criterion by itself, it was not enough  
10 to get some of the systems at the high reliability  
11 enough. But other regulations, programs, and guidance  
12 made it at the acceptable and adequate level. And  
13 examples are like the station blackout rules, and the  
14 ATWS rules, that we realize you need a little more  
15 than just SFCs, and these are based on risk insight,  
16 so it's a two-way street.

17                   Now the next slide is where we tried to  
18 develop this potential risk-informed alternative. We  
19 have to make sure that we're consistent with some of  
20 the existing policy issues, and these are some of the  
21 highlights of the policy issues that we had to comply  
22 with to come up with final alternatives. And that is  
23 a proposed risk-informed and performance-based  
24 alternative to single-failure criterion need to be  
25 consistent with the Commission PRA Regulatory Policy

1 Guidance, which in summary emphasizes that we should  
2 maintain defense-in-depth. We have to maintain  
3 adequate safety margin, as you already mentioned.

4 CHAIRMAN WALLIS: If you say that single-  
5 failure criterion is a defense-in-depth measure, and  
6 you want to maintain it, how are you ever going to  
7 erase it if you have no measure of what's acceptable  
8 defense-in-depth?

9 MEMBER APOSTOLAKIS: That's why 1.174 says  
10 philosophy, maintain the defense-in-depth philosophy.

11 MEMBER POWERS: 1.174 doesn't actually say  
12 that. There is no philosophy in it.

13 CHAIRMAN WALLIS: There is no philosophy  
14 in that?

15 MEMBER APOSTOLAKIS: It says maintain the  
16 defense-in-depth philosophy.

17 MEMBER POWERS: I believe it says one --

18 CHAIRMAN WALLIS: We can easily check  
19 that.

20 MEMBER APOSTOLAKIS: In the safety  
21 margins, it doesn't.

22 CHAIRMAN WALLIS: That's another problem,  
23 safety margins are not usually defined.

24 MR. THADANI: George, it says safety  
25 margin, also.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER APOSTOLAKIS: But not philosophy.

2 MR. THADANI: Not philosophy, but maintain  
3 safety margin.

4 MR. HAMZEHEE: And then we have to be  
5 aware of the security constraints, especially now that  
6 we're coming with some guideline and checklists, and  
7 also consideration of uncertainty, as we all know.  
8 And also, any potential risk-informed performance-  
9 based alternative should be consistent with the  
10 Commission guidance on the phase approach to PRA  
11 quality. And it should also be consistent with the  
12 Commission backfit and reg analysis guidance and  
13 policy. And also, an alternative should be consistent  
14 with other ongoing risk-informed activities, such as  
15 the proposed rulemaking on 10 CFR 50.46 and LOCA/LOOP  
16 exemption request by BWR Owners Group.

17 CHAIRMAN WALLIS: Has anybody figured out  
18 the basic question of how do you risk informed  
19 defense-in-depth, because that's what we're talking  
20 about.

21 MEMBER APOSTOLAKIS: The PRA actually  
22 quantifies defense-in-depth.

23 MEMBER POWERS: That's the rationalist  
24 argument there. Actually, it quantifies the need for  
25 defense-in-depth.

1 MEMBER APOSTOLAKIS: No, but if you look  
2 at what we quantify, we quantify the redundant trains.  
3 That's what we know how to do. We don't put the --

4 MR. HAMZEHEE: And I think also PRA may  
5 help us decide how much defense-in-depth we need.

6 MEMBER APOSTOLAKIS: Well, that's a  
7 controversial part. That's what Dana said.

8 CHAIRMAN WALLIS: Well, maybe what you  
9 have to do is reclassify this single-failure  
10 criterion, not as being defense-in-depth, but being a  
11 surrogate for this PRA, and then replace it by the  
12 PRA. Then you don't get into this logical problem.

13 MEMBER APOSTOLAKIS: Exactly. That's why  
14 I said at the beginning that this was a means for  
15 those guys in the 60s to achieve low probability of  
16 failure, which was very reasonable.

17 CHAIRMAN WALLIS: But in the write-up, the  
18 Staff has defined this as being a defense-in-depth  
19 measure.

20 MEMBER APOSTOLAKIS: Well, everything they  
21 did in the --

22 CHAIRMAN WALLIS: SFC is one element of  
23 the defense-in-depth .

24 MEMBER APOSTOLAKIS: That's right.

25 MR. HAMZEHEE: And then next we quickly

1 want to go over the evaluation process. As part of  
2 this effort, we try to develop a process to identify  
3 and evaluate potential risk-informed and performance-  
4 based alternatives to single-failure criterion. And  
5 if you go back to the next slide quickly, and I do  
6 not intend to spend a lot of time on this flow chart,  
7 but I just want to quickly go over it so that you get  
8 an idea as to how we started to define these potential  
9 alternatives.

10 So we start from the left, go all the way  
11 to the right. We first had to understand clearly what  
12 the intent of existing single-failure criterion is.  
13 And then based on that, we had to review the  
14 regulations, guidelines, implementation documents to  
15 make sure that we know the history and the intent.  
16 And then we made an attempt to define the desirable  
17 attributes that alternatives should have, and I'll go  
18 over those attributes quickly.

19 And then based on these desired  
20 attributes, we looked at the existing SFC and said all  
21 right, how well do we meet these attributes? And the  
22 ones that we don't meet, are the ones that we focus on  
23 to develop alternatives; otherwise, it's going to be  
24 hard to just define alternatives without knowing  
25 exactly what they do and how they serve us.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 And once we did that, then we come up with  
2 a list of possible alternatives. So in other words,  
3 what you see in this report is maybe a number of them,  
4 but at the beginning, we had a lot of ideas, a lot of  
5 alternatives. Many of them did not make it to the  
6 report, and didn't include it, but that's how we  
7 started the process.

8 And then we developed the risk, and then  
9 we looked at those and tried to complete the list, and  
10 also look at implementation. Now once we're ready to  
11 finalize the list of alternatives, we have to do  
12 enough work to understand implementation aspect about  
13 these, because alternatives may sound good, but once  
14 you start implementing, you realize that some of them  
15 may not be implementable. And there's some slides on  
16 these that I'll discuss later.

17 MEMBER APOSTOLAKIS: This is for current  
18 reactors. Right?

19 MR. HAMZEHEE: Yes. This is mainly for  
20 current operating reactors. That's correct. And then  
21 we realize sometimes there are some constraints that  
22 we have to apply to this method, so we look at a  
23 constraint and look at the alternatives, and there's  
24 some of them should not be there. Then we eliminate  
25 those based on those constraints. And then at the

1 end, we come up with a final set of risk-informed  
2 performance-based alternatives to SFC.

3 CHAIRMAN WALLIS: Now these are specific  
4 to each SFC.

5 MR. HAMZEHEE: Correct.

6 CHAIRMAN WALLIS: And also, to each plant?

7 MR. HAMZEHEE: These are right now for all  
8 existing operating power plants that have to comply  
9 with the single-failure criterion requirements.

10 CHAIRMAN WALLIS: If you're going to use  
11 risk-informed, you've got to look at the PRA which is  
12 plant-specific. It may be that these SFCs play a  
13 bigger role in some plants than in others.

14 MR. HAMZEHEE: Correct. So we have not  
15 done any plant-specific work.

16 CHAIRMAN WALLIS: That makes it very  
17 difficult to implement.

18 MEMBER APOSTOLAKIS: But isn't your major  
19 constraint the fact that the plants have been designed  
20 under the SFC?

21 MR. HAMZEHEE: Yes, that's correct.  
22 That's exactly right.

23 MEMBER APOSTOLAKIS: So some of the things  
24 you might say here may not necessarily apply to future  
25 reactors. Right?

1 MR. HAMZEHEE: That's correct. That's  
2 right. All right. Let's go back to the previous one,  
3 John. So that was the process. And again, as you  
4 notice in that flow chart, there's one major step to  
5 define the design attributes. And the design  
6 attributes that we defined for our work are the  
7 following; it should provide functional reliability.  
8 And when we say "reliability" here, we mean anything  
9 that would make a system available. Now things like  
10 common cause failures is one element that would impact  
11 the system reliability. Human error is another  
12 element that could impact the system reliability.  
13 Test and maintenance unavailability are some other  
14 elements that could contribute to the reliability of  
15 that system or component, so that's what we mean by  
16 reliability. It has all those elements.

17 And then maintaining defense-in-depth,  
18 again consistent with Reg Guide 1.174, any attribute  
19 had to have some of the guidelines in 1.174 to make  
20 sure it's a risk-informed approach and not a risk-  
21 based.

22 CHAIRMAN WALLIS: So single-failure  
23 criterion assumes that all the other systems are  
24 available?

25 MR. HAMZEHEE: As I said, single-failure

1 is looking at one system, and says if you have one  
2 failure in that system, can that system still perform  
3 its intended safety function.

4 CHAIRMAN WALLIS: But there's also the  
5 question of availability due to maintenance, which  
6 could be the cause of failure of that, or it could be  
7 something else.

8 MEMBER BONACA: You assume it was single-  
9 failure at the time.

10 MR. HAMZEHEE: Unless it's a support  
11 system, then if you take, for instance, a diesel  
12 generator, you're right. Then in turn, the system  
13 that is supported by diesel generator may not be  
14 available, but this is that case of the definition  
15 that says if there's an occurrence, multiple failure  
16 as a result of one occurrence that's called single-  
17 failure.

18 MEMBER ROSEN: There's another case too,  
19 Graham, and that's if the process fluid to a system is  
20 to break; for instance, if the steam supply to the  
21 high pressure cooling injection pump is the break,  
22 then it takes out the pump, and then you consider  
23 another single-failure besides that.

24 CHAIRMAN WALLIS: You add another one on.

25 MEMBER ROSEN: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. THADANI: May I comment on that,  
2 Graham. All other equipment is assumed to be  
3 functional if it meets certain classifications in  
4 terms of safety systems. But there's a presumption  
5 that non-safety systems are not available.

6 MEMBER ROSEN: And systems damaged by, or  
7 made inoperative, because of the consequence of  
8 whatever the LOCA is --

9 MR. HAMZEHEE: Exactly.

10 MR. THADANI: Yes.

11 MEMBER ROSEN: -- are not available.

12 MR. HAMZEHEE: That's correct. That's  
13 where you look at one system at the time, assuming  
14 everything else is available or functional. And then  
15 we have the alternatives should use performance-based  
16 regulatory approach because, again, this is risk-  
17 informed performance-based alternative. It has to be  
18 amenable to effective implementation. And we talked  
19 a little bit about this, and what we mean here is that  
20 it has to be official use of NRC and licensee  
21 resources, and it has to be amenable to licensing and  
22 regulatory oversight. And all these things are  
23 important because if they're not, then it's not going  
24 to work. So it's a very important part of the whole  
25 process, and it should be coherent with other risk-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 informed regulatory initiatives.

2 And last but not least, it has to maintain  
3 design requirements that contribute significantly to  
4 as-built or built-in plant capabilities that are  
5 necessary to resist security threats. So this is a  
6 security that now we have to put in the equation  
7 whenever we come up with any other alternatives.

8 These were the design attributes that we  
9 developed and tried to compare alternatives against  
10 these attributes.

11 CHAIRMAN WALLIS: Now if we had a risk-  
12 based regulatory system, all of this stuff would be in  
13 the PRA. You wouldn't need any of these single-  
14 failure criteria?

15 MR. HAMZEHEE: I'm sorry, I did not --

16 CHAIRMAN WALLIS: If we had a risk-based  
17 system and all of these failures were properly modeled  
18 in the PRA, presumably we wouldn't need any single-  
19 failure criteria?

20 MR. HAMZEHEE: That's true. If they had  
21 low risk significance, you're right.

22 MEMBER APOSTOLAKIS: Any risk  
23 significance.

24 CHAIRMAN WALLIS: It doesn't matter  
25 whether they're risk significant at all. It's all

1 modeled in the --

2 MEMBER APOSTOLAKIS: Because you would  
3 base everything on reliability numbers, and  
4 probabilities.

5 MR. HAMZEHEE: But what I mean is --

6 MEMBER ROSEN: Well, you still would --

7 CHAIRMAN WALLIS: Yes, if you're going to  
8 bring in some other criterion, but everything is only  
9 risk-based.

10 MEMBER APOSTOLAKIS: He said risk-based,  
11 so we don't need defense-in-depth. Risk-informed,  
12 yes.

13 MR. HAMZEHEE: But what I mean is even on  
14 risk-based, if you were risk-based, but you realize  
15 that there is a system that is not designed against  
16 single-failure, and it is highly unreliability, and  
17 contributes significantly to plant rest, then you have  
18 to take some measures to apply single-failure. That's  
19 what I mean.

20 MEMBER APOSTOLAKIS: If the probability is  
21 low enough --

22 MR. HAMZEHEE: If it's low enough, yes.

23 MEMBER APOSTOLAKIS: Yes. And we have an  
24 example of existing reactors.

25 MR. HAMZEHEE: Yes. But what I mean --

1 MEMBER APOSTOLAKIS: There is a single-  
2 failure that is catastrophic.

3 MR. HAMZEHEE: Yes.

4 MEMBER APOSTOLAKIS: And we don't have any  
5 redundancies, the vessel.

6 MEMBER SIEBER: The problem is that if a  
7 mitigating system is not safety-related, you don't  
8 have the controls in place to assure that it's  
9 available and reliable. And so when you apply a PRA  
10 to the entire plant and say I don't need to deal with  
11 single-failure criterion in this area and that area,  
12 because I can rely on non-safety-related systems, that  
13 doesn't buy you anything in regulatory space, as I see  
14 it, because there's no controls that will limit and  
15 control the availability and failure frequency,  
16 because of the way you maintain and operate the plant.

17 MEMBER APOSTOLAKIS: Presumably, the risk-  
18 based environment, all that staff has taken into  
19 account in the evaluation of probabilities.

20 MEMBER POWERS: It's all in the past.

21 MEMBER APOSTOLAKIS: We are mixing now the  
22 safety-related part with the PRA.

23 MEMBER POWERS: Yes, well, it's all in the  
24 past what's in the PRA.

25 MEMBER ROSEN: George is saying if you



1 believe the PRA.

2 MEMBER APOSTOLAKIS: Well, he said risk-  
3 based. Presumably, you believe it if it's risk-based.

4 MEMBER SIEBER: Yes.

5 MEMBER APOSTOLAKIS: And all that stuff is  
6 there.

7 MEMBER SIEBER: That models the plant up  
8 to today, not tomorrow.

9 MEMBER APOSTOLAKIS: If it's not risk-  
10 based, then you have to worry about other things, as  
11 well. Yes. I think we're making a much bigger deal  
12 about this than it deserves. We really are, as a --

13 MEMBER SIEBER: Okay. Then we recommend  
14 that we keep the single-failure criteria.

15 CHAIRMAN WALLIS: Well, we still have to  
16 make the decision, George.

17 MEMBER APOSTOLAKIS: No, but I mean  
18 seriously, folks; I mean, it was a way of imposing  
19 redundancy.

20 CHAIRMAN WALLIS: But now they're  
21 proposing to change it, so we have to figure out  
22 what's reasonable.

23 MEMBER APOSTOLAKIS: I don't even know  
24 what the broader change means.

25 MEMBER BONACA: It wasn't only the -- I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 mean, in addition to provide you with redundancy, it  
2 provided you with a much better understanding of your  
3 whole system, because you took out one component of  
4 the system at a time, and did all this analysis.

5 MEMBER APOSTOLAKIS: Because you didn't  
6 have event-based.

7 MEMBER BONACA: Exactly right. It was a  
8 way to get the same understanding. The presumption  
9 was you didn't have to address every gate either,  
10 because many mitigation systems were highly reliable.

11 MEMBER SIEBER: It made it easy for the  
12 operation, because they knew what division they were  
13 working with.

14 MEMBER ROSEN: Most of the time.

15 MEMBER SIEBER: Most of the time.

16 MR. HAMZEHEE: Now we have identified as  
17 part of this effort three alternatives, plus a  
18 baseline alternative. The baseline alternative is  
19 where we are today; that is, this alternative  
20 continues to make risk-informed changes to regulatory  
21 requirements that involve specific issues. So today  
22 we are baseline alternative, and examples are proposed  
23 rulemaking on 10 CFR 50.46, even though the main  
24 concern was not single-failure criterion, but as part  
25 of that, we're addressing that specific issue, or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 LOCA/LOOP requirements.

2 Now this alternative, the baseline  
3 alternative, is a good way of making measurable  
4 progress over time on a case-by-case basis; rather  
5 than trying to address all the related issues at the  
6 same time, which could take time to make progress.  
7 But again, this is not going to be a broader change to  
8 single-failure criterion, because you're really not  
9 going to look at that in a global sense. And again,  
10 this baseline alternative may have some limited  
11 improvement and coherence with other risk-informed  
12 activities, because again, you're looking at specific  
13 issues.

14 And as part of this alternative, the only  
15 thing that we are not currently doing in this baseline  
16 alternative is considering, is to resolve or clarify  
17 that footnote on the passive components. So if one  
18 was going to adopt this alternative today, it's not  
19 just what we're doing today, but also go back and try  
20 to figure out how to clarify that footnote in Appendix  
21 A.

22 CHAIRMAN WALLIS: Well, the other thing is  
23 the extreme alternative, is to simply abolish it  
24 across the board, and figure out how to do it better,  
25 how to fulfill the objective better. And he hasn't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 gotten to the final abolish though, has he?

2 MR. HAMZEHEE: Yes, now we have  
3 Alternative One. We have three alternatives, as I  
4 mentioned, and I'll quickly go over these three  
5 alternatives. The first one is the alternative that  
6 would risk-inform failure assumptions made in design-  
7 basis accident analysis in Chapter 15 of Final Safety  
8 Analysis Report. That's really the main objective of  
9 this alternative, or the main feature.

10 MEMBER APOSTOLAKIS: Can you remind me  
11 what the DBA analysis is? Isn't that the thermal-  
12 hydraulic analysis?

13 MR. HAMZEHEE: Correct. These are the  
14 thermal -- that's correct.

15 MEMBER APOSTOLAKIS: Conservative cause --

16 MR. HAMZEHEE: Correct. That you ensure  
17 you have adequate safety margins, such as peak  
18 cladding temperature of 2200 degrees Fahrenheit.

19 MEMBER APOSTOLAKIS: So that's a DBA  
20 analysis.

21 MR. HAMZEHEE: Correct. Maximum oxidation  
22 level of less than 17 percent, or hydrogen production  
23 less than 1 percent, and all those. So what we're  
24 trying to do under this alternative is to risk-inform  
25 it. And again, as you see down the line, the single-

1 failures resulting in sequences with sufficiently low  
2 frequency would no longer be required in design-basis  
3 accident analysis.

4 MEMBER APOSTOLAKIS: What does that mean?

5 MR. HAMZEHEE: That means if you have --  
6 in the design-basis accident analysis, you have to  
7 first take an initiating event, let's say LOCA. And  
8 along with that you have to make an assumption of the  
9 worst single-failure of a safety system. And when you  
10 do that, then you calculate your safety margin.

11 What we say here is if the frequency of  
12 that initiating event and failure of that component is  
13 too low, you can remove that requirement from design-  
14 basis accident analysis.

15 MEMBER APOSTOLAKIS: And what is too low?

16 MR. HAMZEHEE: Well, the next page will  
17 explain what we mean by "low", but just to be  
18 responsive to your question, we have -- if this  
19 alternative was to be adopted today, then we would  
20 have to define quantitative criteria as to what "low"  
21 means. If I could just use my own quick risk insight,  
22 I would say less than one to minus six, for instance.

23 CHAIRMAN WALLIS: It's just the frequency  
24 of these events? It's not --

25 MR. HAMZEHEE: And the failure probability

1 of that component.

2 CHAIRMAN WALLIS: It's not the resulting  
3 core damage frequency.

4 MR. HAMZEHEE: Yes. Correct. No, no, no;  
5 no core damage.

6 CHAIRMAN WALLIS: It's the frequency  
7 alone.

8 MR. HAMZEHEE: Correct.

9 CHAIRMAN WALLIS: And then if there were  
10 a core damage frequency of one, the worst it could be  
11 would be two to the minus six.

12 MR. HAMZEHEE: Correct. In other words,  
13 this could result in a CDF change of maybe one to the  
14 minus eight.

15 CHAIRMAN WALLIS: Right.

16 MR. HAMZEHEE: Or it could not be any  
17 higher than the frequency of the sequence, I mean at  
18 worst.

19 MEMBER POWERS: Additional probability is  
20 one.

21 MR. HAMZEHEE: Correct.

22 MEMBER APOSTOLAKIS: Wait a minute. You  
23 mean only the fail -- you're not looking at the whole  
24 sequence, so the sequence may not even lead to core  
25 damage.

1 MR. HAMZEHEE: Definitely. This is just  
2 a sequence that they use to calculate the safety  
3 margin in thermal-hydraulic evaluation. It's a  
4 design-basis accident analysis. Now that, then you  
5 have to run it through your PRA model to really see  
6 what the impact is on CDF and LERF, for instance.

7 MEMBER APOSTOLAKIS: But if it doesn't  
8 lead to core damage, why do I care?

9 MR. HAMZEHEE: Well, because right now the  
10 licensees are required to every time they refuel, or  
11 put in new, and go through the new cycle to do safety  
12 analysis to show that they have adequate safety  
13 margin, when they refuel or change the fuel, and when  
14 they do that, the limited conditions are for all those  
15 pre-defined initiating events in Chapter 15, and the  
16 worst single-failure assumption. This is how they do  
17 their calculations.

18 Now we're saying when you do that, if you  
19 don't think that single-failure is necessary based on  
20 some quantitative measures, then you can remove those  
21 from your analyses. What does that mean? That means  
22 you may potentially get more margin, and you can use  
23 it for other purposes. Now we'll get there later.

24 MR. THADANI: Hossein, one clarification.  
25 Single-failure criterion does not apply to all

1 transients in Chapter 15. It's a design-based  
2 accident where you apply single-failure criterion.

3 MR. HAMZEHEE: Correct. That's right.  
4 That's why we said all those accidents in Chapter 15.  
5 Now there may be some initiating events in PRAs that  
6 are outside design --

7 MR. THADANI: No. Let me repeat, single-  
8 failure does not apply to all the events in Chapter  
9 15. That's large break LOCA, steam line break, you  
10 apply single-failure.

11 MR. HAMZEHEE: Main feedwater --

12 MR. THADANI: Feedwater line, all the  
13 breaks you apply.

14 MR. HAMZEHEE: Yes, you're right.

15 MR. THADANI: But you don't apply to any  
16 transients, abnormal operation occurrences, which are  
17 in Chapter 15.

18 MR. HAMZEHEE: All right.

19 MEMBER APOSTOLAKIS: But really, I don't  
20 understand this. The third bullet says "multiple  
21 failures and sequences" --

22 MR. HAMZEHEE: I haven't gotten there yet.  
23 You're ahead of me. Let me just go --

24 MEMBER APOSTOLAKIS: Yes, but I mean it's  
25 in the context of whether you have a consequence or



1 not.

2 MR. HAMZEHEE: Yes.

3 MEMBER APOSTOLAKIS: You're saying no,  
4 it's independent of whether I have core damage or  
5 anything. I just look at the product of the initiating  
6 event frequency and the failure, and if that is low  
7 enough, I make a decision.

8 MR. HAMZEHEE: Well now, wait. What we're  
9 saying is based on that quantitative requirement, you  
10 can potentially remove that requirement from your  
11 design-basis accident analysis. However, there's a  
12 next step. The next step says if now you want to make  
13 any changes, you have to meet the guidelines in Reg  
14 Guide 1.174. That means then you have some CDF LERF  
15 criteria that says well, the change in CDF as a result  
16 of removing all these sequences, if you appropriately  
17 go back to your PRAs and change the model so that you  
18 can see what the impact is, should not be more than  
19 some frequency.

20 CHAIRMAN WALLIS: Is this going to have  
21 any effect on -- is there any evidence that doing this  
22 will change the probability that they'll meet the  
23 criteria, let's say, for 50.46? If the worst break  
24 was a small break LOCA where the operator screws up or  
25 something, this isn't going to make any difference,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 is it?

2 MR. HAMZEHEE: Well, as a matter of fact,  
3 this proposed rulemaking for large break LOCA is a  
4 special case of this alternative.

5 CHAIRMAN WALLIS: But maybe that's not the  
6 worst I've got, anyway.

7 MR. HAMZEHEE: That's correct.

8 CHAIRMAN WALLIS: So I don't know. We  
9 don't know what the consequence would be of doing  
10 this.

11 MR. HAMZEHEE: That's right. But if you  
12 really want to implement it all the way through, then  
13 you also have to acknowledge or understand clearly  
14 what the impact would be on potential plant risk, such  
15 as on CDF and LERF. And then you worry about the  
16 consequence.

17 CHAIRMAN WALLIS: That's when the plant  
18 actually wants to make some changes.

19 MR. HAMZEHEE: Correct. That, and also,  
20 if you look at the last sub-bullet under this, you see  
21 that we say that you need to use PRAs to demonstrate  
22 that the cumulative frequency of all sequences  
23 excluded from DBA are less than some threshold that  
24 has to be defined. And also now going back to the  
25 multiple, because George brought it up, but I want to

1 emphasize that this is not just removing things.

2 Now in the design-basis accident analysis  
3 you may only make a single-failure assumption. Now  
4 there may be from PRA results some multiple failures  
5 that could have the same frequency or higher than the  
6 single-failure and that initiating event. Now we're  
7 saying if they exceed some threshold, they should be  
8 added to the design-basis accident analysis. So you  
9 may take some, remove some, you may add some.

10 MEMBER APOSTOLAKIS: I'll have to  
11 understand that a little better, Hossein. I'll take  
12 your word for it right now.

13 MR. HAMZEHEE: For right now, and then we  
14 can look at some examples. And again, some of the  
15 details we have not completed yet, so if all of a  
16 sudden we decide to use this alternative and make a  
17 rule, then we need to go back and to really look how  
18 you can implement it, how the mechanics work.

19 MEMBER APOSTOLAKIS: This is the same  
20 Alternative One as in the Executive Summary. Right?

21 MR. HAMZEHEE: Correct.

22 MEMBER APOSTOLAKIS: Risk-inform  
23 application, the rest have see the DBA analysis.

24 MR. HAMZEHEE: That's correct.

25 MEMBER APOSTOLAKIS: So you're saying

1 here, "permit removal of sufficiently unlikely non-  
2 risk-significant single-failure sequences from the  
3 design-basis." How would you know they're non-risk-  
4 significant?

5 MR. HAMZEHEE: Again, what we mean here is  
6 if you have some -- for instance, currently let's talk  
7 about large break LOCA. This is an example that we're  
8 actually dealing with right now. If the frequency of  
9 large break LOCA is less than one to the minus six,  
10 and if that meets our quantitative threshold, then we  
11 say we move that from design-basis accident analysis,  
12 and call that transition break size, for instance.  
13 This is what it means.

14 CHAIRMAN WALLIS: Ah, but the problem is  
15 transition break size, that brings in new  
16 requirements. If you --

17 MR. HAMZEHEE: Well --

18 CHAIRMAN WALLIS: -- simply said remove  
19 it, forget about it, that's easy to understand.

20 MR. HAMZEHEE: Again, what we're saying is  
21 it has to meet some guidelines and it has to be  
22 defense-in-depth, so maybe we have to provide some  
23 risk-informed requirements for the things that you  
24 will need.

25 CHAIRMAN WALLIS: Defense-in-depth might

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 limit what you can do.

2 MR. HAMZEHEE: Correct.

3 MEMBER APOSTOLAKIS: Anyway, this  
4 particular alternative doesn't really deal with risk.  
5 It deals with the frequencies of combinations of  
6 events.

7 MR. HAMZEHEE: It does, but then to  
8 finalize it, and to implement it, you have to meet the  
9 guidelines of Reg Guide 1.174.

10 MEMBER APOSTOLAKIS: If you make changes.

11 MR. HAMZEHEE: If you remove any of them  
12 from design-basis, if you make any changes.

13 MEMBER APOSTOLAKIS: You're right.

14 VICE CHAIRMAN SHACK: You're removing it  
15 because you know that it leads to low risk.

16 MR. HAMZEHEE: That's correct.

17 VICE CHAIRMAN SHACK: You've looked ahead  
18 at the PRA.

19 MR. HAMZEHEE: Just because of the common  
20 sense, if just initiating event frequency and a  
21 failure is less than some amount, you know that the  
22 impact on CDF cannot be any greater than that. So  
23 right there, you're having some risk insights.

24 CHAIRMAN WALLIS: It's really frequency-  
25 informed, rather than risk-informed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN SHACK: Well, it's risk-  
2 informed because of the frequency. Nobody says that  
3 a large break LOCA is a no-nevermind.

4 CHAIRMAN WALLIS: Nobody says?

5 MEMBER SIEBER: Not yet.

6 VICE CHAIRMAN SHACK: It says low risk-  
7 significant because it doesn't happen very often. If  
8 it does, it's a serious event.

9 MEMBER SIEBER: If you don't have all your  
10 safety systems, it becomes even more serious.

11 MR. HAMZEHEE: And then again, as it was  
12 mentioned earlier, why do we do this? What is it for  
13 the licensees, for instance? It could provide some  
14 higher predicted safety margin, so they can use it for  
15 other purposes.

16 MEMBER APOSTOLAKIS: So could you call  
17 this then -- this alternative would frequency-inform  
18 the failures, not risk-inform.

19 MR. HAMZEHEE: Well, it is risk-informed  
20 because our ultimate goal is to look at the impact of  
21 any of those changes on plant risk.

22 VICE CHAIRMAN SHACK: He picks his  
23 threshold frequencies by looking at the risk  
24 associated with it.

25 MR. HAMZEHEE: Because that's one element

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of risk, so if that element by itself is below some  
2 threshold, you know that it cannot be any greater than  
3 that threshold.

4 MR. THADANI: Hossein, can I help you?

5 MR. HAMZEHEE: Yes, please.

6 MEMBER ROSEN: George, suppose you're  
7 talking about a low pressure safety injection system  
8 where single-failure applies for certain size break.  
9 That low pressure safety injection system is also used  
10 in its RHR, Residual Heat Removal, form to take care  
11 of many other potential events. Now if you're going  
12 to change the reliability of that system, low pressure  
13 safety injection system, you need to make sure you go  
14 through a risk analysis, look at all the cut sets and  
15 so on, where that system may be needed, and you assess  
16 the impact on all those accident sequences to see what  
17 happens if you make this change. And that's really  
18 what Hossein is trying to say, I believe.

19 MR. HAMZEHEE: That's correct.

20 CHAIRMAN WALLIS: I thought you were  
21 saying it's so unlikely that you didn't really need to  
22 do that. It was so unlikely.

23 MEMBER APOSTOLAKIS: Well, I guess the  
24 fourth sub-bullet there is the key then.

25 MR. HAMZEHEE: That's correct. So it is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 risk-informed.

2 CHAIRMAN WALLIS: So that's the cumulative  
3 frequency.

4 MR. HAMZEHEE: Next slide, please.

5 MR. THADANI: Hossein, this doesn't  
6 address I thought one other question. You said it's  
7 coherent, but if you take LOCA/LOOP separately, apply  
8 ten to the minus six, if you take transition break  
9 size and apply ten to the minus six, you take single-  
10 failure criterion separately and apply ten to the  
11 minus six criterion, is that being integrated to make  
12 sure that -- you said it's coherent, but --

13 MR. HAMZEHEE: Yes, but I think ultimately  
14 if we decide to replace SFC with any of these  
15 alternatives, we have to make sure we understand what  
16 the cumulative impact on risk is of all these changes,  
17 if that's what you're talking about. In other words,  
18 if this only change is one to the minus six, we have  
19 to look at the cumulative impact of other changes, as  
20 well. Is that what you're asking, Ashok?

21 MR. THADANI: I'm saying you come up with  
22 LOCA/LOOP later on.

23 MR. HAMZEHEE: Yes.

24 MR. THADANI: But you would have  
25 integrated that in here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. HAMZEHEE: We should, yes. I think  
2 that's the correct way.

3 CHAIRMAN WALLIS: This will provide an  
4 incentive for plants to have better PRAs, because in  
5 order to justify this, they have to --

6 MR. HAMZEHEE: Absolutely, yes.

7 CHAIRMAN WALLIS: There might then be a  
8 reward for having a really good PRA? That would be a  
9 great thing.

10 MR. HAMZEHEE: It's a reward, and also a  
11 requirement, not the reward; because remember, we  
12 mentioned we have to be --

13 CHAIRMAN WALLIS: There might be some  
14 plants who would apply for this, and they wouldn't get  
15 it because their PRA wasn't good enough. Another  
16 plant might get the --

17 MR. HAMZEHEE: That's why up front we said  
18 it has to be consistent with the PRA phase approach  
19 quality, because under that program we define how good  
20 the PRAs have to be, what elements of it have to be  
21 reviewed, and the whole thing. So if it doesn't pass  
22 the test, they can't even enter.

23 MEMBER SIEBER: That could work the other  
24 way. You could have a poor PRA, and be able to claim  
25 things under these concepts. And if you improved your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 PRA, all of a sudden you wouldn't be allowed to, so  
2 you can't make the assumption that --

3 MEMBER ROSEN: I don't think that would  
4 work because your poor PRA would not have passed peer  
5 review.

6 CHAIRMAN WALLIS: It couldn't get through  
7 the door in the first --

8 MEMBER SIEBER: Well, that's one of the  
9 checks and balances.

10 VICE CHAIRMAN SHACK: I don't think this  
11 would be -- this sort of thing would not be an  
12 enabling rule like 50.46, where you pass the rule and  
13 nothing changes when you come in. If you came in and  
14 you --

15 MR. HAMZEHEE: You changed this.

16 VICE CHAIRMAN SHACK: -- change this, you  
17 changed this.

18 MR. HAMZEHEE: That's right.

19 MEMBER SIEBER: But you're doing the same  
20 thing in a --

21 VICE CHAIRMAN SHACK: You have to be sure  
22 up front of what you're doing here.

23 MR. HAMZEHEE: That's correct.

24 VICE CHAIRMAN SHACK: You get to look at  
25 it again each time they propose a change.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: When you risk-inform the  
2 tech specs, for example, change tech specs to give you  
3 more allowed outage time on a diesel generator or high  
4 pressure pump, you're doing the same thing to a lesser  
5 extent than you are by looking at these concepts. And  
6 it seems to me that there should be coherence between  
7 that effort and whatever happens to the single-failure  
8 criterion so that the regulations continue to make  
9 sense.

10 MR. HAMZEHEE: Correct. That's right.

11 MEMBER SIEBER: So the two of them are  
12 married.

13 MEMBER APOSTOLAKIS: I propose that we  
14 hear about the other two alternatives before we have  
15 a --

16 MR. CARUSO: I just have a question,  
17 please. Where in this process do you quantify the  
18 uncertainty, and how do you consider the answer?

19 MEMBER APOSTOLAKIS: In the fourth sub-  
20 bullet?

21 MR. CARUSO: Anywhere in this alternative.

22 MEMBER APOSTOLAKIS: Yes, in the sub-  
23 bullet.

24 MR. CARUSO: What does it mean? How do  
25 you -- what --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER APOSTOLAKIS: When he says  
2 "sufficiently low frequency", presumably he wouldn't  
3 be challenged, whether he says it's ten to the minus  
4 eight.

5 MR. CARUSO: Plus or minus how many orders  
6 of magnitude?

7 MEMBER APOSTOLAKIS: To be determined.

8 MR. CARUSO: And someone has to quantify  
9 that.

10 MEMBER APOSTOLAKIS: And it will have to  
11 be addressed there. Right, Hossein?

12 MR. HAMZEHEE: Yes. Yes.

13 MEMBER APOSTOLAKIS: He is not proposing  
14 numbers right now.

15 MR. HAMZEHEE: We're just trying to  
16 familiarize you with the concept, and to some degree  
17 the mechanics, but once you start applying them, then  
18 you have to understand what kinds of uncertainties are  
19 involved, how to quantify it, if the uncertainty is  
20 high, how to supplement it by defense-in-depth and  
21 other elements of defense-in-depth philosophy.

22 MEMBER ROSEN: So you're going to specify  
23 thresholds, including uncertainty.

24 MEMBER BONACA: A question I had, Hossein,  
25 was, this could be done under Reg Guide 1.174.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HAMZEHEE: Correct.

2 MEMBER BONACA: However, it cannot be done  
3 right now because you have to stay within the  
4 licensing basis, and so this would be an enabling  
5 step, I mean, allowing the licensees to submit  
6 individual requests for eliminating, for example, one  
7 system from their design-basis on this basis.

8 MR. HAMZEHEE: Correct.

9 VICE CHAIRMAN SHACK: You would do this as  
10 a 1.170 defense, this would be a plant-specific --

11 MR. HAMZEHEE: Well, once we agree, and  
12 let's say tomorrow everybody agrees that Alternative  
13 One should be used in lieu of SFC, then it becomes a  
14 generic-type change, and it's not plant-specific any  
15 more. Then all the plants can come -- it depends. If  
16 it's voluntary, then they can stay where they are, or  
17 they can apply for this risk-informed alternative.

18 MEMBER BONACA: You would have to perform  
19 an analysis, and there would have to be an evaluation  
20 on their 1.174 guidelines.

21 MR. HAMZEHEE: Correct.

22 MEMBER BONACA: So right now you cannot do  
23 that, because the requirement 1.174 is that you are  
24 still operating within the licensing-basis.

25 MEMBER APOSTOLAKIS: But my understanding

1 is that this is not going to remove any hardware.

2 MR. HAMZEHEE: Not this alternative, no.  
3 That's correct.

4 MEMBER APOSTOLAKIS: Okay. This is just  
5 in and out of the --

6 MR. HAMZEHEE: This just tells you -  
7 that's right, for the analysis, what to include and  
8 what not to include. It does not change anything.

9 MEMBER APOSTOLAKIS: And you are not  
10 removing anything.

11 MR. HAMZEHEE: Not under this alternative.  
12 That's correct.

13 MEMBER APOSTOLAKIS: Okay. Is there any  
14 chance Alternative Two will come in the next hour or  
15 so?

16 MR. HAMZEHEE: Ask your colleagues. All  
17 right. Should we go to Alternative Two?

18 CHAIRMAN WALLIS: Yes.

19 MR. HAMZEHEE: All right. Alternative Two  
20 --

21 CHAIRMAN WALLIS: The probability is now  
22 one, George.

23 MEMBER SIEBER: Not yet.

24 MR. HAMZEHEE: Now Alternative Two would  
25 risk-inform the application of SFC to safety-related

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 systems based on their risk-significance, or safety-  
2 significance. This alternative tries to take  
3 advantage of current safety categorization process  
4 that was defined in 10 CFR 50.69, "Risk-Informed  
5 Categorization and Treatment of Structures, Systems,  
6 and Components."

7 This one usually under 50.69, the process  
8 is done at the component level. Here we tried to jack  
9 it up at the system level, so you know what the risk  
10 categorization of the safety-related systems are.

11 Now briefly - I'm not going to go over the  
12 whole thing because we don't have time, and a lot of  
13 you may already understand or be familiar with 50.69 -  
14 but under 50.69, there are four major RISC categories  
15 that are defined in the four blocks. RISC Category 1  
16 and 2 are for safety-significant systems, 1 is safety-  
17 related system, 2 is non-safety-related systems. RISC  
18 Category 3 and 4 are for low safety-significant  
19 systems. Again, 1 is safety-related, 1 is non-safety  
20 related.

21 For instance, if you look at 1, the 1 is  
22 the most important because it's safety-related, risk-  
23 significant, or high safety-significant. RISC  
24 Category 4 is the least important because it's non-  
25 safety-related and low safety-significant.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Now where this alternative falls is how to  
2 treat those systems that are in RISC Category 3, and  
3 it's similar to 50.69. Now under this alternative, we  
4 define three sub-alternatives; again, some of them may  
5 or may not be risk-informed, but these are variations  
6 that we could define. And then once we do pros and  
7 cons, we definitely see which one makes more sense, or  
8 is more risk-informed, which one is not.

9 CHAIRMAN WALLIS: The problem is you say  
10 it's based on the level of defense-in-depth desire.  
11 I don't think that's a very good formula.

12 MEMBER APOSTOLAKIS: It says that? Where  
13 is it?

14 CHAIRMAN WALLIS: That alternative, that  
15 bottom bullet.

16 MR. HAMZEHEE: Well, that means --

17 CHAIRMAN WALLIS: Based on the level of  
18 defense, so you have to evaluate the level of defense  
19 desired before you decide whether to remove it.

20 MR. HAMZEHEE: Yes. What we meant here  
21 actually is, right now we define three sub-  
22 alternatives. But these three sub-alternatives, some  
23 of them may not make it because based on some other  
24 guidelines, they don't have enough defense-in-depth,  
25 so that's what we mean by desired defense-in-depth.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 CHAIRMAN WALLIS: Once you've made the  
2 decision, you no longer have to worry about the --

3 MR. HAMZEHEE: That's right. That's  
4 correct.

5 CHAIRMAN WALLIS: Once you've made the  
6 across the board decision.

7 MR. HAMZEHEE: Correct.

8 CHAIRMAN WALLIS: You're not going to look  
9 at each one of them and say --

10 MR. HAMZEHEE: No, no, no, no. In other  
11 words, let me just quickly go over three sub-  
12 alternatives. Then if you take one, because of the  
13 desired defense-in-depth, then you stick to that, and  
14 that's how you apply it. 2-A, it says that if you  
15 have a safety system that has two trays or more, one  
16 tray you maintain as-is safety-related with the same  
17 requirements. The other one you can remove it from  
18 service. Now right there you may say what about  
19 defense-in-depth, and you're right.

20 MEMBER ROSEN: Remove it from service?

21 MR. HAMZEHEE: That is not physically  
22 remove it, but you can like tag it out and say now  
23 this is no longer required, but it's physically still  
24 within the plant.

25 CHAIRMAN WALLIS: It still works?

1 MEMBER SIEBER: No.

2 MR. HAMZEHEE: It may not, yes. Again,  
3 I'm not saying -- that's why I warned you at the  
4 beginning, we're not advocating it. These are just  
5 combinations of alternatives. Let me go through the  
6 other two alternatives. You see that there's some  
7 that are better or more risk-informed.

8 MEMBER APOSTOLAKIS: If this system is not  
9 --

10 MR. HAMZEHEE: If it's in RISC Category 3.  
11 All these are those systems that are RISC Category 3.

12 MEMBER APOSTOLAKIS: Low safety-  
13 significant.

14 MR. HAMZEHEE: Yes. They are safety-  
15 related, low safety-significant.

16 MEMBER BONACA: But the point is that you  
17 may have combined systems that may give you something  
18 more significant.

19 MR. HAMZEHEE: Correct.

20 MEMBER BONACA: Okay. So how do you make  
21 a logical assumption that says since I already  
22 classified this low, I can just assume.

23 MR. HAMZEHEE: All right. Let me then go  
24 back, because --

25 MEMBER BONACA: I don't understand.

1 MR. HAMZEHEE: The same process was  
2 brought up and dealt with under 50.69. Again, when  
3 you do the RISC categorization, I don't want to get  
4 into the details, but the performance measures you  
5 choose somehow take care of your concern. In other  
6 words, they may look at performance measures that are,  
7 for instance, for system importance that says what is  
8 the contribution of a given system to my CDF.

9 Now you may have your highly reliable  
10 system that tomorrow may go down the drain. Then  
11 what? We also look at risk achievement work that says  
12 if this system fails with 1.0 failure probability,  
13 what's the consequence on CDF? So that if they're a  
14 highly reliable system that could change performance  
15 overnight, then that raw is going to capture that, and  
16 that's an other importance measure that we use to  
17 define RISC categorization. So there are a lot of  
18 these things have been captured in 50.69, and we're  
19 just adopting those.

20 MEMBER SIEBER: When we reviewed 50.69 in  
21 the Campaign and South Texas Project pilot, I got the  
22 feeling that we were given a concession to the  
23 regulations by allowing changes in special treatment  
24 requirements. I felt comfortable with that because  
25 there was data presented, a study presented by South

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Texas which basically said operability and  
2 availability do not change in any significant way when  
3 you move from safety grade to commercial grade. So to  
4 me, system still available, it will still most likely  
5 function, if required. Now we suggest that we're  
6 going to take the system out of service, we're going  
7 to tag it out, which means it's guaranteed not  
8 available.

9 MR. HAMZEHEE: That's right. And that's  
10 why 2-A --

11 MEMBER SIEBER: And I think that's a far  
12 cry from 50.69, and you shouldn't be trying to draw  
13 any kind of conclusion or relationship between what we  
14 approved in 50.69 and what we're suggesting --

15 MR. HAMZEHEE: Correct. And I would like  
16 to emphasize that the only thing we inherit from 50.69  
17 is the RISC categorization process. That's it. Now  
18 the rest of them are new under different criteria.  
19 Now we have to see does it make it sense to do  
20 anything, to make any changes based on that  
21 categorization process. And your concern is right.

22 MEMBER SIEBER: Well, the one thing that  
23 I think is important is PRA models may be more  
24 appropriate components in the plant. Some of these  
25 RISC-3 things are in that category, not because the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 PRA said it was inconsequential, but because some  
2 people got together and thought about it, the expert  
3 panel, and said this really doesn't make any  
4 difference.

5 MEMBER ROSEN: We can model it, but it  
6 won't show up in the dominant sequences, anyway, even  
7 if we model it.

8 MEMBER SIEBER: Yes, a lot of it isn't  
9 model.

10 MEMBER ROSEN: Because of that.

11 MEMBER SIEBER: And so this is not the  
12 Rock of Gibraltar that you really want to tie your  
13 boat to, in my opinion.

14 MR. HAMZEHEE: But again, let me go over  
15 other alternatives, then you see how that may -- which  
16 one may make sense. And then 2-B says that if you  
17 have a safety-related system that has two or more  
18 trains, one train you maintain as-is, safety related,  
19 and the one other one or more redundant trains can be  
20 reclassified as non-safety-related systems, but that  
21 doesn't mean you do anything. That's exactly what you  
22 said. That means they still are maybe the same as  
23 what you had before, but some of the regulatory  
24 requirements could change.

25 MEMBER ROSEN: I can see the parts guys

1 going nut with that one.

2 MEMBER SIEBER: I know.

3 MEMBER SIEBER: You just buy all safety-  
4 related stuff, and pay ten times more. Because you  
5 can't afford to take the chance of screwing up.

6 MEMBER ROSEN: That you might mix it up.  
7 Right.

8 MR. HAMZEHEE: And then the other extreme  
9 that gets closer and closer to a more structured  
10 approach is the 2-C. That says if you have a system  
11 of more than two trains, one will stay as-is, the  
12 other one you only provide operational flexibilities,  
13 nothing else. So that is maybe the least severe  
14 option.

15 MEMBER ROSEN: Like operational  
16 flexibility, like a very long AOT.

17 MR. HAMZEHEE: Exactly. You got it.  
18 Well, long, or some definition. Right now it's 72-  
19 hours, you may be able to extend it for three days, or  
20 10 years if it meets the criteria. So these are the  
21 three sub-alternatives, and one can use one or the  
22 other, or combination. Gerardo, would you like to  
23 make some clarification? You've got to speak on the  
24 microphone, and you need to introduce yourself.

25 MR. MARTINEZ: I'm Gerardo Martinez from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Brookhaven Lab. I just would like to clarify that the  
2 Alternative 2 we're proposing is not -- we're not  
3 proposing to move the entire system, even if it's low  
4 safety-significant. We are proposing if we have a  
5 system that has some redundancy, then we will keep at  
6 least one train safety-related, and the flexibility  
7 comes from relaxing the other trains.

8 MEMBER SIEBER: I think that that needs to  
9 be carefully worded, because what you intend and what  
10 licensees will do may be two different things.

11 MEMBER APOSTOLAKIS: Also, speaking of  
12 wording, since you have RISC-2, calling it Alternative  
13 2-A, B, C, confused me. Now the 2 refers to the  
14 alternative, not to the --

15 MR. HAMZEHEE: Correct. Under Alternative  
16 2 --

17 MEMBER APOSTOLAKIS: I know. Maybe you  
18 ought to call them Roman Numeral - Alternative --

19 MR. HAMZEHEE: Next time we'll call them  
20 Roman Numeral I and II, and III.

21 MEMBER APOSTOLAKIS: Well, you just said  
22 the licensee may misunderstand. I was trying to  
23 figure out well, where the hell is --

24 MEMBER SIEBER: Use Greek letters.

25 MEMBER APOSTOLAKIS: Use Greek numbers.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Greek numbers are worse.

2 CHAIRMAN WALLIS: What do they look like,  
3 George?

4 MR. HAMZEHEE: All right. Next, these are  
5 some of the further requirements and clarifications on  
6 Alternative 2, that once that alternative is applied,  
7 then we have to provide risk-inform requirements for  
8 each RISC category. So then we get into some of the  
9 implementation issues, and how to control licensee's  
10 actions. And also, this alternative we have to  
11 provide some performance monitoring for the  
12 reliability of the systems that are going to be  
13 changed. And this is mainly for -- well, that's  
14 enough.

15 And then, again, once you adopt  
16 Alternative 2, if you want to make those changes  
17 depending on which sub-alternative you follow, it has  
18 to meet the guidelines of Reg Guide 1.174, so that  
19 never changes. And again, this alternative is also  
20 coherent with the Risk-Informed Initiatives. And as  
21 you may have seen, and Steve mentioned, implementation  
22 of this alternative may require significant effort by  
23 the licensee and NRC, mainly because if you try to  
24 reclassify things, a lot of procedural requirements.  
25 NRC Staff has to come up with reg guides and all the



1 other things, so it's not an easy thing to do. Any  
2 questions on Alternative 2?

3 MEMBER POWERS: Can I ask you a question  
4 about this alternative?

5 MR. HAMZEHEE: Yes, sir.

6 MEMBER POWERS: If I accepted this  
7 alternative, why would it not be applicable to the  
8 fire protection system?

9 MR. HAMZEHEE: Well, would you expand on  
10 it? For instance, are you talking about fire  
11 protection systems or fire protection program? If you  
12 have this system, if it's safety-related, it could  
13 apply. But remember, the first one, the single-  
14 failure criterion only applies to safety-related  
15 systems. Now a fire protection system has similar  
16 requirements, but is outside 10 CFR 50, Appendix A,  
17 then it's outside the scope. Somebody may want to in  
18 the future risk-inform fire protection, as well, but  
19 this may or may not apply.

20 MEMBER POWERS: Fire protection system  
21 historically not been susceptible to the single-  
22 failure criterion. It is a defense-in-depth system.  
23 Appendix R is the only place in the regulations that  
24 defense-in-depth is defined. Doesn't Alternative 2  
25 force --

1 MR. HAMZEHEE: Currently, no. We did not  
2 intend for the fire protection --

3 MEMBER POWERS: But the reality of --

4 MR. HAMZEHEE: But if the licensee comes  
5 back and claims that this could also apply to fire  
6 protection, we have to go back and look at Appendix R  
7 requirements.

8 MEMBER POWERS: You come in and say well,  
9 why do you have to wait until the licensee -- you say  
10 okay, we're going to do Alternative 2. You've got to  
11 backfit here.

12 MR. HAMZEHEE: We need to meet on that if  
13 we were going to promote that alternative. You're  
14 right.

15 MEMBER POWERS: I think you're going to  
16 have to look at this. You've got to pack that here.

17 CHAIRMAN WALLIS: Are we going to the next  
18 alternative?

19 MR. HAMZEHEE: Yes. Now Alternative 3 -  
20 this alternative is more of a blended approach. So  
21 far you saw two different approaches. This is more of  
22 a blended approach. And what we mean by that is that  
23 this alternative is going to generalize single-failure  
24 criterion by applying a combination of quantitative  
25 targets, and requirements for redundancy and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 diversity. And quantitative targets are recommended  
2 at two levels. One is at the top level RISC targets  
3 which is CDF and LERF, and the other one is at the  
4 lower level for key safety functions that we define  
5 what the quantitative reliability target should be.

6 CHAIRMAN WALLIS: So you then would have  
7 to define these targets.

8 MR. HAMZEHEE: Correct. Yes.

9 MEMBER APOSTOLAKIS: Or you could use what  
10 Mary proposed in one of the early SECYs for new  
11 reactors, that for each initiator no sequence really  
12 should contribute more than one-tenth. I mean, that  
13 would define the lower level function reliability  
14 targets, and it would be consistent with the future  
15 reactors.

16 MR. HAMZEHEE: Yes.

17 MEMBER APOSTOLAKIS: But still, though,  
18 I'm a bit -- I mean, how would you handle the DBA  
19 issue?

20 MR. HAMZEHEE: Remember, this is a  
21 completely different alternative. It has nothing to  
22 do with DBA.

23 MEMBER APOSTOLAKIS: I understand, but  
24 what I'm saying is that can it be completely  
25 different? Because now, let's say I take LOCAs, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 this is existing reactors. I have a good PRA, tells  
2 me what the contribution from LOCAs is. I don't want  
3 any sequence to be more than one-tenth of that  
4 contribution. And I identify one or two sequences  
5 that do have frequency lower than that, what would i  
6 do then? I would remove them from the DBA, from the  
7 design-basis, and also relax some of the requirements  
8 using 1.174?

9 MR. HAMZEHEE: Let me walk you through  
10 this, see if at the end you still have that question,  
11 because I am not sure I understand your whole  
12 question, and I don't want to respond to a question  
13 that I don't completely understand. So this one  
14 provides two levels of quantitative guidelines; one at  
15 the high level says that you have to maintain this  
16 kind of CDF and this kind of LERF, the RISC matrix.  
17 And then you go a lower level, look at your important  
18 safety function and say these safety functions have to  
19 maintain such-and-such reliability. And if you have  
20 those, then you meet this criteria.

21 In addition, you have to look at some  
22 diversity and redundancy requirements. For instance,  
23 this alternative says that if you have -- depending on  
24 the frequency of challenges or initiating events. For  
25 instance, this alternative says that if you have a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 frequent initiator, for that frequent initiator, you  
2 have to maintain a top level CDF and LERF. That's  
3 step one.

4 Step two, you have to maintain for that  
5 frequent initiator, certain unreliability. Let's say,  
6 for instance, if you're talking about post-trip decay  
7 heat removal function, you have to have unreliability  
8 of no greater than 1-E minus four, for instance. This  
9 is Level 2. In addition, because it's so important  
10 that some of the functions that have to be available  
11 and reliable, the third level then you say, I need to  
12 still prescribe or require redundancy for that system,  
13 and even diversity for that function. So this is an  
14 extreme case, that you have all kinds of requirements.

15 The other side of the spectrum is if you  
16 have an infrequent initiator; therefore, that you  
17 still have the top level CDF and LERF requirement, but  
18 for your functional reliability, instead of saying 1-E  
19 minus four, you may say I only need unreliability of  
20 1-E minus two, because now I can afford it. And then  
21 with respect to diversity or redundancy, you may say  
22 I don't need any, or I only need redundancy. So this  
23 is a blended approach of using defense-in-depth, the  
24 diversity that you have, redundancy that you have. In  
25 addition, you apply some high level LERF and CDF

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 requirements.

2 MEMBER APOSTOLAKIS: Why would you define  
3 reliability targets on functions and not on sequences?

4 MR. HAMZEHEE: No. Well, because you can  
5 go as low as you can, but you have to see how far it  
6 makes sense. Now if I'm a licensee and I want to  
7 apply Alternative-3, and I know one of the  
8 requirements for me is to maintain my post-trip decay  
9 heat removal function and certain reliability, and if  
10 I exceed it, NRC is going to be after me. I'm going  
11 to have low level targets at my plant. I am going to  
12 go and look at what are those systems that contribute  
13 to that function.

14 If there are three systems, I set goals  
15 for each system. Then I may set goal at the train  
16 level. That way, there is no way I exceed the  
17 threshold, or if I'm going to exceed, I have enough  
18 leading indicators that would tell me soon you're  
19 going to exceed that high level, and then you violate  
20 the equation.

21 MEMBER APOSTOLAKIS: But the sequences,  
22 though, are a more realistic description of what is  
23 going on, rather than function. Right?

24 MR. HAMZEHEE: Yes.

25 MEMBER APOSTOLAKIS: So why couldn't you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 put the -- I mean, my understanding is that you are  
2 not prepared to recommend any of these alternatives as  
3 the best.

4 MR. HAMZEHEE: Correct.

5 MEMBER APOSTOLAKIS: You are still  
6 exploring.

7 MR. HAMZEHEE: Correct.

8 MEMBER APOSTOLAKIS: So why can't you then  
9 explore also the possibility of putting some kind of  
10 reliability targets on sequences, rather than  
11 individual functions? Because a function can be  
12 conditioned on what has happened before. Right? So  
13 you have to start thinking about it.

14 MR. HAMZEHEE: When you say sequences, are  
15 you talking about PRA sequences?

16 MEMBER APOSTOLAKIS: Yes, yes, PRAs. And  
17 you have already the major initiating events. Okay?  
18 You may use this general guideline of one-tenth and so  
19 on, and see whether you can formulate something there  
20 that would be Alternative 4, for example.

21 MR. HAMZEHEE: We can do that, and I'll  
22 let Bob talk soon. But what I am saying is you can do  
23 that, that's an option. However, from implementation  
24 perspective, which one do you think is easier for the  
25 plant personnel, to look at the functions or the PRA

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 sequences?

2 MEMBER APOSTOLAKIS: Well, the functions  
3 too, though. They have to place them in some PRA  
4 context, don't they?

5 MR. HAMZEHEE: Well, eventually, yes.

6 MEMBER APOSTOLAKIS: Yes. So I don't  
7 think -- I mean, difficulty is concerned no matter  
8 what you do. This is right up there as the  
9 conservation of momentum.

10 MR. HAMZEHEE: Bob, would you like to  
11 expand on that, and introduce yourself, please.

12 MR. YOUNGBLOOD: Bob Youngblood, ISL.

13 MEMBER APOSTOLAKIS: I can't see you.

14 MEMBER SIEBER: As long as you don't  
15 change --

16 MR. YOUNGBLOOD: I'm with Hossein in not  
17 completely understanding your question, but I would  
18 like to say that we did look at the early SECYs. And  
19 in thinking about function here, we're thinking about  
20 families of sequences. And I think family of sequence  
21 is also a concept from those early SECYs.

22 MEMBER APOSTOLAKIS: That's what I mean,  
23 too.

24 MR. YOUNGBLOOD: And so this kind of  
25 initiator and failure of that kind of function is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 going to be a family of sequences. And so I think  
2 that we're not only receptive, but maybe already buy  
3 what you're advocating.

4 MEMBER APOSTOLAKIS: The thing is that if  
5 you try to put -- well, first of all, I'm not sure I  
6 completely understand all the details here, but if you  
7 try to put targets on the sequences, then you're also  
8 achieving what Hossein mentioned earlier; namely, the  
9 frequency of needing a particular function is built  
10 into the system; whereas, now you may declare that you  
11 need post heat removal will have to be this or better  
12 no matter what.

13 MR. HAMZEHEE: But that's not one of the  
14 options, though.

15 MEMBER APOSTOLAKIS: Maybe I'm talking  
16 about the same --

17 MR. YOUNGBLOOD: That's conditional on a  
18 particular family of issues.

19 MEMBER APOSTOLAKIS: Then maybe we're  
20 talking about the same thing.

21 MR. YOUNGBLOOD: We might actually be.

22 MEMBER APOSTOLAKIS: Ultimately, you get  
23 the sequence.

24 MR. YOUNGBLOOD: Yes. And while I'm up  
25 here, let me just point out in case it was missed,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that the example that Hossein is working with actually  
2 was done, and it is a TMI requirement. They said for  
3 this class of initiators, meet this class of  
4 reliability. It was an overlay already.

5 MEMBER APOSTOLAKIS: Yes. I still get  
6 confused about the DBA issue.

7 MR. HAMZEHEE: You are still with  
8 Alternative-1.

9 MEMBER APOSTOLAKIS: No, I think DBA is  
10 everywhere.

11 VICE CHAIRMAN SHACK: The question I have  
12 with 2 and 3. What do they do with the DBA issue, I  
13 mean, if I implement 2 and 3, I still -- do I have to  
14 also implement 1 to get rid of them in the DBA?  
15 Otherwise, I'm going to have to live with them in DBA.

16 MR. HAMZEHEE: Yes. What it means in turn  
17 is that let's, for the sake of the argument, assume we  
18 pick Alternative 2. If you take Alternative 2-B, it  
19 says if you have a system with more than one train,  
20 one train you keep as-is, the other train or trains  
21 you can reclassify as non-safety-related. As soon as  
22 you reclassify a system as non-safety-related, then in  
23 the DBA requirement you cannot use it any more,  
24 because DBA only applies to safety-related system.

25 MEMBER APOSTOLAKIS: So you're --

1 MR. HAMZEHEE: You're done. Correct.

2 MEMBER APOSTOLAKIS: Now how about on  
3 Alternative 3?

4 MR. HAMZEHEE: What about Alternative 3?

5 MEMBER APOSTOLAKIS: Well, give me a  
6 similar example.

7 MR. HAMZEHEE: Alternative 3 is you don't  
8 reclassify anything.

9 VICE CHAIRMAN SHACK: If I haven't  
10 implemented Alternative 1, if I've removed it in  
11 Alternative 2 because I can no longer count on it,  
12 then when I put the single-failure criterion in to do  
13 my DBA analysis, my one system has disappeared, and  
14 I'm dog meat. So unless I implement both 2 and 1, I  
15 haven't gained anything.

16 MR. HAMZEHEE: Yes. Now if you have  
17 Alternative 3, that's why we said these alternatives  
18 are not going to only impact one program or one  
19 requirement. If you try to apply Alternative 3, then  
20 you have to go back and look at all the other  
21 requirements, and see how they would be impacted, and  
22 what changes you need to make.

23 Bob, do you have any additional  
24 clarification of this?

25 MR. YOUNGBLOOD: Bob Youngblood, ISL. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 report has a very short mention of DBA under  
2 Alternative 3. And basically what it says is that,  
3 that the success paths that you credit to satisfy all  
4 this should be met with margin. And you could sort of  
5 work with that. You could overlay Alternative 1 on  
6 top of that, or maintain DBA stuff separately. If you  
7 went down to a single train system for a really rare  
8 initiator, of course, that wouldn't satisfy single-  
9 failure any more. And in that sense, the design-basis  
10 analysis would change. But the main idea that you  
11 need, that really is part of Alternative 3 is to make  
12 sure that your success paths actually work.

13 MEMBER APOSTOLAKIS: When you say post-  
14 trip decay heat removal function, you put a  
15 reliability target, ten to the minus three. How are  
16 you going to convince the NRC that this is a true --

17 MR. YOUNGBLOOD: Okay.

18 MEMBER APOSTOLAKIS: I mean, is it just  
19 the failure rates of the various systems that will be  
20 used, or are you also going to do a thermal-hydraulic  
21 analysis using the wonderful methods that these  
22 fellows have done, conservative, or best estimate, and  
23 all that? I mean, are you in DBA space, in which case  
24 you are constrained on how you prove something, or is  
25 it just failure rate, or both.

1 MR. HAMZEHEE: Again, some of the details  
2 of implementation have not yet been completed. That's  
3 why we are not making any recommendations. However,  
4 to respond to your question, if one says that you need  
5 reliability of let's say one to the minus four for  
6 decay heat removal function, is the question how are  
7 you going to measure and monitor them?

8 MEMBER APOSTOLAKIS: How are you going to  
9 prove it?

10 MR. HAMZEHEE: It's very similar to  
11 Reactor Oversight Process, for instance. These have  
12 to be determined and established. In Reactor  
13 Oversight Process you have mitigating system,  
14 performance index. There you look at reliability of  
15 a given system train based on some guidelines and  
16 equations, and you say this should be the threshold  
17 based on the impact. So there is a lot of work that  
18 has to be done to get there, so something similar, for  
19 instance, to Reactor Oversight Process can be applied  
20 here. Have we done all the thinking to know exactly  
21 how it's going to be done? The answer is no.

22 MEMBER APOSTOLAKIS: No. And what we're  
23 doing is we're trying to give you some hints as to  
24 what else you ought to think about. And I think  
25 Bill's comment and mine really tell you that you

1 cannot address the issue of DBA in Alternative 1 only.  
2 You have to say something about it in the other  
3 alternatives, too.

4 MR. HAMZEHEE: Yes. And that's what --

5 MEMBER APOSTOLAKIS: I'm not asking you to  
6 give the answer now. This is something you have to  
7 think about, what exactly do we do with the DBA  
8 analysis in Alternatives 2 and 3.

9 MR. HAMZEHEE: Yes. And as a matter of  
10 fact, Alternative 3 may have impact on other  
11 requirements that we have to go back and very clearly  
12 identify, and then deal with them.

13 MEMBER APOSTOLAKIS: Yes.

14 MR. HAMZEHEE: So we understand.

15 MEMBER APOSTOLAKIS: I tend to like 3, by  
16 the way.

17 CHAIRMAN WALLIS: Have you finished with  
18 3, or are you going to talk --

19 MR. HAMZEHEE: Are we going to take a vote  
20 on which alternative --

21 CHAIRMAN WALLIS: No. Are you going to  
22 talk about the next slide?

23 MR. HAMZEHEE: Yes.

24 MEMBER APOSTOLAKIS: Are you covering --

25 MR. HAMZEHEE: Very quickly.

1 MR. MARTINEZ: I'm Gerardo Martinez,  
2 Brookhaven Lab. To the question on how the  
3 Alternative 2 addresses the DBA - if you have  
4 Alternative 2, you know there are three sub-  
5 alternatives. 2-C keeps all trains safety-related, so  
6 you still have fully capability to meet DBA, so  
7 there's no really no change. The only facility you  
8 get is on the operational flexibility. If you have,  
9 for example, Alternative 2-B, you have one train  
10 safety-related, and the remaining ones are not safety-  
11 related, you cannot close them on safety-related just  
12 to have one. And what you have to do is you have to  
13 weigh the single-failure requirement. That's the way  
14 you would risk-inform the DBA.

15 MEMBER APOSTOLAKIS: In Alternative 2 it's  
16 fairly evident, and in 3 it's not. I think on 2, I  
17 think Hossein even --

18 MR. HAMZEHEE: Yes. Now if you're done  
19 with Alternative 3, I can move on, if we're running  
20 out of time.

21 CHAIRMAN WALLIS: I'm not done with the  
22 subject of alternatives. You've given us three. I  
23 think there should be more.

24 MR. HAMZEHEE: Yes. Well, let me now  
25 quickly go over --

1 CHAIRMAN WALLIS: I'm going to suggest one  
2 to you, just to throw it up, since you're sort of  
3 being creative here.

4 MR. HAMZEHEE: Yes.

5 CHAIRMAN WALLIS: You're imagining things.  
6 I suggest that you consider abolishing all SFCs, and  
7 you try to see what you would lose by doing that.  
8 What would be sort of the change in risk that you'd  
9 tolerate if you abolish them all, and then see which  
10 ones you might be able to justify reinstating.

11 MR. HAMZEHEE: I think it did --

12 CHAIRMAN WALLIS: Start nibbling away at  
13 these things, and all that stuff. It's better to get  
14 rid of the whole damned thing, and replace it if it  
15 has to be replaced with something better, or see if  
16 you've lost that much by abolishing it all. And if  
17 you abolished it and said well, use 1.174 to check on  
18 changes, would you really be damaging public safety if  
19 you did that? Look at these sort of extreme  
20 alternatives and see what happens, why you wouldn't do  
21 that.

22 MR. HAMZEHEE: All right.

23 CHAIRMAN WALLIS: Is that a useful thing  
24 to suggest?

25 MR. HAMZEHEE: Yes. And actually, we've



1 done some of those exercises, but we didn't document  
2 it. Yes.

3 CHAIRMAN WALLIS: Well, since you're  
4 already mentioning it, we're sort of brainstorming  
5 here.

6 MR. HAMZEHEE: Yes.

7 CHAIRMAN WALLIS: Look at other  
8 alternatives and explain to us why they were rejected,  
9 if they're going to be rejected.

10 MR. HAMZEHEE: That's a good suggestion.  
11 Now quickly on page 16, I want to re-emphasize again  
12 that this is also performance-based alternative, so  
13 all these alternatives, including Alternative 3,  
14 should follow some of the regulatory guidance, such as  
15 NUREG/BR-0303, that is "Guidance for Performance-Based  
16 Regulations", because all these alternatives require  
17 some kind of performance monitoring. And again, this  
18 alternative is more coherent with other risk-informed  
19 initiatives, and there could be some significant  
20 resource requirements on the NRC and licensees to  
21 implement these, because this is a whole different  
22 thinking.

23 Now conclusions. Any questions on the  
24 alternatives?

25 CHAIRMAN WALLIS: I think you might also

1 consider besides having more alternatives, some kind  
2 of a decision matrix for deciding between them, rather  
3 than just talking about them, so we have a logical way  
4 of deciding, rather than just talking about them, and  
5 then sort of guessing oh, I like this one, I don't  
6 like that one.

7 MR. HAMZEHEE: Well, we made an attempt,  
8 and it's in the report, to look at pros and cons  
9 associated with each alternative.

10 CHAIRMAN WALLIS: Then could you put them  
11 in some kind of metric, or some way we can --

12 MR. HAMZEHEE: Yes, that's right.

13 MEMBER ROSEN: A scoring system,  
14 basically.

15 MR. HAMZEHEE: Yes. But because we did  
16 not score them because we don't believe we are  
17 completely done with that --

18 CHAIRMAN WALLIS: You're not that far yet,  
19 but I'm suggesting when you actually come up to --

20 MR. HAMZEHEE: Yes.

21 CHAIRMAN WALLIS: -- one or the other,  
22 give some real measures to why it's better than the  
23 others.

24 MR. HAMZEHEE: Yes.

25 MEMBER APOSTOLAKIS: Actually, this table

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that you have in the Executive Summary is very nice.  
2 I really like that.

3 MEMBER SIEBER: Yes, that works.

4 MEMBER APOSTOLAKIS: It made it easy to  
5 compare.

6 CHAIRMAN WALLIS: The only problem is on  
7 a computer it doesn't fit on one screen so that you  
8 can read it.

9 VICE CHAIRMAN SHACK: There's an even  
10 better table in the draft SECY, because they put a  
11 little motivation on top of each column.

12 MEMBER APOSTOLAKIS: So now next time they  
13 will Alternative Roman I.

14 MR. HAMZEHEE: It's all Greek to me.

15 MEMBER SIEBER: That can get you in  
16 trouble.

17 MR. HAMZEHEE: We believe that we have  
18 identified and evaluated a range of risk-informed  
19 alternatives to single-failure criterion. However, we  
20 believe that additional evaluation and stakeholder  
21 involvements are necessary to assess the practicality  
22 of implementing any of these alternatives.

23 MEMBER DENNING: I think there's another  
24 element here, and that is that I think you need  
25 stakeholder involvement to determine is there really

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a motivation to do this; because basically what I've  
2 heard so far says, I don't see why we would want to do  
3 it. And just because it's such a major investment to  
4 do it, I don't see where there's a driver that says  
5 we're going to have safer systems because of it. So  
6 if the utilities don't have some driver that pushes  
7 for it, then why would we --

8 MEMBER APOSTOLAKIS: Option 0.

9 MEMBER DENNING: Yes. Option 0, but we  
10 have to find out what the stakeholder wants.

11 MR. HAMZEHEE: Sure. And hopefully, when  
12 we have the stakeholders' involvement, interactions,  
13 I think that is one of the major elements that has to  
14 be clarified. Absolutely. Especially if it's going  
15 to be a voluntary change, then you need to pay  
16 attention to it. Yes. Well, it could be unless - it  
17 won't be the case, but unless somebody finds that it  
18 should be changed, but so far based on the work we've  
19 done, based on where we are, we believe that the  
20 existing SFC has served the purpose, and it's done  
21 well so we're not going to just jump to a conclusion  
22 that it should be changed, but we have to look at all  
23 the alternatives. Look at pros and cons, put them in  
24 a matrix, find out which ones are stronger, weaker,  
25 and then at the end, find out if doing nothing is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 best because of where we are, or some of these  
2 alternatives could improve safety. Would that also be  
3 beneficial to licensees. And all those factors have  
4 to be considered before --

5 MEMBER ROSEN: Well, you alluded to that  
6 in the beginning. You said that when you do your  
7 reload safety analysis, you would be able to take  
8 credit for some of the margin that develops here.

9 MR. HAMZEHEE: Correct.

10 MEMBER ROSEN: And if the licensees  
11 believe that margin is worth the difficulty, then you  
12 might have some stakeholder --

13 MR. HAMZEHEE: Driving force.

14 MEMBER ROSEN: If they don't see the  
15 value, then it's possible that you're trying to  
16 construct something that would never be used.

17 MR. HAMZEHEE: That's right.

18 MEMBER SIEBER: But you're responding to  
19 a Staff Requirements Memorandum.

20 MR. HAMZEHEE: Correct.

21 MEMBER SIEBER: That's a substantial  
22 motivation to continue on.

23 MEMBER ROSEN: That should be a good  
24 reason to do so.

25 CHAIRMAN WALLIS: That's right, but in the

1       broadest view, you're actually doing something which  
2       will have some consequences.

3               MR. HAMZEHEE:   Correct.

4               CHAIRMAN WALLIS:   I've always asked the  
5       Staff this, when you do something like this, what are  
6       the consequences going to be, positive and negative?

7               MR. HAMZEHEE:   Correct.

8               CHAIRMAN WALLIS:   And the Staff never  
9       looks that far. They do something and say well, now  
10      we've opened the door for industry, and we'll wait and  
11      see if there are any consequences.

12              MEMBER DENNING:   There is a question in  
13      mind, though, as to whether they've gone beyond the  
14      intent of the SRM; not that I'm saying that that's  
15      inappropriate, because I think that what you've done  
16      is appropriate within this, but I'm not sure that what  
17      was in that SRM really said go here.

18              MR. HAMZEHEE:   That's correct.

19              MEMBER ROSEN:   This is your interpretation  
20      of what's in the SRM.

21              MR. HAMZEHEE:   That's right. And let me  
22      say what our interpretation was. Now if we're going  
23      to pursue follow-up activities, then maybe one step is  
24      to meet with the Commission again and make sure we  
25      understand exactly what's on their mind, and then

1 follow-up.

2 MEMBER ROSEN: It would be a good thing to  
3 do early on.

4 MR. HAMZEHEE: Yes. And again, because of  
5 all these good things that we said, and all the  
6 discussions that we had, at this time we do not  
7 recommend one alternative over another until all the  
8 follow-up activities have been completed.

9 CHAIRMAN WALLIS: Well, this SRM is very  
10 broad, isn't it - pursue a broader change to SFC.  
11 That's a sort of carte blanche --

12 MEMBER ROSEN: I suppose they meant to  
13 leave it open.

14 MR. HAMZEHEE: Now quickly let me  
15 summarize our planned follow-up activities, because we  
16 also want to get feedback from you on these actions.  
17 As you may know, there was an SRM issued on May 9,  
18 2005 that directed the Staff to work together to make  
19 risk-informed and performance-based revisions to 10  
20 CFR Part 50. And currently, we are trying to respond  
21 to that, so we believe that the follow-up activities  
22 should be included in that formal program plan that we  
23 have to develop in response to that SRM. And whatever  
24 that plans tell us, we'll follow-up and continue our  
25 work in this area. And this is a good approach,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 because this would ensure that any changes to SFC are  
2 evaluated in a broader context with all other changes  
3 to Part 50 of 10 CFR.

4 The planned follow-up activities include  
5 additional evaluation of the implementation issues,  
6 interaction with stakeholders, maybe other  
7 alternatives could be identified that could be viable  
8 as a result of further interactions, and we get more  
9 feedback on driving force for the licensees, as well  
10 as practicality of these, more interactions with ACRS,  
11 and then we'll report back to the Commission.

12 MEMBER APOSTOLAKIS: Good.

13 MR. HAMZEHEE: Now if we have time, I  
14 would also like to take at least five minutes of your  
15 time to go over some of the general high level  
16 comments that we received from NRR.

17 CHAIRMAN WALLIS: You said if you have  
18 time, I think if we go to 4:30 that would be  
19 reasonable.

20 MR. HAMZEHEE: Yes, that would be  
21 sufficient. Yes. And I'll try to be reasonably  
22 quick. We sent a technical report to NRR and other  
23 offices, and gave them an opportunity to review and  
24 give us comments, and we got some good comments from  
25 NRR. And what you see here are the high level general



1 comments that we received. And let me go over them  
2 and then tell you where we are.

3 The first one is the fact that the NRR  
4 reviewed it and gave us some specific comments on the  
5 draft report, and that they still should be considered  
6 before the report becomes final. And as a matter of  
7 fact, there were a lot of good comments. We're  
8 working on them as we speak. And hopefully in a short  
9 time, we'll be able to resolve most of them, unless we  
10 don't agree with some. But so far, most of the  
11 comments seem to be resolvable, so we're working on  
12 them.

13 And the general comments are the  
14 following; one of them, they believe that it would be  
15 more appropriate to postpone further effort and  
16 include it in the formal program plan discussed on May  
17 9<sup>th</sup>, 2005 SRM to make risk-informed changes to Part  
18 50. And we agree, and as you heard us, this is what  
19 we are going to recommend or not recommend as one of  
20 our conclusions. And it is also included in our draft  
21 Commission paper.

22 The other comment is that overly broad  
23 replacement of SFC for currently licensed plants is  
24 not considered prudent. Efforts to risk-inform SFC  
25 need to proceed cautiously and systematically with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 clear understanding of potential safety and resource  
2 impact. Therefore, the report should focus more on  
3 pros and cons of broadening the relaxation of SFC  
4 versus not doing so. And we agree with this comment  
5 also. That is why we don't feel at this time we're  
6 going to make any recommendation, because again, it  
7 has to be very systemic, cautious, and these are right  
8 suggestions.

9 MEMBER ROSEN: It occurs to me that if  
10 that's what you're suggesting, that now have time to  
11 get some stakeholder input, perhaps in-process rather  
12 than after you get further own the road.

13 MR. HAMZEHEE: Correct.

14 MEMBER ROSEN: It might help a lot to have  
15 some up front.

16 MR. HAMZEHEE: Correct. Absolutely.

17 CHAIRMAN WALLIS: It will be interesting  
18 to see if you get any stakeholder input.

19 MEMBER ROSEN: You might be surprised.

20 MR. HAMZEHEE: That's why when you put it  
21 in 10 CFR and in the formal program plan to risk-  
22 inform Part 50, then they see it in the broader  
23 context. And then they may pay more attention to  
24 some, and less attention to others. So that would  
25 identify those specific interests.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           And the next one is when the report is  
2           forwarded to the Commission, it should be made clear  
3           that it may be too early to recommend a specific  
4           alternative, and that outstanding technical issues  
5           exist which need to be resolved. Again, we agree, and  
6           we don't plan to make any recommendations at this  
7           time. And actually, recommend new alternatives until  
8           the follow-up activities are completed.

9           MEMBER APOSTOLAKIS: Let me understand  
10          something here. Is it conceivable that you will  
11          forward something to the Commission with which NRR  
12          disagrees?

13          MR. HAMZEHEE: Usually not. We always  
14          have the package to everybody's concurrence. And I  
15          don't remember, but maybe NRR wants to talk about it.  
16          Usually we get concurrence before it goes to the  
17          Commission. If there are rare occasions, my life with  
18          the NRC, I have not observed that, but that's I think  
19          where I should stop.

20          MEMBER APOSTOLAKIS: But it can happen?

21          MR. THADANI: It has happened, but on rare  
22          occasions.

23          CHAIRMAN WALLIS: Now when you give the  
24          Commission alternatives like this, they have the  
25          choice of coming back with an SRM which says pursue

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Alternative 2. Once you give them the alternatives,  
2 whatever you say about being cautious and all that --

3 MR. HAMZEHEE: They always can ask us to  
4 do anything. That's right.

5 CHAIRMAN WALLIS: They may well come back  
6 saying we favor a certain approach

7 MEMBER SIEBER: It might not be a good  
8 one.

9 MEMBER APOSTOLAKIS: I don't disagree with  
10 that statement.

11 MR. HAMZEHEE: Well, hopefully with the  
12 type of effort we've done and the results and  
13 conclusions, that would help them get to where we  
14 think we should go, and how to continue.

15 MEMBER APOSTOLAKIS: The third bullet says  
16 the report should focus more on pros and cons of  
17 broadening versus not doing so.

18 MR. HAMZEHEE: Yes. In other words, I  
19 think we want to make sure we also evaluate in some  
20 detail where we are today, because it has served the  
21 purpose well.

22 MEMBER APOSTOLAKIS: But you haven't done  
23 that today.

24 MR. HAMZEHEE: Not enough. I mean, to  
25 some level we've done, but we have not done enough of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 evaluation, put it in the matrix and compare it to the  
2 scorecard and say this has three points, it has this,  
3 and all the benefits. We've done it to some degree.  
4 We have looked at some of the high level benefits  
5 qualitatively, but that can be done more if one wants  
6 to make a recommendation.

7 CHAIRMAN WALLIS: Why should you be  
8 working out all these benefits? Why shouldn't  
9 industry be working out all of these pros, and cons,  
10 and benefits?

11 MR. HAMZEHEE: That's very true, and I'm  
12 hoping that if we continue our effort, that is going  
13 to be done more or with help from the industry, as we  
14 are doing with 50.46. The Westinghouse Owners Group  
15 is looking at some of the safety benefits.

16 CHAIRMAN WALLIS: They have promised to do  
17 so.

18 MR. HAMZEHEE: Yes. You're absolutely  
19 right. And the last comment is, this report states  
20 that single-failure criterion is a proxy for  
21 reliability. Other benefits of SFC include avoiding  
22 excessive reliance on the particular element of plant  
23 safety, maintaining design-basis accident mitigating  
24 capability during maintenance. These other benefits  
25 need to be addressed more directly in the alternative.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           We agree, however, there was just one  
2 occasion that this was mentioned, and other sections  
3 of the report talked about other elements. However,  
4 we went ahead and looked at the report, and fixed it,  
5 and clarified it so that it doesn't sound like this is  
6 the proxy to reliability, and that's the only thing.

7           MEMBER APOSTOLAKIS: Maintaining DBA,  
8 mitigating, doing maintenance - if you have one train,  
9 and you take it out from maintenance and you keep  
10 running, you don't have the reliability you want, so  
11 it is a proxy for reliability. This is not a serious  
12 comment.

13           MR. HAMZEHEE: Well, it's --

14           MEMBER APOSTOLAKIS: Excuse me. I can say  
15 that, you can't.

16           MR. HAMZEHEE: NRR, would you like to add  
17 anything? No?

18           MEMBER APOSTOLAKIS: Let's not make a big  
19 deal of it, but it really is --

20           MR. HAMZEHEE: But I think that requires  
21 clarification. To some degree, they want to make sure  
22 that we put it in the right context, that there are  
23 other elements. This is not just proxy to  
24 reliability.

25           MEMBER APOSTOLAKIS: And what I'm saying

1 is that you will not have the reliability you need if  
2 you have only one train and you go to maintenance.  
3 You will have to shut down.

4 MR. HAMZEHEE: All right. Yes.

5 MEMBER APOSTOLAKIS: The other three  
6 performance in a previous life made much more sense,  
7 especially when they say you should move cautiously.

8 MR. HAMZEHEE: Now before I go to the next  
9 to schedule, which is my last viewgraph. It should  
10 not take more than a couple of minutes, I would like  
11 to ask the NRR Staff if they want to add or expand on  
12 any of these comments, or should I go ahead? All  
13 right. Thanks. Okay. The next slide is the schedule.

14 MEMBER APOSTOLAKIS: When you say at NRR,  
15 who is it?

16 MR. HAMZEHEE: Why do you have to know,  
17 George? The Division of Engineering, and mainly  
18 they're represented by Division of System Safety and  
19 Analysis. And Jim Lyons is the Acting Division  
20 Director. He's sitting there. Mark Rubin is the  
21 Section Chief.

22 MEMBER APOSTOLAKIS: All right. That's  
23 good enough.

24 MR. HAMZEHEE: And some others, Steve Laur  
25 and Donnie, and Gareth. All the NRC Staff.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 All right. Schedule - we completed a  
2 draft technical report in February of 2005, sent it to  
3 other offices for review and comment. We received the  
4 comments in May of 2005. We're briefing you today,  
5 which is June, 2005. We would appreciate it very much  
6 if get a letter from you by June 30<sup>th</sup>, because the  
7 last bullet is to issue a Commission paper with  
8 technical report by June 29<sup>th</sup>. So if we get the  
9 letter from you by the end of this month, we can  
10 provide your feedback into the Commission paper.

11 CHAIRMAN WALLIS: So what happens then?

12 MR. HAMZEHEE: And then once you see the  
13 SECY paper, you see that it says the conclusion is  
14 that we've looked at some alternatives; however, we  
15 need to do more work and meet with the stakeholders to  
16 make sure that all the viable alternatives have been  
17 defined.

18 CHAIRMAN WALLIS: What you're looking for  
19 is the Commission to give you the go ahead to go and  
20 do those things --

21 MR. HAMZEHEE: We did not ask -- well,  
22 that's right. This is informing of our findings and  
23 we're telling them what we're going to do as  
24 conclusions. But as you said, they may come back and  
25 direct us otherwise, so you help would help. And I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 think once you read the Commission paper, you see it's  
2 very clear how the work progresses, and what kinds of  
3 conclusions we're drawing, and where we want to go  
4 from here.

5 Now the only challenge, which I think we  
6 can achieve, is to resolve or address all NRR comments  
7 before we prepare the package, but I think we've made  
8 significant progress, so it should not be difficult,  
9 but it's challenging.

10 CHAIRMAN WALLIS: Are you going to issue  
11 this Commission paper before you even get public  
12 comments?

13 MR. HAMZEHEE: Yes. We're not going to  
14 get public comment on this, because this is findings  
15 of our effort to the Commission. But if we're going  
16 to follow-up, then we're going to meet with the  
17 public, get comments, feedback, and everything else.

18 MEMBER SIEBER: Now the real endpoint  
19 would be a rule making, because you've got to change  
20 Appendix A to implement for any of these alternatives.

21 MR. HAMZEHEE: If that is an alternative.

22 MEMBER SIEBER: That's two years away.

23 MEMBER APOSTOLAKIS: At least.

24 MR. HAMZEHEE: Again, it also depends on  
25 the formal program plan that we're working on right

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 now to risk-inform Part 50. This may have a lower  
2 priority than some other activities, or it may have a  
3 higher. We don't know yet, because we have not  
4 completed that program plan.

5 MEMBER APOSTOLAKIS: How sympathetic is  
6 the Commission when they issue an SRM asking the Staff  
7 to do something, and the Staff comes back and says  
8 here is a number of alternatives, but we can't really  
9 recommend yet? Are they understanding or are they  
10 saying you didn't really respond to the SRM?

11 MR. LANE: Well, we'll find out.

12 MS. DROUIN: George, this is Mary Drouin.  
13 We do this quite often. I mean, when the Commission  
14 comes back with an SRM, we'll give them periodic  
15 status reports. And, Hossein, would it be fair to  
16 characterize this as a status report, where we are in  
17 response to the SRM?

18 MR. HAMZEHEE: Yes.

19 MS. DROUIN: And that's typical of what we  
20 do.

21 MEMBER APOSTOLAKIS: Oh, so it's not  
22 something that's unusual.

23 MR. HAMZEHEE: It's reasonable.

24 MS. DROUIN: That's true.

25 MR. SNODDERLY: Well, I think this is a

1 little bit more, because it --

2 MEMBER APOSTOLAKIS: A little more what?

3 MR. SNODDERLY: Correct me if I'm wrong,  
4 Hossein, because the impression I got from the SECY  
5 was that you plan to pursue these alternatives as part  
6 of the broader look at Part 50, which you're  
7 developing that formal program plan.

8 MR. HAMZEHEE: Yes.

9 MR. SNODDERLY: That you're going to fold  
10 it into that, so I thought that that was a little more  
11 formal.

12 MR. HAMZEHEE: It is, yes.

13 MR. SNODDERLY: You've done the work,  
14 you've looked at the broader changes. Now you're  
15 going to keep these in mind or pursue them further as  
16 you risk-inform Part 50 from an overall point.

17 MR. HAMZEHEE: Yes. That's correct. Any  
18 other comments or questions? Any comments from the  
19 audience, NRR, or Research Staff, or our consultant?  
20 Thank you.

21 MEMBER SIEBER: Thank you very much.

22 CHAIRMAN WALLIS: Well, we have made it to  
23 4:30. Thank you very much. I very much appreciated  
24 your presentation and explanation of many things which  
25 were somewhat obscure to me before.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HAMZEHEE: My pleasure.

2 CHAIRMAN WALLIS: We will take a break for  
3 15 minutes, and then quarter to five when we come  
4 back, I'd like to look at where we are in terms of  
5 beginning to decide on what should be the substance of  
6 our letters on some of these important matters. You  
7 don't need the report.

8 (Whereupon, the proceedings in the above-  
9 entitled matter went off the record at 4:32 p.m.)  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

CERTIFICATE

This is to certify that the attached proceedings  
before the United States Nuclear Regulatory Commission  
in the matter of:

Name of Proceeding: Advisory Committee on


Reactor Safeguards

523<sup>rd</sup> Meeting

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the  
original transcript thereof for the file of the United  
States Nuclear Regulatory Commission taken by me and,  
thereafter reduced to typewriting by me or under the  
direction of the court reporting company, and that the  
transcript is a true and accurate record of the  
foregoing proceedings.



Rebecca Davis  
Official Reporter  
Neal R. Gross & Co., Inc.

**NEAL R. GROSS**  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

# **Point Beach Nuclear Plant, Units 1 and 2 Discussion of Red Findings**

Staff Presentation to the ACRS Plant  
License Renewal Subcommittee  
Patrick Loudon, Branch Chief  
Division of Reactor Projects, Region III  
June 1, 2005

## **Point Beach Red Findings**



- Licensee identified Auxiliary Feedwater system finding in November 2001
- Two NRC Special Inspections performed:
  - December 2001 – February 2002
  - September 2002 – March 2003
- 2003 Inspection identified second Auxiliary Feedwater system finding

## Point Beach Red Findings



- Plant notified of final decision on first Red finding in April 2003
- Red Finding places Point Beach in Column IV of the NRC Action Matrix
- Second Red finding issued in December 2003

## NRC Inspection Procedure 95003



- Supplemental Inspection 95003 conducted from August to December 2003
  - Diagnostic in nature
  - Focused on known problem areas
  - Results determine any necessary additional NRC actions
- Point Beach 95003 inspection completed in three parts

## Point Beach 95003



- Teams comprised of inspectors from all NRC regional offices and included contractors
- Additional findings and violations identified
- Five general areas of concern identified through 95003 and baseline inspections

## NRC Areas of Concern



- Five areas of regulatory concern:
  - Human Performance
  - Engineering Design Control
  - Engineering/Operations Interface
  - Emergency Preparedness
  - Corrective Action Program



## Point Beach CAL



- These five areas formed basis for NRC Confirmatory Action Letter (CAL)
- CAL issued on April 21, 2004
- Licensee developed Commitment Letter based on their Site-Wide Excellence Plan
- Commitment Letter attached to CAL

## Point Beach Inspections



- Baseline team inspection membership was expanded
- Special inspections were conducted to evaluate the licensee's progress in implementing Confirmatory Action Letter items.

## Point Beach Current Performance



- Substantive Cross-cutting Issues
  - Substantive cross-cutting issues identified in the areas of Human Performance and the Problem Identification and Resolution
  - Also are identified as areas of concern in the Confirmatory Action Letter

## Point Beach Current Performance



- Human Performance has been a licensee focus and recent improvement has been noted
- Corrective Action Program as designed is sound
- Some aspects of implementation of the program need improvement

## Point Beach Current Assessment




- The licensee has made progress in all five Confirmatory Action Letter areas of concern
- The NRC focus is on sustainability of the licensee's corrective actions

**Point Beach Nuclear Plant**

---

**SUSTAINING IMPROVEMENT**

**Doug Cooper  
Senior Vice President**




**Point Beach Nuclear Plant**

---

**95003 Inspection Findings**

- **Corrective Action Program**
- **Human Performance**
- **Emergency Preparedness**
- **Engineering/Operations Interface**
- **Engineering Design**




## Point Beach Nuclear Plant

### Site Excellence Plan

- Overhauled Comprehensive Excellence Plan
- Internal / External Assessments As Basis
- In Progress Prior To 95003 Inspection
- Resource Loaded
- Routinely Monitored and Updated

NIMC  
Committed to Nuclear Excellence

### Picture of Excellence



## Point Beach Nuclear Plant

### Six Critical Milestones "6 For Success"

- Dry Fuel Storage
- Spring Refueling Outage – 2005
- Confirmatory Action Letter (CAL) Closure
- Fall Refueling Outage – 2005
- Operations Training Program Accreditation
- INPO Evaluation

**NMC**  
Commitment to Nuclear Excellence

## Point Beach Nuclear Plant

### Results To Date U2R27 Outage Goals


Accident Free / Personnel Safety	Goal / Actual
• Lost Time Accidents	0 / 0
• OSHA Recordable Injuries	0 / 1
• Radiological Events	<1 / 0
• Event Free / Nuclear Safety	
• Unplanned Orange / Red Paths	0 / 0
• Reactor Trips (either unit)	0 / 0
• Safeguards Actuation (either unit)	0 / 0
• Loss of Shutdown Cooling	0 / 0
• Loss of Reactor Vessel Level Control	0 / 0
• Station Human Performance Clock Reset	0 / 1

**NMC**  
Commitment to Nuclear Excellence

## Point Beach Nuclear Plant

### Results To Date


- Successful Emergency Preparedness Exercise
- Human Performance-Related Issues Improved
- 134 OF 143 Confirmatory Action Letter (CAL) Items Completed
- 60 OF 65 Performance Measures In CAL Met Or Exceeded
- Engineering Related Calculations Longest Action To Complete
- Overall Improved Performance Observed in Excellence Plan
  - Oversight Assessments
  - Self-Assessments
  - INPO Reviews
  - Objective Performance Measures



## Point Beach Nuclear Plant

### NRC Public Comments On Point Beach

- Public Meetings– March 14 and April 19, 2005
  - Reiterated Importance Of CAL Completion and Outage Performance
  - Acknowledged Status of CAL Actions and Challenges in Calculation Project and EAL Revisions
  - Acknowledged Improvements In All CAL Areas
- Agency Action Review Meeting – May 25, 2005
  - Point Beach Continues To Operate Safely
  - Progress Being Made In All Areas Of Confirmatory Action Letter
  - Action Items Are Scheduled And Resource Loaded
  - Improvements Indicate Ability To Complete Commitments





Sandia  
National  
Laboratories



EPRI

SAIC  
An Lockheed Martin Company

## EPRI/NRC-RES FIRE PRA METHODOLOGY

J.S. Hyslop, NRC/RES

Steven P. Nowlen, SNL

Bijan Najafi SAIC (for R. Kassawara, EPRI)

ACRS Full Committee

June 1, 2005

Rockville, MD



A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)

## BACKGROUND

- MOU between NRC-RES and EPRI on fire risk
- One of several elements on MOU
- Primary objective of this program: develop, field test, and document state-of-art
- Prior briefings of ACRS, including focused briefing in May 05
- Purpose: Brief ACRS on final NUREG/CR-6850, EPRI 1008239 "EPRI/NRC-RES Fire PRA Methodology for Nuclear Power Facilities" which addresses public comments



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 2

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)



## ROLES OF PARTICIPANTS

---

- NRC-RES and EPRI develop and test methods
- Three volunteer pilot plants support testing
- Other participating licensees provide peer-review of methods
  - Peer review indicated that step change produced in many areas of fire PRA methodology
- EPRI and NRC-RES reach consensus on documented methodology



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 3

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## EXPECTED USE OF METHODOLOGY

---

- Support for new rule 10CFR50.48c implementation
- Analyses under the current fire protection regulations (i.e. exemptions/deviations or other plant changes such as risk-informed technical specifications)
- Basis for staff review guidance that RES will develop for NFPA 805 related changes
- ANS fire risk standard
- Analysis and reviews of fire protection inspection findings (phase 3 SDP)



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 4

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## ADVANCEMENT TO STATE OF ART

---

- Improvements made in areas important to fire risk (resource constraints considered)
- Means to advance
  - Consolidate existing research
  - Analyze more extensive data
  - Modify existing methods
  - Develop new approaches



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 5

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## RELATIONSHIP TO FIRE MODEL V&V

---

- Fire modeling tools provide input to fire PRA
- Fire model verification and validation (V&V) is required for NFPA 805 applications
- In limited cases, fire models (empirical correlations) utilized
  - Address cases where computational fire models inadequate
  - Fill important gaps in fire PRA
- PRA Methodology document not a reference for fire models
  - Any necessary V&V left to analyst



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 6

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## PUBLIC COMMENTS

---

- Comments provided during public comment period by industry and consultants
  - Duke Power, Florida Power and Light, EPM, RDS
- Comments provided by NRR
- No public comment required NRC-RES and EPRI to significantly adjust our approach
  - Few comments on state-of-the-art limitation
  - Remaining comments were minor and clarifications



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 7

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## MILESTONES

---

- |  |                 |
|--|-----------------|
| • Draft report for public comment      | Oct 2004        |
| • ACRS                                 | May/Jun 2005    |
| • Public Fire PRA Methodology Workshop | Jun 14-16, 2005 |
| • Publication                          | Aug 2005        |
| • BWR pilot                            | 2006            |
| • Revision of methodology (if needed)  | Dec 2006        |



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 8

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## PROJECT TEAM

- Covers all technical disciplines critical to Fire PRA
  - Technical Lead: B. Najafi, S. Nowlen
  - General PRA & plant systems analysis: A. Kolaczowski, R. Anoba
  - Circuit Analysis and Appendix R: D. Funk, F. Wyant
  - Human Reliability Analysis: J. Forrester, W. Hannaman, A. Kolaczowski
  - Fire analysis: F. Joglar, M. Kazarians
  - Consultants: A. Mosleh, D. Bley
- Collectively, over 250 years of relevant experience
- Principal authors of documented Fire PRA methods in the US for the past 2 decades
- Experience with use of previous methods; their strengths and weaknesses
- The Methodology reflects the consensus of this team, EPRI and RES




ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 9

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## FIRE PRA PROCESS FLOW CHART




ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 10

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## FIRE PRA PROCESS FLOW CHART



## Task 2: Fire PRA Component Selection

- Determines what will be credited in Fire PRA model
- Advances over IPEEE model
  - Multiple spurious actuation events
  - Key instrumentation supporting post fire operator actions
- Public comments
  - Added search for “new” scenarios and associated components
  - Added more on unique manual actions including supporting instrumentation needed as well as accounting for equipment effects as a result of actions
- Cable selection (task 3) performed for all fire PRA components
- Fire induced risk model (task 5) models these issues



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 12

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Task 12: Post Fire HRA

- Main advances
  - Screening level Human Error Probabilities (HEPs)
    - Range from 10x Internal Events PRA HEPs to 1.0
  - Identification and discussion of performance shaping factors (PSFs) for detailed analysis
    - Plant and scenario-specific PSFs for estimating best estimate HEPs for significant fire scenarios
- Procedure does not provide detailed quantification guidance
- Public comments
  - Removed discussion of fire-specific pre-initiator human failure events (HFEs)
    - Those impacting fire protection systems, barriers, general fire protection program elements
    - Possible confusion/overlap with use of experience/data covered in other Tasks
    - Does not preclude plant-specific HRA of fire-specific pre-initiator HFEs
  - Added "general" guidance on use of existing HRA methods, BUT no specific quantification guidance as requested by one comment



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 13

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Task 6: Fire Frequencies

- *Fire Frequencies:* significant improvements made here
  - Most fire sources now use component-based frequency
    - Allows for more consistent, refined, and reasoned compartment and scenario frequencies that reflect plant specific configuration
  - Extensive analysis of event data
    - IPEEEs typically used full unscreened event set for frequency and applied generic severity factors
    - We screened events for risk-relevance (potentially challenging)
    - We also utilize fire severity profiles that have implicit links to the final frequency event sets (more on profiles later)
  - This area was the subject of much discussion and adjustment during peer review
  - Several public comments requested clarification of specifics, no major changes



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 14

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Task 9: Detailed Circuit Analysis

---

- Generally reserved for cases in which quantitative screening indicates a clear need and advantage for further analysis
- Detailed failure modes analysis
- Objective is to screen out cables that cannot impact the ability of a component to complete its credited function
- Public comments
  - Enhanced “risk-informed” guidance to focus analysis on failure modes of concern
  - Incorporated guidance for human factors interface



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 15

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Task 10 – Circuit Failure Mode Likelihood Analysis

---

- Probabilistic Based Circuit Analysis
- Two Methods Presented
  - Expert Panel Results
  - Computation-Based Analysis
- Requires Knowledge About Circuit Design, Cable Type and Construction, Installed Configuration, and Component Attributes
- Generally Reserved for Only Those Cases that Cannot be Resolved Through Other Means



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 16

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Task 10 – Circuit Failure Mode Likelihood Analysis

- Key Insights
  - Our Knowledge is Greatly Improved but Uncertainties are Still High
  - Practical Implementation is Challenging
  - Further Analysis of Existing Test Data and Follow-On Tests Would be Beneficial
- Public and Peer Review Comments
  - Extensive Discussions Regarding the Most Appropriate Way to Tally Spurious Actuation Probabilities (Many Subtleties for Implementation)
  - Team's Consensus is that Expert Panel Values are generally Conservative as currently applied
  - Additional Independent Review of the Circuit Analysis Method was Solicited (Favorable, but limitations acknowledged)



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 17

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Task 11: Detailed Fire Modeling

- Scope: Define and evaluate specific fire scenarios
  - Single, multi-compartment, main control room fire scenarios
- General approach follows traditional pattern:
  - Identify fire sources and targets
  - Fire growth/spread/damage analysis including fire severity
  - Fire detection/suppression analysis
  - Final output is conditional probability of fire consequences given fire ignition
- Special models developed to account for NPP fire scenarios beyond the capability of existing computational fire models



ACRS Full Committee,  
June 1, 2005, Rockville, MD


Slide 18

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)



## Task 11: Detailed Fire Modeling Heat Release Rate and Severity

- Previous methods (e.g. IPEEE) used a fixed HRR and severity factor
- New approach ties severity factor to a distribution on peak fire intensity
- HRR distributions developed for various ignition sources
  - Expert judgment based upon evidence from events and data
  - Captures high intensity fires
- Basis for scoping fire modeling (Task 8) which eliminates components from fire model



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 19

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Task 11: Detailed Fire Modeling Special Models

- High energy arcing faults (new)
  - Critical to switchgear room fire risk
  - An empirical rule set type model based on operating experience
  - High-energy phase, defined by a “zone of influence”
  - Thermal phase (enduring fire) treated like other fire sources
- Main control board (new)
  - Critical to control room fire risk
  - A probabilistic model for fire propagation inside the main control board
- Cable fires (modified from IPEEE approaches)
  - Critical to cable spreading room and cable tunnel fire risk
  - Fire spread in a single tray or cable tray stacks



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 20

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Task 11: Detailed Fire Modeling Other Special Models

- Fire propagation to adjacent cabinets (consolidation)
- Passive fire protection features (consolidation)
- Hydrogen fires (new)
- Turbine generator fires (new)
- Smoke damage (consolidation)



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 21

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Task 11: Detailed Fire Modeling Detection & Suppression Analysis

- Probability of Non-Suppression = conditional probability that fire lasts long enough to cause postulated damage
- Approach credits:
  - Prompt detection & suppression (by plant personnel or fire watch)
  - Automatic detection and suppression
    - Reliability and availability
    - Effectiveness (scenario-specific)
  - Manual detection
  - Manual suppression by fire brigade
    - Model based on operating experience – fire suppression time curves
- Improvements over previous methods:
  - More rigorous review/analysis of event data – long lasting fires
  - Explicit calculation framework (event tree)



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 22

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Public Comments on Task 11

- Editorial/clarification comments including consistency with fire protection SDP, and NEI 04-02
- V&V of fire models
  - NFPA 805 requires that fire models are verified and validated.
  - Our report documents fire PRA state-of-the-art – broader applicability
  - “Models” are cited when team consensus concluded need is critical, and identified method represents a reasonable approach and/or current best practice
    - e.g., the “special models” discussed previously
  - We did not V&V recommended approaches



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 23

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Task 15: Uncertainty and Sensitivity Analyses

- Addresses the *process* for uncertainty and sensitivity analyses
  - Modeling and data uncertainties
  - A comprehensive list of *specific* uncertainty sources for each task has been developed
  - Explicit guidance on quantification (e.g., uncertainty bounds) for each identified source is NOT provided
    - May be able to add as more demonstrations are performed
- Some changes were made as a result of public comments
  - Consolidated discussions of uncertainties from individual tasks under Task 15 (clarification issue)
  - Separated uncertainties to be addressed from technical quality issues
    - Discussion of both remains – see Appendix V
  - Added discussion on usefulness of sensitivities for screened compartments
  - Other minor clarifications and editorial comments included



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 24

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## INSIGHTS

---

- CDF Insights (in the author's judgment compared to IPEEE)
  - Expect overall range of CDF for fleet of plants to be maintained
  - Expect individual risk profile of some plants to change
    - Multiple spurious actuations, high energy arcing faults
    - Control room
  - Continued use of this methodology needed
- Cable tracing to support fire PRA still major resource requirement
  - Address via iterative, screening nature of fire PRA



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 25

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## STATE OF ART IN FIRE PRA

---

- Best available method to estimate fire risk and obtain insights.
- Improvements will benefit state-of-the-art
  - Spurious actuations
  - Post-fire HRA
  - Low power and shutdown operations
  - Plant-specific assessment of fire fighting



ACRS Full Committee,  
June 1, 2005, Rockville, MD

Slide 26

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)



# Policy Issues Related to New Plant Licensing

---

Presented to  
Advisory Committee on Reactor Safeguards

June 1, 2005



# Purpose of Presentation

---

- Brief Committee on the staff's recommendation on two policy issues
  - What shall be the minimum level of safety that new plants need to meet to achieve enhanced safety?
  - How shall the risk from multiple reactors at a single site be accounted for?
- Requesting approval on staff's recommendation on the two policy issues
  - Requesting approval in a letter

# Background/History

- SECY-03-0047, Policy Issues Related to Licensing Non-Light Water Reactor Designs, March 28, 2003
  - Staff recommended that implementation of enhanced safety through a process similar to that used in the evolutionary LWR and advanced light-water design certification reviews.
  - The staff also recommended that the following considerations be applied:
    - When using probabilistic or risk information, modular reactor designs should account for the integrated risk posed by multiple reactors necessary to achieve the overall electrical output desired.
    - The incremental risk to the surrounding population from adding additional units to an existing site is expected to be small due to the enhanced safety characteristics of new designs.
- SRM (to SECY-03-0047), June 26, 2003, direction on the policy issues:
  - Approved the staff's recommendation on implementation of the Commission's expectation for enhanced safety in future non-LWRs
    - Requested the staff to provide further details on the options for, and associated impacts of, requiring that modular reactor designs account for the integrated risk posed by multiple reactors

# Background/History (cont'd)

- In SECY-04-0157, "Status of Staff's Proposed Regulatory Structure for New Plant Licensing and Potentially New Policy Issues," the staff alerted the Commission to the new policy issue regarding level of safety
  - What level of safety should be the goal to achieve enhanced safety?
- SECY-05-0006, "Second Status Report of Staff's Proposed Regulatory Structure for New Plant Licensing and Policy Issues Related to Licensing Non-Light-Water Reactor Designs," dated January 7, 2005, the staff
  - The staff would submit final recommendations on integrated risk, containment performance, level of safety in mid 2005 to support pre-application reviews of new reactor designs.
  - Resolution of level of safety and integrated risk are also fundamental to the development of the Framework





# General Guidelines in Assessing Options and Developing Recommendations

---

- Keep the risk to the population around a nuclear power plant site consistent with the Commission's 1986 policy statement on Safety Goals
- Utilize a risk-informed and performance-based approach, wherever practical, consistent with Commission guidance
- Use a technology-neutral approach
- Use the Commission's performance goals to assess the advantages and disadvantages of the options and to develop a recommendation
- Consider previous Commission guidance on these issues
- Consider the practicality of the options and recommendations

# Previous Commission Guidance (Policy Statements)

---

- Regulation of Advanced Nuclear Power Plants
  - "... the Commission expects, as a minimum, at least the same degree of protection of the public and the protection of the public and the environment that is required for current-generation light water reactors. Furthermore, the Commission expects that advanced reactors will provide enhanced margins of safety .... The Commission also expects that advanced reactor designs will comply with this Commission's safety goal policy statement...."
- Severe Reactor Accident Regarding Future Designs and Existing Plants
  - "Although in the licensing of existing plants the Commission has determined that these plants pose no undue risk to public health and safety, this should not be viewed as implying a Commission policy that safety improvements in new plant design should not be actively sought. The Commission fully expects that vendors engaged in designing new standard (or custom) plants will achieve a higher standard of severe accident safety performance than their prior designs."
- Safety Goals for the Operation of Nuclear Power Plants
  - "Current regulatory practices are believed to ensure that the basic statutory requirement, adequate protection of the public, is met."



# Two Policy Issues

---

- What shall be the minimum level of safety that new plants need to meet to achieve enhanced safety?
- How shall the risk from multiple reactors at a single site be accounted for?

# First Issue: Level of Safety

## Four Options Identified

---

- Option 1: Use current process
  - A minimum level of safety is not explicitly defined for achieving enhanced safety
  - A case-by-case determination of enhanced safety is made
  - A minimum level of safety would not be specified in the technology-neutral framework for new plant licensing

# First Issue: Level of Safety

## Four Options Identified (cont'd)

---

- Option 2: Define the minimum level of safety as the Quantitative Health Objectives (QHOs)
  - The QHOs (as expressed in the Commission's Safety Goal Policy) are selected as the minimum level of safety to demonstrate that enhanced safety has been achieved for new reactor designs
  - The QHOs would be used to assess whether new reactor designs, currently under review, meet the Commission's expectation of enhanced safety
  - The framework would be developed based on a minimum level of safety defined by the QHOs
    - The technology-neutral regulations would be developed to achieve at least the safety goal level of safety

# First Issue: Level of Safety

## Four Options Identified (cont'd)

---

- Option 3: Develop other risk objectives for the minimum level of safety
  - Other risk objectives would be developed for the QHOs on a technology-neutral basis similar to the subsidiary risk objectives, core damage frequency (CDF) and large early release frequency (LERF), developed for the current operating LWRs
  - Other risk objectives would be used to assess whether new reactor designs, currently under review, meet the Commission's expectation of enhanced safety
  - The framework would be developed based on a minimum level of safety defined by these new risk objectives

# First Issue: Level of Safety

## Four Options Identified (cont'd)

---

- Option 4: Develop new Quantitative Health Objectives for the minimum level of safety
  - New QHOs, which are more stringent than the ones defined the Commission's Safety Goal policy statement, would be developed
  - The QHOs would be used to assess whether new reactor designs, currently under review, meet the Commission's expectation of enhanced safety
  - The framework would be developed based on a minimum level of safety defined by the QHOs

# Option 1: Advantages & Disadvantages

---

## *Use Current Process*

### Advantages

- No changes needed to current regulatory practice
- Provides maximum flexibility

### Disadvantages

- Not necessarily result in technology-neutral, risk-informed or performance-based
- Not clear that supports Commission's expectations
- Could lead to different results
- May be more likely to be challenged by stakeholders
- Not readily scrutable
- Relies on subjective judgment
- Likely not to result in consistency and uniformity
- Likely not to promote stability and predictability



# Option 2: Advantages & Disadvantages

## ***Define Safety Level as the QHOs***

### Advantages

- Eliminates need to develop criteria on a case-by-case basis
- Provides for a more efficient, scrutable and objective regulatory process
- Increases the level of consistency and uniformity
- Promotes regulatory stability and predictability
- Defines safety level that is technology-neutral, risk-informed and performance-based
- Implements Commission's expectations
- Allows flexibility, allows applicant to propose other risk measures

### Disadvantages

- In providing the flexibility, may result in inconsistent approaches for similar designs in an increase in resources
- Level 3 PRA needed

# Option 3: Advantages & Disadvantages

## ***Define other Risk Measures as the Safety Level***

### Advantages

- Eliminates need to develop criteria on a case-by-case basis
- Provides for a more efficient, scrutable and objective regulatory process
- Ensures consistency and uniformity
- Promotes regulatory stability and predictability
- Defines safety level that is technology-neutral, risk-informed and performance-based
- Implements Commission's expectations
- Level 3 PRA not needed

### Disadvantages

- Significant uncertainties regarding feasibility
- Not apparent that technology-neutral risk objectives tied to the QHOs can be developed
- LWR surrogates: CDF and LERF
  - Definition of core damage, for example, does not apply to the PBMR
- CDF and LERF quantitative objectives (1E-4/ry and 1E-5/ry, respectively)
  - Based on experience gained from substantial number of Level 3 LWR PRAs
- Data and experience needed
- Large increase in resources

# Option 4: Advantages & Disadvantages

## ***Develop More Stringent QHOs as the Safety Level***

### Advantages

- Eliminates need to develop criteria on a case-by-case basis
- Provides for a more efficient, scrutable and objective regulatory process
- Ensures consistency and uniformity
- Promotes regulatory stability and predictability
- Defines safety level that is technology-neutral, risk-informed and performance-based
- Implements Commission's expectations

### Disadvantages

- Require considerable time and staff resources
- Need to identify type of analysis (or even develop new method) to demonstrate that these new QHOs have been met
- Likely to have significant concerns from external stakeholders
- Significant uncertainties regarding feasibility

# Recommendation for Minimum Level of Safety

---

- Recommend that Option 2 be selected
  - ***The QHOs should be the minimum level of safety for new plant licensing in achieving the Commission's expectation for enhanced safety***
- Provides for a uniform application of safety level across all reactor technologies
- Promotes regulatory stability and predictability for new plant licensing
- Defines safety level that is technology-neutral, risk-informed, performance-based
- Implements Commission's expectations
- Consistent with level of safety adopted by the industry
- Allows greater flexibility to both staff and the applicant
- Feasible with the least impact on time and staff resources

# Second Issue: Integrated Risk

## Three Options Identified

---

- Option 1: No consideration of integrated risk
  - The risk information is evaluated on a per reactor basis, not a per site basis
  - Integrated risk from new reactors would not be considered
  - Technology-neutral framework would not consider integrated risk

# Second Issue: Integrated Risk

## Three Options Identified (cont'd)

---

- Option 2: Quantification of integrated risk at the site solely from new reactors
  - The integrated risk solely associated with new reactors at a site would not exceed the risk expressed by the QHOs
  - For ongoing design reviews, staff would ensure that their integrated risk not exceed the risk expressed by the QHOs
  - Criteria and guidelines in technology-neutral framework developed so that the integrated risk from new reactors not exceed the risk expressed by the QHOs

# Second Issue: Integrated Risk

## Three Options Identified (cont'd)

---

- Option 3: Quantification of integrated site risk
  - The integrated risk from both existing and new reactors would not exceed the risk expressed by the QHOs
  - For ongoing design reviews, staff would ensure that the integrated risk from both the existing and new reactors not exceed the risk expressed by the QHOs
  - Criteria and guidelines in technology-neutral framework developed so that the integrated risk from both existing and new reactors not exceed the risk expressed by the QHOs

# Option 1 Advantages & Disadvantages

## ***No Quantification of Integrated Risk***

### Advantages

- Status quo is maintained with no consideration of integrated from multiple reactors at same site
- Least impact on time and staff resources

### Disadvantages

- No quantitative assessment of or limit on integrated risk
- Risk to population near a site could be greater than the QHOs
- May be difficult to justify and communicate to the public



# Option 2 Advantages & Disadvantages

## *Quantification of Integrated Risk of New Reactors Only*

### Advantages

- Qualitatively assesses and limits the total integrated site risk
- The integrated risk from new reactors would not exceed the risk expressed by the QHOs
- Preserves the current regulatory stability and predictability
- Consistent with Commission's statements

### Disadvantages

- Full quantitative assessment of the integrated site risk is not evaluated
- Increases COL action items arising from ESPs and design certifications
- Public may find it difficult to understand why existing reactors should not be held to the higher minimum level of safety

# Option 3 Advantages & Disadvantages

## *Quantification of Integrated Risk of both Existing and New Reactors*

### Advantages

- Quantitatively assesses and limits the total integrated site risk
- The integrated risk from both existing and new reactors would not exceed the risk expressed by the QHOs
- Relatively straightforward to communicate to the public

### Disadvantages

- Disrupts the current regulatory process
- Significantly increases COL action items arising from ESPs and design certifications
- Goes beyond Commission's expectations
- Generic site may not bound the actual site
- May not be workable for construction of new reactors at existing sites if applicant unrelated to current licensee

# Recommendation on Integrated Risk

---

- Recommend that Option 2 be selected
  - ***The integrated risk solely associated with new reactors at a site not exceed the risk expressed by the QHOs***
- Existing reactors, under current regulatory structure, found to pose no undue risk to public health and safety
- Ensures that any incremental risk to the site is insignificant
- Defines integrated risk criteria that is technology-neutral, risk-informed, performance-based
- Implements Commission's expectations
- Promotes regulatory stability and predictability for new plant licensing while preserving the current regulatory structure



# In Summation

---

- Requesting letter from Committee
  - approving staff recommendation on the two policy issues, level of safety and integrated risk
- Staff SECY paper due to the Commission June 30, 2005

# **STATUS OF EVALUATION OF A BROADER CHANGE TO SINGLE FAILURE CRITERION**



## **PRESENTATION TO ACRS**

**Hossein Hamzehee (415-6228)  
John Lane (415-6442)  
Office of Nuclear Regulatory Research**

**June 1, 2005**

## **Status of Evaluation of Broader Change to Single Failure Criterion**

### **Purpose:**

- The purpose of this presentation is to provide a summary of:
  - Status of our evaluation of a broader change to Single Failure Criterion.
  - Planned follow-up activities.
- We are seeking ACRS to provide feedback (via a letter) on:
  - Work completed to date on risk-informed alternatives to current Single Failure Criterion (SFC)
  - Planned follow-up activities

## **Evaluation of Broader Change to Single Failure Criterion**

### **Presentation outline:**

- **Background**
- **Summary of Technical Approach and Work Completed To date**
- **Summary of NRR Major Comments**
- **Planned Follow-up Activities**
- **Schedule**

## **Broader Change to Single Failure Criterion**

### **Background:**

- In March 31, 2003 SRM on risk-informed changes to 10 CFR 50.46 (ECCS Acceptance Criteria), the Commission approved most of staff recommendations on possible changes to LOCA requirements, and also directed the staff to:
  - Risk-inform current requirements of coincidental LOCA/LOOP.
  - Pursue a broader change to SFC and inform the Commission of its findings beyond what is being considered for exemption request for LOCA/LOOP.
- This work was done in response to Commission directive to “Pursue a Broader change to SFC”
  - Our interpretation of “Broader Change” is RI alternatives that could apply to all plant functions (safety and non-safety).
  - Could lead to changes in licensing, programmatic activities (e.g., testing and inspections), and plant performance monitoring.



## **Broader Change to Single Failure Criterion**

### **Background (Cont'd):**

- **The term “Single Failure” is defined in 10 CFR Part 50 Appendix A:**

**“A single failure means an occurrence which results in the loss of capability of a component to perform its intended safety functions. Multiple failures resulting from a single occurrence are considered to be a single failure. Fluid and electric systems are considered to be designed against an assumed single failure if neither (1) a single-failure of any active component (assuming passive components function properly) nor (2) a single failure of a passive component (assuming active components function properly), results in a loss of the capability of the system to perform its safety functions.”**

**[Associated Footnote: “Single failures of passive components in electric systems should be assumed in designing against a single failure. The conditions under which a single failure of a passive component in a fluid system should be considered in designing the system against a single failure are under development.”]**

## **Broader Change to Single Failure Criterion**

### **Background (Cont'd):**

- **SFC requirements exist in two major contexts:**
  - **GDC of 10 CFR 50 Appendix A which identify safety functions and associated safety systems to which SFC applies.**
  - **Design-Basis Accident (DBA) guidance of chapter 15 of RG 1.70 and Standard Review Plan (SRP)**
- **SFC is one element of NRC defense-in depth philosophy**
  - **Accomplishment of key safety functions should not be dependent on a single element of design, construction or operation.**
  - **SFC promotes high safety system (safety function) reliability**
  - **Other regulations, guidelines, and programs, along with SFC, promote high reliability; e.g., QA requirements, Tech. Specifications, Testing, Maintenance requirements, Inspections**

### **Background (Cont'd):**

- **Application of SFC has sometimes led to redundant system components having low risk significance based on PRAs.**
  - **DEG LOCA coincident with LOOP and a DG failure.**
  - **Application of worst single failure assumption for DBAs may result in unnecessary constraints on licensees.**
- **SFC has not always been applied uniformly to passive components in fluid systems**
  - **A risk-informed alternative should also consider potential failure of passive components**
- **Application of SFC has not always led to safety system design with reliabilities that were commensurate with their safety significance.**
  - **SFC supplemented by other NRC guidance, rulemaking and programs contributed significantly to maintaining acceptable level of safety; e.g., SBO rule, ATWS rule, etc.**


## **Policy Issues**

- A proposed risk-informed and performance-based alternative to SFC need to be consistent with Commission PRA regulatory policy guidance.
  - Maintaining defense-in-depth
  - Maintaining adequate safety margin
  - Security constraints
  - Consideration of uncertainty
- A proposed risk-informed and performance-based alternative to SFC need to be consistent with Commission guidance on phased approach to PRA quality.
- A proposed risk-informed and performance-based alternative to SFC need to be consistent with Commission backfit and regulatory analysis policy.
- A proposed risk-informed and performance-based alternative to SFC need to be consistent with other on-going risk-informed activities; examples are:
  - Risk-informing requirements of 10 CFR 50.46
  - LOCA/LOOP exemption request from BWROG
  - Technical Specifications improvement

## **Summary of Technical Approach and Evaluation Results**

### **Evaluation Process:**

- A process was developed to identify and evaluate potential risk-informed and performance-based alternatives to SFC
  - This process is shown in a flowchart
- One major step of the process was to define desired attributes that a potential risk-informed and performance-based alternative should have. These attributes are:
  - Provide functional reliability
  - Maintain defense-in-depth
  - Risk-inform application of SFC in design-basis safety analysis
  - Use performance-based regulatory approach
  - Amenable to effective implementation
  - Coherent with other risk-informed regulatory initiatives
  - Maintain design requirements that contribute significantly to plant built-in capability to resist security threats



**SFC Alternative Process Flowchart**

## **Summary of Technical Approach and Evaluation Results**

### **Baseline Alternative:**

- This alternative continues to make risk-informed changes to regulatory requirements that involve specific issues, such as:
  - Proposed rulemaking on 10 CFR 50.46
  - LOCA/LOOP requirements
  - Risk-informed Tech. Specifications initiatives
- This alternative could result in measurable progress over time (one issue at a time) rather than attempting to address many related issues and regulations simultaneously.
- This alternative would not include a broad change to current licensing requirements to risk-inform SFC.
- Improvement of coherence among risk-informed programs would be limited under this alternative.
- This alternative would also consider updating the footnote in 10CFR50 Appendix A on passive failures in fluid systems.

## **Summary of Technical Approach and Evaluation Results**

### **Alternative 1:**

- This alternative would risk-inform failure assumptions made in DBA analyses in Chapter 15 of FSAR.
  - Single failures resulting in sequences with sufficiently low frequency would no longer be required in DBA analysis.
  - Unlikely initiating events would also be eliminated from DBA analysis.
  - Multiple failures in sequences with sufficiently high frequency would be added to DBA analysis.
  - Plant PRA will be used to demonstrate that cumulative frequency of sequences excluded from DBA is small.
- Potential plant changes proposed under Alternative 1 must also satisfy RG 1.174 guidelines.
  - This alternative could result in additional predicted safety margin.
  - Examples of potential changes are core peaking factors, power uprate, EQ requirements, allowed outage times



## **Summary of Technical Approach and Evaluation Results**

### **Alternative 1 (Cont'd):**

- Quantitative frequency criteria would be established for removal/addition of event sequences in DBA analysis.
- Proposed rule for 10 CFR50.46 could be considered special case of Alternative 1
  - SFC not required for LOCA sizes greater than Transition Break Size
- This alternative would be consistent with other ongoing risk-informed activities
  - 10 CFR 50.46
  - LOCA/LOOP
  - Framework for advanced reactors

### **Alternative 2:**

- **This alternative would risk-inform application of SFC to safety-related systems based on their safety significance.**
- **Risk-informed process proposed here takes advantage of current safety categorization process used in 10 CFR 50.69, "Risk-Informed Categorization and Treatment of Structures, Systems, and Components."**
  - **RISC-1 Systems: Safety Related & Safety Significant**
  - **RISC-2 Systems: Non-Safety Related & Safety Significant**
  - **RISC-3 Systems: Safety Related & Low Safety Significant**
  - **RISC-4 Systems: Non-Safety Related & Low Safety Significant**
- **This alternative includes 3 sub-alternatives based on level of defense-in-depth desired for RISC-3 systems.**
  - **Alternative 2a: Redundant safety-related train(s) would be removed from service**
  - **Alternative 2b: Redundant safety-related train(s) would be re-classified as non-safety-related**
  - **Alternative 2c: Operational flexibility would be provided for redundant train(S)**

## **Summary of Technical Approach and Evaluation Results**

### **Alternative 2 (Cont'd):**

- Risk-informed requirements would be established for each risk category .
- Performance monitoring of system reliability would be required.
- Potential plant changes proposed under Alternative 2 must also satisfy RG 1.174 guidelines.
- This alternative promotes coherence with other risk-informed regulatory initiatives; e.g., 10CFR50.69, 10CFR50.46, etc.
- Implementation of this alternative is expected to require significant effort by NRC and industry.

## **Summary of Technical Approach and Evaluation Results**

### **Alternative 3:**

- This alternative would generalize SFC by applying a combination of:
  - Quantitative top-level risk targets (CDF and LERF)
  - Lower-level functional reliability targets commensurate with challenge frequency (e.g., post-trip decay heat removal function)
  - Requirements (targets) on redundancy and diversity
- This alternative would allow Licensees to determine which plant features to credit to meet targets.
  - Regulatory attention would be on plant-specific performance weakness relative to established targets.
- Extra licensee and regulatory attention would be directed to areas where plant redundancy and diversity do not meet targets.

## **Summary of Technical Approach and Evaluation Results**

### **Alternative 3 (Cont'd):**

- Performance monitoring would be required to determine whether performance targets are met, per regulatory guidance such as NUREG/BR-0303, "Guidance for Performance-Based regulation."
  - This applies to all 3 alternatives.
- This alternative promotes coherence with other risk-informed regulatory initiatives, such as Reactor Oversight Process.
- Implementation of this alternative is expected to require significant effort by NRC and industry.

## **Summary of Technical Approach and Evaluation Results**

### **Conclusions:**

- **This work has identified and evaluated a range of risk-informed alternatives to current Single Failure Criterion.**
- **Additional evaluation and stakeholder involvement are necessary to assess practicality of implementing these alternatives**
  - **Interactions with stakeholders could result in identification of other viable alternatives.**
- **At this time, the staff does not recommend one alternative over another until follow-up activities are completed.**

## **Broader Change to Single Failure Criterion**

### **Planned Follow-up Activities:**

- In response to a May 9, 2005 SRM, the staff will develop a formal program plan to make risk-informed and performance-based revision to 10 CFR Part 50.
  - The staff plans to continue follow-up activities and will include them in this formal program plan
  - This approach ensures that any changes to SFC are evaluated in a broader context with other risk-informed changes to 10 CFR Part 50.
- Planned follow-up activities include additional evaluation of implementation issues and additional stakeholder involvement.

## **Summary of NRR General Comments**

- **NRR has provided general and specific comments on the draft report that must be considered before the report becomes final. RES is working to resolve these comments as practicable. General comments from NRR are summarized below.**
- **It may be more appropriate to postpone further effort and include it in the “formal program plan” discussed in May 9, 2005 SRM to make risk-inform and performance-based revisions to 10 CFR Part 50.**
- **Overly broad replacement of SFC for currently licensed plants is not prudent. Efforts to risk-inform SFC need to proceed cautiously and systematically, with clear understanding of potential safety and resource impact. Therefore, the report should focus more on pros and cons of broadening the relaxation of SFC versus not doing so.**
- **When the report is forwarded to the Commission, it should be made clear that it may be too early to recommend a specific alternative, and that outstanding technical issues exist which need to be resolved.**



### **Summary of NRR General Comments (Cont'd)**

- **The report states that SFC is proxy for reliability. Other benefits of SFC include avoiding excessive reliance on a particular element of plant safety, maintaining DBA mitigating capability during maintenance. These other benefits need to be addressed more directly in the alternatives.**

## **Broader Change to Single Failure Criterion**

### **Schedule:**

- Draft technical report was completed in February 2005
- Draft technical report was issued for inter-office review/comment in March 2005 and comments were received in May 2005.
- ACRS briefing in June 2005
- Receive ACRS feedback via a letter by June 30, 2005
- Issue a Commission paper (with technical report) by July 29, 2005

# Evaluation of Broader Change to the Single Failure Criterion

SFC Alternative Examples

# Alternative 1

## Example Description

- Illustrates potential for removal from design-basis an operationally-limiting, low frequency DBA sequence that includes an initiating event with a single failure

# Alternative 1 Example

## Key Features & Application

- Simplified containment event tree constructed for a double-ended MSLB in a PWR
- Limiting containment pressure event sequence: MSLB at low power with SFC = loss of DC bus
- Estimates for the IE frequency, low power probability and loss of DC probability, were obtained from typical PWR data

# Alternative 1 Example Results

- Limiting DBA event sequence has frequency of  $5E-10$  /yr. Containment pressure for this event sequence is 41.85 psig (design pressure 42 psig)
- If all single failure sequences were removed from the MLSB analysis on the basis of low frequency, peak predicted containment pressure would be in the range 32-36 psig, therefore larger margins predicted
- Illustrates instance where low frequency event sequence, including SFC, may limit plant operations. Alternative 1 could provide more operational or performance flexibility

# Alternative 2 Example Description

- Illustrates:
  - Potential for relaxation of SFC requirements for non-safety-significant, safety-related systems (RISC 3)
  - Enhancement of safety by now requiring monitoring of safety-significant, non-safety-related systems (RISC 2)

# Alternative 2 Example

## Key Features & Application

- BWR/4 PRA SPAR model plus 50.69 safety classifications used to classify all plant systems
- Use RAW importance measure to identify safety-related/low safety-significant systems and non-safety-related/safety significant systems
- 3 risk-informed sub-alternatives for relaxation of the SFC requirements are applied, including potential removal of redundancy requirement for low safety-significant systems. The impact on  $\Delta CDF$  was evaluated.



# Alternative 2 Example Results

- Four systems categorized as safety-related and low-safety-significant (RISC-3): Emergency Cooling Water, Standby Liquid Control, Core Spray, Reactor Building and Closed Cooling Water
- Bounding evaluation reduced all 4 RISC-3 systems to single train;  $\Delta\text{CDF} = 1.2\text{E-}5$  /yr
- 3 RISC-3 systems reduced to single train (SLC, CS, RBCCW)  $\Delta\text{CDF} = 4.1\text{E-}7$  /yr
- 2 non-safety related, safety-significant (RISC-2) systems (PCS, TBCCW) would require monitoring of reliability
- Illustrates potential for relaxing SFC requirements with small impact on plant risk and for increased safety as result of RISC-2 monitoring

# Alternative 3 Example Description

- Illustrates
  - use of graded redundancy requirements based upon initiating event category
  - Guidance on diversity, and
  - Supplementation of SFC with top-level risk guidelines and safety function reliability targets

# Alternative 3

## Key Features & Application

- PWR PRA SPAR model
- Loss of offsite power initiating event (.03/yr)
- Decay heat removal safety function
- Based upon assignment of IE category “frequent” ( $>1\text{E}-2/\text{yr}$ )
  - A double-failure requirement specified for DHR
  - DHR functional unreliability target specified  $1\text{E}-4$
  - Overall plant CDF target specified  $1\text{E}-4/\text{yr}$
- Demonstrates how different combinations of DHR systems may be credited to satisfy the targets

# Alternative 3 Example Results

- CDF (total, not just LOOP contribution) and DHR function unreliability computed for several combinations of DHR systems
- {EFW only} satisfies SFC, but none of the new targets
- {EFW + any other train} satisfies all targets
- {EFW + all other trains} provides increased flexibility
- Illustrates how plant system combinations may be used to address CDF and Initiator-category-specific targets on redundancy, diversity and functional reliability