

(5) Additional Conditions

The Additional Conditions contained in Appendix C as revised through Amendment No. 211 are hereby incorporated into this license. Calvert Cliffs Nuclear Power Plant, Inc., shall operate the facility in accordance with the Additional Conditions.

(6) Secondary Water Chemistry Monitoring Program

The Calvert Cliffs Nuclear Power Plant, Inc. shall implement a secondary water chemistry monitoring program to inhibit steam generator tube degradation. This program shall include:

- a. Identification of a sampling schedule for the critical parameters and control points for these parameters;
- b. Identification of the procedures used to quantify parameters that are critical to control points;;
- c. Identification of process sampling points;
- d. Procedure for recording and management of data;
- e. Procedures defining corrective actions for off control point chemistry conditions; and
- f. A procedure identifying the authority responsible for the interpretation of the data and the sequence and timing of administrative events required to initiate corrective action.

D. The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification, and safeguards contingency plans, including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans, which contain Safeguards Information protected under 10 CFR 73.21, is entitled: "Calvert Cliffs Nuclear Power Plant Security Plan, Training and Qualification Plan, and Safeguards Contingency Plan, Revision 0" submitted by letter dated October 12, 2004, as supplemented by letter dated October 21, 2004.

E. The Calvert Cliffs Nuclear Power Plant, Inc. shall implement and maintain in effect all provisions of the approved fire protection program as described in the Updated Final Safety Analysis Report for the facility and as approved in the SER dated September 14, 1979, and Supplements dated October 2, 1980; March 18, 1982; and September 27, 1982; and Exemptions dated August 16, 1982; April 21, 1983; March 15, 1984; August 22, 1990; and April 7, 1999 subject to the following provision: The Calvert Cliffs Nuclear Power Plant, Inc. may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

- c. Identification of process sampling points;
 - d. Procedure for recording and management of data;
 - e. Procedures defining corrective actions for off control point chemistry conditions; and
 - f. A procedure identifying the authority responsible for the interpretation of the data and the sequence and timing of administrative events required to initiate corrective action.
- D. The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification, and safeguards contingency plans, including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans, which contain Safeguards Information protected under 10 CFR 73.21, is entitled: "Calvert Cliffs Nuclear Power Plant Security Plan, Training and Qualification Plan, and Safeguards Contingency Plan, Revision 0" submitted by letter dated October 12, 2004, as supplemented by the letter dated October 21, 2004.
- E. The licensee shall implement and maintain in effect all provisions of the approved fire protection program as described in the Updated Final Safety Analysis Report for the facility and as approved in the SER dated September 14, 1979 and Supplements dated October 2, 1980; March 18, 1982; and September 27, 1982; and Exemptions dated August 16, 1982; April 21, 1983; March 15, 1984; August 22, 1990; and April 7, 1999 subject to the following provision: The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.
- F. At the time of the next scheduled update to the FSAR required pursuant to 10 CFR 50.71(e)(4) following the issuance of this renewed license, the licensee shall update the FSAR to include the FSAR supplement submitted pursuant to 10 CFR 54.21(d), as amended and supplemented by the program descriptions in Appendix E to the Safety Evaluation Report, NUREG-1705. Until that FSAR update is complete, the licensee may make changes to the programs described in Appendix E without prior Commission approval, provided that the licensee evaluates each such change pursuant to the criteria set forth in 10 CFR 50.59 and otherwise complies with the requirements in that section.
- G. Any future actions listed in Appendix E to the Safety Evaluation Report, NUREG-1705, shall be included in the FSAR. The licensee shall complete these actions by July 31, 2014, except for the volumetric inspections of the control element drive mechanisms, which must be completed no later than 2029 for Unit 1 (Appendix E, Item 65).