

GL 97-02

June 9, 2005
2130-05-20109

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555 - 0001

Oyster Creek Generating Station
Facility Operating License No. DPR-16
NRC Docket No. 50-219

Subject: Monthly Operating Report - May 2005

Enclosed is the May 2005 Monthly Operating Report for Oyster Creek Generating Station. The content and format of information submitted in this report is in accordance with the guidance provided by Generic Letter 97-02.

If any further information or assistance is needed, please contact David Fawcett at 609-971-4284.

Sincerely,



C. N. Swenson
Vice President, Oyster Creek Generating Station

CNS/DIF
Enclosure

cc: S. J. Collins, Administrator, USNRC Region I
P. S. Tam, USNRC Senior Project Manager, Oyster Creek
R. J. Summers, USNRC Senior Resident Inspector, Oyster Creek
File No. 05002

IE24

OPERATING DATA REPORT

DOCKET NO. 50-219
UNIT NAME Oyster Creek 1
DATE June 07, 2005
COMPLETED BY Roger B. Gayley
TELEPHONE (609) 971-4406

REPORTING PERIOD: May 2005

1. Design Electrical Rating	<u>650.00</u>			
2. Maximum Dependable Capacity (MWe-Net)	<u>619.00</u>			
	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>	
3. Number of Hours the Reactor was Critical	<u>744.00</u>	<u>3,623.00</u>	<u>230,102.50</u>	
4. Number of Hours Generator On-line	<u>744.00</u>	<u>3,623.00</u>	<u>225,793.45</u>	
5. Reserve Shutdown Hours	<u>0.00</u>	<u>0.00</u>	<u>918.20</u>	
6. Net Electrical Energy Generated (MWHrs)	<u>463,245.00</u>	<u>2,273,457.00</u>	<u>129,515,181.0</u>	

UNIT SHUTDOWNS

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason 1	Method of Shutting Down 2	Cause & Corrective Action Comments
-----	------	-----------------------------------	---------------------	----------	---------------------------------	---------------------------------------

SUMMARY: During May Oyster Creek generated 463,245 net MWh electric, which was 100.6% of its MDC

1

Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training & License Examination
- F Administration
- G Operational Error (Explain)
- H Other (Explain)

2

Method:

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)