

**From:** "Knorr, Jim" <Jim.Knorr@nmcco.com>  
**To:** "Stacey Imboden (E-mail)" <sxf@nrc.gov>, <rlp3@nrc.gov>  
**Date:** 6/14/05 8:12AM  
**Subject:** PBNP Cost of Pump trip on Low RWST level.

Stacey and Bob: The cost of installing a pump trip on low RWST level at Point Beach would approach \$1M. Following are some details on the difficulty of such a modification.

- \* PBNP would need to add a third channel of level instruments to provide for the required 2/3 logic
- \* existing cables would need to be re-run and separated to avoid certain fire-vulnerable areas
- \* a license amendment could be needed to add the new trip to SI and/or RH pumps - at a minimum, the 50.59 evaluation would be difficult due to the increase in risk.

If you have any further questions do not hesitate to call.

James E. Knorr  
License Renewal Project  
Office 920-755-6863  
Fax 920-755-6349  
Pager - 800.225.9372 #5149  
jim.knorr@nmcco.com

**Mail Envelope Properties** (42AEC9B1.F2E : 11 : 36654)

**Subject:** PBNP Cost of Pump trip on Low RWST level.  
**Creation Date:** 6/14/05 8:11AM  
**From:** "Knorr, Jim" <Jim.Knorr@nmcco.com>

**Created By:** Jim.Knorr@nmcco.com

**Recipients**

nrc.gov  
TWGWPO01.HQGWDO01  
RLP3 (Robert Palla)

nrc.gov  
owf4\_po.OWFN\_DO  
SXF (Stacey Imboden)

**Post Office**  
TWGWPO01.HQGWDO01  
owf4\_po.OWFN\_DO

**Route**  
nrc.gov  
nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	773	06/14/05 08:11AM
Mime.822	1679	

**Options**

**Expiration Date:** None  
**Priority:** Standard  
**Reply Requested:** No  
**Return Notification:** None

**Concealed Subject:** No  
**Security:** Standard