

Richard Anderson
Vice President-Nuclear

440-280-5579
Fax: 440-280-8029

June 15, 2005
PY-CEI/NRR-2887L

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Perry Nuclear Power Plant
Docket No. 50-440
License No. NPF-58
Monthly Operating Report

Ladies and Gentlemen:

Attached is the May 2005 Monthly Operating Report for Perry Unit 1. Page 1 is the Operating Data Report and page 2 is the Unit Shutdowns Report. This report is submitted in accordance with Technical Specification 5.6.4 and Generic Letter 97-02, "Revised Contents of the Monthly Operating Report."

If you have questions or require additional information, please contact Ms. Toni Phelps at (440) 280-7660.

Very truly yours,



Attachment

cc: NRC Region III Administrator
NRC Project Manager
NRC Resident Inspector

IE24

OPERATING DATA REPORT

UNIT: Perry
DATE: 6/8/05

1. Docket: 50-440
2. Unit Name: Perry Nuclear Power Plant
3. Reporting Period May 2005
4. Utility Contact: T. Phelps
5. Telephone: 440-280-7660
6. Design Electrical Rating (Net MWe): 1260
7. Maximum Dependable Capacity (Net MWe): 1235

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
8. Hours Reactor was Critical	<u>678.7</u>	<u>1,331.9</u>	<u>122,001.3</u>
9. Hours Generator On-Line	<u>602.3</u>	<u>1,226.5</u>	<u>119,117.8</u>
10. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
11. Net Electrical Energy (MWeH)	<u>640,649.0</u>	<u>1,311,282.0</u>	<u>136,667,039.0</u>

* Note: The Yr-to-Date number for #9. Hours Generator On-Line for the month of February contained a typographical error. The number was 624.4 and it should have been 624.2. This number was carried through on the March and April report as 624.4. This month, the Yr-to-Date total is corrected using the 624.2 total and adding 602.3 equals 1,226.5.

UNIT SHUTDOWNS REPORT MONTH – MAY 2005

DOCKET NO: 50-440
 NAME: Perry Nuclear Power Plant
 DATE: 6/8/05
 CONTACT: T. Phelps
 TELEPHONE: (440) 280-7660

No.	Date	Type 1	Duration Hours	Reason 2	Method 3	Cause and Corrective Action to Prevent Recurrence
05-02	2/22/05	S	1,772.7	C	4	The plant entered refuel outage #10 on February 22, 2005 @0001. The plant completed Refuel outage #10 at 2143 on 5/6/05.

SUMMARY: The Perry Nuclear Power plant commenced refuel outage #10 on 2/22/05. The outage ended on 5/6/05 at 2143. The plant commenced startup activities at that time and Continued rampup until 5/13/05 at 23:00 when 100% power was achieved. The plant remained on line through month's end.

1. TYPE:

F: Forced
 S: Scheduled

2. REASON:

A - Equipment Failure (explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory
 E - Operating Training &
 License Examination
 F - Administrative
 G - Operational Error (explain)
 H - Other (explain)

3. METHOD:

1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continuation
 5 - Other