



**FPL Energy**  
**Seabrook Station**

FPL Energy Seabrook Station  
P.O. Box 300  
Seabrook, NH 03874  
(603) 773-7000

JUN 14 2005

Docket No. 50-443  
SBK-L-05131

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555-0001

**Seabrook Station**  
**May 2005 Monthly Operating Report**

Enclosed please find Monthly Operating Report 05-05. This report addresses the operating and shutdown experience relating to Seabrook Station Unit 1 for the month of May, 2005 and is submitted in accordance with the requirements of Seabrook Station Technical Specification 6.8.1.5.

Should you require further information regarding this matter, please contact Mr. Paul V. Gurney, Reactor Engineering Supervisor, at (603) 773-7776.

Very truly yours,

FPL Energy Seabrook, LLC

Mark E. Warner  
Site Vice President

*For*

cc: S. J. Collins, NRC Region I Administrator  
V. Nerses, NRC Project Manager, Project Directorate I-2  
G.T. Dentel, NRC Senior Resident Inspector

*IE24*

## OPERATING DATA REPORT

**DOCKET NO.** 50-443  
**UNIT NAME** Seabrook 1  
**DATE** June 08, 2005  
**COMPLETED BY** Peter Nardone  
**TELEPHONE** 603 773-7074

**REPORTING PERIOD:** May 2005

1. Design Electrical Rating	<u>1,220.00</u>			
2. Maximum Dependable Capacity (MWe-Net)	<u>1,218.00</u>			
	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>	
3. Number of Hours the Reactor was Critical	<u>726.55</u>	<u>2,876.88</u>	<u>114,490.68</u>	
4. Number of Hours Generator On-line	<u>682.32</u>	<u>2,791.87</u>	<u>111,490.16</u>	
5. Reserve Shutdown Hours	<u>0.00</u>	<u>0.00</u>	<u>0.00</u>	
6. Net Electrical Energy Generated (MWHrs)	<u>768,634.64</u>	<u>3,188,607.14</u>	<u>125,819,903.91</u>	

### UNIT SHUTDOWNS

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason 1	Method of Shutting Down 2	Cause & Corrective Action Comments
05-02	04/01/2005	S	33.55	C	4	Scheduled Refueling Outage
05-03	05/02/2005	S	21.47	B	1	Turbine off-line for overspeed testing and balancing
05-04	05/04/2005	F	6.67	A	5	Turbine offline to repair steam leak on Main Steam Drain line from Turbine Control Valve # 3. Reactor power held at 16%RTP.

**SUMMARY:** The Unit returned to full power operation following Refueling Outage 10. It is now operating at a new uprated 100% RTP of 3587 MW.

1

**Reason:**

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training & License Examination
- F Administration
- G Operational Error (Explain)
- H Other (Explain)

2

**Method:**

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)