



RONALD A JONES
Vice President
Oconee Nuclear Site

Duke Power
ON01VP / 7800 Rochester Hwy.
Seneca, SC 29672

864 885 3158
864 885 3564 fax

June 13, 2005

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Subject: Duke Energy Corporation
Oconee Nuclear Station, Unit 1
Docket No. 50-269
Steam Generator Inservice Inspection 1EOC22
Steam Generator Tube Plugging and Repair 30-day Report

The Oconee Nuclear Station Technical Specification (TS) 5.5.10 establishes the Steam Generator (SG) tube surveillance program requirements for SGs. TS 5.6.8, a, requires reporting of the number of Steam Generator (SG) requiring plugging or repairs.

Both of the original Oconee Unit 1 SGs were replaced with new SGs in 1EOC21 (2003).

During 1EOC22, the tables below identify the number of tubes removed from service by plugging. There were no tubes repaired in either steam generator.

<u>Steam Generator</u> <u>Stabilized</u>	<u>Number of Tubes Plugged and</u>
---	------------------------------------

A	30 - for ECT indications
B	18 - for ECT indications

Please address any questions to Randall P. Todd at (864) 885-3418.

Very Truly Yours,

R. A. Jones,
Site Vice President,
Oconee Nuclear Station

A047

US Nuclear Regulatory Commission
June 13, 2005

Page 2

cc: W. D. Travers
L. N. Olshan
M. C. Shannon
S. E. Peters