

June 23, 2005

Mark A. Peifer
Site Vice President
Duane Arnold Energy Center
Nuclear Management Company, LLC
3277 DAEC Road
Palo, IA 52324-0351

SUBJECT: DUANE ARNOLD ENERGY CENTER - ISSUANCE OF AMENDMENT RE:
REVISED ACTION FOR SCRAM DISCHARGE VOLUME VENT AND DRAIN
VALVES (TAC NO. MC5136)

Dear Mr. Peifer:

The U.S. Nuclear Regulatory Commission has issued the enclosed Amendment No. 259 to Facility Operating License No. DPR-49 for the Duane Arnold Energy Center. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated October 29, 2004.

The amendment revises TS 3.1.8, "Scram Discharge Volume (SDV) Vent and Drain Valves," for the condition of having one or more SDV vent or drain lines with one valve inoperable. A notice of availability for this TS improvement using the consolidated line item improvement process was published in the *Federal Register* on April 15, 2003 (68 FR 18294).

A copy of the Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

/RA/

Deirdre W. Spaulding, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-331

Enclosures: 1. Amendment No. 259 to
License No. DPR-49
2. Safety Evaluation

cc w/encls: See next page

June 23, 2005

Mark A. Peifer
Site Vice President
Duane Arnold Energy Center
Nuclear Management Company, LLC
3277 DAEC Road
Palo, IA 52324-0351

SUBJECT: DUANE ARNOLD ENERGY CENTER - ISSUANCE OF AMENDMENT RE:
REVISED ACTION FOR SCRAM DISCHARGE VOLUME VENT AND DRAIN
VALVES (TAC NO. MC5136)

Dear Mr. Peifer:

The U.S. Nuclear Regulatory Commission has issued the enclosed Amendment No. 259 to Facility Operating License No. DPR-49 for the Duane Arnold Energy Center. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated October 29, 2004.

The amendment revises TS 3.1.8, "Scram Discharge Volume (SDV) Vent and Drain Valves," for the condition of having one or more SDV vent or drain lines with one valve inoperable. A notice of availability for this TS improvement using the consolidated line item improvement process was published in the *Federal Register* on April 15, 2003 (68 FR 18294).

A copy of the Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

/RA/

Deirdre W. Spaulding, Project Manager, Section 1
Project Directorate III
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-331

Enclosures: 1. Amendment No. 259 to
License No. DPR-49
2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION:

GHill (2)	DSpaulding
PUBLIC	GGrant, RIII
PD 3-1 r/f	TBoyce (DRIP/IROB)
ACRS	OGC
THarris	

ADAMS ACCESSION NUMBER: (Package) ML051750031

ADAMS ACCESSION NUMBER: (TS) ML051750343

ADAMS ACCESSION NUMBER: ML051730479

OFFICE	CLIIP LPM	PM:PD3-1	LA:PD3-1	SC:PD3-1
NAME	WReckley	DSpaulding	THarris	LRaghavan
DATE	6/17/05	6/23/05	6/23/05	6/23/05

OFFICIAL RECORD COPY

Duane Arnold Energy Center

cc:

Mr. John Paul Cowan
Executive Vice President &
Chief Nuclear Officer
Nuclear Management Company, LLC
700 First Street
Hudson, MI 54016

Chairman, Linn County
Board of Supervisors
930 1st Street SW
Cedar Rapids, IA 52404

Craig G. Anderson
Senior Vice President, Group Operations
700 First Street
Hudson, WI 54016

John Bjorseth
Plant Manager
Duane Arnold Energy Center
3277 DAEC Road
Palo, IA 52324

Steven R. Catron
Manager, Regulatory Affairs
Duane Arnold Energy Center
3277 DAEC Road
Palo, IA 52324

U. S. Nuclear Regulatory Commission
Resident Inspector's Office
Rural Route #1
Palo, IA 52324

Regional Administrator
U. S. NRC, Region III
801 Warrenville Road
Lisle, IL 60532-4531

Jonathan Rogoff
Vice President, Counsel & Secretary
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Bruce Lacy
Nuclear Asset Manager
Alliant Energy/Interstate Power
and Light Company
3277 DAEC Road
Palo, IA 52324

Daniel McGhee
Utilities Division
Iowa Department of Commerce
Lucas Office Buildings, 5th floor
Des Moines, IA 50319

NUCLEAR MANAGEMENT COMPANY, LLC

DOCKET NO. 50-331

DUANE ARNOLD ENERGY CENTER

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 259

License No. DPR-49

1. The U.S. Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Nuclear Management Company, LLC (the licensee) dated October 29, 2004, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-49 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 259, are hereby incorporated in the license. NMC shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 90 days of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

L. Raghavan, Chief, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: June 23, 2005

ATTACHMENT TO LICENSE AMENDMENT NO. 259

FACILITY OPERATING LICENSE NO. DPR-49

DOCKET NO. 50-331

Replace the following page of the Appendix A Technical Specifications with the attached revised page. The revised page is identified by amendment number and contains marginal lines indicating the areas of change.

Remove

3.1-25

Insert

3.1-25

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 259 TO FACILITY OPERATING LICENSE NO. DPR-49
NUCLEAR MANAGEMENT COMPANY, LLC
DUANE ARNOLD ENERGY CENTER
DOCKET NO. 50-331

1.0 INTRODUCTION

By application dated October 29, 2004 (ADAMS Accession No. ML043140302), the Nuclear Management Company, LLC (the licensee), requested changes to the Technical Specifications (TSs) for the Duane Arnold Energy Center. The requested changes would revise the required action within TS 3.1.8, "Scram Discharge Volume (SDV) Vent and Drain Valves," for the condition of having one or more SDV vent or drain lines with one valve inoperable. These changes are based on TSs Task Force (TSTF) change traveler TSTF-404 (Revision 0) that has been approved generically for the Boiling-Water Reactor/4 (BWR) Standard Technical Specifications, NUREG-1433. A notice announcing the availability of this proposed TS change using the consolidated line item improvement process (CLIIP) was published in the *Federal Register* on April 15, 2003 (68 FR 18294).

2.0 REGULATORY EVALUATION

U.S. Nuclear Regulatory Commission (NRC) regulations and review standards such as Appendix A, "General Design Criteria for Nuclear Power Plants," to Title 10 of the *Code of Federal Regulations* (10 CFR), Part 50, include specific requirements for reactor protection and reactivity control systems. The reactor protection systems for BWRs use a hydraulic system to insert control rods into the reactor core. During an actuation of the reactor protection system (a scram), water is exhausted from the control rod drive mechanisms to the SDVs. Proper maintenance and operation of the SDVs in terms of instrumentation and limiting water volumes are essential for assuring the reliability of the reactor protection system (see NRC Bulletin 80-17, "Failure of Control Rods to Insert During a Scram at a BWR," related Orders to specific facilities, and information provided in plant final safety analysis reports and TS Bases). Maintaining the SDVs to ensure that accumulated water does not hamper or slow the insertion of control rods requires vent and drain valves. The vent and drain valves isolate during a scram to limit the amount of coolant discharged so that adequate core cooling is maintained and offsite doses remain within regulatory limits.

Specific regulatory requirements for SDV vent and drain valves are defined in TS 3.1.8. The existing Limiting Condition for Operation 3.1.8, requires that each SDV vent and drain valve be operable. The operability of all SDV vent and drain valves ensures that the SDV vent and drain valves will close during a scram to contain reactor water discharged to the SDV piping. Since

the vent and drain lines are provided with two valves in series, the single failure of one valve in the open position will not impair the isolation function of the system. Additionally, the valves are required to open on scram reset and during plant operation to control the amount of water accumulating in the SDV. If one or more SDV vent and drain lines have a single valve that is inoperable, the existing required action is to restore the valve(s) to operable status within 7 days. If an inoperable valve is not restored to operable status, a plant shutdown to MODE 3 is required within 12 hours.

If one or more SDV vent or drain lines have both valves inoperable, the associated line must be isolated within 8 hours. In this condition, the plant is allowed to operate indefinitely. A note associated with the required action clarifies that the valves may be opened under administrative controls to allow draining of the SDV. The existing SDV vent and drain valve required actions are inconsistent in that, although the operational and safety concerns are similar for having one or both valves in a line being inoperable, the actions for a single inoperable valve do not allow for the isolation of the line and administrative controls to support the draining of the SDV.

The proposed change would revise the required actions to be more consistent with the safety significance of one inoperable valve in a SDV line versus two inoperable valves in an SDV line.

3.0 TECHNICAL EVALUATION

The proposed changes to TS 3.1.8 are:

Required Action A.1 is revised from restoring the single inoperable SDV vent and drain valve in one or more SDV vent and drain lines to operable status to isolating the associated line.

The Note to Required Action B.1, which allows an isolated line to be unisolated under administrative controls for the purpose of draining and venting the SDV, is moved to a note that applies to both Conditions A (single inoperable valve) and B (both valves inoperable).

With one SDV vent or drain valve inoperable in one or more lines, the isolation function would be maintained since the redundant valve in the affected line would perform its safety function of isolating the SDV. The current ACTION statement allows 7 days to repair the inoperable valve; the proposed change is to allow for the isolation of the affected line and continue operation. If the affected line is not isolated within the 7-day time period (or the inoperable valve is not restored), the licensee would then be required to proceed to MODE 3 in the next 12 hours. Maintaining the 7-day Completion Time (CT) is acceptable because of the low probability of the concurrent events of a scram within the 7 days of the CT and a failure of the redundant valve(s). Alternately, if the inoperable valve was initially closed, there would be ample time and warning available to drain the SDV before an automatic scram would occur due to SDV high level.

The allowance to administratively open a line that is isolated to comply with the actions (to permit draining and venting the SDV) is allowed by the existing Required Action B.1. This allowance is being moved to apply to all ACTIONS based on the change proposed to Action A. This would allow any accumulated water in the line to be drained, to preclude a reactor scram on SDV high level. A reactor scram is initiated if the SDV water level in the instrument volume

exceeds a specified setpoint. The setpoint is chosen so that all control rods are inserted before the SDV has insufficient volume to accept a full scram. Regarding the isolation of the SDV, the remaining operable SDV vent and drain valve(s) would close automatically on a scram signal to isolate the lines. Or, if both valves in a line were inoperable (and opened under this provision), the reactor coolant release could be terminated by resetting the scram from the control room, or by manually closing the valves. Resetting the scram automatically closes the scram outlet valves, isolating the control rod drive discharge path to the SDV.

Based on the low probability of an event occurring during the defined CT associated with this condition, the subsequent isolation of the affected lines, and the ability to open and drain the lines before an automatic scram due to SDV high water level, the proposed change maintains the necessary safety features and is therefore acceptable.

The licensee stated that associated changes to the Bases Section for TS 3.1.8 will be made in accordance with the Bases Control Program defined by TS 5.5.11. The NRC staff agrees that the TS Bases Control Program is the appropriate process for updating the affected TS Bases pages.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Iowa State official was notified of the proposed issuance of the amendment. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATIONS

This amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluent that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration and there has been no public comment on such finding (70 FR 5247). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

6.0 CONCLUSION

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: W. Reckley

Date: June 23, 2005