Westinghouse Non-Proprietary Class 3

WCAP-16305-NP Revision 0

August 2004

V. C. Summer Heatup and Cooldown Limit Curves for Normal Operation



WCAP-16305-NP Revision 0

V. C. Summer Heatup and Cooldown Limit Curves for Normal Operation

C. M. Burton

AUGUST 2004

urain Approved:

John Ghergurovich, Manager Reactor Component Design & Analysis

Westinghouse Electric Company LLC Energy Systems P. O. Box 355 Pittsburgh, PA 15230-0355

©2004 Westinghouse Electric Company LLC All Rights Reserved

PREFACE

This report has been technically reviewed and verified by:

T. J. Laubham

RECORD OF REVISION



TABLE OF CONTENTS

| LIST C | OF TABLES | iv |
|--------|---|-----|
| LIST C | PF FIGURES | vi |
| EXECI | JTIVE SUMMARY | /ii |
| 1. | INTRODUCTION & PURPOSE | 1 |
| 2. | FRACTURE TOUGHNESS PROPERTIES | 2 |
| 3. | CRITERIA FOR ALLOWABLE PRESSURE-TEMPERATURE RELATIONSHIPS | 7 |
| 4. | CALCULATION OF ADJUSTED REFERENCE TEMPERATURE | 2 |
| 5. | HEATUP AND COOLDOWN PRESSURE-TEMPERATURE LIMIT CURVES2 | :0 |
| 6. | REFERENCES | 0 |
| APPEN | NDIX A: THERMAL STRESS INTENSITY FACTORS | 51 |

III

;

LIST OF TABLES

| Table 2 Calculated Integrated Neutron Exposure of the Surveillance Capsules @ V. C. Summer | Table 1 | Summary of the Best Estimate Cu and Ni Weight Percent and Initial RT _{NDT} Values for the V. C. Summer Reactor Vessel Materials |
|---|----------|---|
| Table 3 Calculation of Chemistry Factors using V. C. Summer Surveillance Capsule Data5 Table 4 Summary of the V. C. Summer Reactor Vessel Beltline Material Chemistry Factors 6 Table 5 Summary of the Peak Pressure Vessel Neutron Fluence Values at the Clad/Base Metal Interface (n/cm ² , E > 1.0 MeV) | Table 2 | Calculated Integrated Neutron Exposure of the Surveillance Capsules @ V. C. Summer4 |
| Table 4 Summary of the V. C. Summer Reactor Vessel Beltline Material Chemistry Factors 6 Table 5 Summary of the Peak Pressure Vessel Neutron Fluence Values at the Clad/Base Metal Interface (n/cm², E > 1.0 MeV) 13 Table 6 Summary of the Vessel Surface, 1/4T and 3/4T Fluence Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves 13 Table 7 Summary of the Vessel Surface, 1/4T and 3/4T Fluence Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves 14 Table 8 Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves 14 Table 9 Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves 15 Table 10 Calculation of the ART Values for the 1/4T Location @ 32 EFPY 16 Table 11 Calculation of the ART Values for the 3/4T Location @ 32 EFPY 17 Table 12 Calculation of the ART Values for the 3/4T Location @ 32 EFPY 18 Table 13 Calculation of the ART Values for the 3/4T Location @ 56 EFPY 19 Table 14 Summary of the Limiting ART Values Used in the Generation of the V. C. Summer Heatup/Cooldown Curves 19 Table 15 32 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors) 26 | Table 3 | Calculation of Chemistry Factors using V. C. Summer Surveillance Capsule Data5 |
| Table 5 Summary of the Peak Pressure Vessel Neutron Fluence Values at the Clad/Base Metal Interface (n/cm², E > 1.0 MeV) 13 Table 6 Summary of the Vessel Surface, 1/4T and 3/4T Fluence Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves 13 Table 7 Summary of the Vessel Surface, 1/4T and 3/4T Fluence Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves 14 Table 8 Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves 14 Table 9 Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves 15 Table 9 Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves 15 Table 10 Calculation of the ART Values for the 1/4T Location @ 32 EFPY 16 Table 11 Calculation of the ART Values for the 3/4T Location @ 32 EFPY 17 Table 12 Calculation of the ART Values for the 3/4T Location @ 56 EFPY 18 Table 13 Calculation of the ART Values for the 3/4T Location @ 56 EFPY 19 Table 14 Summary of the Limiting ART Values Used in the Generation of the V. C. Summer Heatup/Cooldown Curves 19 Table 15 32 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrument | Table 4 | Summary of the V. C. Summer Reactor Vessel Beltline Material Chemistry Factors |
| Table 6 Summary of the Vessel Surface, 1/4T and 3/4T Fluence Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves 13 Table 7 Summary of the Vessel Surface, 1/4T and 3/4T Fluence Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves 14 Table 8 Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves 14 Table 9 Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves 14 Table 9 Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves 15 Table 10 Calculation of the ART Values for the 1/4T Location @ 32 EFPY 16 Table 10 Calculation of the ART Values for the 3/4T Location @ 32 EFPY 17 Table 11 Calculation of the ART Values for the 1/4T Location @ 32 EFPY 18 Table 12 Calculation of the ART Values for the 3/4T Location @ 56 EFPY 19 Table 13 Calculation of the ART Values for the 3/4T Location @ 56 EFPY 19 Table 14 Summary of the Limiting ART Values Used in the Generation of the V. C. Summer Heatup/Cooldown Curves 19 Table 15 32 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors) 26 | Table 5 | Summary of the Peak Pressure Vessel Neutron Fluence Values at the Clad/Base Metal Interface (n/cm ² , E > 1.0 MeV)13 |
| Table 7 Summary of the Vessel Surface, 1/4T and 3/4T Fluence Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves 14 Table 8 Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves 14 Table 9 Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves 14 Table 9 Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves 15 Table 10 Calculation of the ART values for the 1/4T Location @ 32 EFPY 16 Table 11 Calculation of the ART Values for the 3/4T Location @ 32 EFPY 17 Table 12 Calculation of the ART Values for the 1/4T Location @ 56 EFPY 18 Table 13 Calculation of the ART Values for the 3/4T Location @ 56 EFPY 19 Table 14 Summary of the Limiting ART Values Used in the Generation of the V. C. 19 Table 15 32 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors) 26 Table 16 32 EFPY Cooldown Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors) 27 | Table 6 | Summary of the Vessel Surface, 1/4T and 3/4T Fluence Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves |
| Table 8Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves14Table 9Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves15Table 10Calculation of the ART Values for the 1/4T Location @ 32 EFPY16Table 11Calculation of the ART Values for the 3/4T Location @ 32 EFPY17Table 12Calculation of the ART Values for the 1/4T Location @ 32 EFPY17Table 12Calculation of the ART Values for the 1/4T Location @ 56 EFPY18Table 13Calculation of the ART Values for the 3/4T Location @ 56 EFPY19Table 14Summary of the Limiting ART Values Used in the Generation of the V. C. Summer Heatup/Cooldown Curves19Table 1532 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors)26Table 1632 EFPY Cooldown Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors)27 | Table 7 | Summary of the Vessel Surface, 1/4T and 3/4T Fluence Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves |
| Table 9Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves15Table 10Calculation of the ART Values for the 1/4T Location @ 32 EFPY16Table 11Calculation of the ART Values for the 3/4T Location @ 32 EFPY17Table 12Calculation of the ART Values for the 1/4T Location @ 56 EFPY18Table 13Calculation of the ART Values for the 3/4T Location @ 56 EFPY19Table 14Summary of the Limiting ART Values Used in the Generation of the V. C. Summer Heatup/Cooldown Curves19Table 1532 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors)26Table 1632 EFPY Cooldown Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors)27 | Table 8 | Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 32 EFPY Heatup/Cooldown Curves14 |
| Table 10Calculation of the ART Values for the 1/4T Location @ 32 EFPY | Table 9 | Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves |
| Table 11Calculation of the ART Values for the 3/4T Location @ 32 EFPY | Table 10 | Calculation of the ART Values for the 1/4T Location @ 32 EFPY16 |
| Table 12Calculation of the ART Values for the 1/4T Location @ 56 EFPY | Table 11 | Calculation of the ART Values for the 3/4T Location @ 32 EFPY |
| Table 13Calculation of the ART Values for the 3/4T Location @ 56 EFPY19Table 14Summary of the Limiting ART Values Used in the Generation of the V. C. Summer Heatup/Cooldown Curves19Table 1532 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors)26Table 1632 EFPY Cooldown Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors)27 | Table 12 | Calculation of the ART Values for the 1/4T Location @ 56 EFPY18 |
| Table 14Summary of the Limiting ART Values Used in the Generation of the V. C. Summer Heatup/Cooldown Curves19Table 1532 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors)26Table 1632 EFPY Cooldown Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors)27 | Table 13 | Calculation of the ART Values for the 3/4T Location @ 56 EFPY19 |
| Table 1532 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors)26Table 1632 EFPY Cooldown Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors)27 | Table 14 | Summary of the Limiting ART Values Used in the Generation of the V. C. Summer Heatup/Cooldown Curves19 |
| Table 16 32 EFPY Cooldown Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors) | Table 15 | 32 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors) |
| | Table 16 | 32 EFPY Cooldown Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors)27 |

.

iv

ł

LIST OF TABLES (Continued)

| Table 17 | 56 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors) | 28 |
|----------|--|----|
| Table 18 | 56 EFPY Cooldown Curve Data Points Using 1998 Appendix G Methodology (without Uncertainties for Instrumentation Errors) | 29 |

<u>v</u>

LIST OF FIGURES

| Figure 1 | V. C. Summer Reactor Coolant System Heatup Limitations (Heatup Rates of 50 and 100°F/hr) Applicable for 32 EFPY (Without Margins for Instrumentation Errors) Using 1998 Appendix G Methodology | .22 |
|----------|--|-----|
| Figure 2 | V. C. Summer Reactor Coolant System Cooldown Limitations (Cooldown Rates up to 100°F/hr) Applicable for 32 EFPY (Without Margins for Instrumentation Errors) Using 1998 Appendix G Methodology | .23 |
| Figure 3 | V. C. Summer Reactor Coolant System Heatup Limitations (Heatup Rates of 50 and 100°F/hr) Applicable for 56 EFPY (Without Margins for Instrumentation Errors) Using 1998 Appendix G Methodology | .24 |
| Figure 4 | V. C. Summer Reactor Coolant System Cooldown Limitations (Cooldown Rates up to 100°F/hr) Applicable for 56 EFPY (Without Margins for Instrumentation Errors) Using 1998 Appendix G Methodology | .25 |

vi

EXECUTIVE SUMMARY

This report provides the methodology and results of the generation of heatup and cooldown pressure temperature (PT) limit curves for normal operation of the V. C. Summer reactor vessel. The PT curves were generated based on the latest available reactor vessel information and updated calculated fluences. The new V. C. Summer heatup and cooldown pressure-temperature limit curves were generated using the "axial flaw" methodology of the 1998 ASME Code, Section XI through the 2000 Addenda^[6,4]. Included in this methodology, is the use of the K_{IC} stress intensity factors, which was formerly documented under ASME Code Case N-641^[6,3]. The material with the highest adjusted reference temperature (ART) was the Intermediate shell plate A9154-1. The PT limit curves were generated for 32 and 56 EFPY using heatup rates of 50 and 100°F/hr and cooldown rates of 0, 25, 50 and 100°F/hr. These curves can be found in Figures 1, 2, 3 and 4.

vii

1. INTRODUCTION & PURPOSE

Heatup and cooldown limit curves are calculated using the adjusted RT_{NDT} (reference nilductility temperature) corresponding to the limiting beltline region material of the reactor vessel. The adjusted RT_{NDT} of the limiting material in the core region of the reactor vessel is determined by using the unirradiated reactor vessel material fracture toughness properties, estimating the radiation-induced ΔRT_{NDT} , and adding a margin. The unirradiated RT_{NDT} is designated as the higher of either the drop weight nil-ductility transition temperature (NDTT) or the temperature at which the material exhibits at least 50 ft-lbs of impact energy and 35-mil lateral expansion (normal to the major working direction) minus 60°F.

 RT_{NDT} increases as the material is exposed to fast-neutron radiation. Therefore, to find the most limiting RT_{NDT} at any time period in the reactor's life, ΔRT_{NDT} due to the radiation exposure associated with that time period must be added to the unirradiated RT_{NDT} (IRT_{NDT}). The extent of the shift in RT_{NDT} is enhanced by certain chemical elements (such as copper and nickel) present in reactor vessel steels. The Nuclear Regulatory Commission (NRC) has published a method for predicting radiation embrittlement in Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials"^[6,1]. Regulatory Guide 1.99, Revision 2, is used for the calculation of Adjusted Reference Temperature (ART) values (IRT_{NDT} + ΔRT_{NDT} + margins for uncertainties) at the 1/4T and 3/4T locations, where T is the thickness of the vessel at the beltline region measured from the clad/base metal interface.

The heatup and cooldown curves documented in this report were generated using the most limiting ART values and the NRC approved methodology documented in WCAP-14040-NP-A, Revision 4^[6.2], "Methodology Used to Develop Cold Overpressure Mitigating System Setpoints and RCS Heatup and Cooldown Limit Curves".

The purpose of this report is to present the calculations and the development of the V. C. Summer heatup and cooldown curves for 32 and 56 EFPY. This report documents the calculated ART values and the development of the PT limit curves for normal operation. The PT curves herein were generated without margins for instrumentation errors. The PT curves include a hydrostatic leak test limit curve from 2485 psig to 2000 psig, along with the pressure-temperature limits for the vessel flange region per the requirements of 10 CFR Part 50, Appendix G^[6.5].

2. FRACTURE TOUGHNESS PROPERTIES

The fracture-toughness properties of the ferritic materials in the reactor coolant pressure boundary are determined in accordance with the NRC Standard Review Plan^[6,6]. The beltline material properties of the V. C. Summer reactor vessel are presented in Table 1.

Best estimate copper (Cu) and nickel (Ni) weight percent values used to calculate chemistry factors (CF) in accordance with Regulatory Guide 1.99, Revision 2, are provided in Table 1. Additionally, surveillance capsule data is available for five capsules (Capsules U, V, X, W and Z) already removed from the V. C. Summer reactor vessel. This surveillance capsule data was also used to calculate CF values per Position 2.1 of Regulatory Guide 1.99, Revision 2 in Table 3. These CF values are summarized in Table 4.

The Regulatory Guide 1.99, Revision 2 methodology used to develop the heatup and cooldown curves documented in this report is the same as that documented in WCAP-14040, Revision 4^[6.2].

TABLE 1

| Material Description | Cu (%) | Ni(%) | Initial RT _{NDT} ^(a) |
|---|--------|-------|--|
| Closure Head Flange 5297-V1 ^(b) | ` | | 10°F ^(b) |
| Vessel Flange 5301-V-1 | | | 0°F ^(b) |
| Intermediate Shell Plate A9154-1 | 0.10 | 0.51 | 30°F |
| Intermediate Shell Plate A9153-2 | 0.09 | 0.45 | -20°F |
| Lower Shell Plate C9923-1 | 0.08 | 0.41 | 10°F |
| Lower Shell Plate C9923-2 | 0.08 | 0.41 | 10°F |
| Intermediate Shell Longitudinal Weld Seams BC & BD | 0.05 | 0.91 | -44°F |
| Intermediate Shell Longitudinal Weld Seams BA & BB | 0.05 | 0.91 | -44°F |
| Intermediate to Lower Shell Plate Circumferential Weld Seam AB | 0.05 | 0.91 | -44°F |
| Surveillance Program Weld Metal | 0.04 | 0.95 | |

Summary of the Best Estimate Cu and Ni Weight Percent and Initial RT_{NDT} Values for the V. C. Summer Reactor Vessel Materials

(a) The initial RT_{NDT} values for the plates and welds are based on measured data per WCAP-12867^[6,7]

(b) In the past the closure head flange was reported as Heat A9231 with an IRT_{NDT} of -20°F. Based on a review of Westinghouse files, the correct data is Heat # 5297-V1 with an IRT_{NDT} of 10°F. Also, the vessel flange reported an IRT_{NDT} of 10°F., however, based on a review Westinghouse files, the correct IRT_{NDT} is 0°F.

The chemistry factors are calculated using Regulatory Guide 1.99 Revision 2, Positions 1.1 and 2.1. Position 1.1 uses the Tables from the Reg. Guide along with the best estimate copper and nickel weight percents. Position 2.1 uses the surveillance capsule data from all capsules withdrawn to date. The fluence values used to determine the CFs in Table 3 are the calculated fluence values at the surveillance capsule locations. Hence, the calculated fluence values were used for all cases. Included in Table 2 are the calculated fluence values for V. C. Summer. All capsule fluence values were determined using ENDF/B-VI cross-sections and followed the guidance in Regulatory Guide 1.190^[6.10].

It should be noted that in the calculation of chemistry factor in Table 3, the ratio was applied to account for chemistry differences between the vessel weld material and the surveillance weld material. As for temperature adjustments, the V. C. Summer data does not require any adjustments since it is being applied to its own plant.

TABLE 2

Calculated Integrated Neutron Exposure of the Surveillance Capsules @ V. C. Summer

| Capsule | Fluence ^(a) |
|---------|---|
| U | 6.77 x 10 ¹⁸ n/cm ² , (E > 1.0 MeV) |
| V | $1.56 \times 10^{19} \text{ n/cm}^2$, (E > 1.0 MeV) |
| X | 2.53 x 10 ¹⁹ n/cm ² , (E > 1.0 MeV) |
| w | 4.63 x 10 ¹⁹ n/cm ² , (E > 1.0 MeV) |
| Z | 6.54 x 10 ¹⁹ n/cm ² , (E > 1.0 MeV) |

(a) Per Capsule Z Report, WCAP-16298^[6.8]

:

TABLE 3

Calculation of Chemistry Factors using V. C. Summer Surveillance Capsule Data

| Material | Capsule | Capsule f ^(ə) | FF ^(b) | | FF*∆RT _{NDT} | FF ² | |
|--------------------|---|-----------------------------|-------------------|----------------------------|-----------------------|-----------------|--|
| Intermediate Shell | U | 0.677 | 0.891 | 36.1 | 32.2 | 0.793 | |
| Plate A9154-1 | v | 1.56 | 1.123 | 53.2 | 59.7 | 1.261 | |
| (Longitudinal) | x | 2.53 | 1.249 | 38.3 | 47.8 | 1.560 | |
| | w | 4.63 | 1.387 | 66.2 | 91.8 | 1.924 | |
| | z | 6.54 | 1.452 | 98.9 | 143.6 | 2.108 | |
| Intermediate Shell | U | 0.677 | 0.891 | 14.5 | 12.9 | 0.793 | |
| Plate A9154-1 | v | 1.56 | 1.123 | 32.1 | 36.0 | 1.261 | |
| (Transverse) | × | 2.53 | 1.249 | 26.7 | 33.3 | 1.560 | |
| | w | 4.63 | 1.387 | 57.8 | 80.2 | 1.924 | |
| | z | 6.54 | 1.452 | 87.0 | 126.3 | 2.108 | |
| | SUM: | | | | 663.8 | 15.292 | |
| | C | ÷ (15.292) = 43. | .4°F | | | | |
| Surveillance Weld | υ | 0.677 | 0.891 | 28.6 (22.7) ^(d) | 25.4 | 0.793 | |
| Material | v | 1.56 | 1.123 | 59.2 (47.0) ^(d) | 66.5 | 1.261 | |
| | × | 2.53 | 1.249 | 28.6 (22.7) ^(d) | 35.7 | 1.560 | |
| | w | 4.63 | 1.387 | 54.8 (43.5) ^(d) | 76.0 | 1.924 | |
| | Z | 6.54 | 1.452 | 82.2 (65.2) ^(d) | 119.3 | 2.108 | |
| | SUM: 323.0 7.646 | | | | | | |
| | $CF_{Surv. Weld} = \sum (FF * RT_{NDT}) + \sum (FF^2) = (323.0) + (7.646) = 42.2°F$ | | | | | | |

(a) f = fluence. See Table 2, [x 10¹⁹ n/cm², E > 1.0 MeV]

(b) FF = fluence factor = $f^{(0.28 - 0.1^{\circ} \log f)}$

(c) ΔRT_{NDT} values are the measured 30 ft-lb shift values taken from Capsule Z Report, WCAP-16298^[6,8], Appendix B [°F]

(d) The Surveillance Weld ΔRT_{NDT} values have been adjusted by a ratio of 1.26, Pre-adjusted values in parenthesis

| | ······································ | |
|---|--|--|
| Material | Reg. Guide 1.99, Rev. 2 Position 1.1 CF's | Reg. Guide 1.99, Rev. 2 Position 2.1 CF's |
| Intermediate Shell Plate A9154-1 | 65.0°F | 43.4°F ^(a) |
| Intermediate Shell Plate A9153-2 | 58.0°F | |
| Lower Shell Plate C9923-1 | 51.0°F | |
| Lower Shell Plate C9923-2 | 51.0°F | |
| Intermediate Shell Longitudinal Weld Seams BC & BD | 68.0°F | 42.2°F ^(a) |
| Lower Shell Longitudinal Weld Seams BA & BB | 68.0°F | 42.2°F ^(a) |
| Intermediate to Lower Shell Plate Circumferential Weld Seam AB | 68.0°F | 42.2°F ^(a) |

 TABLE 4

 Summary of the V. C. Summer Reactor Vessel Beltline Material Chemistry Factors

(a) See Capsule Z Report, WCAP-16298^[6.8], for the credibility evaluation of the V.C. Summer Unit 1 surveillance data. The Intermediate Shell Plate A9154-1 was deemed "non-credible" while the weld was deemed "credible".

3. CRITERIA FOR ALLOWABLE PRESSURE-TEMPERATURE RELATIONSHIPS

3.1 OVERALL APPROACH

The ASME approach for calculating the allowable limit curves for various heatup and cooldown rates specifies that the total stress intensity factor, K_{l} , for the combined thermal and pressure stresses at any time during heatup or cooldown cannot be greater than the reference stress intensity factor, K_{lc} , for the metal temperature at that time. K_{lc} is obtained from the reference fracture toughness curve, defined in Code Case N-641, "Alternative Pressure-Temperature Relationship and Low Temperature Overpressure Protection System Requirements Section XI, Division 1"^[6.3 & 6.4] of the ASME Appendix G to Section XI. The K_{lc} curve is given by the following equation:

$$K_{I_{o}} = 33.2 + 20.734^{*} e^{[0.02(T - RT_{NDT})]}$$
(1)

where,

 K_{lc} = reference stress intensity factor as a function of the metal temperature T and the metal reference nil-ductility temperature RT_{NDT}

This K_{lc} curve is based on the lower bound of static critical K_l values measured as a function of temperature on specimens of SA-533 Grade B Class1, SA-508-1, SA-508-2, SA-508-3 steel.

3.2 METHODOLOGY FOR PRESSURE-TEMPERATURE LIMIT CURVE DEVELOPMENT

The governing equation for the heatup-cooldown analysis is defined in Appendix G of the ASME Code as follows:

$$C^* K_{im} + K_{it} < K_{ic}$$
 (2)

where,

K_{Im} = stress intensity factor caused by membrane (pressure) stress

- K_{tt} = stress intensity factor caused by the thermal gradients
- K_{lc} = function of temperature relative to the RT_{NDT} of the material

C = 2.0 for Level A and Level B service limits

C = 1.5 for hydrostatic and leak test conditions during which the reactor core is not critical

For membrane tension, the corresponding K_I for the postulated defect is:

$$K_{\rm lm} = M_m \times (pR_i/t) \tag{3}$$

where, M_m for an inside surface flaw is given by:

$$M_{m} = 1.85 \text{ for } \sqrt{t} < 2$$

$$M_{m} = 0.926 \sqrt{t} \text{ for } 2 \le \sqrt{t} \le 3.464$$

$$M_{m} = 3.21 \text{ for } \sqrt{t} > 3.464$$

Similarly, M_m for an outside surface flaw is given by:

$$M_{m} = 1.77 \text{ for } \sqrt{t} < 2$$

$$M_{m} = 0.893 \sqrt{t} \text{ for } 2 \le \sqrt{t} \le 3.464$$

$$M_{m} = 3.09 \text{ for } \sqrt{t} > 3.464$$

and p = internal pressure, Ri = vessel inner radius and t = vessel wall thickness.

For bending stress, the corresponding K_I for the postulated defect is:

 $K_{lb} = M_b * Maximum Stress$, where M_b is two-thirds of M_m

The maximum K₁ produced by radial thermal gradient for the postulated inside surface defect of G-2120 is $K_{tt} = 0.953 \times 10^{-3} \times CR \times t^{2.5}$, where CR is the cooldown rate in °F/hr., or for a postulated outside surface defect, $K_{tt} = 0.753 \times 10^{-3} \times HU \times t^{2.5}$, where HU is the heatup rate in °F/hr.

The through-wall temperature difference associated with the maximum thermal K_I can be determined from Figure G-2214-1. The temperature at any radial distance from the vessel surface can be determined from Figure G-2214-2 for the maximum thermal K_I .

- (a) The maximum thermal K_1 relationship and the temperature relationship in Figure G-2214-1 are applicable only for the conditions given in G-2214.3(a)(1) and (2).
- (b) Alternatively, the K₁ for radial thermal gradient can be calculated for any thermal stress distribution and at any specified time during cooldown for a ¼-thickness inside surface defect using the relationship:

$$K_{II} = (1.0359C_0 + 0.6322C_1 + 0.4753C_2 + 0.3855C_3) * \sqrt{\pi a}$$
⁽⁴⁾

or similarly, K_{Π} during heatup for a ¼-thickness outside surface defect using the relationship:

$$K_{Il} = (1.043C_0 + 0.630C_1 + 0.481C_2 + 0.401C_3) * \sqrt{\pi a}$$
(5)

where the coefficients C_0 , C_1 , C_2 and C_3 are determined from the thermal stress distribution at any specified time during the heatup or cooldown using the form:

$$\sigma(x) = C_0 + C_1(x/a) + C_2(x/a)^2 + C_3(x/a)^3$$
(6)

and x is a variable that represents the radial distance from the appropriate (i.e., inside or outside) surface to any point on the crack front and a is the maximum crack depth.

Note, that equations 3, 4 and 5 were implemented in the OPERLIM computer code, which is the program used to generate the pressure-temperature (P-T) limit curves. No other changes were made to the OPERLIM computer code with regard to P-T calculation methodology. Therefore, the P-T curve methodology is unchanged from that described in WCAP-14040, "Methodology used to Develop Cold Overpressure Mitigating System Setpoints and RCS Heatup and Cooldown Limit Curves"^[6.2] with the exceptions just described above.

At any time during the heatup or cooldown transient, K_{lc} is determined by the metal temperature at the tip of a postulated flaw at the 1/4T and 3/4T location, the appropriate value for RT_{NDT} , and the reference fracture toughness curve. The thermal stresses resulting from the temperature gradients through the vessel wall are calculated and then the corresponding (thermal) stress intensity factors, K_{lt} , for the reference flaw are computed. From Equation 2, the pressure stress intensity factors are obtained and, from these, the allowable pressures are calculated.

For the calculation of the allowable pressure versus coolant temperature during cooldown, the reference flaw of Appendix G to the ASME Code is assumed to exist at the inside of the vessel wall. During cooldown, the controlling location of the flaw is always at the inside of the wall because the thermal gradients produce tensile stresses at the inside, which increase with increasing cooldown rates. Allowable pressure-temperature relations are generated for both

WCAP-16305-NP

steady-state and finite cooldown rate situations. From these relations, composite limit curves are constructed for each cooldown rate of interest.

The use of the composite curve in the cooldown analysis is necessary because control of the cooldown procedure is based on the measurement of reactor coolant temperature, whereas the limiting pressure is actually dependent on the material temperature at the tip of the assumed flaw. During cooldown, the 1/4T vessel location is at a higher temperature than the fluid adjacent to the vessel inner diameter. This condition, of course, is not true for the steady-state situation. It follows that, at any given reactor coolant temperature, the ΔT (temperature) developed during cooldown results in a higher value of K_{lc} at the 1/4T location for finite cooldown rates than for steady-state operation. Furthermore, if conditions exist so that the increase in K_{lc} exceeds K_{lt}, the calculated allowable pressure during cooldown will be greater than the steady-state value.

The above procedures are needed because there is no direct control on temperature at the 1/4T location and, therefore, allowable pressures may unknowingly be violated if the rate of cooling is decreased at various intervals along a cooldown ramp. The use of the composite curve eliminates this problem and ensures conservative operation of the system for the entire cooldown period.

Three separate calculations are required to determine the limit curves for finite heatup rates. As is done in the cooldown analysis, allowable pressure-temperature relationships are developed for steady-state conditions as well as finite heatup rate conditions assuming the presence of a 1/4T defect at the inside of the wall. The heatup results in compressive stresses at the inside surface that alleviate the tensile stresses produced by internal pressure. The metal temperature at the crack tip lags the coolant temperature; therefore, the K_{Ic} for the 1/4T crack during heatup is lower than the K_{Ic} for the 1/4T crack during steady-state conditions may exist so that the effects of compressive thermal stresses and lower K_{Ic} values do not offset each other, and the pressure-temperature curve based on steady-state conditions no longer represents a lower bound of all similar curves for finite heatup rates when the 1/4T flaw is considered. Therefore, both cases have to be analyzed in order to ensure that at any coolant temperature the lower value of the allowable pressure calculated for steady-state and finite heatup rates is obtained.

The second portion of the heatup analysis concerns the calculation of the pressure-temperature limitations for the case in which a 1/4T flaw located at the 1/4T location from the outside surface is assumed. Unlike the situation at the vessel inside surface, the thermal gradients established at the outside surface during heatup produce stresses which are tensile in nature and therefore tend to reinforce any pressure stresses present. These thermal stresses are dependent on both the rate of heatup and the time (or coolant temperature) along the heatup ramp. Since the thermal stresses at the outside are tensile and increase with increasing heatup rates, each heatup rate must be analyzed on an individual basis.

Following the generation of pressure-temperature curves for both the steady-state and finite heatup rate situations, the final limit curves are produced by constructing a composite curve based on a point-by-point comparison of the steady-state and finite heatup rate data. At any given temperature, the allowable pressure is taken to be the lesser of the three values taken from the curves under consideration. The use of the composite curve is necessary to set conservative heatup limitations because it is possible for conditions to exist wherein, over the course of the heatup ramp, the controlling condition switches from the inside to the outside, and the pressure limit must at all times be based on analysis of the most critical criterion.

3.3 CLOSURE HEAD/VESSEL FLANGE REQUIREMENTS

10 CFR Part 50, Appendix $G^{[6.5]}$ addresses the metal temperature of the closure head flange and vessel flange regions. This rule states that the metal temperature of the closure flange regions must exceed the material unirradiated RT_{NDT} by at least 120°F for normal operation when the pressure exceeds 20 percent of the pre-service hydrostatic test pressure (3106 psi), which is 621 psig for V. C. Summer. The limiting unirradiated RT_{NDT} of 10°F occurs in the closure head flange of the V. C. Summer reactor vessel, so the minimum allowable temperature of this region is 130°F at pressures greater than 621 psig. This limit is shown in Figures 1, 2, 3 and 4 wherever applicable.

4. CALCULATION OF ADJUSTED REFERENCE TEMPERATURE

From Regulatory Guide 1.99, Revision 2, the adjusted reference temperature (ART) for each material in the beltline region is given by the following expression:

$$ART = Initial RT_{NDT} + \Delta RT_{NDT} + Margin$$
(7)

Initial RT_{NDT} is the reference temperature for the unirradiated material as defined in paragraph NB-2331 of Section III of the ASME Boiler and Pressure Vessel Code^[6,9]. If measured values of initial RT_{NDT} for the material in question are not available, generic mean values for that class of material may be used if there are sufficient test results to establish a mean and standard deviation for the class.

 ΔRT_{NDT} is the mean value of the adjustment in reference temperature caused by irradiation and should be calculated as follows:

$$\Delta RT_{NDT} = CF * f^{(0.28 - 0.10 \log f)}$$
(8)

To calculate ΔRT_{NDT} at any depth (e.g., at 1/4T or 3/4T), the following formula must first be used to attenuate the fluence at the specific depth.

$$f_{(depth x)} = f_{surface} * e^{(-0.24x)}$$
(9)

where x inches (vessel beltline thickness is 7.75 inches) is the depth into the vessel wall measured from the vessel clad/base metal interface. The resultant fluence is then placed in Equation 8 to calculate the ΔRT_{NDT} at the specific depth.

The Westinghouse Radiation Engineering and Analysis Group evaluated the vessel fluence projections and the results of the calculated peak fluence values at various azimuthal locations on the vessel clad/base metal interface are presented in Table 5. The evaluation used the ENDF/B-VI scattering cross-section data set. This is consistent with methods presented in WCAP-14040-NP-A. Tables 6 and 7 contain the 1/4T and 3/4T calculated fluences and fluence factors, per the Regulatory Guide 1.99, Revision 2, used to calculate the ART values for all beltline materials in the V. C. Summer reactor vessel at 32 and 56 EFPY.

| Summary of the Peak Pressure Vessel Neutron Fluence Values ^(a) at the Clad/Base Metal Interface (n/cm ² , E > 1.0 MeV) | | | | | | | |
|---|-------------------------|-------------------------|-------------------------|-------------------------|--|--|--|
| | Azimuthal Location | | | | | | |
| EFPY | 0° | 15° | 30° | 45° | | | |
| 32 | 3.92 x 10 ¹⁹ | 2.41 x 10 ¹⁹ | 1.85 x 10 ¹⁹ | 1.36 x 10 ¹⁹ | | | |
| 56 | 6.80 x 10 ¹⁹ | 4.15 x 10 ¹⁹ | 3.18 x 10 ¹⁹ | 2.35 x 10 ¹⁹ | | | |

TABLE 5

(a) Obtained from the Capsule Z Report, WCAP-16298^[6,8]. These fluence projection are the calculated fluence projections determined following the methodology of Reg. Guide 1.190^[6.10].

TABLE 6Summary of the Vessel Surface, 1/4T and 3/4T Fluence Valuesused for the Generation of the 32 EFPY Heatup/Cooldown Curves

| Material | Surface | 1/4T | 3/4T |
|---|-------------------------|-------------------------|-------------------------|
| | (n/cm², E > 1.0 MeV) | (n/cm², E > 1.0 MeV) | (n/cm², E > 1.0 MeV) |
| Intermediate Shell Plate A9154-1 | 3.92 x 10 ¹⁹ | 2.46 x 10 ¹⁹ | 0.97 x 10 ¹³ |
| Intermediate Shell Plate A9153-2 | 3.92 x 10 ¹⁹ | 2.46 x 10 ¹⁹ | 0.97 x 10 ¹⁹ |
| Lower Shell Plate C9923-1 | 3.92 x 10 ¹⁹ | 2.46 x 10 ¹⁹ | 0.97 x 10 ¹⁹ |
| Lower Shell Plate C9923-2 | 3.92 x 10 ¹⁹ | 2.46 x 10 ¹⁹ | 0.97 x 10 ¹⁹ |
| Intermediate to Lower Shell Circumferential Weld Seam AB | 3.92 x 10 ¹⁹ | 2.46 x 10 ¹⁹ | 0.97 x 10 ¹⁹ |
| Intermediate Lower Shell Longitudinal Weld Seam BC, BD, BA & BB (45° Azimuth) | 1.36 x 10 ¹⁹ | 0.85 x 10 ¹⁹ | 0.34 x 10 ¹⁹ |

13

IL.

TABLE 7Summary of the Vessel Surface, 1/4T and 3/4T Fluence Valuesused for the Generation of the 56 EFPY Heatup/Cooldown Curves

| Material | Surface | 1/4T | 3/4T |
|---|-------------------------|-------------------------|-------------------------|
| | (n/cm², E > 1.0 MeV) | (n/cm², E > 1.0 MeV) | (n/cm², E > 1.0 MeV) |
| Intermediate Shell Plate A9154-1 | 6.80 x 10 ¹⁹ | 4.27 x 10 ¹⁹ | 1.69 x 10 ¹⁹ |
| Intermediate Shell Plate A9153-2 | 6.80 x 10 ¹⁹ | 4.27 x 10 ¹⁹ | 1.69 x 10 ¹⁹ |
| Lower Shell Plate C9923-1 | 6.80 x 10 ¹⁹ | 4.27 x 10 ¹⁹ | 1.69 x 10 ¹⁹ |
| Lower Shell Plate C9923-2 | 6.80 x 10 ¹⁹ | 4.27 x 10 ¹⁹ | 1.69 x 10 ¹⁹ |
| Intermediate to Lower Shell Circumferential Weld Seam AB | 6.80 x 10 ¹⁹ | 4.27 x 10 ¹⁹ | 1.69 x 10 ¹⁹ |
| Intermediate Lower Shell Longitudinal Weld Seam BC, BD, BA & BB (45° Azimuth) | 2.35 x 10 ¹⁹ | 1.48 x 10 ¹⁹ | 0.58 x 10 ¹⁹ |

Contained in Tables 8 and 9 is a summary of the fluence factor (FF) values used in the calculation of adjusted reference temperatures for the V. C. Summer reactor vessel beltline materials for 32 and 56 EFPY.

TABLE 8

Calculation of the 1/4T and 3/4T Fluence Factor Values

| used for the | Generation | of the 3 | 2 EFPY | 'Heatup/Co | oldown Curv | /es |
|--------------|------------|----------|--------|------------|-------------|-----|
|--------------|------------|----------|--------|------------|-------------|-----|

| Material | 1/4T F ^(a) | 1/4T FF | 3/4T F ^(a) | 3/4T FF |
|---|-------------------------|---------|-------------------------|---------|
| Intermediate Shell Plate A9154-1 | 2.46 x 10 ¹⁹ | 1.242 | 0.97 x 10 ¹⁹ | 0.991 |
| Intermediate Shell Plate A9153-2 | 2.46 x 10 ¹⁹ | 1.242 | 0.97 x 10 ¹⁹ | 0.991 |
| Lower Shell Plate C9923-1 | 2.46 x 10 ¹⁹ | 1.242 | 0.97 x 10 ¹⁹ | 0.991 |
| Lower Shell Plate C9923-2 | 2.46 x 10 ¹⁹ | 1.242 | 0.97 x 10 ¹⁹ | 0.991 |
| Intermediate to Lower Shell Circumferential Weld Seam AB | 2.46 x 10 ¹⁹ | 1.242 | 0.97 x 10 ¹⁹ | 0.991 |
| Intermediate Lower Shell Longitudinal Weld Seam BC, BD, BA & BB (45° Azimuth) | 0.85 x 10 ¹⁹ | 0.954 | 0.34 x 10 ¹⁹ | 0.703 |

(a) Units: n/cm^2 , E > 1.0 MeV

TABLE 9

| Material | 1/4T F ^(a) | 1/4T FF | 3/4T F ^(a) | 3/4T FF |
|---|-------------------------|---------|-------------------------|---------|
| Intermediate Shell Plate A9154-1 | 4.27 x 10 ¹⁹ | 1.370 | 1.69 x 10 ¹⁹ | 1.144 |
| Intermediate Shell Plate A9153-2 | 4.27 x 10 ¹⁹ | 1.370 | 1.69 x 10 ¹⁹ | 1.144 |
| Lower Shell Plate C9923-1 | 4.27 x 10 ¹⁹ | 1.370 | 1.69 x 10 ¹⁹ | 1.144 |
| Lower Shell Plate C9923-2 | 4.27 x 10 ¹⁹ | 1.370 | 1.69 x 10 ¹⁹ | 1.144 |
| Intermediate to Lower Shell Circumferential Weld Seam AB | 4.27 x 10 ¹⁹ | 1.370 | 1.69 x 10 ¹⁹ | 1.144 |
| Intermediate Lower Shell Longitudinal Weld Seam BC, BD, BA & BB (45° Azimuth) | 1.48 x 10 ¹⁹ | 1.109 | 0.58 x 10 ¹⁹ | 0.848 |

Calculation of the 1/4T and 3/4T Fluence Factor Values used for the Generation of the 56 EFPY Heatup/Cooldown Curves

(a) Units: n/cm^2 , E > 1.0 MeV

Margin is calculated as, $M = 2 \sqrt{\sigma_i^2 + \sigma_{\Delta}^2}$. The standard deviation for the initial RT_{NDT} margin term, is $\sigma_i 0^\circ F$ when the initial RT_{NDT} is a measured value, and 17°F when a generic value is available. The standard deviation for the ΔRT_{NDT} margin term, σ_{Δ} , is 17°F for plates or forgings, and 8.5°F for plates or forgings when surveillance data is used. For welds, σ_{Δ} is equal to 28°F when surveillance capsule data is not used, and is 14°F (half the value) when credible surveillance capsule data is used. σ_{Δ} need not exceed 0.5 times the mean value of ΔRT_{NDT} .

Contained in Tables 10 and 11 are the calculated ART values used for the generation of the heatup and cooldown curves at 32 EFPY. Contained in Tables 12 and 13 are the calculated ART values used for the generation of the heatup and cooldown curves at 56 EFPY.

| Material | Reg. Guide 1.99 Rev. 2 Method | CF ^(a) (°F) | % T FF | IRT _{NDT} ^(b) (°F) | ΔRT _{NDT} ^(c) (°F) | M ^(d) (°F) | ART ^(e) (°F) |
|---|-------------------------------------|---------------------------|--------|---|---|--------------------------|----------------------------|
| Intermediate Shell Plate | Position 1.1 | 65.0 | 1.242 | 30 | 80.73 | 34.0 | 145 |
| A9154-1 | Position 2.1 | 43.4 | 1.242 | 30 | 53.90 | 34.0 ^(r) | 118 |
| Intermediate Shell Plate | Position 1.1 | 58.0 | 1.242 | -20 | 72.04 | 34.0 | 86 |
| A9153-2 | | | | | | 34.0 | |
| Lower Shell Plate C9923-1 | Position 1.1 | 51.0 | 1.242 | 10 | 63.34 | 34.0 | 107 |
| Lower Shell Plate C9923-2 | Position 1.1 | 51.00 | 1.242 | 10 | 63.34 | 34.0 | 107 |
| Intermediate to Lower Shell | Position 1.1 | 68.0 | 1.242 | -44 | 84.46 | 56.0 | 96 |
| AB | Position 2.1 | 42.2 | 1.242 | · -4 4 | 52.41 | 28.0 | 36 |
| Intermediate Lower Shell | Position 1.1 | 68.0 | 0.954 | -44 | 64.87 | 56.0 | 77 |
| Longitudinal Weld Seam BC, BD, BA & BB (45° Azimuth) | Position 2.1 | 42.2 | 0.954 | -44 | 40.26 | 28.0 | 24 |

 TABLE 10

 Calculation of the ART Values for the 1/4T Location @ 32 EFPY

(b) Initial RT_{NDT} values are measured values; see Table 1

(c) $\Delta RT_{NDT} = CF + FF$

(d) Margin =
$$2^* (\sigma_i^2 + \sigma_{\Delta}^2)^{1/2}$$

(e) ART = $IRT_{NDT} + \Delta RT_{NDT} + M$ (This value was rounded per ASTM E29, using the "Rounding Method")

(f) Surveillance Plate Data is not-credible, thus the full σ_{Δ} was used

| Material | Reg. Guide 1.99 Rev. 2 Method | CF ^(a) (°F) | % T FF | IRT _{NDT} ^(b) (°F) | ∆RT _{NDT} ^(c) (°F) | M ^(d) (°F) | ART ^(e) (°F) |
|---------------------------------|-------------------------------------|---------------------------|--------|---|---|--------------------------|----------------------------|
| Intermediate Shell Plate | Position 1.1 | 65.0 | 0.991 | 30 | 64.42 | 34.0 | 128 |
| A9154-1 | Position 2.1 | 43.4 | 0.991 | 30 | 43.01 | 34.0 ^(f) | 107 |
| Intermediate Shell Plate | Position 1.1 | 58.0 | 0.991 | -20 | 57.48 | 34.0 | 71 |
| A9153-2 | | | | | | 34.0 | |
| Lower Shell Plate C9923-1 | Position 1.1 | 51.0 | 0.991 | 10 | 50.54 | 34.0 | 95 |
| Lower Shell Plate C9923-2 | Position 1.1 | 51.00 | 0.991 | 10 | 50.54 | 34.0 | 95 |
| Intermediate to Lower Shell | Position 1.1 | 68.0 | 0.991 | -44 | 67.39 | 56.0 | 79 |
| Circumferential Weld Seam AB | Position 2.1 | 42.2 | 0.991 | -44 | 41.82 | 28.0 | 26 |
| Intermediate Lower Shell | Position 1.1 | 68.0 | 0.703 | -44 | 47.80 | 56.0 | 60 |
| BD, BA & BB (45° Azimuth) | Position 2.1 | 42.2 | 0.703 | -44 | 29.67 | 28.0 | 14 |

 TABLE 11

 Calculation of the ART Values for the 3/4T Location @ 32 EFPY

(b) Initial RT_{NDT} values are measured values; see Table 1

(c) $\Delta RT_{NDT} = CF * FF$

(d) Margin = $2^* (\sigma_i^2 + \sigma_{\Delta}^2)^{1/2}$

(e) ART = $IRT_{NDT} + \Delta RT_{NDT} + M$ (This value was rounded per ASTM E29, using the "Rounding Method")

(f) Surveillance Plate Data is not-credible, thus the full σ_{Δ} was used

| Material | Reg. Guide 1.99 Rev. 2 Method | CF ^(a) (°F) | ¼TFF | IRT _{NDT} ^(b) (°F) | ∆RT _{NDT} ^(c) (°F) | M ^(d) (°F) | ART ^(e) (°F) |
|---|-------------------------------------|---------------------------|-------|---|---|--------------------------|----------------------------|
| Intermediate Shell Plate | Position 1.1 | 65.0 | 1.370 | 30 | 89.05 | 34.0 | 153 |
| A9154-1 | Position 2.1 | 43.4 | 1.370 | . 30 | 59.46 | 34.0 ^(f) | 123 |
| Intermediate Shell Plate | Position 1.1 | 58.0 | 1.370 | -20 | 79.46 | 34.0 | 93 |
| A9153-2 | | | | | | 34.0 | |
| Lower Shell Plate C9923-1 | Position 1.1 | 51.0 | 1.370 | 10 | 69.87 | 34.0 | 114 |
| Lower Shell Plate C9923-2 | Position 1.1 | 51.00 | 1.370 | 10 | 69.87 | 34.0 | 114 |
| Intermediate to Lower Shell | Position 1.1 | 68.0 | 1.370 | -44 | 93.16 | 56.0 | 105 |
| Circumferential Weld Seam AB | Position 2.1 | 42.2 | 1.370 | -44 | 57.81 | 28.0 | 42 |
| Intermediate Lower Shell | Position 1.1 | 68.0 | 1.109 | -44 | 75.41 | 56.0 | 87 |
| Longitudinal Weld Seam BC, BD, BA & BB (45° Azimuth) | Position 2.1 | 42.2 | 1.109 | -44 | 46.80 | .28.0 | 31 |

 TABLE 12

 Calculation of the ART Values for the 1/4T Location @ 56 EFPY

(b) Initial RT_{NDT} values are measured values; see Table 1

(c) $\Delta RT_{NDT} = CF + FF$

(d) Margin =
$$2^* (\sigma_i^2 + \sigma_{\Delta}^2)^{1/2}$$

(e) ART = $IRT_{NDT} + \Delta RT_{NDT} + M$ (This value was rounded per ASTM E29, using the "Rounding Method")

(f) Surveillance Plate Data is not-credible, thus the full σ_{Δ} was used

| Material | Reg. Guide 1.99 Rev. 2 Method | CF ^(a) (°F) | ¾ T FF | IRT _{NDT} ^(b) (°F) | ∆RT _{NDT} ^(c) (°F) | M ^(d) (°F) | ART ^(e) (°F) |
|---------------------------------|-------------------------------------|---------------------------|--------|---|---|--------------------------|----------------------------|
| Intermediate Shell Plate | Position 1.1 | 65.0 | 1.144 | 30 | 74.36 | 34.0 | 138 |
| A9154-1 | Position 2.1 | 43.4 | 1.144 | 30 | 49.65 | 34.0 ⁽¹⁾ | 114 |
| Intermediate Shell Plate | Position 1.1 | 58.0 | 1.144 | -20 | 66.35 | 34.0 | 80 |
| A9153-2 | | | | | | 34.0 | |
| Lower Shell Plate C9923-1 | Position 1.1 | 51.0 | 1.144 | 10 | 58.34 | 34.0 | 102 |
| Lower Shell Plate C9923-2 | Position 1.1 | 51.00 | 1.144 | 10 | 58.34 | 34.0 | 102 |
| Intermediate to Lower Shell | Position 1.1 | 68.0 | 1.144 | -44 | 77.79 | 56.0 | 90 |
| Circumferential Weld Seam AB | Position 2.1 | 42.2 | 1.144 | -44 | 48.28 | 28.0 | 32 |
| Intermediate Lower Shell | Position 1.1 | 68.0 | 0.848 | -44 | 57.66 | 56.0 | 70 |
| BD, BA, BB (45° Azimuth) | Position 2.1 | 42.2 | 0.848 | -44 | 35.79 | 28.0 | 20 |

TABLE 13Calculation of the ART Values for the 3/4T Location @ 56 EFPY

(b) Initial RT_{NDT} values are measured values; see Table 1

- (c) $\Delta RT_{NDT} = CF * FF$
- (d) Margin = $2^* (\sigma_i^2 + \sigma_{\Delta}^2)^{1/2}$

(e) ART = $IRT_{NDT} + \Delta RT_{NDT} + M$ (This value was rounded per ASTM E29, using the "Rounding Method")

(f) Surveillance Plate Data is not-credible, thus the full σ_{Δ} was used

The Intermediate Shell Plate A9154-1 is the limiting beltline material for all the PT limit curves to be generated. Contained in Table 14 is a summary of the limiting ART values to be used in the generation of the V. C. Summer reactor vessel PT limit curves. These limiting curves will be presented in Section 5.

TABLE 14 Summary of the Limiting ART Values Used in the Generation of the V. C. Summer Heatup/Cooldown Curves

| EFPY | ¼ T Limiting ART | ³ ⁄ ₄ T Limiting ART | | |
|------|------------------|--|--|--|
| 32 | 145 | 128 | | |
| 56 | 153 | 138 | | |

5. HEATUP AND COOLDOWN PRESSURE-TEMPERATURE LIMIT CURVES

Pressure-temperature limit curves for normal heatup and cooldown of the primary reactor coolant system have been calculated for the pressure and temperature in the reactor vessel beltline region using the methods discussed in Sections 3 and 4 of this report. This approved methodology is also presented in WCAP-14040-NP-A, Revision 4.

Figures 1 and 3 present the limiting heatup curves without margins for possible instrumentation errors using heatup rates of 50 and 100°F/hr applicable for 32 and 56 EFPY. These curves were generated using the1998 ASME Code Section XI, Appendix G with the limiting ART values. Figures 2 and 4 present the limiting cooldown curves without margins for possible instrumentation errors using cooldown rates of 0, 25, 50 and 100°F/hr applicable for 32 and 56 EFPY. Again, these curves were generated using the1998 ASME Code Section XI, Appendix G with the limiting ART values. Allowable combinations of temperature and pressure for specific temperature change rates are below and to the right of the limit line shown in Figures 1, 2, 3 and 4. This is in addition to other criteria, which must be met before the reactor is made critical, as discussed below in the following paragraphs.

The reactor must not be made critical until pressure-temperature combinations are to the right of the criticality limit line shown in Figure 1. The straight-line portion of the criticality limit is at the minimum permissible temperature for the 2485 psig inservice hydrostatic test as required by Appendix G to 10 CFR Part 50. The governing equation for the hydrostatic test is defined in the 1998 ASME Code^[6.4] as follows:

 $1.5 \text{ K}_{\text{im}} < \text{ K}_{\text{ic}}$

where,

 K_{Im} is the stress intensity factor covered by membrane (pressure) stress $K_{Ic} = 33.2 + 20.734 e^{[0.02 (T - RT_{NDT})]}$

T is the minimum permissible metal temperature

 RT_{NDT} is the metal reference nil-ductility temperature

The criticality limit curve specifies pressure-temperature limits for core operation to provide additional margin during actual power production as specified in [6.5]. The pressure-temperature limits for core operation (except for low power physics tests) are that the reactor

vessel must be at a temperature equal to or higher than the minimum temperature required for the inservice hydrostatic test, and at least 40°F higher than the minimum permissible temperature in the corresponding pressure-temperature curve for heatup and cooldown calculated as described in Section 4 of this report. For the heatup and cooldown curves without margins for instrumentation errors, the minimum temperatures for the in service hydrostatic leak tests for the V. C. Summer reactor vessel at 32 EFPY is 202°F and at 56 EFPY is 210°F. The vertical line drawn from these points on the pressure-temperature curve, intersecting a curve 40°F higher than the pressure-temperature limit curve constitutes the limit for core operation for the reactor vessel.

Figures 1, 2, 3 and 4 define all of the above limits for ensuring prevention of non-ductile failure for the V. C. Summer reactor vessel for 32 and 56 EFPY. The data points used for the heatup and cooldown pressure-temperature limit curves shown in Figures 1, 2, 3 and 4 are presented in Tables 15, 16, 17 and 18.

. u.

MATERIAL PROPERTY BASIS:

Limiting Material: Intermediate Shell Plate A9154-1 Limiting ART Values @ 32 EFPY: 1/4T: 145°F, 3/4T: 128°F



Figure 1 V. C. Summer Reactor Coolant System Heatup Limitations (Heatup Rates of 50 and 100°F/hr) Applicable for 32 EFPY (Without Margins for Instrumentation Errors) Using 1998 Appendix G Methodology



Limiting Material: Intermediate Shell Plate A9154-1 Limiting ART Values @ 32 EFPY: 1/4T: 145°F, 3/4T: 128°F



Figure 2 V. C. Summer Reactor Coolant System Cooldown Limitations (Cooldown Rates up to 100°F/hr) Applicable for 32 EFPY (Without Margins for Instrumentation Errors) Using 1998 Appendix G Methodology

ш.,

MATERIAL PROPERTY BASIS:

Limiting Material: Intermediate Shell Plate A9154-1 Limiting ART Values @ 56 EFPY: 1/4T: 153°F, 3/4T: 138°F

Operlim Version: 5.2 Run: 17345 Operlim.xls Version: 5.2 2500 Leak Test Limit 2250 Unacceptable Acceptable 2000 Operation Operation 1750 Calculated Pressure (PSIG) **Critical Limit** 1500 50 Deg. F/Hr **Heatup Rate** 50 Deg. F/Hr **Critical Limit** 1250 100 Deg. F/Hr **Heatup Rate** 100 Deg. F/Hr 1000 750 500 Boltup **Criticality Limit based on** Temp. 250 inservice hydrostatic test temperature (210 F) for the service period up to 56 EFPY 0 0 50 100 150 200 250 300 350 400 450 500 550 Moderator Temperature (Deg. F)

Figure 3 V. C. Summer Reactor Coolant System Heatup Limitations (Heatup Rates of 50 and 100°F/hr) Applicable for 56 EFPY (Without Margins for Instrumentation Errors) Using 1998 Appendix G Methodology



Figure 4 V. C. Summer Reactor Coolant System Cooldown Limitations (Cooldown Rates up to 100°F/hr) Applicable for 56 EFPY (Without Margins for Instrumentation Errors) Using 1998 Appendix G Methodology

Moderator Temperature (Deg. F)

MATERIAL PROPERTY BASIS: Limiting Material: Intermediate Shell Plate A9154-1 Limiting ART Values @ 56 EFPY: 1/4T: 153°F, 3/4T: 138°F Ц.,,

į

;

TABLE 15

32 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology

| 50 H | eatup | Critica | al. Limit | 100 ł | leatup | Critical. Limit | | Leak T | est Limit |
|--------|----------|---------|-----------|------------|----------|-----------------|----------|--------|-----------|
| Т (°F) | P (psig) | T (°F) | P (psig) | T (°F) | P (psig) | T (°F) | P (psig) | T (°F) | P (psig) |
| 60 | 0 | 202 | 0 | 60 | 0. | 202 | 0 | 184 | 2000 |
| 60 | 621 | 202 | 621 | 60 | 621 | 202 | 621 | 202 | 2485 |
| 65 | 621 | 202 | 621 | 65 | 621 | 202 | 621 | | |
| 70 | 621 | 202 | 621 | 70 | 621 | 202 | 621 | | |
| 75 | 621 | 202 | 621 | 75 | 621 | 202 | 621 | | |
| 80 | 621 | 202 | 621 | 80 | 621 | 202 | 621 | | |
| 85 | 621 | 202 | 621 | 85 | 621 | 202 | 621 | | |
| 90 | 621 | 202 | 621 | 90 | 621 | 202 | 621 | | |
| 95 | 621 | 202 | 621 | 95 | 621 | 202 | 621 | | |
| 100 | 621 | 202 | 621 | 100 | 621 | 202 | 621 | | |
| 105 | 621 | 202 | 621 | 105 | 621 | 202 | 621 | | |
| 110 | 621 | 202 | 621 | 110 | 621 | 202 | 621 | | |
| 115 | 621 | 202 | 621 | .115 | 621 | 202 - | 621 | | |
| 120 | 621 | 202 | 621 | 120 | 621 | 202 | 621 | | |
| 125 | 621 | 202 | 621 | 125 | 621 | 202 | 621 | | |
| 130 | 621 | 202 | 862 | 130 | 621 | 202 | 723 | | |
| 130 | 862 | 202 | 891 | 130 | 723 | 202 | 739 | | |
| 135 | 891 | 202 | 923 | 135 | 739 | 202 | 757 | | |
| 140 | 923 | 202 | 958 | 140 | 757 | 202 | 778 | | |
| 145 | 958 | 202 | 997 | 145 | 778 | 202 | 801 | | |
| 150 | 997 | 202 | 1041 | 150 | 801 | 202 | 828 | | |
| 155 | 1041 | 202 | 1089 | 155 | 828 | 202 | 858 | | |
| 160 | 1089 | 205 | 1142 | 160 | 858 | 205 | 891 | | |
| 165 | 1142 | 210 | 1201 | 165 | 891 | 210 | 929 | | |
| 170 | 1201 | 215 | 1266 | 170 | 929 | 215 | 970 | | |
| 175 | 1266 | 220 | 1337 | 175 | 970 | 220 | 1016 | | |
| 180 | 1337 | 225 | 1416 | 180 | 1016 | 225 | 1067 | | |
| 185 | 1416 | 230 | 1504 | 185 | 1067 | 230 | 1123 | | |
| 190 | 1504 | 235 | 1600 | 190 | 1123 | 235 | 1186 | | |
| 195 | 1600 | 240 | 1707 | 195 | 1186 | 240 | 1255 | | |
| 200 | 1707 | 245 | 1824 | 200 | 1255 | 245 | 1331 | | |
| 205 | 1824 | 250 | 1937 | 205 | 1331 | 250 | 1416 | | |
| 210 | 1937 | 255 | 2062 | 210 | 1416 | 255 | 1509 | | |
| 215 | 2062 | 260 | 2199 | 215 | 1509 | 260 | 1612 | | |
| 220 | 2199 | 265 · | 2351 | 220 | 1612 | 265 | 1725 | | |
| 225 | 2351 | | | 225 | 1725 | 270 | 1851 | | |
| | | | | 230 | 1851 | 275 | 1989 | | |
| | | | | 235 | 1989 | 280 | 2141 | | |
| | | | | 240 | 2141 | 285 | 2310 | | |
| | | | | 245 | 2310 | | | | |

(without Uncertainties for Instrumentation Errors)

----- · ·

TABLE 16

32 EFPY Cooldown Curve Data Points Using 1998 Appendix G Methodology

| Stead | y State | 25° | F/hr. | 50°F/hr. | | °F/hr. 100°F/hr | |
|--------|----------|--------|----------|----------|----------|-------------------|----------|
| T (°F) | P (psig) | T (°F) | P (psig) | Т (°F) | P (psig) | T (°F) | P (psig) |
| 60 | 0 | 60 | 0 | 60 | 0 | 60 | 0 |
| 60 | 621 | 60 | 621 | 60 | 617 | 60 | 524 |
| 65 | 621 | 65 | 621 | 65 | 621 | 65 | 535 |
| 70 | 621 | 70 | 621 | 70 | 621 | 70 | 546 |
| 75 | 621 | 75 | 621 | 75 | 621 | 75 | 559 |
| 80 | 621 | 80 | 621 | 80 | 621 | 80 | 574 |
| 85 | 621 | 85 | 621 | 85 | 621 | 85 | 590 |
| 90 | 621 | 90 | 621 | 90 | 621 | 90 | 608 |
| 95 | 621 | 95 | 621 | 95 | 621 | 95 | 621 |
| 100 | 621 | 100 | 621 | 100 | 621 | 100 | 621 |
| 105 | 621 | 105 | 621 | 105 | 621 | 105 | 621 |
| 110 | 621 | 110 | 621 | 110 | 621 | 110 | 621 |
| 115 | 621 | 115 | 621 | 115 | 621 | 115 | 621 |
| 120 | 621 | 120 | 621 | 120 | 621 | 120 | 621 |
| 125 | 621 | 125 | 621 | 125 | 621 | 125 | 621 |
| 130 | 621 | 130 | 621 | 130 | 621 | 130 | 621 |
| 130 | 928 | 130 | 904 | 130 | 881 | 130 | 846 |
| 135 | 959 | 135 | 938 | 135 | 919 | 135 | 892 |
| 140 | 993 | 140 | 975 | 140 | 960 | 140 | 944 |
| 145 | 1031 | 145 | 1017 | 145 | 1006 | 145 | 1001 |
| 150 | 1073 | 150 | 1063 | 150 | 1057 | 150 | 1057 |
| 155 | 1119 | 155 | 1114 | 155 | 1114 | 155 | 1114 |
| 160 | 1170 | 160 | 1170 | 160 | 1170 | 160 | 1170 |
| 165 | 1226 | 165 | 1226 | 165 | 1226 | 165 | 1226 |
| 170 | 1288 | 170 | 1288 | 170 | 1288 | 170 | 1288 |
| 175 | 1357 | 175 | 1357 | 175 | 1357 | 175 | 1357 |
| 180 | 1433 | 180 | 1433 | 180 | 1433 | 180 | 1433 |
| 185 | 1517 | 185 | 1517 | 185 | 1517 | 185 | 1517 |
| 190 | 1610 | 190 | 1610 | 190 | 1610 | 190 | 1610 |
| 195 | 1712 | 195 | 1712 | 195 | 1712 | 195 | 1712 |
| 200 | 1825 | 200 | 1825 | 200 | 1825 | 200 | 1825 |
| 205 | 1951 | 205 | 1951 | 205 | 1951 | 205 | 1951 |
| 210 | 2089 | 210 | 2089 | 210 | 2089 | 210 | 2089 |
| 215 | 2242 | 215 | 2242 | 215 | 2242 | 215 | 2242 |
| 220 | 2411 | 220 | 2411 | 220 | 2411 | 220 | 2411 |

(without Uncertainties for Instrumentation Errors)

-4-

.

TABLE 17

56 EFPY Heatup Curve Data Points Using 1998 Appendix G Methodology

| 50 H | eatup | Critical. Limit | | 100 Heatup | | Critical. Limit | | Leak T | est Limit |
|--------|----------|-----------------|----------|------------|----------|-----------------|----------|--------|-----------|
| T (°F) | P (psig) | T (°F) | P (psig) | Т (°F) | P (psig) | T (°F) | P (psig) | T (°F) | P (psig) |
| 60 | 0 | 210 | 0 | 60 | 0. | 210 | 0 | 192 | 2000 |
| 60 | 621 | 210 | 621 | 60 | 621 | 210 | 621 | 210 | 2485 |
| 65 | 621 | 210 | 621 | 65 | 621 | 210 | 621 | | |
| 70 | 621 | 210 | 621 | 70 | 621 | 210 | 621 | | |
| 75 | 621 | 210 | 621 | 75 | 621 | 210 | 621 | | |
| 80 | 621 | 210 | 621 | 80 | 621 | 210 | 621 | | |
| 85 | 621 | 210 | 621 | 85 | 621 | 210 | 621 | | |
| 90 | 621 | 210 | 621 | 90 | 621 | 210 | 621 | | |
| 95 | 621 | 210 | 621 | 95 | 621 | 210 | 621 | | |
| 100 | 621 | 210 | 621 | 100 | 621 | 210 | 621 | | |
| 105 | 621 | 210 | 621 | 105 | 621 | 210 | 621 | | |
| 110 | 621 | 210 | 621 | 110 | 621 | 210 | 621 | | |
| 115 | 621 | 210 | 621 | 115 | 621 | 210 | 621 | | |
| 120 | 621 | 210 | 621 | 120 | 621 | 210 | 621 | | |
| 125 | 621 | 210 | 621 | 125 | 621 | 210 | 621 | | |
| 130 | 621 | 210 | 810 | 130 | 621 | 210 | 684 | | |
| 130 | 810 | 210 | 833 | 130 | 684 | 210 | 697 | | |
| 135 | 833 | 210 | 859 | 135 | 697 | 210 | 711 | | |
| 140 | 859 | 210 | 888 | 140 | 711 | 210 | 728 | | |
| 145 | 888 | 210 | 920 | 145 | 728 | 210 | 747 | | |
| 150 | 920 | 210 | 956 | 150 | 747 | 210 | 768 | | |
| 155 | 956 | 210 | 995 | 155 | 768 | 210 | 792 | | |
| 160 | 995 | 210 | 1039 | 160 | 792 | 210 | 819 | | |
| 165 | 1039 | 210 | 1087 | 165 | 819 | 210 | 850 | | |
| 170 | 1087 | 215 | 1140 | 170 | 850 | 215 | 883 | | |
| 1/5 | 1140 | 220 | 1198 | 1/5 | 883 | 220 | 921 | l | |
| 180 | 1198 | 225 | 1263 | 180 | 921 | 225 | 962 | | |
| 185 | 1263 | 230 | 1334 | 185 | 962 | 230 | 1008 | | |
| 190 | 1334 | 235 | 1413 | 190 | 1008 | 235 | 1059 | 1 | |
| 195 | 1413 | 240 | 1500 | 195 | 1059 | 240 | 1115 | | |
| 200 | 1500 | 240 | 1097 | 200 | 1110 | 245 | 11/0 | l | |
| 205 | 1097 | 250 | 1703 | 205 | 11/0 | 250 | 1247 | | |
| 210 | 103 | 255 | 1020 | 210 | 1247 | 200 | 1323 | | |
| 215 | 1020 | 200 | 1950 | 215 | 1323 | 200 | 1407 | | |
| 220 | 1900 | 205 | 2092 | 220 | 1407 | 205 | 1500 | | |
| 220 | 2092 | 270 | 2250 | 220 | 1500 | 275 | 1715 | l . | |
| 230 | 2200 | 210 | 2410 | 230 | 1715 | 280 | 1840 | | |
| 200 | 2410 | | | 240 | 1840 | 285 | 1978 | | |
| | | | | 245 | 1078 | 200 | 2120 | | |
| | | | | 250 | 2129 | 295 | 2297 | | |
| l | | ļ | | 255 | 2297 | 300 | 2481 | | |
| | | | | 260 | 2481 | | | | |

(without Uncertainties for Instrumentation Errors)

·- ·

TABLE 18

32 EFPY Cooldown Curve Data Points Using 1998 Appendix G Methodology

| Stead | y State | 25° | F/hr. | 50° | F/hr. | 100 | °F/hr. |
|--------|----------|--------|----------|--------|----------|--------|----------|
| T (°F) | P (psig) | T (°F) | P (psig) | T (°F) | P (psig) | Т (°F) | P (psig) |
| 60 | 0 | 60 | 0 | 60 | 0 | 60 | 0 |
| 60 | 621 | 60 | 621 | 60 | 604 | 60 | 508 |
| 65 | 621 | 65 | 621 | 65 | 611 | 65 | 517 |
| 70 | 621 | 70 | 621 | 70 | 619 | 70 | 527 |
| 75 | 621 | 75 | 621 | 75 | 621 | 75 | 538 |
| 80 | 621 | 80 | 621 | 80 | 621 | 80 | 550 |
| 85 | 621 | 85 | 621 | 85 | 621 | 85 | 564 |
| 90 | 621 | 90 | 621 | 90 | 621 | 90 | 579 |
| 95 | 621 | 95 | 621 | 95 | 621 | 95 | 596 |
| 100 | 621 | 100 | 621 | 100 | 621 | 100 | 615 |
| 105 | 621 | 105 | 621 | 105 | 621 | 105 | 621 |
| 110 | 621 | 110 | 621 | 110 | 621 | 110 | 621 |
| 115 | 621 | 115 | 621 | 115 | 621 | 115 | 621 |
| 120 | 621 | 120 | 621 | 120 | 621 | 120 | 621 |
| 125 | 621 | 125 | 621 | 125 | 621 | 125 | 621 |
| 130 | 621 | 130 | 621 | 130 | 621 | 130 | 621 |
| 130 | 885 | 130 | 856 | 130 | 828 | 130 | 781 |
| 135 | 911 | 135 | 885 | 135 | 860 | 135 | 820 |
| 140 | 940 | 140 | 917 | 140 | 896 | 140 | 864 |
| 145 | 972 | 145 | 952 | 145 | 935 | 145 | 912 |
| 150 | 1008 | 150 | 991 | 150 | 978 | 150 | 966 |
| 155 | 1047 | 155 | 1035 | 155 | 1026 | 155 | 1025 |
| 160 | 1091 | 160 | 1082 | 160 | 1079 | 160 | 1079 |
| 165 | 1139 | 165 | 1136 | 165 | 1136 | 165 | 1136 |
| 170 | 1192 | 170 | 1192 | 170 | 1192 | 170 | 1192 |
| 175 | 1250 | 175 | 1250 | 175 | 1250 | 175 | 1250 |
| 180 | 1315 | 180 | 1315 | 180 | 1315 | 180 | 1315 |
| 185 | 1386 | 185 | 1386 | 185 | 1386 | 185 | 1386 |
| 190 | 1465 | 190 | 1465 | 190 | 1465 | 190 | 1465 |
| 195 | 1553 | 195 | 1553 | 195 | 1553 | 195 | 1553 |
| 200 | 1649 | 200 | 1649 | 200 | 1649 | 200 | 1649 |
| 205 | 1756 | 205 | 1756 | 205 | 1756 | 205 | 1756 |
| 210 | 1874 | 210 | 1874 | 210 | 1874 | 210 | 1874 |
| 215 | 2004 | 215 | 2004 | 215 | 2004 | 215 | 2004 |
| 220 | 2148 | 220 | 2148 | 220 | 2148 | 220 | 2148 |
| 225 | 2308 | 225 | 2308 | 225 | 2308 | 225 | 2308 |
| 1 230 | 2484 | 1 230 | 2484 | 1 230 | 2484 | 230 | 2484 |

(without Uncertainties for Instrumentation Errors)

__ II..

:

6. **REFERENCES**

6.1 Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials," U.S. Nuclear Regulatory Commission, May 1988

t,

- 6.2 WCAP-14040-NP-A, Revision 4, "Methodology used to Develop Cold Overpressure Mitigating system Setpoints and RCS Heatup and Cooldown Limit Curves", J.D. Andrachek, et. al., May 2004
- 6.3 ASME Code Case N-641, "Alternative Pressure-Temperature Relationship and Low Temperature Overpressure Protection System Requirements Section XI, Division 1", January 17, 2000.[Sub Reference 1: ASME Code Case N-640, "Alternative Reference Fracture Toughness for Development of P-T Limit Curves for Section XI, Division 1", February 26, 1999]
- 6.4 ASME Code 1998 Edition through the 2000 Addenda of Section XI, Appendix G
- 6.5 Code of Federal Regulations, 10 CFR Part 50, Appendix G, "Fracture Toughness Requirements", U.S. Nuclear Regulatory Commission, Washington, D.C., Federal Register, Volume 60, No. 243, dated December 19, 1995
- 6.6 "Fracture Toughness Requirements", Branch Technical Position MTEB 5-2, Chapter 5.3.2 in <u>Standard Review Plan</u> for the Review of Safety Analysis Reports for Nuclear Power Plants, LWR Edition, NUREG-0800, 1981
- 6.7 WCAP-12867, "Analysis of Capsule X from the South Carolina Electric & Gas Company Virgil C. Summer Unit 1 Reactor Vessel Radiation Surveillance Program", J. M. Chicots, et. al., March 1991
- 6.8 WCAP-16298-NP, "Analysis of Capsule Z From The South Carolina Electric & Gas Company, V. C. Summer Reactor Vessel Radiation Surveillance Program", C. M. Burton, et. al., August 2004
- 6.9 1989 Section III, Division 1 of the ASME Boiler and Pressure Vessel Code, Paragraph NB-2331, "Material for Vessels"
- 6.10 Regulatory Guide 1.190, "Calculational and Dosimetry Methods for Determining Pressure Vessel Neutron Fluence", March 2001

APPENDIX A

Thermal Stress Intensity Factors (K_{lt})

Thermal Stress Intensity Factors

In order to aid in the review and approval process, the NRC has typically requested that the thermal stress intensity factors be provided. This request was performed under the condition that only the thermal stress intensity factors for the maximum heatup and cooldown rates would be supplied for information. In recent history, this was accomplished via a letter report after the issuance of the PT limit curve. Now that it is known that the NRC will request this information upon each PT limit curve submittal, Westinghouse has decided to include the thermal stress intensity factors directly in the WCAP Report.

Presented in Tables A1 through A4 are the thermal stress intensity factors for the maximum heatup and maximum cooldown rates for the 32 and 56 EFPY PT limit curves. Note the following:

Vessel Radius to the 1/4T and 3/4T Locations are as follows:

- ¼T Radius = 80.563"
- ³⁄₄T Radius = 84.438"

ί,

•

:

| Water | Vessel | 1/AT Thermal | Vessel | 3/4T Thermal | | | |
|--|-------------------|--|-------------------|-------------------|--|--|--|
| Tomp | Tomporaturo | Stroce | Tomporaturo | Stross | | | |
| /0E) | 1/AT Location for | Intensity Eactor | 2/AT Location for | Intensity Eactor | | | |
| (°F) | 100°E/br Hostup | INCEISING PACION | 100°E/br Hostup | | | | |
| | | $(NS) \supset W, N, W, $ | | (1.51.502.1.11.1) | | | |
| | (°F) | | (°F) | | | | |
| 60 | 56.16 | -0.9848 | 55.07 | 0.4968 | | | |
| 65 | 58.99 | -2.3617 | 55.45 | 1.4567 | | | |
| PT Curves are Limited by Steady State Conditions up to 65°F and %T Limited for the Remainder of the Cu | | | | | | | |
| 70 | 62.22 | -3.4855 | 56.39 | 2.3654 | | | |
| 75 | 65.68 | -4.5265 | 57.88 | 3.1790 | | | |
| 80 | 69.41 | -5.3899 | 59.83 | 3.8791 | | | |
| 85 | 73.25 | -6.1620 | 62.20 | 4.4877 | | | |
| 90 | 77.29 | -6.8111 | 64.93 | 5.0115 | | | |
| 95 | 81.43 | -7.3918 | 67.96 | 5.4680 | | | |
| 100 | 85.70 | -7.8834 | 71.25 | 5.8624 | | | |
| 105 | 90.05 | -8.3232 | 74.77 | 6.2068 | | | |
| 110 | 94.49 | -8.6987 | 78.47 | 6.5079 | | | |
| 115 | 98.99 | -9.0368 | 82.34 | 6.7728 | | | |
| 120 | 103.56 | -9.3271 | 86.35 | 7.0052 | | | |
| 125 | 108.18 | -9.5901 | 90.47 | 7.2108 | | | |
| 130 | 112.84 | -9.8175 | 94.70 | 7.3923 | | | |
| 135 | 117.54 | -10.0250 | 99.02 | 7.5542 | | | |
| 140 | 122.28 | -10.2059 | 103.42 | 7.6982 | | | |
| 145 | 127.04 | -10.3726 | 107.87 | 7.8277 | | | |
| 150 | 131.82 | -10.5191 | 112.39 | 7.9441 | | | |
| 155 | 136.63 | -10.6556 | 116.95 | 8.0498 | | | |
| 160 | 141.45 | -10.7767 | 121.56 | 8.1456 | | | |
| 165 | 146.29 | -10.8909 | 126.20 | 8.2336 | | | |
| 170 | 151.14 | -10.9932 | 130.87 | 8.3143 | | | |
| 175 | 156.01 | -11.0907 | 135.57 | 8.3892 | | | |
| 180 | 160.88 | -11.1791 | 140.29 | 8.4587 | | | |
| 185 | 165.76 | -11.2644 | 145.03 | 8.5239 | | | |
| 190 | 170.65 | -11.3425 | 149.78 | 8.5851 | | | |
| 195 | 175.55 | -11.4186 | 154.56 | 8.6430 | | | |
| 200 | 180.45 | -11.4891 | 159.34 | 8.6980 | | | |
| 205 | 185.35 | -11.5585 | 164.13 | 8.7507 | | | |
| 210 | 190.26 | -11.6233 | 168.94 | 8.8011 | | | |
| 215 | 195.17 | -11.6877 | 173.75 | 8.8498 | | | |
| 220 | 200.09 | -11.7483 | 178.57 | 8.8968 | | | |
| 225 | 205.01 | -11.8089 | 183.39 | 8.9426 | | | |
| 230 | 209.93 | -11.8665 | 188.22 | 8.9871 | | | |
| 235 | 214.85 | -11.9244 | 193.06 | 9.0307 | | | |
| 240 | 219.77 | -11.9798 | 197.89 | 9.0734 | | | |
| 245 | 224.70 | -12.0356 | 202.73 | 9.1154 | | | |

TABLE A1K_{lt} Values for 100°F/hr Heatup Curve (32 EFPY)

· -----

TABLE A2

. _

K_{it} Values for 100°F/hr Cooldown Curve (32 EFPY)

| Water | Vessel Temperature | 100°F/hr Cooldown | | |
|-------------|--|---------------------|--|--|
| Temp. | @ 1/4T Location for | 1/4T Thermal Stress | | |
| (°F) | 100°F/hr Cooldown | Intensity Factor | | |
| | (°F) | (KSI SQ. RT. IN.) | | |
| 220 | 241.83 | 13.0578 | | |
| 215 | 236.76 | 13.0038 | | |
| 210 | 231.68 | 12.9503 | | |
| 205 | 226.61 | 12.8962 | | |
| 200 | 221.54 | 12.8428 | | |
| 195 | 216.47 | 12.7888 | | |
| 190 | 211.40 | 12.7354 | | |
| 185 | 206.33 | 12.6815 | | |
| 180 | 201.26 | 12.6282 | | |
| 175 | 196.18 | 12.5745 | | |
| 170 | 191.11 | 12.5214 | | |
| 165 | 186.04 | 12.4678 | | |
| 160 | 180.97 | 12.4149 | | |
| 155 | 175.90 | 12.3615 | | |
| 100°F Coold | 100°E Cooldown Rate is limited by the Steady State | | | |
| Cor | Condition from $T = 155^{\circ}F$ to 220°F | | | |
| 150 | 170.83 | 12 3087 | | |
| 145 | 165.76 | 12.3007 | | |
| 140 | 160.60 | 12 2030 | | |
| 135 | 155.62 | 12 1501 | | |
| 130 | 150.55 | 12.1301 | | |
| 125 | 145 47 | 12.0317 | | |
| 120 | 140.40 | 11 9928 | | |
| 115 | 135.33 | 11 9403 | | |
| 110 | 130.26 | 11 8884 | | |
| 105 | 125.19 | 11.8362 | | |
| 100 | 120.10 | 11 7844 | | |
| 95 | 115.05 | 11 7325 | | |
| 90 | 109.98 | 11 6810 | | |
| 85 | 104.92 | 11 6292 | | |
| 80 | 99.85 | 11.5780 | | |
| 75 | 94 78 | 11 5265 | | |
| 70 | 89.71 | 11.4755 | | |
| 65 | 84.64 | 11.4242 | | |
| 60 | 79.57 | 11.3727 | | |

_- H.

| r | | | | | | | |
|---|--------------|---|-------------------|-------------------|-------------------|--|--|
| l | Water | Vessel | 1/4T Thermal | Vessel | 3/4T Thermal | | |
| | Temp. | Temperature @ | Stress | Temperature @ | Stress | | |
| | (°F) | 1/4T Location for | Intensity Factor | 3/4T Location for | Intensity Factor | | |
| Į | | 100°F/hr Heatup | (KSI SQ. RT. IN.) | 100°F/hr Heatup | (KSI SQ. RT. IN.) | | |
| E | | (°F) | | · _ (°F) | | | |
| ĺ | 60 | 56.16 | -0.9848 | 55.07 | 0.4968 | | |
| | 65 | 58.99 | -2.3617 | 55.45 | 1.4567 | | |
| | PT Curves a | PT Curves are Limited by the %T Location up to 65°F and %T Limited for the Remainder of the Curve | | | | | |
| | 70 | 62.22 | -3.4855 | 56.39 | 2.3654 | | |
| l | 75 | 65.68 | -4.5265 | 57.88 | 3.1790 | | |
| | 80 | 69.41 | -5.3899 | 59.83 | 3.8791 | | |
| ł | 85 | 73.25 | -6.1620 | 62.20 | 4.4877 | | |
| ł | 90 | 77.29 | -6.8111 | 64.93 | 5.0115 | | |
| | 95 | 81.43 | -7.3918 | 67.96 | 5.4680 | | |
| | 100 | 85.70 | -7.8834 | 71.25 | 5.8624 | | |
| | 105 | 90.05 | -8.3232 | 74.77 | 6.2068 | | |
| | 110 | 94.49 | -8.6987 | 78.47 | 6.5079 | | |
| | 115 | 98.99 | -9.0368 | 82.34 | 6.7728 | | |
| | 120 . | 103.56 | -9.3271 | 86.35 | 7.0052 | | |
| l | 125 | 108.18 | -9.5901 | 90.47 | 7.2108 | | |
| ١ | 130 | 112.84 | -9.8175 | 94.70 | 7.3923 | | |
| | 135 | 117.54 | -10.0250 | 99.02 | 7.5542 | | |
| l | 140 | 122.28 | -10.2059 | 103.42 | 7.6982 | | |
| | 145 | 127.04 | -10.3726 | 107.87 | 7.8277 | | |
| l | 150 | 131.82 | -10.5191 | 112.39 | 7.9441 | | |
| Î | 155 | 136.63 | -10.6556 | 116.95 | 8.0498 | | |
| | 160 | 141.45 | -10.7767 | 121.56 | 8,1456 | | |
| | 165 | 146.29 | -10.8909 | 126.20 | 8.2336 | | |
| Į | 170 | 151.14 | -10.9932 | 130.87 | 8.3143 | | |
| ļ | 175 | 156.01 | -11.0907 | 135.57 | 8.3892 | | |
| | 180 | 160.88 | -11,1791 | 140.29 | 8.4587 | | |
| | 185 | 165.76 | -11.2644 | 145.03 | 8.5239 | | |
| | 190 | 170.65 | -11.3425 | 149.78 | 8.5851 | | |
| | 195 | 175.55 | -11.4186 | 154.56 | 8.6430 | | |
| | 200 | 180.45 | -11,4891 | 159.34 | 8.6980 | | |
| | 205 | 185.35 | -11.5585 | 164.13 | 8.7507 | | |
| | 210 | 190.26 | -11.6233 | 168.94 | 8.8011 | | |
| | 215 | 195.17 | -11.6877 | 173.75 | 8.8498 | | |
| | 220 | 200.09 | -11.7483 | 178.57 | 8 8968 | | |
| | 225 | 205.01 | -11,8089 | 183.39 | 8.9426 | | |
| | 230 | 209.93 | -11 8665 | 188 22 | 8 9871 | | |
| | 235 | 214 85 | -11,9244 | 193.06 | 9 0307 | | |
| | 200 | 214.05 | -11 0708 | 197.89 | 9 0734 | | |
| | 240 | 213.77 | -12 0356 | 202 73 | 9 1154 | | |
| | 240 | 224.70 | -12.0000 | 202.75 | 0 1567 | | |
| | 250 | 223.02 | -12 1/26 | 212 42 | 9 1076 | | |
| | 260 | 239.48 | -12 1962 | 217.72 | 9 2379 | | |
| f | 200 | 200.70 | I IE. IVVE | | 0.2010 | | |

| TABLE A3 | 1 · |
|--|-----------|
| K _{it} Values for 100°F/hr Heatup Curve | (56 EFPY) |

TABLE A4

K_{It} Values for 100°F/hr Cooldown Curve (56 EFPY)

| Water | Vessel Temperature | 100°F/hr Cooldown |
|-------------|-----------------------|---------------------|
| Temp. | @ 1/4T Location for | 1/4T Thermal Stress |
| (°F) | 100°F/hr Cooldown | Intensity Factor |
| | (°F) | (KSI SQ. RT. IN.) |
| 230 | 251.97 | 13.1653 |
| 225 | 246.90 | 13.1113 |
| 220 | 241.83 | 13.0578 |
| 215 | 236.76 | 13.0038 |
| 210 | 231.68 | 12.9503 |
| 205 | 226.61 | 12.8962 |
| 200 | 221.54 | 12.8428 |
| 195 | 216.47 | 12.7888 |
| 190 | 211.40 | 12.7354 |
| 185 | 206.33 | 12.6815 |
| 180 | 201.26 | 12.6282 |
| 175 | 196.18 | 12.5745 |
| 170 | 191.11 | 12.5214 |
| 165 | 186.04 | 12.4678 |
| 100°F Coold | own Rate is limited b | by the Steady State |
| Cor | ndition from T = 165° | F to 230°F |
| 160 | 180.97 | 12.4149 |
| 155 | 175.90 | 12.3615 |
| 150 | 170.83 | 12.3087 |
| 145 | 165.76 | 12.2556 |
| 140 | 160.69 | 12.2030 |
| 135 | 155.62 | 12.1501 |
| 130 | 150.55 | 12.0977 |
| 125 | 145.47 | 12.0450 |
| 120 | 140.40 | 11.9928 |
| 115 | 135.33 | 11.9403 |
| 110 | 130.26 | 11.8884 |
| 105 | 125.19 | 11.8362 |
| 100 | 120.12 | 11.7844 |
| 95 | 115.05 | 11.7325 |
| 90 | 109.98 | 11.6810 |
| 85 | 104.92 | 11.6292 |
| 80 | 99.85 | 11.5780 |
| 75 | 94.78 | 11.5265 |
| 70 | 89.71 | 11.4755 |
| 65 | 84.64 | 11.4242 |
| 60 | 79.57 | 11.3727 |

....