



**JAMES R MORRIS**  
Vice President, Nuclear Support  
Nuclear Generation

**Duke Power**  
526 South Church St.  
Charlotte, NC 28202

Mailing Address:  
EC07H / PO Box 1006  
Charlotte, NC 28201-1006

704 382 6401

704 382 6056 fax

[james.morris@duke-energy.com](mailto:james.morris@duke-energy.com)

June 14, 2005

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Subject: Duke Energy Corporation  
Oconee Nuclear Station, Docket Nos. 50-269, -270, -287  
McGuire Nuclear Station, Docket Nos. 50-369, -370  
Catawba Nuclear Station, Docket Nos. 50-413, -414  
Monthly Performance and Operation Status – May 2005

Please find attached information concerning the performance and operation status of the Oconee, McGuire and Catawba Nuclear Stations for the month of May 2005.

Please direct any questions or comments to Roger A. Williams at (704) 382-5346.

James R. Morris

Attachment

IE24

U.S. Nuclear Regulatory Commission  
Monthly Performance and Operation Status  
June 14, 2005  
Page 2

xc: W. D. Travers, Regional Administrator  
U.S. Nuclear Regulatory Commission  
Sam Nunn Atlanta Federal Center  
61 Forsythe Street SW, Suite 23T85  
Atlanta, GA 30303-8931

L. N. Olshan, Senior Project Manager (ONS)  
U.S. Nuclear Regulatory Commission  
11555 Rockville Pike Mail Stop O-8 G9A  
Rockville, MD 20852-2738

S. E. Peters, Project Manager (MNS and CNS)  
U.S. Nuclear Regulatory Commission  
11555 Rockville Pike Mail Stop O-8 G9A  
Rockville, MD 20852-2738

Ms. Margaret Aucoin  
Nuclear Assurance Corporation  
3930 E. Jones Bridge Road #300  
Norcross, GA 30092-2107

INPO Records Center  
700 Galleria Parkway  
Atlanta, GA 30339-5957

Dottie Sherman, ANI Library  
American Nuclear Insurers  
95 Glastonbury Blvd.  
Glastonbury, CT 06033

M. Shannon, Senior Resident Inspector, Oconee Nuclear Station  
J. Brady, Senior Resident Inspector, McGuire Nuclear Station  
E. Guthrie, Senior Resident Inspector, Catawba Nuclear Station

# Operating Data Report

Docket No.	<u>50-269</u>
Date	<u>June 13, 2005</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

- |   |                            |
|---|----------------------------|
| 1. Unit Name:   | Oconee 1                   |
| 2. Reporting Period:  | May 1, 2005 - May 31, 2005 |
| 3. Licensed Thermal Power (MWt):  | 2568                       |
| 4. Nameplate Rating (Gross MWe):  | 934                        |
| 5. Design Electrical Rating (Net Mwe):  | 886                        |
| 6. Maximum Dependable Capacity (Gross MWe):   | 886                        |
| 7. Maximum Dependable Capacity (Net MWe):   | 846                        |
| 8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons: |                            |

**Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.**

- 
9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
10. Reason for Restrictions, If any: \_\_\_\_\_
- 

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	3623.0	279432.0
12. Number of Hours Reactor was Critical	410.3	2762.5	221345.3
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	391.5	2742.4	217640.2
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	971937	7008175	539747800
17. Gross Electrical Energy Generated (MWH)	339726	2453173	186795701
18. Net Electrical Energy Generated (MWH)	319774	2342500	177721758
19. Unit Service Factor	52.6	75.7	77.9
20. Unit Availability Factor	52.6	75.7	77.9
21. Unit Capacity Factor (Using MDC Net)	50.8	76.4	74.6
22. Unit Capacity Factor (Using DER Net)	48.5	73.0	71.8
23. Unit Forced Outage Rate	0.0	0.0	8.8
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup
26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-269  
 UNIT NAME: Oconee 1  
 DATE: June 13, 2005  
 COMPLETED BY: Roger Williams  
 TELEPHONE: 704-382-5346

REPORT MONTH: May, 2005

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
1	05/01/05	S	239.85	C	4		END OF CYCLE 22 REFUELING OUTAGE
2	05/10/05	S	111.63	B	4		OUTAGE EXTENDED DUE TO REACTOR BUILDING COATING REPAIR
3	05/15/05	S	1.07	B	--		TURBINE OVERSPEED TRIP TEST

**Summary:**  
 Oconee unit 1 began the month of May, 2005 in end-of-cycle 22 refueling outage. The refueling outage was extended 4.65 days due to reactor building coating repairs. The refueling outage spanned 36.65 days. The unit was placed on-line 05/15/05 at 1529 holding at approximately 18% power. The turbine overspeed trip was performed at 2034 and the unit returned to service at 2138. During power escalation, the unit held at 27.6% power on 05/15/05 at 2315 to 05/16/05 at 0004 to evaluate low pressure turbine bearing #8 vibration. The unit held at 49.9% power from 0157 to 219 to change power escalation rate. The unit held at 73% power from 0804 to 1518 to perform intermediate power testing. On 05/16/05 from 1656 to 1903 the unit held at 80% power to perform functional check of incore detectors. The unit held at 89.8% power from 2139 to 05/17/05 at 0009 to change power escalation rate. The unit returned to 100% full power on 05/17/05 at 0533 and operated at or near 100% full power the remainder of the month.

(1) Reason

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 1
2. Scheduled next refueling shutdown: Currently Refueling
3. Scheduled restart following refueling: May 2005

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies  
(a) in the core: 177  
(b) in the spent fuel pool: 962\*  
(c) in the ISFSI: 2016\*\*
8. Present licensed fuel pool capacity: 1312  
Size of requested or planned increase: \*\*
9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*

DUKE POWER COMPANY

DATE: June 13, 2005

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

- \* Represents the combined total for Units 1 and 2
- \*\* On March 29, 1990, received a site specific license for ISFSI which will store 2112 assemblies (88 modules). Forty (40) site specific modules were constructed and loaded.
- \*\*\* In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded.  
Additional modules will be installed on an as-needed basis.
- \*\*\*\* Represents the combined total for Units 1, 2, and 3

# Operating Data Report

Docket No.	<u>50-270</u>
Date	<u>June 13, 2005</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

- |   |                            |
|---|----------------------------|
| 1. Unit Name:   | Oconee 2                   |
| 2. Reporting Period:  | May 1, 2005 - May 31, 2005 |
| 3. Licensed Thermal Power (MWt):  | 2568                       |
| 4. Nameplate Rating (Gross MWe):  | 934                        |
| 5. Design Electrical Rating (Net Mwe):  | 886                        |
| 6. Maximum Dependable Capacity (Gross MWe):   | 886                        |
| 7. Maximum Dependable Capacity (Net MWe):   | 846                        |
| 8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons: |                            |

**Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.**

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	3623.0	269352.0
12. Number of Hours Reactor was Critical	744.0	3623.0	220214.4
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	3623.0	217542.5
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1909976	9301502	539242836
17. Gross Electrical Energy Generated (MWH)	673922	3294998	185783099
18. Net Electrical Energy Generated (MWH)	646277	3164322	177129359
19. Unit Service Factor	100.0	100.0	80.8
20. Unit Availability Factor	100.0	100.0	80.8
21. Unit Capacity Factor (Using MDC Net)	102.7	103.2	77.1
22. Unit Capacity Factor (Using DER Net)	98.0	98.6	74.2
23. Unit Forced Outage Rate	0.0	0.0	8.0
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
 1 037 937 KVA x 0.90 Pf=934 MW

## UNIT SHUTDOWNS

DOCKET NO. 50-270UNIT NAME: Oconee 2DATE: June 13, 2005COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: May, 2005

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		
Summary:							

**(1) Reason**

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

**(2) Method**

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 2
2. Scheduled next refueling shutdown: October, 2005
3. Scheduled restart following refueling: November, 2005

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies  
(a) in the core: 177  
(b) in the spent fuel pool: 962\*  
(c) in the ISFSI: See unit 1 \*\*\*\*
8. Present licensed fuel pool capacity: 1312  
Size of requested or planned increase: \*\*
9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*

DUKE POWER COMPANY

DATE: June 13, 2005

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

\* Represents the combined total for Units 1 and 2

\*\* See footnote on Unit 1

\*\*\* In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded. Additional modules will be installed on an as-needed basis.

\*\*\*\* See footnote on Unit 1



# Operating Data Report

Docket No.	<u>50-287</u>
Date	<u>June 13, 2005</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

1. Unit Name: Oconee 3
2. Reporting Period: May 1, 2005 - May 31, 2005
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net Mwe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

**Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.**

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	3623.0	266999.0
12. Number of Hours Reactor was Critical	744.0	3486.6	212859.6
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	3418.2	209991.7
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1908743	8645737	525962692
17. Gross Electrical Energy Generated (MWH)	678511	3078945	182235576
18. Net Electrical Energy Generated (MWH)	651166	2950438	173902378
19. Unit Service Factor	100.0	94.3	78.6
20. Unit Availability Factor	100.0	94.3	78.6
21. Unit Capacity Factor (Using MDC Net)	103.5	96.3	76.4
22. Unit Capacity Factor (Using DER Net)	98.8	91.9	73.5
23. Unit Forced Outage Rate	0.0	4.4	8.6
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:  
 $1\ 037\ 937\ \text{KVA} \times 0.90\ \text{Pf} = 934\ \text{MW}$

### UNIT SHUTDOWNS

**DOCKET NO.** 50-287  
**UNIT NAME:** Oconee 3  
**DATE:** June 13, 2005  
**COMPLETED BY:** Roger Williams  
**TELEPHONE:** 704-382-5346

**REPORT MONTH:** May, 2005

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		

**Summary:**

- (1) Reason**
- A - Equipment failure (Explain)
  - B - Maintenance or Test
  - C - Refueling
  - D - Regulatory restriction
  - E - Operator Training/License Examination
  - F - Administrative
  - G - Operator Error (Explain)
  - H - Other (Explain)

- (2) Method**
- 1 - Manual
  - 2 - Manual Trip/Scram
  - 3 - Automatic Trip/Scram
  - 4 - Continuation
  - 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 3
2. Scheduled next refueling shutdown: April 2006
3. Scheduled restart following refueling: May 2006

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies           (a)     in the core: 177  
   (b)     in the spent fuel pool: 460  
   (c)     in the ISFSI: See Unit 1 \*\*\*\*
8. Present licensed fuel pool capacity: 825  
Size of requested or planned increase: \*\*
9. Projected date of last refueling which can be accommodated by present capacity: January 2005\*\*\*\*

DUKE POWER COMPANY

DATE: June 13, 2005

Name of Contact:       R. A. Williams

Phone: (704) - 382-5346

\*\* See footnote of Unit 1

\*\*\* In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded.  
Additional modules will be installed on an as-needed basis.

\*\*\*\* See footnote on Unit 1

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

APRIL 2005

1. Personnel Exposure -

The total station liquid release for APRIL has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for APRIL has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.



## UNIT SHUTDOWNS

DOCKET NO. 50-369UNIT NAME: McGuire 1DATE: June 13, 2005COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: May, 2005

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		
Summary:							

**(1) Reason**

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

**(2) Method**

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation







### UNIT SHUTDOWNS

**DOCKET NO.** 50-370  
**UNIT NAME:** McGuire 2  
**DATE:** June 13, 2005  
**COMPLETED BY:** Roger Williams  
**TELEPHONE:** 704-382-5346

**REPORT MONTH:** May, 2005

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			<b>No</b>	<b>Outages</b>	<b>for the Month</b>		

**Summary:**

**(1) Reason**

- |                                 |   |
|---------------------------------|---|
| A - Equipment failure (Explain) | E - Operator Training/License Examination |
| B - Maintenance or Test         | F - Administrative                        |
| C - Refueling                   | G - Operator Error (Explain)              |
| D - Regulatory restriction      | H - Other (Explain)                       |

**(2) Method**

- |                          |                       |
|--------------------------|-----------------------|
| 1 - Manual               | 2 - Manual Trip/Scram |
| 3 - Automatic Trip/Scram | 4 - Continuation      |
| 5 - Other (Explain)      |                       |

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: McGuire Unit 2
2. Scheduled next refueling shutdown: September 2006
3. Scheduled restart following refueling: October 2006

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies           (a)     in the core: 193  
   (b)     in the spent fuel pool: 1166  
   (c)     in the ISFSI: 368
8. Present licensed fuel pool capacity: 1463  
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present license capacity:  
June 2003

DUKE POWER COMPANY

DATE: June 13, 2005

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

McGUIRE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

APRIL 2005

1. Personnel Exposure -

The total station liquid release for APRIL has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for APRIL has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.



## UNIT SHUTDOWNS

**DOCKET NO.** 50-413

**UNIT NAME:** Catawba 1

**DATE:** June 13, 2005

**COMPLETED BY:** Roger Williams

**TELEPHONE:** 704-382-5346

**REPORT MONTH:** May, 2005

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
1	05/07/05	S	595.13	C	I		END-OF-CYCLE 15 REFUELING OUTAGE

**Summary:**

Catawba unit 1 began the month of May, 2005 operating at or near 100% full power. On 05/04/05 at 2000 the unit began decreasing power to perform main steam safety valve testing. The unit held at 95% power from 05/05/2005 at 0110 to 1732 to perform main steam safety valve testing. The unit returned to 100% full power on 05/06/05 at 0136. On 05/06/05 at 2034 the unit began decreasing power to begin end-of-cycle 15 refueling outage. The unit was taken off-line 05/07/05 at 0452 to begin end-of-cycle 15 refueling outage. The unit was in the end-of-cycle 15 refueling outage the remainder of the month.

**(1) Reason**

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)



# Operating Data Report

Docket No.	<u>50-414</u>
Date	<u>June 13, 2005</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

## Operating Status

- |   |                            |
|---|----------------------------|
| 1. Unit Name:   | Catawba 2                  |
| 2. Reporting Period:  | May 1, 2005 - May 31, 2005 |
| 3. Licensed Thermal Power (MWt):  | 3411                       |
| 4. Nameplate Rating (Gross MWe):  | 1305 *                     |
| 5. Design Electrical Rating (Net Mwe):  | 1145                       |
| 6. Maximum Dependable Capacity (Gross MWe):   | 1192                       |
| 7. Maximum Dependable Capacity (Net MWe):   | 1129                       |
| 8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons: |                            |

Notes: \*Nameplate Rating (GrossMWe) calculated as 1450.000 MVA \* .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

10. Reason for Restrictions, If any: \_\_\_\_\_

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	3623.0	164664.0
12. Number of Hours Reactor was Critical	744.0	3623.0	139274.9
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	721.2	3600.2	137771.8
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	2432705	12238452	454594921
17. Gross Electrical Energy Generated (MWH)	863973	4397151	162167787
18. Net Electrical Energy Generated (MWH)	817713	4179986	153318702
19. Unit Service Factor	96.9	99.4	83.7
20. Unit Availability Factor	96.9	99.4	83.7
21. Unit Capacity Factor (Using MDC Net)	97.3	102.2	82.4
22. Unit Capacity Factor (Using DER Net)	96.0	100.8	81.3
23. Unit Forced Outage Rate	3.1	0.6	6.0
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

**UNIT SHUTDOWNS**

**DOCKET NO.** 50-414  
**UNIT NAME:** Catawba 2  
**DATE:** June 13, 2005  
**COMPLETED BY:** Roger Williams  
**TELEPHONE:** 704-382-5346

**REPORT MONTH:** May, 2005

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
1	05/11/05	F	22.77	A	2		TURBINE VALVE CONTROL OIL LEAK

**Summary:**  
 Catawba unit 2 began the month of May, 2005 operating at or near 100% full power. On 05/10/05 at 0839 the unit began decreasing power due to a spurious trip of both "C" heater drain pumps and held at 97% power from 0843 to 1300. The unit returned to 100% full power on 05/10/05 at 1507. On 05/11/05 at 2050 the unit began decreasing power and was taken off-line 05/11/05 at 2053 due to a turbine valve control oil leak. The unit was placed on-line 05/12/05 at 1939. During power escalation, the unit held at 21% power from 2030 to 05/13/05 at 0220 pending completion of swap to main feedwater nozzles.. The unit held at 85% power from 1009 to 1058 to perform the main turbine control valve movement performance test. The unit returned to 100% full power on 05/13/05 at 1429. On 05/15/05 at 1226 the unit began decreasing power due to condenser vacuum as a result of 2A cooling tower fans being shutdown for 1HTA outage work and held at 96% power from 1335 to 1454. The unit returned to 100% full power on 05/15/05 at 1800 and operated at or near 100% full power the remainder of the month.

**(1) Reason**

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)





CATAWBA NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

APRIL 2005

1. Personnel Exposure -

The total station liquid release for APRIL has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for APRIL has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.