



**Constellation Energy**

Nine Mile Point Nuclear Station

P.O. Box 63  
Lycoming, NY 13093

June 16, 2005  
NMP1L 1959

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

**SUBJECT:** Nine Mile Point Unit 1  
Docket No. 50-220  
License No. DPR-63

Cycle 17 Core Operating Limits Report, Revision 0

Gentlemen:

Attached is a copy of the Cycle 17 Core Operating Limits Report (COLR), Revision 0, for Nine Mile Point Unit 1 (NMP1). This report is being submitted pursuant to NMP1 Technical Specification 6.6.5.d.

Very truly yours,

William C. Holston  
Manager Engineering Services

WCH/RF/sac  
Attachment

cc: Mr. S. J. Collins, NRC Regional Administrator, Region I  
Mr. G. K. Hunegs, NRC Senior Resident Inspector  
Mr. P. S. Tam, Senior Project Manager, NRR (2 copies)







A001

NINE MILE POINT UNIT 1

CORE OPERATING LIMITS REPORT

Document No.: COLR1-17

Revision 0

|                            | <u>Name</u>  | <u>Title</u>                       | <u>Date</u> |
|----------------------------|--|------------------------------------|-------------|
| Prepared by:               | <br>C. W. Lepine      | Fuel Engineer                      | 4-5-05      |
| Reviewed by:               | <br>J. L. Winklebleck | Fuel Engineer                      | 4-5-05      |
| Independently Reviewed by: | <br>R. S. Close     | Fuel Engineer                      | 4-5-05      |
| Approved by:               | <br>M. A. Armenta   | Supervisor, Nuclear Fuels Services | 4/6/05      |
| Approved by:               | <br>J. N. Darweesh  | Supervisor, Reactor Engineering    | 4/6/05      |
| Approved by:               | <br>G. S. Pavis     | Director, Nuclear Fuels Services   | 4/7/05      |

This Controlled Document provides cycle specific core operating limits for use in conjunction with the Nine Mile Point Unit 1 Technical Specifications. Document pages may only be changed through a reissue of the entire document.

**CORE OPERATING LIMITS REPORT**

**Table of Contents**

---

|  | <u>Page</u> |
|--|-------------|
| <b>1.0 AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR).....</b>    | <b>1</b>    |
| <b>1.1 Limits for Technical Specification 3.1.7.a.....</b>             | <b>1</b>    |
| <b>1.2 Limits for Technical Specification 3.1.7.e.....</b>             | <b>1</b>    |
| <b>2.0 MINIMUM CRITICAL POWER RATIO (MCPR).....</b>                    | <b>2</b>    |
| <b>2.1 Limits for Technical Specification 3.1.7.c.....</b>             | <b>2</b>    |
| <b>2.2 Limits for Technical Specification 3.1.7.e.....</b>             | <b>2</b>    |
| <b>3.0 LINEAR HEAT GENERATION RATE (LHGR) .....</b>                    | <b>3</b>    |
| <b>3.1 Limits for Technical Specifications 3.1.7.b.....</b>            | <b>3</b>    |
| <b>4.0 POWER/FLOW RELATIONSHIP DURING OPERATION.....</b>               | <b>4</b>    |
| <b>4.1 Limits for Technical Specification Table 3.1.7.d and e.....</b> | <b>4</b>    |
| <b>5.0 REFERENCES FOR TECHNICAL SPECIFICATIONS.....</b>                | <b>4</b>    |
| <b>6.0 SOURCE DOCUMENTS .....</b>                                      | <b>5</b>    |

**CORE OPERATING LIMITS REPORT****1.0 AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)****1.1 Limits for Technical Specification 3.1.7.a**

During power operation, the APLHGR for each type of fuel as function of average planar exposure shall not exceed the limiting values shown in Table 1.

**1.2 Limits for Technical Specification 3.1.7.e**

During partial loop operation with four recirculation loops in operation, the APLHGR as a function of average planar exposure shall not exceed 98 percent of the limiting values shown in Table 1.

During partial loop operation with three recirculation loops in operation, the APLHGR as a function of average planar exposure shall not exceed 98 percent of the limiting values shown in Table 1.

## 2.0 MINIMUM CRITICAL POWER RATIO (MCPR)

### 2.1 Limits for Technical Specification 3.1.7.c

During power operation, the operating MCPR at rated power and flow shall be greater than or equal to the Operating Limit MCPR of:

1.48<sup>(1)</sup> for cycle exposures<sup>(2)</sup> from BOC19 to EOR19-2417 MWd/ST, and  
1.53<sup>(1)</sup> for cycle exposures<sup>(2)</sup> from EOR19-2417 MWd/ST to EOC19.

If the feedwater pump configuration, as defined by Nuclear Engineering Report No. NER-1M-022, is such that a feedwater controller failure could result in maximum feedwater flow greater than that for two feedwater pumps (i.e., the shaft-driven pump plus one motor-driven pump), then the Operating Limit MCPR shall be 1.59.

For core flows other than rated, the MCPR limit shall be the Operating Limit MCPR identified above times  $K_f$  where  $K_f$  is as shown in Figure 2a.

Additional limits for operation between 45% and 90% Rated Thermal Power (RTP)<sup>(3)(4)</sup> are required for operations without a backup pressure regulator. These limits are shown in Figure 2b.

### 2.2 Limits for Technical Specification 3.1.7.e

During 3 loop operation, the Operating Limit MCPR shall be increased by 0.02. No adjustment is needed during 4 loop operation.

- NOTES:**
- (1) Based on a 1.07 MCPR Safety Limit (SLCPR).
  - (2) These cycle exposures are defined in the Cycle Management Report.
  - (3) Below 45% and above 90% RTP no additional limits are required for operation without a backup pressure regulator.
  - (4) These limits are valid for 3, 4, and 5 loop operation. (Note that for the MCPR Limit for  $70\% \leq 90\%$ , i.e. MCPR Limit = (Rated OLMCPR) / FRTP, the Rated OLMCPR is as determined by 2.1 and 2.2 above.)

### 3.0 LINEAR HEAT GENERATION RATE (LHGR)

#### 3.1 Limits for Technical Specification 3.1.7.b

During power operation, the Linear Heat Generation Rate (LHGR) of any rod in any fuel assembly at any axial location shall not exceed the limiting values shown in RSLD-18, Revision 0, "Nine Mile Point Unit 1 Reload 18, Reload Specific Lattice Data". This document contains the LHGR limits for both UO<sub>2</sub> rods (which contain no gadolinium) and the most limiting gadolinium-bearing rods. Other gadolinium-bearing rods have LHGR limits which lie between these two curves. Compliance with these limits will be monitored by the plant's process computer.

Additional limits for operation between 45% and 90% RTP<sup>(1)</sup> are required for operations without a backup pressure regulator. These limits are shown in Figure 3.

**NOTE:**           (1)   Below 45% and above 90% RTP no additional limits are required for operation without a backup pressure regulator.

**4.0 POWER/FLOW RELATIONSHIP DURING OPERATION**

**4.1 Limits for Technical Specification 3.1.7.d and e**

The power/flow relationship shall not exceed the limiting values shown in Figure 4.

**5.0 REFERENCES FOR TECHNICAL SPECIFICATIONS**

**Technical Specification 6.6.5.b:**

NEDE 24011-P-A, "General Electric Standard Application for Reactor Fuel,"  
U.S. Supplement, Revision 14, June 2000.

6.0 SOURCE DOCUMENTS

The Core Operating Limits contained in this report were obtained from the following documents:

| CORE OPERATING LIMITS   | REFERENCE   |
|---|---|
| <p><u>APLHGR Limits (Section 1.0)</u><br/>Table 1<br/>and corresponding three and four<br/>loop multipliers</p> | <p>0000-0017-3629-SRLR, Revision 1, March 2005,<br/>Supplemental Reload Licensing Report for<br/>Nine Mile Point Nuclear Power Station Unit 1,<br/>Reload 18 Cycle 17</p> |
| <p><u>MCPR Limits (Section 2)</u></p>   | <p>0000-0017-3629-SRLR, Revision 1, March 2005,<br/>Supplemental Reload Licensing Report for<br/>Nine Mile Point Nuclear Power Station Unit 1,<br/>Reload 18 Cycle 17</p> |
| <p>Pressure Regulator Out-of-Service<br/>Restriction</p>  | <p>0000-0017-3637-ER, Revision 0, March 2005,<br/>Engineering Report for Nine Mile Point Nuclear<br/>Power Station Unit 1, Reload 18 Cycle 17</p>                         |
| <p><u>LHGR Limits (Section 3)</u></p>   | <p>GE-NE-J11-03433-16-01-R1, "Pressure Regulator<br/>Out of Service Calculations for Nine Mile Point<br/>Unit 1", January 2005</p>  |
| <p>Pressure Regulator Out-of-Service<br/>Restriction</p>  | <p>GE-NE-J11-03433-16-01-R1, "Pressure Regulator<br/>Out of Service Calculations for Nine Mile Point<br/>Unit 1", January 2005</p>  |
| <p><u>Power/Flow Relationship (Section 4)</u></p>   | <p>0000-0017-3629-FBIR, Revision 0, "Fuel Bundle<br/>Information Report for Nine Mile Point Nuclear Station<br/>Unit 1 Reload 18 Cycle 17," March, 2005.</p>              |
| <p><u>Power/Flow Relationship (Section 4)</u></p>   | <p>NMP1 Technical Specification Amendment 92, Figure<br/>3.1.7.aa</p>   |



Table 1

MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

| Average Planar Exposure<br>GWd/ST | MAPLHGR Limits (kw/ft) |                    |                     |                     |                    |
|-----------------------------------|------------------------|--------------------|---------------------|---------------------|--------------------|
|                                   | Bundle<br>GE11-C14     | Bundle<br>GE11-C15 | Bundle<br>GE11-C16A | Bundle<br>GE11-C16B | Bundle<br>GE11-C17 |
| 0.00                              | 8.90                   | 8.82               | 9.93                | 9.93                | 9.81               |
| 0.20                              | 8.90                   | 8.82               | 9.93                | 9.93                | 9.81               |
| 1.00                              | 8.96                   | 8.89               | 9.89                | 9.90                | 9.78               |
| 5.00                              | 9.32                   | 9.22               | 9.78                | 9.70                | 9.64               |
| 10.00                             | 9.66                   | 9.56               | 9.61                | 9.67                | 9.49               |
| 15.00                             | 9.57                   | 9.50               | 9.53                | 9.53                | 9.36               |
| 17.50                             | 9.33                   | 9.49               | 9.53                | 9.53                | -                  |
| 20.00                             | 8.64                   | 9.44               | 8.88                | 8.88                | 8.87               |
| 25.00                             | 8.46                   | 8.58               | 8.61                | 8.61                | 8.41               |
| 30.00                             | -                      | 8.32               | 8.45                | 8.45                | -                  |
| 35.00                             | 7.90                   | 8.26               | 8.42                | 8.42                | 8.30               |
| 45.00                             | 6.79                   | 8.34               | 8.44                | 8.44                | 8.31               |
| 50.00                             | 6.31                   | -                  | 8.47                | 8.47                | -                  |
| 55.00                             | -                      | 8.41               | 8.48                | 8.48                | 8.37               |
| 65.00                             | 6.38                   | 8.48               | 6.38                | 6.38                | 8.46               |
|                                   |                        |                    |                     |                     |                    |
|                                   |                        |                    |                     |                     |                    |
|                                   |                        |                    |                     |                     |                    |
|                                   |                        |                    |                     |                     |                    |
|                                   |                        |                    |                     |                     |                    |
|                                   |                        |                    |                     |                     |                    |

NOTE:

- (1) A "-" indicates that there is no entry for this box and the limit can be determined by linearly interpolating between the previous and next point in each column. MAPLHGRs are interpolated between exposure points for which explicit values are given.
- (2) These MAPLHGR are not lattice dependent. The values shown also correspond to the limiting value for the most limiting lattice for use when hand calculations are required.

| Fuel Type                           | ID        |
|-------------------------------------|-----------|
| GE11-P9DUB339-12GZ-100T-145-T6-2537 | GE11-C14  |
| GE11-P9DUB362-13GZ-100T-145-T6-3899 | GE11-C15  |
| GE11-P9DUB376-12GZ-100T-145-T6-2585 | GE11-C16A |
| GE11-P9DUB376-12GZ-100T-145-T6-2586 | GE11-C16B |
| GE11-P9DUB382-13GZ-100T-145-T6-2831 | GE11-C17  |

Figure 2a NMP-1 K(f) Curve for MCPR




Figure 2b: MCPR Limits for Operation Between 45% and 90% RTP  
Without a Backup Pressure Regulator




Figure 3: LHGR Limits for Operation Between 45% and 90% RTP  
Without a Backup Pressure Regulator




Figure4 Limiting Power/Flow Line

