DCS No.: 05000333050630 Date: July 1, 2005

#### PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-I-05-020

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility	
Entergy Nuclear Northeast	Licensee Emergency Classification
James A. FitzPatrick Nuclear Power Plant	X Notification of Unusual Event
Lycoming, New York 13093	Alert
	Site Area Emergency
Docket: 50-333	General Emergency
License: DPR-059	Not Applicable

Egoility

### SUBJECT: SHUTDOWN EXPECTED TO BE GREATER THAN 72 HOURS TO REPAIR A SMALL CRACK IN THE TORUS PORTION OF PRIMARY CONTAINMENT

Entergy's James A. FitzPatrick plant declared the Primary Containment inoperable due to a small crack located below the waterline of the torus at 7:29 p.m. on June 30, 2005. The plant began a Technical Specification required shutdown to cold shutdown. In addition, Entergy declared a Notification of Unusual Event (NOUE) in accordance with EAL 9.1.2, for the "Potential Loss of Containment." The crack was initially identified during a walk down associated with an unrelated surveillance test on June 27, 2005. The crack had an active "weeping" leak of torus water at a rate of one to two drops per minute to the torus room floor. The crack was determined to be "X" shaped with a major dimension of 4.6 inches in length. Entergy developed a reasonable expectation of operability shortly after the discovery of the crack. This initial evaluation identified a maximum acceptable crack length under required design conditions. The maximum acceptable crack length that was calculated was 16.8 inches, therefore Entergy initially believed that the primary containment was operable. On June 29, 2005, it was determined that the high pressure coolant injection (HPCI) pump turbine exhaust was located near the crack in the torus. Entergy re-evaluated their operability evaluation, and determined that the torus and thus the primary containment were inoperable due to the potential for cyclic thermal stresses at the crack location caused by HPCI pump exhaust during a postulated Small Break LOCA.

As of 12:00 p.m. on July 1, 2005, the plant is in Mode 3 at 140 psig, and in the process of cooling down. Entergy plans to complete the plant cool down to Mode 4 by approximately 5:00 p.m. on July 1, 2005, and terminate the NOUE at that time.

The licensee currently plans to complete a code repair of the crack area and perform required testing of the repair prior to restart of the unit.

The Region 1 Public Affairs has been responding to media inquiries. The State of New York was notified. Entergy released a statement to the press during the evening of June 30, 2005, stating that a NOUE had been declared, the plant was being shutdown, and that a small leak exists in the torus.

Region 1 received initial notification of this occurrence by phone to the Resident Inspector by control room personnel at approximately 7:30 p.m. on June 30, 2005. The information presented herein has been discussed with the licensee, and is current as of 12:00 p.m. on July 1, 2005.

ADAMS Accession Number: ML051820371

CONTACT: John R. White (610) 337-5114

#### **DISTRIBUTION: (PN Recipient List)**

OWFN Chairman Meserve Comm. Dicus Comm. Diaz Comm. McGaffigan Jr. Comm. Merrifield OIP OCA OGC OPA EDO OE NRR SECY	TWFN IRO NMSS ACRS OIG RES NSIR	<u>LST</u> PDR
Regional Offices		
By Fax: DOT:Trans INPO NSAC RI Resident Office Licensee:		

# ML051820371

# SISP Review Complete: <u>DEJ</u> (Reviewer's Initials)

### DOCUMENT NAME: E:\Filenet\ML051820371.wpd

After declaring this document "An Official Agency Record" it <u>will</u> be released to the Public. To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/ORA		RI/ORA		RI/DRP		RI/DRP			
NAME	RBores/SAM for DS		DScrenci/DPS		DJackson/DEJ		BHolian/BEH			
DATE	07/01/05		07/01/05		07/01/05		07/01/05			

OFFICIAL RECORD COPY

Region I Form 83

(Rev. July 2, 2003)