

TABLE 4.2-1

SECTION A. MISCELLANEOUS INSPECTIONS

<u>Item No.</u>	<u>Required Examination Area</u>	<u>Required Examination Methods</u>	<u>10-Year Interval Inspection</u>	<u>Remarks</u>
1.1	Deleted			
1.2	Low Head SIS piping located in valve pit	Visual	Non-applicable	This pipe shall be visually inspected once per 18 months.
1.3	Primary Pump Flywheel	See remarks	See remarks	Inspect once every 20 years by a qualified in-place UT examination over the volume from the inner bore of the flywheel to the circle of one-half the outer radius or a surface examination (MT and/or PT) of exposed surfaces defined by the volume of the disassembled flywheels. The provisions of Specification 4.0.2 are not applicable.
1.4	Low Pressure Turbine Rotor	Visual and Magnetic Particle or Dye Penetrant	See remarks	100% of blades every six operating years. Inspections are normally performed concurrent with LP turbine rotor disk and hub inspections.

Amendment Nos. 242 and 241