

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.3.7.1 Perform CHANNEL CHECK.	12 hours
SR 3.3.7.2 Perform CHANNEL FUNCTIONAL TEST.	24 months
<p>SR 3.3.7.3 Perform CHANNEL CALIBRATION with setpoint Allowable Values as follows:</p> <p>a. Degraded Voltage Function:</p> <ul style="list-style-type: none"> i. Dropout ≥ 4123.0 V* ii. Pickup ≤ 4144.6 V* <p>SDVS (Sustained Degraded Grid Voltage Signal):</p> <p>Time delay:</p> <ul style="list-style-type: none"> i. 127D ≤ 2.17 seconds. ii. 162D ≥ 78 seconds and ≤ 128 seconds. <p>DGVSS (Degraded Grid Voltage with SIAS Signal):</p> <p>Time delay:</p> <ul style="list-style-type: none"> i. 127D ≥ 1.83 seconds and ≤ 2.17 seconds. ii. 162S ≥ 4.16 seconds and ≤ 4.44 seconds. iii. 162T ≥ 0.88 seconds and ≤ 1.62 seconds. <p>b. Loss of Voltage Function ≥ 3554 V and ≤ 3796 V</p> <p>Time delay: ≥ 0.75 seconds and ≤ 1.0 seconds at 0 V.</p>	24 months

* Dropout and pickup values will be set to ≥ 4151.0 V and ≤ 4172.8 V, respectively, until actions identified in SCE submittal dated May 27, 2005 are completed.