

g-58



Plant Status Report

Plant: Point Beach Nuclear Plant

Date: Tuesday, April 13, 2004

Operations Report (Summary of Last 24 Hours of Operations):

Unit 1 is at refueling shutdown (Mode 6). Reactor coolant system is at 70%. Unit 2 is at 100% power.

Days Without LTA: 570

Homeland Security Condition: Yellow

Unit 1				Unit 2			
PWR Mode 6	PWR Level 0%	MWE (Gross) 0	MWE (Net) 0	PWR Mode 1	PWR Level 100%	MWE (Gross) 543.3	MWE (Net) 521.2
Days On Line: 0		Days Since Last Reactor Trip: 271		Days On Line: 145		Days Since Last Reactor Trip: 277	

Technical Specification Action Conditions

Item	Unit	Condition	Out of Service		Length (Hr/Days)	Tech Spec Number	Expires		Responsibility	Equip Expected RTS Date
			Date	Time			Date	Time		
2RC-508, U2C RMW Supply	2	Out of service.	11/9/03	0749	31 Days	3.6.3.A	4/26/04	1900	M. Rosseau	8/27/04

Major Equipment Out of Service or Degraded

Item	Unit	Condition	Date	Time	Work Order Number	Due Date	Responsibility
K-2B, Instrument Air Compressor	0	Failed SW solenoid.	4/8/04	1708	WO 0407694	4/12/04	D. Laing
G-500, G-05 GT Generator Starting Diesel Engine	0	Out of service. Fuel oil leak.	4/11/04	2250	WO 0407739	4/12/04	N. Stuart

Operational Problems / Concerns

Item	Unit	Condition	Actions Needed	Due Date	Responsibility
W-30B, F-23/F-29 PAB Exhaust Filter Fan	0	Motor failed.	Motor on-site for re-installation.	4/10/04	D. Laing
2RC-508, U2C Reactor Makeup Supply	2	Valve comes off shut seat momentarily when RMW pump starts.	Provide decision tree to Plant Manager.	4/16/04	K. Krause
Unit 2, Excess Letdown Flow	2	Inadequate excess letdown flow.	Open and inspect, 2CV-285.	5/7/04	N. Stuart
2RE-215, 2HX-46 Air Ejector Gas Monitor	2	Elevated indication, temperature related.	4 step action plan is developed. Scheduled completion is 5/14/04.	5/14/04	B. Carberry

Aggregate Review of Issues

Item	Unit	Condition	Actions Planned	Due Date	Responsibility
NONE					

Reportable Events

NONE

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 4
FOIA/PA-2604-0282

S-55

Plant Status Report

Outstanding Operability Determinations
NONE
Protected Equipment
Load Changes (Planned or Unplanned)
NONE

ex4

Reactor Coolant System Leakage		
	Unit 1	Unit 2
Unidentified (gpm)	0 (No leak rate determined due to draindown)	0.05
Identified (gpm)	0	0.03
Major Tests and Evolutions Scheduled in Next 24 Hours		
Unit 2, 2ICP 2.3, reactor protection logic test.		
Unit 2, 2ICP 2.5, safeguards logic test.		
Unit 2, 2TS-ECCS-2, safeguards system venting.		

U#1 ACTIVITIES :

HEAD STUDS REMOVED
POLAR CRANE T/S DONE
RCP MOTOR LIFT
FUEL XFER CHECKOUT
RV HEAD UNDER INSP. PREP.

3 ACTIVE SROs REMOVED
FROM OCA ON ADMIN.
LEAVE PENDING . . . +
1 MANAGER IN OPERATIONS.

NRC ACTIVITIES :

RYAN ALEXANDER - RP
MEL HILMBERG - IS1
BRUCE PALADY - TI 153 : JUMP