

Site Communication

Revised 4/12/04

Priorities:

- The Safe Operation of Unit 2
- Safely Commence Scheduled Outage Work Activities on Unit 1 and Common Systems Using Unit 1 R28 Recovery and Restart Checklist

- 1st Priority Increase RCS Inventory and Exit Safety Assessment "Yellow" Conditions on Core Cooling and Inventory
- 2nd Priority Focused Specialty Activities
 - SG Eddy Current and Sludge Lancing
 - Main Turbine and Generator Work
 - Rx Vessel Head Inspection
 - Hx Hydro Lance and Eddy Current
- 3rd Priority Remaining Scheduled Work

Communication Improvement Initiatives

Due to the recent problems encountered with outage activities, changes are being made to improve communication and turnovers and to focus our efforts on achieving all green shutdown safety assessment parameters. Effective 4/13/2004 at 0600 the following expectations are in effect:

Outage Briefing Schedule - NSB Cafeteria:

Day Shift	Night Shift	Activity
0600 – 0640	1800 – 1840	OCC Turnover **
0645 – 0725	1845 – 1925	Supervisor Communication of OCC Turnover to Work Force
0730 – 0800	1930 – 2000	Supervisor Feedback to OCC of Turnover to Work Force

** Outage Briefing Schedule Notes:

- The following personnel are required to attend the OCC turnover meeting: Upcoming shift supervisory personnel, General Supervisors, temporary supervisors, managers, and other personnel performing in a supervisory capacity for outage activities.
- Attendance will be taken at the OCC turnover meeting.
- It is recognized that this will result in longer durations for the outage. Since the safest place to be is on schedule, the outage schedule is being revised to include these meetings.
- Very few exceptions will be made to the briefing schedule requirement. The OCC will control all exceptions.

Additional Changes:

- Just in Time Information Sharing identified in the Priority Working Schedule shall be developed and presented for the associated significant task.
- A responsible Manager will be assigned to selected work activities as directed by the OCC. These managers will monitor the job from pre-job briefing through completion or end of their shift.

These changes are being implemented immediately. Please provide feedback to your supervisor on ways to improve this process.

Point Beach Nuclear Plant U1R28 Refueling Outage

Safety Topic for week of April 11-17th
Theme for the week
This week's theme is Housekeeping . What does housekeeping have to do with safety? Lots! A clean and orderly workplace is essential to avoid falls, fires and many other kinds of accidents and injuries.
Daily Safety Snippets
Sunday
"Outage rubble can lead to trouble" On April 21, 2001 the Point Beach declared an Unusual Event due to a small fire in the Unit 1 containment building during a refueling outage. The fire was in a bag of rags on the manway platform of the Alpha steam generator in Unit 1. The fire brigade was summoned and put out the fire within about 20 minutes.
Monday
"When you clean up hazards, you scrub out accidents" Why is good housekeeping important? Just think about it. A clean workplace has less fire hazards, fewer safety hazards and just plain looks better. A clean workplace promotes pride in your job.
Tuesday
"Improper storing can be more than annoying" What are those yellow cabinets for? Remember to properly store all flammable chemicals in fire cabinets. These should be in properly labeled containers and the storage capacity of the cabinet should never be exceeded.
Wednesday
"Avoid a fatal scene; Keep your job site clean" A building contractor died when he was trapped in the burning basement of a house under construction. Another worker was using an oxyacetylene cutting torch to cut I-beams over the basement of the house. Stray sparks set fire to some sawdust and scrap wood used as packing material. The worker escaped and sounded the alarm, however the contractor jumped into the basement, in a fatal attempt to put the fire out.
Thursday
"Ashes to ashes, dust to dust; A clean workplace is a must" At the PI a couple of years ago during a refueling outage on unit 1, welding sparks ignited a small fire in some rags in containment. An alert fire watch was able to put out the fire immediately but the fire was preventable with some very basic housekeeping practices.
Friday
"Don't be a slob; Clean up after each job" After going through the snippets for this week makes you feel as if you have just gotten a lecture from your mother about keeping your room tidy, that's okay. Mom was right! Housekeeping is everyone's job and working together will not only ensure a clean workspace, it will also help to ensure a safe one.
Saturday
"Clean up and care will speed up repair" It is a good practice to assign one coworker as the "housekeeping conscious" on each job. This person is responsible not to clean up after you but to remind everybody on the job to clean up after themselves. This helps to minimize the gradual buildup of clutter as the job progresses.



Point Beach Nuclear Plant Outage 1R28

DAY 10

Path



Picture

Meets



Doesn't Meet Exceeds

Supporting Operational Excellence

Outage Radiation Performance

Definition/Goal

Analysis and Actions

This indicator measures cumulative dose radiation exposure and total number of personnel-contamination events (PCE's > 5000 cpm) during refueling outages. The dose indicator is measured in Rem and individual PCE events.


Day 10 - April 13
 Actual = 0.424
 Cumulative = 23.370
 Cumulative Forecast = 35.463

Meets:	≤ 75 Rem	Actual Cum.	
Exceeds:	≤ 71 Rem	Dose:	23.37 Rem
Meets:	≤ 18	Exceeds:	≤ 12
		Actual PCE's:	5


Responsible Manager/Owner

Stu Thomas

Personnel Contamination Events



Cummulative Dose Exposure



Outage Status Report

Plant: Point Beach Unit 1 Day: Wednesday Today's Date / Time: 4/14/04 / 1600

Outage Duration: Day 11 of 28

Safety Status

Industrial - Within the last 12 hours
 OSHA Recordables 0 First Aid cases 1 Significant near misses 0
 Total for this outage 0
 Summary: Chem Tech Received Minor Finger Laceration

Radiological
 Dose outage to date 23.370 Projected to date 35.463 Outage Goal ≤75 R
 Difference -12.093 Number of PCEs 5
 Summary:

Nuclear
 Significant human performance errors and events in last 24 hours 0
 Summary:

Plant Status

Mode: Hot Standby (Mode 3) Hot Shutdown (Mode 4) Cold Shutdown (Mode 5) Refueling Shutdown (Mode 6)
 RCS: Temperature: 98 Pressure: Vented to Atmosphere RV Level: 68%
 Time to Boil: 50 Minutes

Shutdown Safety Assessment

Reactivity: Green Core Cooling: Yellow Power Availability: Green
 Containment: Green Inventory: Yellow Spent Fuel Pool Cooling: N/A

Protected Equipment:

et4

Major Activities Completed in Last 24 Hours

Critical Path and Near Critical Path Activities (Next 24 Hours)

ORT 15A Fuel Transfer System Checkout
 Schedule: Activities Required to Exit Yellow Risk Conditions
 1) Troubleshoot & Repair Z-13 Polar Crane
 2) B RCP Motor Move
 3) Reactor Vessel Head Stud Removal
 4) Reactor Vessel Head Lift

Significant Outstanding Issues

Date	Issue	Due	Responsibility
4/03/04	Repair Blowdown Tank Leakage	4/20/04	Scott Manthei
4/04/04	1P2A Charging Pump Troubleshooting	4/16/04	Clay Hill ..
4/08/04	Incorporate Lessons Learned from 1 ST Reduced Inventory Orange Path	4/18/04	Dave Dyzak
4/08/04	B RCP Motor Oil Sludge	4/14/04	Jim McGough
4/13/04	Z-13 Polar Crane troubleshooting and oil particulate issue	4/14/04	Paul Lagasse

Upcoming Major Milestones

	Scheduled		Actual			Scheduled		Actual	
	Date	Time	Date	Time		Date	Time	Date	Time
Cooldown <200°	4/03/04	2100	4/03/04	2230	Heatup >200°	4/25/04	0900		
Head Lift	4/09/04	0900			Initial	4/28/04	1100		
Refueled	4/14/04	0300			On-Line	4/30/04	0100		

Point Beach Nuclear Plant
PBNP SHUTDOWN SAFETY ASSESSMENT AND FIRE CONDITION CHECKLIST
OUTAGE SAFETY ASSESSMENT

UNIT: 1 DATE: April 14, 2004 TIME: 1400

KEY SAFETY FUNCTIONS:

REACTIVITY:	GREEN
CORE COOLING:	YELLOW
POWER AVAILABLE:	GREEN
INVENTORY:	YELLOW
CONTAINMENT:	GREEN
SFP COOLING:	NA


PROTECTED EQUIPMENT:

COMMENTS:

Fire Protection Condition III: Crediting existing fire rounds as fire prevention contingency
RCS Time to Boil is 50 minutes
RCS is at 68% Reactor Vessel Level
Hot Leg Vent Path is the Pressurizer Manway

ex4

ACEMAN INDIVIDUAL EXCELLENCE WORKSHEET



Date: _____

Time: _____ 31

after 14APR04 12:00

U1R28 WORKING SCHEDULE

after 14APR04 12:00

U	ID	RESP	WO ST	WO	EQID	DESCRIPTION	RD	ES	EF	APR																											
										14	15	16	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1	MM0303383	MMV	76	0303383	SC-00966B	SC-966B - VALVE LEAKING BY, REPAIR	28	09APR04 11:00A	17APR04 09:59	MM0303383 SC-966B - VALVE LEAKING BY, REPAIR																											
1	MM0214143	MM2	76	0214143	SC-1B	HYDROLANCE SC-1B CONDENSER (BOTH WATERBOXES)	42	09APR04 11:00A	19APR04 13:59	MM0214143 HYDROLANCE SC-1B CONDENSER (BOTH WATERBOXES)																											
1	TG9949102N	TGG	76	9949102	TG-01-T1	LP1- REPLACE EXTRACTION BELLOWS (NIGHTS)	78	13APR04 00:00A	23APR04 00:59	TG9949102N LP1- REPLACE EXTRACTION BELLOWS (NIGHTS)																											
1	CE-1600-20	CE8	76	0213472	R-1	ENERGIZE AND CAL UNDERHEAD INSPECTION EQUIPMENT	26	13APR04 02:00A	17APR04 02:59	CE-1600-20 ENERGIZE AND CAL UNDERHEAD INSPECTION EQUIPMENT																											
1	TG0302135	TGG	76	0302135	MS-02033-O	MS-2033 - OVERHAUL LH GOV VALVE OPERATOR	15	13APR04 09:00A	15APR04 16:59	TG0302135 MS-2033 - OVERHAUL LH GOV VALVE OPERATOR HP TURBINE LOWER LEFT HAND GOVERNOR																											
1	TG-30470	TGG	76	0302153	TG-01-T	PERFORM HP SPINDLE ROTOR BORE INSPECTION-PT2	46	13APR04 09:00A	18APR04 09:59	TG-30470 PERFORM HP SPINDLE ROTOR BORE INSPECTION-PT2																											
1	TG9949102D	TGG	76	9949102	TG-01-T1	LP1- REPLACE EXTRACTION BELLOWS (DAYS)-PT2	77	13APR04 09:00A	23APR04 08:59	TG9949102D LP1- REPLACE EXTRACTION BELLOWS (DAYS)-PT2																											
1	TGSUPPORT	TGG			TG-01-T	PROVIDE CRANE, RIGGER, AND TOOLROOM SUPPORT (PT2)	267	13APR04 09:00A	29APR04 18:59	TGSUPPORT PROVIDE CRANE, RIGGER, AND TOOLROOM SUPPORT (PT2)																											
1	TG0302133	TGG	76	0302133	MS-02026	MS-2026 - OVERHAUL LH STOP VALVE-PT2	35	13APR04 12:00A	17APR04 16:59	TG0302133 MS-2026 - OVERHAUL LH STOP VALVE-PT2																											
1	TG0302134	TGG	76	0302134	MS-02027	MS-2027 - OVERHAUL RH STOP VALVE-PT2	35	13APR04 12:00A	17APR04 16:59	TG0302134 MS-2027 - OVERHAUL RH STOP VALVE-PT2																											
1	TG-30360	TGG	76	0302153	TG-01-T	CLEAN AND INSPECT #1 AND 2 BEARINGS	2	13APR04 14:00A	14APR04 13:59	TG-30360 CLEAN AND INSPECT #1 AND 2 BEARINGS HIGH PRESSURE TURBINE 0302153																											
1	TG0407679	TGG	76	0407679	HX-022A	1HX-22A: REPLACE WELDED DRAIN LINE	16	13APR04 14:00A	16APR04 07:59	TG0407679 1HX-22A: REPLACE WELDED DRAIN LINE MOISTURE SEPARA																											
1	MM0213779	MMV	76	0213779	FD-00145	1FD-145 BODY TO BONNET LEAK	22	13APR04 20:00A	16APR04 18:59	MM0213779 1FD-145 BODY TO BONNET LEAK																											

Run Date

14APR04 15:59

LT-51 PRIORITY PUBLICATION-ES
FL-50 Priority Publication

Sheet 2 of 18

after 14APR04 12:00

U1R28 WORKING SCHEDULE

after 14APR04 12:00

U	ID	RESP	WO ST	WO	EQID	DESCRIPTION	RD	ES	EF	APR																											
										14	15	16																									
1	EP0301956	EPT	76	0301956	HX-001A	EDDY CURRENT TEST STEAM GENERATOR A	129	14APR04 00:00A	20APR04 04:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16
1	EP0301957	EPT	76	0301957	HX-001B	EDDY CURRENT TEST STEAM GENERATOR B	129	14APR04 00:00A	20APR04 04:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16
1	TG-30450	TGG	76	0302153	TG-01-T	PERFORM NDE OF HP SPINDLE	8	14APR04 02:00A	14APR04 19:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16
1	MM0214093	MM2	76	0214093	HX-048	HX-048 - HYDROLANCE CLEAN GLAND STEAM	5	14APR04 08:00A	14APR04 16:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16
1	MM0214079	MM2	76	0214079	HX-020A	HX-20A, HYDROLANCE CLEAN LP FEEDWATER HEATER	25	14APR04 08:00A	16APR04 16:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16
1	TG0215004	TGG	76	0215004	HX-054B	HX-54B - INSTALL NEW EH COOLER	4	14APR04 09:00A	14APR04 15:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16
1	IC0400553A	IC1	76	0400553	SERVICE	SERVICE MAINT SUPPORT-EQ VERIFYING	58	14APR04 09:00A	22APR04 09:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16
1	CEDIVPPHSE	CE1	76	0400396	U1-FOREBAY	INSPECT & CLEAN PUMPHOUSE-PT2	15	14APR04 10:00A	15APR04 16:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16
1	IT300BRIEF	OPS				PRE JOB BRIEF FOR IT-300A	1	14APR04 12:00*	14APR04 12:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16
1	T-0711-H	WCC		0010711	Z-024A	1 RC Z-24A RMP-9096 MM REV0-1	1	14APR04 12:00	14APR04 12:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16
1	Z13-PREJOB	EM			Z-013	Z-013 PREJOB BREIF FOR T/S AND REPAIR	1	14APR04 12:00	14APR04 12:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16
1	T-2075-H	WCC		0012075	P-029	1 AF P-29 UNCOUPLE MM REV0-1	2	14APR04 12:00	14APR04 13:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16
1	T-2724-H	WCC		0012724	C-703	1 TU C-703 EM REV0-1	2	14APR04 12:00*	14APR04 13:59	0	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16	18	20	22	0	2	4	6	8	10	12	14	16

after 14APR04 12:00

U1R28 WORKING SCHEDULE

after 14APR04 12:00

U	ID	RESP	WO ST	WO	EQID	DESCRIPTION	RD	ES	EF	APR																			
										14	15	16																	
1	T-9697-R	WCC		0009697	HX-001B	1 MS HX-1B WLU MMV REV0-1	2	14APR04 12:00	14APR04 13:59	T-9697-R	1 MS HX-1B WLU MMV REV0-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	
1	IT-300ASMP	CH			HX-001A	SAMPLE S/G HX-1A PER IT-300A	3	14APR04 12:00*	14APR04 14:59	IT-300ASMP	SAMPLE S/G HX-1A PER IT-300A																		
1	T-3729-H	WCC		0013729	HX-22B	1 MS HX-22B TGG REV0-1	3	14APR04 12:00*	14APR04 14:59	T-3729-H	1 MS HX-22B TGG REV0-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	
1	TG-30650	TGG	76	0302153	TG-01-T	REMOVE HP HORIZONTAL JOINT BOLT STUDS-PT2	3	14APR04 12:00	14APR04 14:59	TG-30650	REMOVE HP HORIZONTAL JOINT BOLT STUDS-PT2																		
1	T-1673-H	WCC		0011673	HX-17B/19B	1 CS HX-17B/19B MM REV0-1	4	14APR04 12:00*	14APR04 15:59	T-1673-H	1 CS HX-17B/19B MM REV0-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	
1	TG-30410	TGG	76	0302153	TG-01-T	CLEAN/INSPECT GOV PED OIL SEAL & ENDCOVER-PT2	4	14APR04 12:00	14APR04 15:59	TG-30410	CLEAN/INSPECT GOV PED OIL SEAL & ENDCOVER-PT2																		
1	TG-9000	TGG	76	0302150	TG-01	UNBOLT AND RMV #5 BEARING PED COVER	4	14APR04 12:00*	14APR04 15:59	TG-9000	UNBOLT AND RMV #5 BEARING PED COVER																		
1	TGHX22ARP	TGG	76	0302108	HX-022A	MSR A INTERNALS REPAIRS (SHELL SIDE)PT2	5	14APR04 12:00	14APR04 16:59	TGHX22ARP	MSR A INTERNALS REPAIRS (SHELL SIDE)PT2																		
1	TGHX22BVIS	TGG	76	0302109	HX-022B	MSR B INTERNALS INSPECTION (SHELL SIDE)	5	14APR04 12:00	14APR04 16:59	TGHX22BVIS	MSR B INTERNALS INSPECTION (SHELL SIDE)																		
1	TG-30240	TGG	76	0302153	TG-01-T	CLEAN / INSPECT GOVERNOR PEDESTAL	10	14APR04 12:00	14APR04 21:59	TG-30240	CLEAN / INSPECT GOVERNOR PEDESTAL																		
1	TG-30615	TGG	76	0302153	TG-01-T	PERFORM REPAIRS TO CYLINDER BASED ON INSPECTION	10	14APR04 12:00	14APR04 21:59	TG-30615	PERFORM REPAIRS TO CYLINDER BASED ON INSPECTION																		
1	TG0205499	TGG	76	0205499	LG-03951	1LG-3951 MINOR SEAL OIL LEAKAGE	8	14APR04 12:00*	15APR04 09:59	TG0205499	1LG-3951 MINOR SEAL OIL LEAKAGE																		
1	TG-30460	TGG	76	0302153	TG-01-T	DUSTBLAST THE HP BLADE RINGS	9	14APR04 12:00	15APR04 10:59	TG-30460	DUSTBLAST THE HP BLADE RINGS																		

Run Date

14APR04 15:59

LT-51 PRIORITY PUBLICATION-ES
FL-50 Priority Publication

Sheet 4 of 18

© Primavera Systems, Inc.

after 14APR04 12:00

U1R28 WORKING SCHEDULE

after 14APR04 12:00

U	ID	RESP	WO ST	WO	EQID	DESCRIPTION	RD	ES	EF	APR		
										14	15	16
										0,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22	0,2,4,6,8,10,12,14,16,18,20,22
1	TGHX22BLKT	TGG	76	0214084	HX-022B	MSR B LEAK CHECK (TUBE SIDE)	20	14APR04 15:00*	16APR04 14:59	TGHX22BLKT	MSR B LEAK CHECK (TUBE SIDE)	MOIST
1	TG-9010	TGG	76	0302150	TG-01	UNBOLT AND REMOVE THRUST BEARING COVER	4	14APR04 16:00	14APR04 19:59	TG-9010	UNBOLT AND REMOVE THRUST BEARING COVER	
										0302150	TURBINE GENERATOR (GENERIC; SEE COMPONENTS)	
1	NG-SC1ANRV	EPT	76	0301978	SC-1A	SC-1A - EDDY CURRENT REVIEW / RERUN (1AN)	12	14APR04 17:00	15APR04 04:59	NG-SC1ANRV	SC-1A - EDDY CURRENT REVIEW / RERUN (1AN)	
										0301978	CONDENSER (DEAERATING)	
1	NG-SC1ASEC	EPT	76	0301978	SC-1A	EDDY CURRENT INSPECT COND (1AS)	24	14APR04 17:00	15APR04 16:59	NG-SC1ASEC	EDDY CURRENT INSPECT COND (1AS)	
										0301978	CONDENSER (DEAERATING)	
1	IT-300AB	OPS	77	0215904	O-IT-0300A	PRESSURIZE S/G HX-1A TO 100 PSIG FOR IT-300A	2	14APR04 18:00	14APR04 19:59	IT-300AB	PRESSURIZE S/G HX-1A TO 100 PSIG FOR IT-300A	
										0215904	A SG MAIN FEED LINE CHECK VALVES (COLD SHUTDOWN)	
1	PM-BRIEF2	ADM				OCC INTERACTIVE TURNOVER and FOLLOWUP	2	14APR04 18:00*	14APR04 19:59	PM-BRIEF2	OCC INTERACTIVE TURNOVER and FOLLOWUP	
-1	TG-30630	TGG	76	0302153	TG-01-T	NDE HP NOZZLE BLOCK IN-PLACE	8	14APR04 18:00	15APR04 01:59	TG-30630	NDE HP NOZZLE BLOCK IN-PLACE	
										0302153	HIGH PRESSURE TURBINE	
1	TG-30511	TGG	76	0302153	TG-01-T	CLEAN/INSPECT/REPAIR OUTER STEAM GLAND CASINGS	10	14APR04 19:00*	15APR04 08:59	TG-30511	CLEAN/INSPECT/REPAIR OUTER STEAM GLAND CASINGS	
										0302153	HIGH PRESSURE TURBINE	
1	IC0302178A	ICV	76	0302178	FD-02518A	1FD-2518A POST MTN DIAGNOSTIC	4	14APR04 20:00*	14APR04 23:59	IC0302178A	1FD-2518A POST MTN DIAGNOSTIC	
										0302178	HX-22B MSR SHELL SIDE LEVEL CONTROL	
1	O-RT-031	OPS	77	0215969	O-RT-031	LLRT N2 SUPPLY TO PRT	4	14APR04 20:00*	14APR04 23:59	O-RT-031	LLRT N2 SUPPLY TO PRT	
										0215969	NITROGEN SUPPLY TO THE PZR RELIEF TANK (P-14A)	
1	O-RT-035A	OPS	77	0215973	O-RT-035	PRE O-RT-035, HOT LEG SAMPLE LINE	4	14APR04 20:00*	14APR04 23:59	O-RT-035A	PRE O-RT-035, HOT LEG SAMPLE LINE	
										0215973	HOT LEG SAMPLE LINE (P-28A)	
1	IC10.10A	IC	76	0300885	ICP-10.010	A S/G INSTRUMENT BLOWDOWN	5	14APR04 20:00	15APR04 00:59	IC10.10A	A S/G INSTRUMENT BLOWDOWN	
										0300885	SG TRANSMITTERS - BLOWDOWN, FILLING AND VENTING	
1	MM0301145	MM1	76	0301145	HX-15B5	HX-15B5, CFC COIL INTERNAL INSP/CLEANING	8	14APR04 20:00	15APR04 03:59	MM0301145	HX-15B5, CFC COIL INTERNAL INSP/CLEANING	
										0301145	CONTAINMENT ACCIDENT RECIRC HEAT EXCHANGER	

Run Date

14APR04 15:59

LT-51 PRIORITY PUBLICATION-ES

Sheet 6 of 18

© Primavera Systems, Inc.

FL-50 Priority Publication

after 14APR04 12:00

U1R28 WORKING SCHEDULE

after 14APR04 12:00

U	ID	RESP	WO ST	WO	EQID	DESCRIPTION	RD	ES	EF	APR		
										14	15	16
										0,12,14,16,18,20,22	0, 2, 4, 6, 8, 10,12,14,16,18,20,22	0, 2, 4, 6, 8, 10,12,14,16,18,20,22
1	RP1D-005	OPS			O-RP-001D	ESTABLISH RP 1D INITIAL CONDITIONS	4	15APR04 08:00	15APR04 11:59		RP1D-005 ESTABLISH RP 1D INITIAL CONDITIONS	
1	CE937787TR	CE4	76	9937787	FD-02543A	REMOVE INSULATION FOR 1FD-2543A	5	15APR04 08:00	15APR04 12:59		CE937787TR REMOVE INSULATION FOR 1FD-2543A 9937787 HX-19B LP FWH 3B DRAIN TO HX-17B CONTROL	
1	CE0301623	CE5	76	0301623	FD-00208A	1FD-208A - REPLACE VALVE	24	15APR04 08:00	16APR04 11:59		CE0301623 1FD-208A - REPLACE VALVE 0301623 HX-21A HP F	
1	CE0305003	CE5	76	0305003	FD-00210A	FD-210A - STEAM LEAK, REPLACE VALVE	24	15APR04 08:00	16APR04 11:59		CE0305003 FD-210A - STEAM LEAK, REPLACE VALVE 0305003 HX-21A HP F	
1	MM0305397	MM1	76	0305397	W-001C1	W-1C1 REPLACE SPRING ISOLATORS	36	15APR04 08:00*	18APR04 07:59		MM0305397 W-1C1 REPLACE SPRING ISOLATORS 0305397	
1	MM0214099	MM2	76	0214099	HX-056A	HX-056A - OPEN SGFP OIL COOLER	2	15APR04 09:00*	15APR04 10:59		MM0214099 HX-056A - OPEN SGFP OIL COOLER 0214099 P-28A SGFP OIL COOLER	
1	TG-30580	TGG	76	0302153	TG-01-T	MEASURE HP OUTER STM GLD CLEARANCES	2	15APR04 09:00	15APR04 10:59		TG-30580 MEASURE HP OUTER STM GLD CLEARANCES 0302153 HIGH PRESSURE TURBINE	
1	RPSH078-I	RP1			PACKAGE 78	INSTALL SHIELDING ON REGEN FOR CV-296	3	15APR04 09:00*	15APR04 11:59		RPSH078-I INSTALL SHIELDING ON REGEN FOR CV-296	
1	IC5.73A-1	IC1	76	0300878	ICP-05.073	ICP-5.73 T-34A ACCUMULATOR LEVEL XMTR'S RESTART	5	15APR04 09:00*	15APR04 13:59		IC5.73A-1 ICP-5.73 T-34A ACCUMULATOR LEVEL XMTR'S RESTART 0300878 ACCUMULATOR LEVEL TRANSMITTERS RWP: Containment General Area Maintenance	
0	AP0303705	APS	77	0303705	SWYD CTL B	SWITCHYARD EQUIPMENT INSPECTION	6	15APR04 09:00*	15APR04 14:59		AP0303705 SWITCHYARD EQUIPMENT INSPECTION 0303705 SWITCHYARD CONTROL BUILDING	
1	IT-300B	OPS	77	0215905	O-IT-0300B	FILL B S/G TO MSIV AND PRESSURIZE TO 100 PSIG	6	15APR04 09:00	15APR04 14:59		IT-300B FILL B S/G TO MSIV AND PRESSURIZE TO 100 PSIG 0215905 B SG MAIN FEED LINE CHECK VALVES (COLD SHUT)	
1	EM0215183A	EMV	76	0215183	SI-00860A-	SI-860A-O MOV ACTUATOR CHECK-OUT (RESTART)	10	15APR04 09:00*	15APR04 18:59		EM0215183A SI-860A-O MOV ACTUATOR CHECK-OUT (RESTART) 0215183 P-14A CONT SPRAY PUMP DISCH REDUND	
1	MM0214089	MM2	76	0214089	HX-024	HX-24, HYDROLANCE CLEAN CONDENSATE COOLER	10	15APR04 09:00*	16APR04 08:59		MM0214089 HX-24, HYDROLANCE CLEAN CONDENSATE COOLER 0214089 CONDENSATE CO	

Run Date

14APR04 15:59

LT-51 PRIORITY PUBLICATION-ES
FL-50 Priority Publication

Sheet 10 of 18

after 14APR04 12:00

U1R28 WORKING SCHEDULE

after 14APR04 12:00

U	ID	RESP	WO ST	WO	EQID	DESCRIPTION	RD	ES	EF	APR																					
										14				15				16													
										0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17				
1	IC4.1J	IC1	76	0300831	ICP-04.001	PZR LVL AND FIRST STAGE PRESS CAL	16	15APR04 09:00*	16APR04 12:59																					IC4.1J PZR LVL AND FIRST STAGE PRESS CAL 0300831	RP/SAFEGR
1	IC5.19-1	IC1	76	0300857	ICP-05.019	COND STEAM DUMP CNTL SYS CAL RESTART	32	15APR04 09:00*	17APR04 16:59																					IC5.19-1 COND STEAM DUMP CNTL SYS CAL RESTART 0300857	
1	IC5.47-1	IC1	76	0300867	ICP-05.047	SECONDARY LEVEL CONTROLLERS AND SWIT	178	15APR04 09:00	02MAY04 06:59																					IC5.47-1 SECONDARY LEVEL CONTROLLERS AND SWIT 0300867	
1	IC5.49DAY1	ICV	76	0300869	ICP-05.049	ICP 5.49 SEC CONTROL VALVES	180	15APR04 09:00	02MAY04 08:59																					IC5.49DAY1 ICP 5.49 SEC CONTROL VALVES 0300869	
1	CAMP-113A	CH			HX-001A	CAMP-113 SAMPLE A STEAM GENERATOR (NO SPARGE)	3	15APR04 10:00	15APR04 12:59																					CAMP-113A CAMP-113 SAMPLE A STEAM GENERATOR (NO SPARGE) [REDACTED]	
1	EM0301758	EM	76	0301758	P-037D-M	1P-037D-M PERFORM MCE TESTING	3	15APR04 10:00*	15APR04 12:59																					EM0301758 1P-037D-M PERFORM MCE TESTING 0301758	DC EMERGENCY LUBE OIL PUMP MOTOR
1	IC425N36-1	IC5	76	0300838	ICP-04.025	ICP 4.25 NI IR N-36 CAL	4	15APR04 10:00	15APR04 13:59																					IC425N36-1 ICP 4.25 NI IR N-36 CAL 0300838	NUCLEAR INSTRUMENTATION SYSTEM INTERMEDI
1	TG-9040	TGG	78	0302150	TG-01	INSPECT TURBINE THRUST BEARING	6	15APR04 10:00	15APR04 15:59																					TG-9040 INSPECT TURBINE THRUST BEARING 0302150	TURBINE GENERATOR (GENERIC; SEE COMPON
1	TG0303396	TGG	76	0303396	LO-00035	LO-35 VALVE STEM BENT.	8	15APR04 10:00	16APR04 07:59																					TG0303396 LO-35 VALVE STEM BENT. 0303396	Z-26 LO CONDITION
0	EM0301792	EM	76	0301792	A52-DHVR-3	BREAKER MAINTENANCE 3000-01 (A52-01)	24	15APR04 10:00*	16APR04 09:59																					EM0301792 BREAKER MAINTENANCE 3000-01 (A52-01) 0301792	4.18 KV/3000 AM
1	IC5.54-1	IC5	76	0300874	ICP-05.054	ICP 5.54 SECONDARY LOW RANGE PRESSURE RESTART	71	15APR04 10:00	22APR04 08:59																					IC5.54-1 ICP 5.54 SECONDARY LOW RANGE PRESSURE RESTART 0300874	
1	IC9944161	IC5	76	9944161	DPS-05933	1DPS-5933 INSTALL SNUBBERS	71	15APR04 10:00	22APR04 08:59																					IC9944161 1DPS-5933 INSTALL SNUBBERS 9944161	
1	MM-8480R2	MM1	76	0214134	R-1	CHECK SANDBOX & TOP HAT COVER BOLT TORQUE	1	15APR04 11:00	15APR04 11:59																					MM-8480R2 CHECK SANDBOX & TOP HAT COVER BOLT TORQUE 0214134	REACTOR VESSEL AND ASSEMBLY

Run Date

14APR04 15:59

LT-51 PRIORITY PUBLICATION-ES
FL-50 Priority Publication

Sheet 11 of 18

© Primavera Systems, Inc.

after 14APR04 12:00

U1R28 WORKING SCHEDULE

after 14APR04 12:00

U	ID	RESP	WO ST	WO	EQID	DESCRIPTION	RD	ES	EF	APR													
										14				15				16					
										0	1	2	3	0	1	2	3	0	1	2	3		
1	RP4A-031	EM			O-RP-004A	RESTORE WALKWAY POST ROD UNLATCHING	2	16APR04 12:00	16APR04 13:59													RP4A-031	RESTORE W
1	MM0214095	MM2	76	0214095	HX-053B	HX-053B - HYDROLANCE CLEAN HYDROGEN SIDE SEAL	3	16APR04 12:00*	16APR04 14:59													MM0214095	HX-053B - HY 0214095 HYDRO
1	CE937787TI	CE4	76	9937787	FD-02543A	INSTALL INSULATION FOR 1FD-2543A	5	16APR04 12:00	16APR04 16:59													CE937787TI	INSTALL INS 9937787 HK
1	TG0302116	TGG	76	0302116	T-036	T-036 - LUBE OIL RESERVOIR INSPECTION	6	16APR04 12:00	16APR04 17:59													TG0302116	T-036 - LUBE 0302116 T
1	MM-8480E1	MM1	76	0214134	R-1	UPPER INTERNALS LIFT IPTE BRIEF	1	16APR04 13:00	16APR04 13:59													MM-8480E1	UPPER INT 0214134 REACTO
1	NGNDE18X	NDE			NDE-18	MINI-SUB SPECTIONS-INTERNAL LIFT (NDE-18)	3	16APR04 14:00	16APR04 16:59													NGNDE18X	MINI-SUB MIN
1	RPSH081-I	RP1			PACKAGE 81	INSTALL SHADOW SHIELDING (FROM RX HEAD)	3	16APR04 14:00	16APR04 16:59													RPSH081-I	INSTALL
1	RPSH082-I	RP1			PACKAGE 82	INSTALL SHIELDING FOR D-FAN (FROM RX HEAD)	3	16APR04 14:00	16APR04 16:59													RPSH082-I	INSTALL
1	MM-8480E	MM1	76	0214134	R-1	REMOVE UPPER INTERNALS	4	16APR04 14:00	16APR04 17:59													MM-8480E	REMOVE 0214134 R RWP: Up
1	MM0214100	MM2	76	0214100	HX-056B	HX-056B - HYDROLANCE CLEAN SGFP OIL COOLER	2	16APR04 15:00*	16APR04 16:59													MM0214100	HX-056 0214100 P-2
1	TG0215001	TGG	76	0215001	HX-053B	HX-53B - REPLACE BRASS RING	8	16APR04 15:00*	16APR04 22:59													TG0215001	HX-53B 0215001
1	MM0214098	MM2	76	0214098	HX-056A	HX-056A - HYDROLANCE CLEAN SGFP OIL COOLER	3	16APR04 15:00*	17APR04 07:59													MM0214098	HX-056 0214098
1	MM-1600-20	MM1	76	0213472	R-1	INSTALL CONOSEAL COVERS	3	16APR04 16:00	16APR04 18:59													MM-1600-20	INST 0213472

