

U.S. Nuclear Regulatory Commission

Site-Specific SRO Written Examination

Applicant Information

Name: PROCTOR COPY

Date: 20 MAY, 2005

Facility/Unit: James A. FitzPatrick

Region: I

Reactor Type: GE

Start Time:

Finish Time:

Instructions

Use the answer sheets provided to document your answers. Staple this cover sheet on top of the answer sheets. To pass the examination you must achieve a final grade of at least 80.00 percent overall, with a 70.00 percent or better on the SRO-only items if given in conjunction with the RO exam; SRO-only exams given alone require an 80.00 percent to pass. You have eight hours to complete the combined examination, and three hours if you are only taking the SRO portion.

Applicant Certification

All work done on this examination is my own. I have neither given nor received aid.

Applicant's Signature

Results

RO / SRO-Only / Total Examination Values 75 / ²⁴25 / ⁹⁹100 Points

Applicant's Scores _____ / _____ / _____ Points

Applicant's Grade _____ / _____ / _____ Percent

SCANTRON

SUBJECTIVE SCORE INSTRUCTOR USE ONLY				
<50>	<40>	<30>	<20>	<10>
<9>	<8>	<7>	<6>	<5>
<4>	<3>	<2>	<1>	<0>

TO USE SUBJECTIVE SCORE FEATURE:

- Mark each possible subjective point.
- Only one mark per line or key.
- 100 possible marks.

EXAMPLE: 1 2 3 4 5

DATE: LOI-05-01 KEY

SUBJECT: _____

TEST ID: _____

TEST RESULTS	
PART 1	
PART 2	
TOTAL	

TO REORDER CALL 1-800-722-8876 CUSTOMER SERVICE DEPARTMENT

PART 1

SRO

© SCANTREN CORPORATION 1995
ALL RIGHTS RESERVED. THIS IS NOT A SCANTREN FORM.

www.scantrenforms.com

FEED THIS DIRECTION

20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

	(T)	(F)	KEY		
1	A	B	C	D	E
2	A	B	C	D	E
3	A	B	C	D	E
4	A	B	C	D	E
5	A	B	C	D	E
6	A	B	C	D	E
7	A	B	C	D	E
8	A	B	C	D	E
9	A	B	C	D	E
10	A	B	C	D	E
11	A	B	C	D	E
12	A	B	C	D	E
13	A	B	C	D	E
14	A	B	C	D	E
15	A	B	C	D	E
16	A	B	C	D	E
17	A	B	C	D	E
18	A	B	C	D	E
19	A	B	C	D	E
20	A	B	C	D	E
21	A	B	C	D	E
22	A	B	C	D	E
23	A	B	C	D	E
24	A	B	C	D	E
25	A	B	C	D	E
26	A	B	C	D	E
27	A	B	C	D	E
28	A	B	C	D	E
29	A	B	C	D	E
30	A	B	C	D	E
31	A	B	C	D	E
32	A	B	C	D	E
33	A	B	C	D	E
34	A	B	C	D	E
35	A	B	C	D	E
36	A	B	C	D	E
37	A	B	C	D	E
38	A	B	C	D	E
39	A	B	C	D	E
40	A	B	C	D	E
41	A	B	C	D	E
42	A	B	C	D	E
43	A	B	C	D	E
44	A	B	C	D	E
45	A	B	C	D	E
46	A	B	C	D	E
47	A	B	C	D	E
48	A	B	C	D	E
49	A	B	C	D	E
50	A	B	C	D	E

change from B to D - 10

KEY

deleted - 30

9-30 40-30

SUBJECTIVE SCORE INSTRUCTOR USE ONLY				
(100)	(90)	(80)	(70)	(60)
(50)	(40)	(30)	(20)	(10)
(9)	(8)	(7)	(6)	(5)
(4)	(3)	(2)	(1)	(0)

INSTRUCTIONS	
<ul style="list-style-type: none"> • Mark bubbles correctly. • Bubble completely. • Do not mark outside the bubble. • Do not mark inside the bubble. 	<ul style="list-style-type: none"> • Mark test number, subjective score feature. • Mark test number, subjective score. • Mark test number per the bubble. • Mark bubble correctly.

EXAM	LOF-05-01 KEY
SUBJECT	
DATE	

TEST RECORD	
PART 1	
PART 2	
TOTAL	

PART 2

SAO

KEY

FEED THIS DIRECTION

	(T)	(F)	(3)	KEY
51	A	B	C	E
52	A	B	C	E
53	A	B	C	E
54	A	B	C	E
55	A	B	C	E
56	A	B	C	E
57	A	B	C	E
58	A	B	C	E
59	A	B	C	E
60	A	B	C	E
61	A	B	C	E
62	A	B	C	E
63	A	B	C	E
64	A	B	C	E
65	A	B	C	E
66	A	B	C	E
67	A	B	C	E
68	A	B	C	E
69	A	B	C	E
70	A	B	C	E
71	A	B	C	E
72	A	B	C	E
73	A	B	C	E
74	A	B	C	E
75	A	B	C	E
76	A	B	C	E
77	A	B	C	E
78	A	B	C	E
79	A	B	C	E
80	A	B	C	E
81	A	B	C	E
82	A	B	C	E
83	A	B	C	E
84	A	B	C	E
85	A	B	C	E
86	A	B	C	E
87	A	B	C	E
88	A	B	C	E
89	A	B	C	E
90	A	B	C	E
91	A	B	C	E
92	A	B	C	E
93	A	B	C	E
94	A	B	C	E
95	A	B	C	E
96	A	B	C	E
97	A	B	C	E
98	A	B	C	E
99	A	B	C	E
100	A	B	C	E

15-30 35-40

LOI-05-01 NRC WRITTEN EXAMINATION
ATTACHED REFERENCES

- EOP-2, 4, 5 and 6 without entry conditions.
- EOP-3, 3A, 4A, 7 and 11
- IAP-2, Attachment IAP-2.1, EAL Classifications Table
- FM-48A, STANDBY GAS TREATMENT FLOW DIAGRAM
- AOP-8, LOSS OR REDUCTION OF REACTOR COOLANT FLOW
(WITHOUT SYMPTOMS)
- T/S 3.4.3, 3.5.1, 3.5.2, 3.6.2.2, 3.6.2.4, 3.6.4.1
AND 3.6.4.2 (SPEC'S ONLY, NO BASES)
- RAP-7.3.16, ATTACHMENTS 4 AND 5, CORE POWER TO FLOW
MAPS
- SDLP-07B, FIGURE 2, CORE SRM/IRM LOCATIONS GRID MAP

Examination Outline Cross-reference:

(Page 10) 205000 Shutdown Cooling K2.02

Knowledge of electrical power supplies to the following:

- Motor operated valves

Level	RO	SRO
Tier #	2	-----
Group #	1	-----
K/A #	205000 K2.02	-----
Importance Rating	2.5	-----

Proposed Question: # 1

Currently, 10MOV-18 (RHR Shutdown Cooling Suction Isolation Valve) is "OPEN" with the associated Appendix R Power Disconnect and Isolation Switches in the following positions:

- Power Disconnect Switch is in the "CLOSED" position
- Isolation Switch is in the "LOCAL" position

From which of the following locations can 10MOV-18 be CLOSED?

- On the Valve Control Switch located on 10MOV-18
- Control Room Panel 09-4 Valve Control Switch for 10MOV-18
- BMCC-4 Valve Control Switch located on the Motor Controller Front Panel
- MCC-156 Valve Control Switch located on the Motor Controller Front Panel

Proposed Answer: d.

Explanation
(Optional):

- CORRECT:** with the isolation switch in "LOCAL", 10MOV-18 may be operated electrically from MCC-156 using the valve control switch located on the motor controller – allows closure from a convenient location and provides a location for isolation switch that would not be compromised during a LOCA due to radiological conditions.
- Incorrect:** 10MOV-18 is in the Drywell, but has no valve control switch mounted on it.
- Incorrect:** with the isolation switch in "LOCAL", 10MOV-18 may not be operated from the Control Room. The switch must be in "REMOTE" to allow Control Room operation of 10MOV-18 from the 09-4 Panel.
- Incorrect:** correct concept, but power supply is for 10MOV-17 (RHR Shutdown Cooling Suction Valve) and 10MOV-17 is not set up in this manner.

Technical Reference(s): OP-13D (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-10, EO 1.11.b.2 (As available)

Question Source:

Bank #	
Modified Bank #	

(Note changes or attach parent)

New

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content:

55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 20) 268000 Radwaste K1.03

Knowledge of the physical connections and/or cause-effect relationships between RADWASTE and the following:

- Reactor building equipment drains: Plant-Specific

Level	RO	SRO
Tier #	2	-----
Group #	2	-----
K/A #	268000 K1.03	-----
Importance Rating	2.6	-----

Proposed Question: # 2

Because leakage collected in the Reactor Building Equipment Drain Sumps is considered to be _____, this volume is pumped directly to either the _____ or the _____.

- Low Conductivity (High Purity) / Waste Collector Tank *or the* Waste Surge Tank
- High Conductivity (Low Purity) / Floor Drain Collector Tank *or the* Waste Surge Tank
- Low Conductivity (High Purity) / Waste Sample Tanks *or the* Condensate Storage Tanks
- High Conductivity (Low Purity) / Waste Sample Tanks *or the* Radwaste Equipment Drain Sump

Proposed Answer: a.

Explanation
(Optional):

- CORRECT – Low Conductivity and the WCT is where that is primarily delivered with the Waste Surge Tank being a surge volume
- If the improper assumption is made for whatever reason, that the drains are high conductivity, then these are potential delivery locations.
- Although it is considered Low Conductivity Waste, it would not be sent directly to the CST's at a minimum and not the WST's without some filtering/processing
- If the improper assumption is made for whatever reason, that the drains are high conductivity, then these are potential delivery locations.

Technical Reference(s): OP-49 (Attach if not previously provided)
FM-17A thru C

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-20, EO 1.05 a & 1.06 (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:
Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content:
55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 22) G2.1.20

Ability to execute procedure steps.

Level

RO

SRO

Tier #

3

Group #

K/A #

Cat 1 G2.1.20

Importance Rating

4.3

Proposed Question: # 3

The EPIC computer system is down for reboot. I&C is investigating a logic failure that resulted in a dual recirculation pump runback. Several minutes after the runback, the following indications were observed:

- ◆ 09-5 Average APRM Power is 62%
- ◆ 09-5 Total Core Flow is 34 Mlbm/hr

Which of the below describes the required operator actions?

- a. Insert Control Rods to reduce reactor power by at least 7%.
- b. Raise recirculation flow to raise reactor reactor power by at least 7%.
- c. Insert Control Rods to reduce reactor power by at least 30%.
- d. No action required, operation in this conditions is acceptable.

Proposed Answer: a.

Explanation
(Optional):

- a. CORRECT: These conditions place operation in the unshaded buffer region of RAP-7.3.16, Att 4/5. In this region with Solomon unavailable, AOP-8 requires exit by control rod insertion or raising of recirculation flow. The stem conditions prohibit the raising of recirculation flow.
- b. Incorrect: Stem conditions prohibit the raising of recirculation flow
- c. Incorrect: Incorrect use of the RAP-7.3.16 Att 4/5 curve would show operation in the Shaded Exclusion region if the lower axis is read on the % Core Flow values rather than the mlbm/hr values. This act would require a power reduction by at least 30%.
- d. Incorrect: Misreading the stem conditions as Solomon being available would make this an acceptable answer.

Technical Reference(s): AOP-8 (Attach if not previously provided)
RAP-7.3.16

Proposed references to be provided to applicants during examination: AOP-8, RAP-7.3.16, Att 4 or 5

Learning Objective: LP-AOP EO 2.08 (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 22) G2.1.27

Knowledge of system purpose and/or function.

Level

RO

SRO

Tier #

3

Group #

K/A #

Cat 1 G2.1.27

Importance Rating

2.8

Proposed Question: # 4

As Reactor Power is reduced from 100% to 95% by lowering recirculation flow, Turbine Control Valves are repositioned by EHC sensing _____ as compared to _____.

- RPV Pressure; Pressure Setpoint
- RPV Pressure; Turbine 1st Stage Pressure
- Turbine Inlet Pressure; Pressure Setpoint
- Turbine Inlet Pressure; Turbine 1st Stage Pressure

Proposed Answer: c.

Explanation
(Optional):

- CORRECT** – A recirc flow reduction will result in lower core thermal power and, therefore, lower steam pressure. The lower steam pressure sensed at the Pressure Averaging Manifold will result in further control valve closure; thus lowering MWe. The Pressure Control Unit is a proportional controller which positions control valves proportional to the error between pressure set and actual pressure.
- Incorrect – See above.
- Incorrect – See above.
- Incorrect – See above.

Technical Reference(s): SDLP-94C (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-94C, EO 1.05.a.4 (As available)

Question Source: Bank # 25679
 Modified Bank # [Redacted]
 New [Redacted] (Note changes or attach parent)

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 19) 216000 Nuclear Boiler Inst. A2.14

Ability to (a) predict the impacts of the following on the NUCLEAR BOILER INSTRUMENTATION; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:

- Recirculation flow: Design-Specific

(10CFR 55.43.5)

Level	RO	SRO
Tier #	-----	2
Group #	-----	2
K/A #	216000	A2.14
Importance Rating	-----	2.9

Proposed Question: # 5

The "A" Recirculation Pump MG Set has tripped from full power resulting in:

- ◆ All "A" loop jet pumps reading ~7% psid at the 09-38.
- ◆ All "B" loop jet pumps reading ~43% psid at the 09-38.

Which of the below describe the 09-5 Total Core Flow (02-3FR-95) indication and the appropriate procedure?

- The indication is accurate; Enter AOP-29, Jet Pump Malfunction
- The indication is inaccurate; Enter AOP-29, Jet Pump Malfunction
- The indication is accurate, Enter AOP-8, Loss or Reduction of Reactor Coolant Flow
- The Indication is inaccurate, Enter AOP-8, Loss or Reduction of Reactor Coolant Flow

Proposed Answer: c.

Explanation (Optional):

- CORRECT:** The MG set trip will result in field breaker opening which will place the reverse flow summer into service. The reverse flow summer is intended for Total Core Flow indication accuracy specifically for this condition. Although jet pump indications are distinctly different between loops, they are at the expected values. There is no indication of a jet pump failure provided.
- Incorrect: See Above.
- Incorrect: See Above.
- Incorrect: See Above.

Technical Reference(s): ARP-09-4-3-2, AOP-8 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-02E EO-1.05.a.8, b; LPAOP EO-1.02 (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

(Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content:

55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 3) 295006 SCRAM G2.4.29

Knowledge of the emergency plan.

(10CFR 55.43.5)

Level

RO

SRO

Tier #

1

Group #

1

K/A #

295006 G2.4.29

Importance Rating

4.0

Proposed Question: # 6

A fire has started in the Cable Spreading Room. Thick smoke pours into the Control Room requiring a Control Room Evacuation. The event timeline is as follows:

09:03 Fire is reported to the Control Room

09:06 Main Control Room evacuation ordered

09:30 Fire is reported extinguished

09:33 Control at Remote Shutdown Panel is established. All stations have reported in with all conditions as expected.

Which of the below is the correct EAL classification and expected plant condition at 09:33?

- a. Alert 8.2.2, Mode 1
- b. Alert 7.2.2, Mode 3**
- c. Site Area Emergency 9.1.5, Mode 1
- d. Site Area Emergency 7.2.4, Mode 3

Proposed Answer: **b.**Explanation
(Optional):

- b. CORRECT: A control room evacuation results in an alert declaration. Escalation to SAE is warranted if control is not established within 30 minutes. The stem conditions indicate control is established at 27 minutes. The AOP-43 actions complete a reactor scram prior to staffing the individual panels resulting in a Hot Shutdown (Mode 3) condition.
- a. Incorrect: This alert declaration is correct based upon a fire in the Cable Spreading Room of such magnitude to evacuate the control room. The plant is scrammed from the control room prior to departure or via RPS MG Set tripping while enroute to the Remote Shutdown Panels resulting in plant operation in Mode 3 vice Mode 1.
- b. Incorrect: A conceivable declaration if no more definitive declaration existed. The operating mode is incorrect.
- d. Incorrect: This Site Area Emergency declaration would be true if Remote Shutdown Panel control was not established within 30 minutes. The stem indicates control established at 27 minutes. The operating mode is correct.

Technical Reference(s): IAP-2 (Attach if not previously provided)
AOP-43

Proposed references to be provided to applicants during examination: IAP-2, Attachment IAP-2.1

Learning Objective: LP-AOP, EO-2.29
EP-12.5.4.2, EO-2.04

Question Source:

Bank #	
Modified Bank #	22361 (attached)
New	

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Plant: Nine Mile Point 2

Exam Date: 8/2/2002

Question ID: 22361

Exam Type: ILO

Question A fire has started in the Control Building HVAC room. Thick smoke pours into the Control Room requiring a Control Room Evacuation.

Event timeline is as follows:

- 09:03 Fire is reported to the Control Room.
- 09:06 Main Control Room evacuation ordered.
- 09:08 Reactor is manually scrammed.
- 09:23 Control at Remote Shutdown Panel is established.
- 09:30 Fire is reported extinguished.

Which one of the following Emergency Event Classifications is required per the EALs?

- Answer** Site Area Emergency
- Distractor 1** Unusual Event
- Distractor 2** Alert
- Distractor 3** General Emergency

RefMaterial

- Question Comment** C is correct- fire w/ control not established at RSP within 15 min is Site Area Emergency 7.2.4. A incorrect- this would be for fire not extinguished within 10 min. B incorrect- would be for fire in vital area. D incorrect-NP
- Distract1 Comment** C is correct- fire w/ control not established at RSP within 15 min is Site Area Emergency 7.2.4. A incorrect- this would be for fire not extinguished within 10 min. B incorrect- would be for fire in vital area. D incorrect-NP
- Distract2 Comment** C is correct- fire w/ control not established at RSP within 15 min is Site Area Emergency 7.2.4. A incorrect- this would be for fire not extinguished within 10 min. B incorrect- would be for fire in vital area. D incorrect-NP
- Distract3 Comment** C is correct- fire w/ control not established at RSP within 15 min is Site Area Emergency 7.2.4. A incorrect- this would be for fire not extinguished within 10 min. B incorrect- would be for fire in vital area. D incorrect-NP

Cognitive Level	Exam Level	Ka Number			
2	S	286000, 2.4, 30			
KaSegment1	KaSegment2	KaSegment3	KaSegment4	KaSegment5	KaRevision
		286000	2.4	30	

Examination Outline Cross-reference:

(Page 12) 215004 Source Range Monitor K4.04

Knowledge of SOURCE RANGE MONITOR (SRM) SYSTEM design feature(s) and/or interlocks which provide for the following:

- Changing detector position

Level	RO	SRO
Tier #	2	-----
Group #	1	-----
K/A #	215004 K4.04	-----
Importance Rating	2.8	-----

Proposed Question: # 7

A reactor startup is in progress. "Alpha" and "Charlie" Source Range Monitors (SRMs) are to be withdrawn to maintain the count rate level band. The "RETRACT PERMIT" light is illuminated (on) for SRM "A" and is **NOT** illuminated (off) for SRM "C". The Reactor Operator selects SRMs "A" and "C" and presses the "DRIVE OUT / DRIVING OUT" pushbutton.

Which of the following occurs?

- Neither of the selected SRMs moves from its full-in position and a control rod block occurs.
- "Alpha" SRM moves outward and "Charlie" SRM does NOT move due to a SRM withdraw block.
- Both of the selected SRMs will continue to move outward until either SRM withdraw block occurs.
- Both of the selected SRMs will continue to move outward and a concurrent control rod block occurs.

Proposed Answer: d.Explanation
(Optional):

- CORRECT** – Backlighting behind upper half of information window (Green) "RETRACT PERMIT" indicates detector may be withdrawn without causing a rod block. This is For Information Only, as there are no interlocks to inhibit detector insertion or withdrawal.
- Incorrect – See above
- Incorrect – See above
- Incorrect – See above

Technical Reference(s): ARP-09-5-2-2 / ARP-09-5-2-21 (Attach if not previously provided)
OP-16

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-07B, EO 1.11.b.4 (As available)

Question Source:

Bank #	
Modified Bank #	

 (Note changes or attach parent)

Question History:

New	X
Last NRC Exam	

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input checked="" type="checkbox"/>
Comprehension or Analysis	<input type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 2) 295001 Partial or Complete Loss of Forced Core Flow Circulation AA1.07

Ability to operate and/or monitor the following as they apply to PARTIAL OR COMPLETE LOSS OF FORCED CORE FLOW CIRCULATION :

- Nuclear Boiler Instrumentation System

Level

RO

SRO

Tier #

1

Group #

1

K/A #

295001 AA1.07

Importance Rating

3.1

Proposed Question: # 8

The "Bravo" Recirculation Pump trips during normal, full-power operation. If all the jet pumps are intact and operating properly, you would expect to see which of the following?

When the "B" Recirculation Pump is trips, the flow indication for all the "Bravo-loop" Jet Pumps should decrease to zero as the pump coasts to a stop. Then, the flow indication for all of the "B-loop" Jet Pumps should _____ and the flow indication for all of the "Alpha-loop" Jet Pumps should _____.

- drop below zero as flow reverses; increase during the transient.
- drop below zero as flow reverses; not change during the transient.
- increase to a positive value as flow reverses; increase during the transient.
- increase to a positive value as flow reverses; not change during the transient.

Proposed Answer: c.

Explanation
(Optional):

- CORRECT** – Per AOP-8, a rise in flow will result in the operating loop. RAP-7.3.25 graphically illustrates in Att. 1. Per UFSAR, Section 7.1.6.b, the discussion of the reason for the Reverse Flow Summer indicates the reasoning for removing the apparent positive flow through inactive Jet Pumps during single-loop operations.
- Incorrect – The first part of the distracter is invalidated by the above UFSAR discussion. The second part is true, per the above discussion of AOP-8 and RAP-7.3.25.
- Incorrect – Neither part of this distracter is true, per above references to AOP-8, RAP-7.3.25, and the UFSAR.
- Incorrect – The first part of the distracter is true. The second part is invalidated by the above discussion of AOP-8 and RAP-7.3.25.

Technical Reference(s): Tech Spec 3.4.2 Bases, UFSAR 7.1.6.b (Attach if not previously provided)
RAP-7.3.25, AOP-8, AOP-29

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-02E, EO 1.05.a.7/8 & 1.06.d (As available)
SDLP-02I, EO 1.09.d/e

Question Source: Bank # 20448 (Quad Cities 8/13/01)

Modified Bank #		(Note changes or attach parent)
New		
Last NRC Exam		

Question History:

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 18) 201003 Control Rod and Drive Mechanism K6.02

Knowledge of the effect that a loss or malfunction of the following will have on the CONTROL ROD AND DRIVE MECHANISM:

- Reactor pressure

Level	RO	SRO
Tier #	2	---
Group #	2	---
K/A #	201003 K6.02	
Importance Rating	3.0	---

Proposed Question: # 9

A common-cause failure has resulted in all 137 CRD Hydraulic Control Unit (HCU) Accumulators becoming inoperable. Per the Technical Specification Bases, which of the following reactor pressures is designated as the transition point between acceptable and unacceptable Control Rod Scram Times?

- 750 psig
- 800 psig
- 850 psig
- 900 psig

Proposed Answer: b.

Explanation
(Optional):

- CORRECT:** Reference Tech Spec Bases 3.1.4 and SDLP-03a, Figure 8 "Accumulator to Reactor Pressure Scram Times. 800 psig is the pressure below which reactor pressure alone will result in insufficient scram times to prevent exceeding fuel thermal limits during Design Basis Accidents and transients.
- Incorrect: Incorrect pressure.
- Incorrect: Incorrect pressure.
- Incorrect: Incorrect pressure.

Technical Reference(s): SDLP-03A, Figure 8 (Attach if not previously provided)
T.S. 3.1.4 and Bases

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-03A, EO 1.10.b (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input checked="" type="checkbox"/>
Comprehension or Analysis	<input type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 3) 295018 Partial or Total Loss of CCW AK2.01Knowledge of the interrelations between PARTIAL OR COMPLETE
LOSS OF COMPONENT COOLING WATER and the following:

- System loads

Level	RO	SRO
Tier #	1	-----
Group #	1	-----
K/A #	295018 AK2.01	-----
Importance Rating	3.3	-----

Proposed Question: # 10

The plant is operating at 90% power with one Reactor Building Closed Loop Cooling (RBCLC) pump tagged out of service. An electrical problem causes the two running RBCLC pumps to trip. Operators have the ability to restore cooling via Emergency Service Water to EACH of the following EXCEPT:

- a. Drywell Cooling Assemblies
- b. Drywell Equipment Sump Cooler
- c. Recirculation Pump Seal Coolers
- d. RWCU Non-Regenerative Heat Exchanger

Proposed Answer: d.

Explanation
(Optional):

- d. CORRECT – Per AOP-11 actions, operators must consider shutting down RWCU (as all cooling flow to the RWCU NRHX will be lost).
- a. Incorrect – Per AOP-11 actions, ESW can/will be supplied to this load.
- b. Incorrect – Per AOP-11 actions, ESW can/will be supplied to this load.
- c. Incorrect – Per AOP-11 actions, ESW can/will be supplied to this load.

Technical Reference(s): AOP-11 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-15, EO 1.06.b & 1.09 (As available)

Question Source:	Bank #	25604	(Note changes or attach parent)
	Modified Bank #		
	New		

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 2) 295004 Partial or Total Loss of DC Pwr AK2.03
Knowledge of the interrelations between PARTIAL OR COMPLETE
LOSS OF D.C. POWER and the following:

- D.C. bus loads

Level	RO	SRO
Tier #	1	_____
Group #	1	_____
K/A #	295004 AK2.03	_____
Importance Rating	3.3	_____

Proposed Question: # 11

A Loss of Coolant Accident has just occurred. Conditions are as follows:

- RPV water level is +58 inches
- RPV Pressure is 500 psig
- Annunciator 09-8-3-7, "LPCI MOV IPS A BATT VOLTS LO OR BKR TRIP" Is in alarm
- NPO reports that the LPCI Battery Breaker 1CB2 is destroyed

Which of the following operator actions / event sequences will support successful "Alpha" Low Pressure Coolant Injection System (LPCI) injection to the reactor vessel?

- NO immediate operator actions are necessary. Valves required for LPCI "A" operation will reposition, when required, using the normal AC feed (MCC-152).
- Immediately take the LPCI MOV A PWR SUPP switch to "ISOLATE". Valves required for LPCI "A" operation will then reposition, when required, using the alternate AC feed (MCC-153).
- Immediately take the LPCI MOV A PWR SUPP switch to "ALT PULL TO LOCK". Valves required for LPCI "A" operation will then reposition, when required, using the alternate AC feed (MCC-153).
- After waiting a mandatory 10 minutes, take the LPCI MOV A PWR SUPP switch to "BYPASS". Valves required for LPCI "A" operation will then reposition, when required, using the normal AC feed (MCC-152).

Proposed Answer: c.

Explanation
(Optional):

- CORRECT:** On a loss of LPCI DC Power, Per ARP 09-8-3-7, "If LPCI Bus immediately required..." this is the only action directed.
- Incorrect:** Normal AC Feed would trip on LPCI initiation signal. Even so, with the DC lost/breaker open, the normal AC feed to the inverter/charger will not provide adequate current to the inverter to allow stroking any of the MOVs. (Reference OP-43C, Caution C.2.5)
- Incorrect:** Taking the switch to "ISOLATE" will result in immediate opening of the normal AC input breaker from MCC-152, but does not contain logic to swap to the alternate AC feed.
- Incorrect:** This plays on the 10 minute wait after a LPCI initiation signal, where taking the switch to "BYPASS" will allow the closing of the normal AC input breaker to the inverter/charger. See above.

Technical Reference(s): OP-43C (Attach if not previously provided)
ARP 09-8-3-7

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-71B, EO 1.05.b.1, 1.13.c. & 1.14.c.12 (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: **Memory or Fundamental Knowledge**

Comprehension or Analysis

10 CFR Part 55 Content: **55.41**

55.43

Comments:

Examination Outline Cross-reference:

(Page 4) 295023 Refueling Acc Cooling Mode AK3.02

Knowledge of the reasons for the following responses as they apply to REFUELING ACCIDENTS:

- Interlocks associated with fuel handling equipment

Level

RO

SRO

Tier #

1

Group #

1

K/A #

295023 AK3.02

Importance Rating

3.4

Proposed Question: # 12

Fuel Handling operations are in progress. The following conditions exist:

- Mode switch in REFUEL
- Fuel Grapple NOT loaded
- Fuel Grapple full up
- One (1) control rod selected and fully withdrawn
- Bridge over the Spent Fuel Pool

From these conditions, which one (1) of the following restrictions occurs and what is the basis for that restriction?

- Bridge motion near or over the core will not be permitted, to prevent bridge operator overexposure
- A second control rod selected will cause a rod block, to prevent bridge operator overexposure
- Bridge motion near or over the core will not be permitted, to prevent inadvertent criticality
- A second control rod selected will cause a rod block, to prevent inadvertent criticality

Proposed Answer: d.

Explanation
(Optional):

- CORRECT – OP-66A, Attachments 2, 3, and 4 indicate via flowcharts what will result in a rod block, bridge motion block, and a bridge hoist block. Selecting the second control rod will, in fact cause a rod block, per Attachment 2. UFSAR Section 14.6.1.4 on Refueling Accidents. "The refueling interlocks, which impose restrictions on the movements of refueling equipment and control rods, prevent inadvertent criticality during refueling operations..."
- Incorrect – Per Attachment 3, stem conditions will not cause a bridge motion block and reasoning would be invalid.
- Incorrect – Although the selection of the second rod is true, the reasoning is invalid (see above).
- Incorrect – Although the reasoning is true as it relates to Refuel Interlocks as a whole, the stem conditions will not cause a bridge motion block (per Attachment 3).

Technical Reference(s): OP-66A (Attach if not previously provided)
UFSAR 14.6.1.4

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-08B, EO 1.02 & 1.05 (As available)

Question Source:

Bank #	25607
Modified Bank #	
New	

 (Note changes or attach parent)

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 3) 295019 Partial or Total Loss of Inst. Air AA1.04Ability to operate and/or monitor the following as they apply to
PARTIAL OR COMPLETE LOSS OF INSTRUMENT AIR:

- Service air isolation valves: Plant-Specific

Level	RO	SRO
Tier #	1	_____
Group #	1	_____
K/A #	295019 AA1.04	_____
Importance Rating	3.3	_____

Proposed Question: # 13

The Instrument Air System (IAS) has developed a leak. Which of the following describes the operation of the Service Air Isolation Valve (39FCV-110) during this transient?

- Automatically closes at 85 psig (lowering) and will automatically reset at 90 psig (rising)
- Automatically closes at 85 psig (lowering) and can be manually reset at 90 psig (rising)
- Automatically closes at 95 psig (lowering) and will automatically reset at 100 psig (rising)
- Automatically closes at 95 psig (lowering) and can be manually reset at 100 psig (rising)

Proposed Answer: d.

Explanation
(Optional):

- CORRECT:** Per AOP-12 and OP-39, 39FCV-110 will automatically close if air header pressure drops to 95 psig. Additionally, OP-39 specifies that the red Reset pushbutton must be manually pressed (which overrides and opens valve) and then released when header pressure is greater than 100 psig (to maintain valve open)
- Incorrect:** See above. 85 psig is the setpoint for the **Breathing** Air Header Isolation Valve 39AOV-111. Reset pressure is correct for 39AOV-111, but does **not** automatically reset.
- Incorrect:** See above. 85 psig is the setpoint for the **Breathing** Air Header Isolation Valve 39AOV-111. Function and Reset pressure is correct for 39AOV-111.
- Incorrect:** See above. Correct setpoint for Isolate and Reset, but does **not** automatically reset.

Technical Reference(s): AOP-12 (Attach if not previously provided)
OP-39, Section G.11

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-39, EO 1.05 a 9/10, 1.05.c 1/2, & 1.11.b.3/4 (As available)

Question Source:

Bank #	
Modified Bank #	24638 (attached)

 (Note changes or attach parent)

Question History:

New	
Last NRC Exam	

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:
Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content:
55.41
55.43

Comments:

PLANT
Seabrook 1

Exam Date
5/30/2003

Exam Type
ILO

Question Id
24838

NESSType
PWR

Question Which of the following describes the operation of the Service Air Isolation valves, SA-V92 and SA-V93, during an Instrument Air leak?

Answer Automatically CLOSE at 90 psig decreasing, resets to allow manual opening above 95 psig increasing.

Distractor 1 Automatically CLOSE at 80 psig decreasing, automatically REOPEN above 83 psig INCREASING.

Distractor 2 Automatically CLOSE at 90 psig decreasing, automatically reopen above 95 psig INCREASING.

Distractor 3 Automatically CLOSE at 80 psig decreasing, resets to allow manual OPENING above 83 psig INCREASING.

Ref Material

Question Comment D - correct - IAS and SAS systems are cross connected through valves SA-V92 and - V93 which automatically close when service air pressure lowers to 90psig (reopens on 93psig increasing).

Distract1Comment

Distract2Comment

Distract3Comment

<i>KaNumber</i>	<i>KaSegment1</i>	<i>KaSegment2</i>	<i>KaSegment3</i>	<i>KaSegment4</i>	<i>KaSegment5</i>
.079.A2.01			079	A2	01
<i>KaRevision</i>				<i>CognitiveLevel</i>	<i>ExamLevel</i>
				1	R

Examination Outline Cross-reference:

(Page 2) 295003 Partial or Complete Loss of AC G2.1.7
Ability to evaluate plant performance and make operational judgments based on operating characteristics / reactor behavior / and instrument interpretation.

Level	RO	SRO
Tier #	1	---
Group #	1	---
K/A #	295003 G2.1.7	---
Importance Rating	3.7	---

Proposed Question: # 14

From a normal full power operating condition, a complete and instantaneous loss of bus 10500 occurs. All equipment functions as designed. Several minutes after the loss, the bus is still de-energized.

Which of the following is the probable cause?

- Ground fault trip of circuit breaker 10514
- Loss of DC Control Power to the 10500 Bus
- Overcurrent condition on CRD Pump "Alpha" Motor
- Actuation of the 10500 Degraded Bus Voltage Timer

Proposed Answer: a.

Explanation
(Optional):

- CORRECT – Per ARP-09-8-2-8, a trip of 10514 (10300 – 10500 Tie Breaker) is a cause of the loss of 10500. The ground fault trip is an "86" Device trip which requires a manual reset.
- Incorrect – Loss of DC Control Power to the 10500 breaker(s) would not generate a trip (result in loss) but would result in a loss of breaker position indications.
- Incorrect – Via selective tripping methodology, the CRD Pump breaker, alone, should trip on overcurrent. If that didn't work, then L15 power supply breaker should trip. It would take failure of both selective trips to propagate to the entire 10500 bus, and credibility of occurrence would be a stretch at best.
- Incorrect – The "several minutes" portion of the stem, along with the absence of any delineated EDG failure(s), nullifies distracter "d" as this would trip the breaker momentarily but only until EDGs came up to speed and closed back in.

Technical Reference(s): AOP-18 (Attach if not previously provided)
ARP-09-8-2-8

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-71E, EO 1.05 c & 1.10 (As available)
SDLP-71O, EO 1.23

Question Source: Bank # 25599
Modified Bank # (Note changes or attach parent)
New

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 4) 295024 High Drywell Pressure / 5 EK3.05

Knowledge of the reasons for the following responses as they apply to HIGH DRYWELL PRESSURE:

- RPV flooding

Level	RO	SRO
Tier #	1	-----
Group #	1	-----
K/A #	295024 EK3.05	-----
Importance Rating	3.5	-----

Proposed Question: # 15

Which of the below scenarios describes a condition which may require entry into EOP-7, RPV Flooding, and the reason for that entry?

- Several minutes after a LOCA, Drywell Pressure is 5 psig and Drywell Temperature is 240 degrees with no RHR pumps available. EOP-7 entry enables flooding the RPV to the level of the pipe break thus effecting Drywell Spray through the pipe break.
- RPV Water level below the Top of Active Fuel with RPV Pressure at 400 psig and only SLC injecting to the RPV. EOP-7 entry will perform the Emergency Depressurization that enables the low pressure injection sources to inject to the RPV.
- Several minutes after an unisolable large break LOCA, Drywell Pressure is 25 psig and all Drywell Temperatures are above 320 degrees. EOP-7 entry enables the use of all available injection sources to raise RPV water level to the Main Steam Lines.
- RPV Water Level on the Fuel Zone Recorder and Refuel Zone is 170 inches with Drywell Temperatures 150 to 200 degrees. All other RPV Level Indicators are unavailable. EOP-7 will restore RPV Water Level to the usable range of the Refuel Zone Level Indicator.

Proposed Answer: c.

Explanation
(Optional):

- CORRECT:** The conditions presented describe a DBA-LOCA which results in pressure equalization between the RPV and the Drywell. Using the Drywell Pressure value on the EOP-11 RPV Saturation curve, you find yourself on the bad side indicating that level instrumentation MAY be unreliable due to boiling in the reference leg. Should this occur, a conclusion that RPV level cannot be determined will lead to direction to enter EOP-7.
- Incorrect:** These parameters are on the bad side of the Drywell Spray Initiation Pressure Limit and the EOP-4 Drywell Spray Leg is not used until Torus Pressure exceeds 15 psig. Without additional information the candidate is forced to conclude that Torus Pressure is approximately 3 psig.
- Incorrect:** Although EOP-7 entry will accomplish the ED enabling Low Pressure injection, the conditions described do not result in EOP-7 entry. Per the Alternate RPV Level Control Leg of EOP-2, these conditions result in waiting until RPV level drops to -19 inches before an ED is required.
- Incorrect:** Although the conditions describe a significant degradation in RPV Level Indication, they do not describe the inability to determine level. The correct course of action would be to raise RPV level 5 inches to the useable range.

Examination Outline Cross-reference:

(Page 23) G2.3.9

Knowledge of the process for performing a containment purge.

Level

RO

SRO

Tier #

3

Group #

K/A #

Cat 3 G2.3.9

Importance Rating

2.5

Proposed Question: # 16

The plant is conducting a shutdown, power is currently 30% and lowering. It is desired to de-inert the Primary Containment (both the Drywell and Torus) as soon as possible to permit containment access for maintenance.

Which procedurally allowed flowpath would be used for de-inerting the Primary Containment?

- Through the Standby Gas Treatment System with the Drywell and Torus de-inerted simultaneously.
- Through the Standby Gas Treatment System with the Drywell de-inerted first and then the Torus de-inerted.
- Through the Reactor Building Ventilation System with the Drywell and Torus de-inerted simultaneously.
- Through the Reactor Building Ventilation System with the Drywell de-inerted first and then the Torus de-inerted.

Proposed Answer: **b.**Explanation
(Optional):

- CORRECT** – Test of OP-37, Section F, Caution on simultaneous opening of Drywell and Torus Exhaust Isolation Valves bypassing the pressure suppression function of the Torus when Primary Containment is required. Per stem power conditions, Primary Containment is required
- Incorrect – See above. Word “simultaneously” makes incorrect.
- Incorrect – See above. Wrong system and “simultaneously.”
- Incorrect – See above. Wrong system with correct order.

Technical Reference(s): OP-37, Section F (Attach if not previously provided)
TS 3.6.1.1

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-16B, EO 1.13.c/d (As available)
SDLP-01B, EO 1.06.b

Question Source: Bank # 25686
 Modified Bank # (Note changes or attach parent)
 New

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 18) 202002 Recirculation Flow Control K5.02

Knowledge of the operational implications of the following concepts as they apply to RECIRCULATION FLOW CONTROL SYSTEM:

- Feedback signals

Level	RO	SRO
Tier #	2	-----
Group #	2	-----
K/A #	202002 K5.02	-----
Importance Rating	2.6	-----

Proposed Question: # 17

The plant is operating at normal 100% power, steady-state, when Alarm 09-4-3-40, "RWR MG B SPEED CNTRL SIG FAILED" is received. All plant operating parameters are within required bands at the time of the alarm.

Which of the following is expected to occur as a result of this condition?

- Alarm 09-4-3-20 "RWR MG B SCOOP TUBE LOCK" only
- Alarm 09-4-3-39 "RWR MG B 30% OR 44% SPEED LIMIT" only
- Alarm 09-4-3-10 "RWR MG B GEN LOCKOUT" concurrent with Alarm 09-4-3-19 "RWR MG B DRV MTR BKR TRIP"
- Alarm 09-4-3-39 "RWR MG B 30% OR 44% SPEED LIMIT" concurrent with the "RWR MG B RUNBACK" red light on the 09-4 apron

Proposed Answer: a.

Explanation
(Optional):

- CORRECT:** Per ARP 09-4-3-40, a loss of signal to the scoop tube positioner results in an automatic scoop tube lock; which would yield the subsequent 09-4-3-20 alarm. ARP 09-4-3-20 validates cause/effect.
- Incorrect:** Per ARP 09-4-3-40, a loss of signal to the scoop tube positioner results in an automatic scoop tube lock **only**; which would **not** yield the subsequent 09-4-3-39 alarm only (indicative of 30% runback) without plant parameters warranting the runback (stem parameters normal).
- Incorrect:** Per ARP 09-4-3-40, a loss of signal to the scoop tube positioner results in an automatic scoop tube lock **only**; which would **not** yield the subsequent 09-4-3-10 / 09-4-3-19 alarms without some type of concurrent overvoltage / overcurrent condition, which the stem lacks.
- Incorrect:** Per ARP 09-4-3-40, a loss of signal to the scoop tube positioner results in an automatic scoop tube lock **only**; which would **not** yield the subsequent 09-4-3-39 alarm / apron red light (indicative of 44% runback) without the scoop tube being in Auto-Unlock and plant parameters warranting the runback (stem parameters normal).

Technical Reference(s): ARP 09-4-3-39 (Attach if not previously provided)
ARP 09-4-3-40

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-02I, EO 1.05.a.8/b.5/c.3, 1.12.b, & 1.14.d (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input checked="" type="checkbox"/>
Comprehension or Analysis	<input type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 23) G2.3.4

Knowledge of radiation exposure limits and contamination control / including permissible levels in excess of those authorized.

Level	RO	SRO
Tier #	3	-----
Group #	-----	-----
K/A #	Cat 3 G2.3.4	
Importance Rating	2.5	-----

Proposed Question: **# 18**

The 10 CFR 20 limit on Occupational Radiation Exposure (Total Effective Dose Equivalent) for a licensed Reactor Operator is _____; and only the _____ has the authority to approve radiation exposures in excess of 10CFR20 limits?

- a. 5 Rem/year; Emergency Director
- b. 4 Rem/year; Emergency Director
- c. 5 Rem/year; Vice President Operations
- d. 4 Rem/year; Vice President Operations

Proposed Answer: **a.**

Explanation
(Optional):

- a. CORRECT – 10CFR20 establishes a TEDE Federal Dose Limit for Radiation Workers at 5 Rem/year. Per EAP-15, ONLY the Emergency Director can authorize exposure limits in excess of 10CFR20 limits.
- b. Incorrect – See above. 4 Rem/year is a site-specific administrative exposure limit versus federal. The Emergency Director, by nature of the question could authorize exceeding this value, but it is not the intent of the question.
- c. Incorrect – See above. Correct Federal Limit. VPO can authorize exceeding administrative limit, but not federal limit.
- d. Incorrect – See above. This is the site admin limit which does require approval, by the Vice President of Plant Operations, to exceed.

Technical Reference(s): AP-07.05 / 10CFR20 (Attach if not previously provided)
EAP-15

Proposed references to be provided to applicants during examination: None

Learning Objective: ENN GET, EO 8.4.1 & 8.4.3 (As available)
EP-12.5.3, EO 1.20.B

Question Source: Bank # 25683
Modified Bank # (Note changes or attach parent)
New

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments: This question was SRO-level on the last exam and is being used as an RO-level question on this exam.

Examination Outline Cross-reference:

(Page 20) 271000 Offgas A2.10

Ability to (a) predict the impacts of the following on the OFFGAS SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:

- Offgas system high flow

Level	RO	SRO
Tier #	2	---
Group #	1	---
K/A #	271000 A2.10	---
Importance Rating	3.1	---

Proposed Question: # 19

The plant is operating at 10% power when annunciator 09-6-1-29 "CNDSR VAC LO" alarms. Condenser vacuum has slowly dropped to 25.5 inches of Hg. A NPO, dispatched to search for potential causes, has just reported a small tear in the expansion boot between the Main Condenser and the LP turbine hood. How has the Offgas flow changed (prior to any operator action) and what actions will the operator take in response to this event?

- Offgas flow has RISEN; place the spare Steam Jet Air Ejector(s) in service.
- Offgas flow has DROPPED; trip Hydrogen Addition and start the Condenser Air Removal Pumps.
- Offgas flow has RISEN; trip Hydrogen Addition and start the Condenser Air Removal Pumps.
- Offgas flow has DROPPED; trip the Turbine, Scram the Reactor and close the Main Steam Line Isolation Valves.

Proposed Answer: a.

Explanation
(Optional):

- CORRECT – AOP-31 indicates that air in-leakage will be indicated by a rise in Offgas flow rate; and directs placing the spare SJAES in service.
- Incorrect – Offgas flow will rise (see above) and Condenser Air Removal Pumps discharge to the 1.75 minute holdup pipe, which is not designed for explosion pressure. For this reason, their operation is not permitted if reactor power is greater than 5%. Power is greater than 5%. Hydrogen Addition trip ok.
- Incorrect – Offgas flow rise correct, but Condenser Air Removal Pump operation is not permitted if reactor power is greater than 5% (see above). Hydrogen Addition trip ok.
- Incorrect – Offgas flow will rise (see above) and the stem condition provided for vacuum lowering would not warrant these actions.

Technical Reference(s): AOP-31 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-38, EO 1.10.h & 1.14.b (As available)

Question Source: Bank # 21356 (Note changes or attach parent)

Modified Bank #	
New	

Question History: Last NRC Exam LOI-01-01 (11/5/01)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 21) 286000 Fire K4.01

Knowledge of FIRE PROTECTION SYSTEM design feature(s) and/or interlocks which provide for the following:

- Adequate supply of water for the fire protection system

Level	RO	SRO
Tier #	2	---
Group #	2	---
K/A #	286000 K4.01	---
Importance Rating	3.4	---

Proposed Question: # 20

A power loss has occurred, rendering 76P-3 (Makeup "Jockey" Fire Pump) inoperable. The Fire Protection System functions as designed. For these conditions, the Electric Fire Pump (76P-2) will automatically start if the fire protection header pressure drops to:

- 92 psig
- 95 psig
- 105 psig
- 120 psig

Proposed Answer: c.

Explanation
(Optional):

- CORRECT:** Per OP-33, Electric Fire Pump 76P-2 auto-start setpoint is 105 psig decreasing.
- Incorrect:** Per OP-33, **East Diesel** Fire Pump 76P-4 auto-start setpoint is 92 psig decreasing.
- Incorrect:** Per OP-33, **West Diesel** Fire Pump 76P-1 auto-start setpoint is 95 psig decreasing.
- Incorrect:** Arbitrary pressure slightly lower than the normal operating header pressure range of 140 – 160 psig (from OP-33)

Technical Reference(s): OP-33 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-76, EO 1.05.c.1/2 & 1.14.f (As available)

Question Source:	Bank #		
	Modified Bank #	25838 (attached)	(Note changes or attach parent)

	New		
Question History:	Last NRC Exam		

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: **Memory or Fundamental Knowledge**

Comprehension or Analysis

10 CFR Part 55 Content: **55.41**

55.43

Comments:

PLANT
Susquehanna 1

ExamDate
8/8/2003

ExamType
ILO

QuestionId
25838

NSSSType
BWR

Question The T-20 Transformer developed an internal fault causing a fire and automatic actuation of the Fire Protection Deluge System. The Fire Protection System functions as designed. For these conditions the Diesel Driven Fire Pump will automatically start if the fire protection header pressure drops to:

Answer 85 psig.

Distractor 1 95 psig

Distractor 2 105 psig

Distractor 3 125 psig

RefMaterial

QuestionComment

Distract1 Comment The auto start of the Motor Driven Fire pump

Distract2 Comment The auto start of the Jockey Fire Pump

Distract3 Comment The auto shutdown of the Jockey Fire Pump

<i>KaNumber</i>	<i>KaSegment1</i>	<i>KaSegment2</i>	<i>KaSegment3</i>	<i>KaSegment4</i>	<i>KaSegment5</i>
.600000.2.1.31			800000	2.1	31
<i>KaRevision</i>				<i>CognitiveLevel</i>	<i>ExamLevel</i>
				1	R

Examination Outline Cross-reference:

(Page 23) G2.3.11

Ability to control radiation releases.

Level	RO	SRO
Tier #	3	-----
Group #	-----	-----
K/A #	Cat 3 G2.3.11	
Importance Rating	2.7	-----

Proposed Question: # 21

The plant was operating at 100% power when a large steam leak occurred inside the Reactor Building. Standby Gas Treatment System (SGT) Trains "Alpha" and "Bravo" are operating at rated flows. Secondary Containment differential pressure (to atmospheric) is +1.5" Water Gage (WG). All equipment performed as designed.

Off-Site radioactivity releases are expected to be _____ and can be minimized by _____.

- ground level releases via Standby Gas Treatment (SGT) only; securing one of the operating SGT trains.
- elevated releases via SGT and ground level releases via Reactor Building Ventilation; securing Reactor Building Ventilation.
- ground level releases via SGT and Reactor Building Ventilation; securing one of the operating SGT trains and manually isolating Reactor Building Ventilation.
- elevated releases via SGT and ground level releases via Reactor Building leakage (exfiltration); lowering the pressure in the secondary containment.

Proposed Answer: d.

Explanation
(Optional):

- CORRECT** – Per EAP-4, only the Stack is an elevated release. Everything else is considered ground level. SGT is discharging to the stack and Rx Building exfiltration is considered a ground level. Lowering pressure in the Rx Bldg will have the impact of lowering exfiltration from the building.
- Incorrect – See above. SGT is not a ground level. Securing one train of SGT would have the impact of lowering release rates though.
- Incorrect – See above. Rx Bldg Ventilation would be isolated on stem condition d/p and therefore would be in a recirculate/cool mode. Additionally, securing ventilation would have no impact.
- Incorrect – See above. SGT would not be a ground level release; and, although securing one train of SGT may lower release rates, Rx Bldg Vent is already isolated on stem condition d/p.

Technical Reference(s): OP-51A (Attach if not previously provided)
EOP-5 / EAP-4

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-16A, EO 1.09.b (As available)
SDLP-66A, EO 1.05.c
SDLP-01B, EO 1.20

Question Source:

Bank #	
Modified Bank #	25680 (attached)
New	
Last NRC Exam	

 (Note changes or attach parent)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

PLANT
FitzPatrick 1

ExamDate
7/1/2003

ExamType
ILO

QuestionId
25680

NSSSType
BWR

Question The plant was operating at 100% power when a large steam leak occurred inside the Reactor Building. SGT Train "A" and "B" are operating at rated flows. Secondary Containment pressure is +1.5" WG. Off-Site radioactivity release rates are expected to be

Answer Elevated releases via SGT and Ground releases via Reactor Building leakage

Distractor 1 Ground releases via SGT only

Distractor 2 Ground releases via SGT and Reactor Building Ventilation

Distractor 3 Elevated releases via SGT and Ground releases via Reactor Building Ventilation

RefMaterial

QuestionComment

Distract1Comment

Distract2Comment

Distract3Comment

<i>KaNumber</i>	<i>KaSegment1</i>	<i>KaSegment2</i>	<i>KaSegment3</i>	<i>KaSegment4</i>	<i>KaSegment5</i>
290001.K3.01			290001	K3	01
<i>KaRevision</i>				<i>CognitiveLevel</i>	<i>ExamLevel</i>
				2	R

Examination Outline Cross-reference:

(Page 23) G2.4.49

Ability to perform without reference to procedures those actions that require immediate operation of system components and controls.

(10CFR 55.43.5)***Industry OE and JAF Corrective Action***

Level

RO

SRO

Tier #

3

Group #

K/A #

Cat 4 G2 4.49

Importance Rating

4.0

Proposed Question: # 22

While operating at 100% CTP, A grid instability has resulted in a Generator Load Reject and a Residual Transfer. All plant equipment operated as expected.

Which one of the following actions is required to be performed IMMEDIATELY?

- Per AOP-1, "Reactor Scram", commence a reactor coolant system cooldown.
- Per AOP-11, "Loss of RBCLC", align Emergency Service Water for Drywell cooling.
- Per EOP-2, "RPV Control", restart the feed and condensate system.
- Per EOP-4, "Primary Containment Control", start RHR in full torus cooling.

Proposed Answer: a.

Explanation
(Optional):

- CORRECT:** A JAF corrective action from the 16 Aug 2003 Northeast Grid Instability Event was an immediate action added to AOP-1 to address RPV Bottom Head Cooldown. The major actions available in this scenario to address the concern are an RPV cooldown and actions to reduce CRD injection.
- Incorrect:** Although the action addressed will be performed at some point during this transient, and at Shift Manager's discretion, it is a subsequent action and will not be addressed "immediately" as stem requires.
- Incorrect:** This action cannot be completed immediately. It requires completion of AOP-57. Although RPV water level is not an immediate concern in this scenario, it is better addressed through the use of HPCI/RCIC.
- Incorrect:** Although this scenario will eventually demand that this action be completed due to SRV and HPCI operation, it is not of immediate concern.

Technical Reference(s): AOP-1 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: LP-AOP EO-1.03 (As available)

Question Source: Bank #
 Modified Bank # (Note changes or attach parent)
 New X

Question History: Last NRC Exam

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 22) G2.1.9

Ability to direct personnel activities inside the control room.

(10CFR 55.43.5)

Level

Tier #

Group #

K/A #

Importance Rating

RO	SRO
-----	3

Cat 1 G2.1.9	
-----	4.0

Proposed Question: # 23

A reactor startup is in progress at 8 % power, Mode 2, when the Feedwater Startup Valve (34FCV-137) fails full-open with the following results:

- Full SCRAM
- SNO-1 reports 4 rods at positions between 04 and 48
- All four of the rods are widely separated across the core
- APRMs are Downscale
- Lowest RPV level observed was 190 inches; and currently, RPV water level is slowly rising
- SNO-2 is able to control Feedwater Startup Valve, 34FCV-137, in "MANUAL"
- RPV pressure is 900 psig and slowly trending down

Which of the following is the cause of the SCRAM and the required direction to the SNO-1?

- a. APRM Upscale; Determine an EP-3 success path and insert control rods
- b. APRM Upscale; Insert control rods per AOP-1, Subsequent Operator Actions
- c. RPV High Water Level; Determine an EP-3 success path and insert control rods
- d. RPV High Water Level; Insert control rods per AOP-1, Subsequent Operator Actions

Proposed Answer: b.

Explanation
(Optional):

- b. CORRECT: APRM set-down SCRAM of 15% when RMS is out of RUN. AOP-1 provides Operator guidance for these conditions.
- a. Incorrect: APRM Upscale is correct, but, stem provides no EOP-2 entry conditions, therefore EOP-3 and thus EP-3 are not applicable.
- c. Incorrect: Main Turbine not yet operating. Therefore, no High Level Trip / Scram.
- d. Incorrect: See above. First half incorrect – second half correct.

Technical Reference(s): AOP-1 (Attach if not previously provided)
SDLP-05/07C

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-07C, EO 1.05.c.3.b & 1.07.c (As available)
SDLP-05, EO 1.07.a.5

Question Source: Bank # 25648
Modified Bank # [Redacted] (Note changes or attach parent)
New [Redacted]

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 11) 211000 SLC A3.07

Ability to monitor automatic operations of the STANDBY LIQUID CONTROL SYSTEM including:

- Lights and alarms: Plant-Specific

Level

RO

SRO

Tier #

2

Group #

1

K/A #

211000 A3.07

Importance Rating

3.7

Proposed Question: # 24

The plant experiences an ATWS during 100% power operation. Reactor power, level, and pressure remain at their previous full-power values. The CRS has directed you to initiate Standby Liquid Control (SLC). You operate the keylock switch to "SYS A" and successfully start 11P-2A ("Alpha" SLC Pump).

Which of the following sets of indications (10-seconds after pump start) supports your making the report that "Alpha SLC pump is running and injecting to the reactor"?

	Squib Valve Continuity (SQUIB VLVS READY) Lights	Alarm 09-3-3-30, "SLC SQUIB VLC CONTINUITY LOSS"	SLC Pump 11P- 2A Discharge Pressure
a.	Illuminated (<i>on</i>)	Extinguished (<i>no alarm</i>)	1045 psig
b.	Extinguished (<i>off</i>)	Illuminated (<i>alarming</i>)	1045 psig
c.	Illuminated (<i>on</i>)	Illuminated (<i>alarming</i>)	1280 psig
d.	Extinguished (<i>off</i>)	Extinguished (<i>no alarm</i>)	1280 psig

Proposed Answer: a.

Explanation
(Optional):

- CORRECT: OP-17 provides a startup validation list for SLC. Squib Valve Ready Lights are "ON" and SLC Pump Discharge Pressure is \geq reactor pressure, which the stem indicates remained at its previous full-power value of approximately 1040 psig. ARP 09-3-3-30 does not indicate SLC Pump Start as a possible cause for this alarm; and the alarm is "OFF". (verified in simulator)
- Incorrect: Per OP-17, Squib Ready Lights are "ON" and SLC Pump Discharge Pressure is \geq reactor pressure, which is still correct in this distracter. ARP 09-3-3-30 does not indicate SLC Pump Start as a possible cause; and the alarm is "OFF".
- Incorrect: Per OP-17, Squib Ready Lights are "ON" and SLC Pump Discharge Pressure is \geq reactor pressure, which is still correct in this distracter, but would **not** be expected to be this high. ARP 09-3-3-30 does not indicate SLC Pump Start as a possible cause; and the alarm is "OFF".
- Incorrect: Per OP-17, Squib Ready Lights are "ON" and SLC Pump Discharge Pressure is \geq reactor pressure, which is still correct in this distracter, but would **not** be expected to be this high. ARP 09-3-3-30 does not indicate SLC Pump Start as a possible cause; and the alarm is "OFF".

Technical Reference(s): OP-17, Section D (Attach if not previously provided)
GE 791E462

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-11, EO 1.05.b.4 & 1.12.a (As available)

Question Source:

Bank #	
Modified Bank #	25852 (attached)

 (Note changes or attach parent)

Question History:

New	
Last NRC Exam	

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

PLANT Susquehanna 1	ExamDate 8/8/2003	ExamType ILO	QuestionId 25852	NSSSType BWR
-------------------------------	-----------------------------	------------------------	----------------------------	------------------------

Question An ATWS transient occurs and boron must be injected with the Standby Liquid Control System (SLC).
Which of the following describes the effect of a successful initiation of SLC on these indications:
1) Squib Valve Ready (Continuity) lights
2) Alarm on Panel 1C601, SBLC SQUIB VALVES LOSS OF CKT CONTINUITY AR-107-A03
3) Pump discharge pressure

Answer 1) Extinguished
2) Annunciator In Alarm
3) 200 psig greater than reactor pressure

Distractor 1 1) Illuminated
2) Annunciator in Alarm
3) 200 psig greater than reactor pressure

Distractor 2 1) Illuminated
2) Annunciator not in Alarm.
3) Just above reactor pressure

Distractor 3 1) Extinguished
2) Annunciator not in Alarm
3) Just above reactor pressure

RefMaterial

QuestionComment correct answer, Squib valve fires, causing loss of continuity, alarm annunciates indicating loss of continuity, pumps start with discharge pressure slightly greater than reactor pressure.

Distract1 Comment Continuity lights go out.

Distract2 Comment Continuity lights go out. Alarm is annunciates, discharge pressure 200 psig reactor pressure.

Distract3 Comment Alarm is annunciates, discharge pressure 200 psig above reactor pressure.

KaNumber .211000.A4.08	KaSegment1	KaSegment2	KaSegment3 211000	KaSegment4 A4	KaSegment5 08
KaRevision				CognitiveLevel 1	ExamLevel R

Examination Outline Cross-reference:

(Page 11) 215003 IRM K6.05

Knowledge of the effect that a loss or malfunction of the following will have on the INTERMEDIATE RANGE MONITOR (IRM) SYSTEM:

- Trip units

Level	RO	SRO
Tier #	2	-----
Group #	1	-----
K/A #	215003 K6.05	-----
Importance Rating	3.1	-----

Proposed Question: # 25

The Reactor Mode Switch has just been placed in "RUN" during a plant startup. Subsequently, a low detector voltage condition on Intermediate Range Monitor (IRM) "Golf" has brought in Alarm 09-5-2-52 "IRM TRIP SYS A INOP OR UPSCALE TRIP". The result is...

- alarm only, as all IRM protective actions are bypassed.
- if APRM "Golf" is downscale, a control rod block occurs.
- if APRM "Echo" is downscale, a half-scam on RPS "Alpha" occurs.
- an immediate control rod block and a half-scam on RPS "Alpha" occur.

Proposed Answer: c.

Explanation
(Optional):

- CORRECT:** Per ARP 09-5-2-52(53), a low detector voltage is indicated as a cause for the alarm, and automatic actions are dependent on mode switch position. With mode switch in "RUN", the result is a RPS Half-Scram on that side if the companion APRM is downscale. With the mode switch NOT in "RUN", a rod block and a RPS Half-Scram on that side would occur.
- Incorrect:** See above – only rod blocks bypassed in "RUN"
- Incorrect:** See above.
- Incorrect:** See above.

Technical Reference(s): ARP 09-5-2-52(53) (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-07B, EO 1.05.a.4.h, 1.14.f, & 1.15.g (As available)

Question Source:

Bank #	
--------	--

Modified Bank #	25642 (attached)
-----------------	------------------

 (Note changes or attach parent)

Question History:

New	
-----	--

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
---------------------------------	--------------------------

Comprehension or Analysis	<input checked="" type="checkbox"/>
---------------------------	-------------------------------------

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
-------	-------------------------------------

55.43	<input type="checkbox"/>
-------	--------------------------

Comments:

PLANT
FitzPatrick 1

ExamDate
7/1/2003

ExamType
ILO

QuestionId
25842

NSSSType
BWR

Question An IRM HI Flux Control Rod Block is automatically bypassed when _____ ?

Answer The Reactor Mode Switch is placed in RUN.

Distractor 1 The IRM is on Range 1.

Distractor 2 The IRM's companion APRM is downscale.

Distractor 3 The SRM's are fully inserted.

RefMaterial

QuestionComment

Distract1Comment

Distract2Comment

Distract3Comment

<i>KaNumber</i>	<i>KaSegment1</i>	<i>KaSegment2</i>	<i>KaSegment3</i>	<i>KaSegment4</i>	<i>KaSegment5</i>
215003.A3.04			215003	A3	B4
<i>KaRevision</i>				<i>CognitiveLevel</i>	<i>ExamLevel</i>
				1	R

Examination Outline Cross-reference:

(Page 10) 203000 RHR/LPCI: Injection Mode G2.3.4Knowledge of radiation exposure limits and contamination control /
including permissible levels in excess of those authorized.

Level	RO	SRO
Tier #	2	
Group #	1	
K/A #	203000 G2.3.4	
Importance Rating	2.5	

Proposed Question: # 26

You are the SNO during a significant plant transient in which a General Emergency has just been declared. None of the Emergency Response Facilities have reported in as staffed. The only RPV injection source is "A" RHR yet due to a power supply loss, you have been directed to dispatch a NPO to manually open 10MOV-25A. Your RP Tech reports that dose rates in the area of 10MOV-25A are 300 Rem/Hour. Which of the below actions are required to be performed, by your Control Room Supervisor, to complete this task?

- No additional permissions are required. Dispatch the NPO to the area above the Drywell Personnel Access. Instruct him that he is limited to 5 minutes to complete the task.
- No additional permissions are required. Dispatch the NPO to the Reactor Building 300 Elevation West. Instruct him that he is limited to 10 minutes to complete the task.
- Obtain Shift Manager permission. Dispatch the NPO to the area above the Drywell Personnel Access. Instruct him that he is limited to 5 minutes to complete the task.
- Obtain Shift Manager permission. Dispatch the NPO to the Reactor Building 300 Elevation West. Instruct him that he is limited to 10 minutes to complete the task.

Proposed Answer: c.

Explanation
(Optional):

- CORRECT:** Until the Emergency Director has taken over for the Shift Manager, the SM has all ED responsibilities including the authorization of Emergency Exposures. This responsibility cannot be delegated to the CRS as many SM duties can. This emergency exposure is clearly required to protect the public and therefore is allowed 25 Rem. The location of the 10RHR-25A manual operator is in the LPCI Mezzanine above the Drywell Personnel Access.
- Incorrect:** This exposure requires Shift Manager/Emergency Director permission and this permission cannot be delegated. The time allotment and locations are correct.
- Incorrect:** This exposure requires Shift Manager/Emergency Director permission and this permission cannot be delegated. The time allotment is another Emergency Exposure limitation intended to protect valuable property. The location given is the location of the "A" Core Spray injection valves vice RHR.
- Incorrect:** The permission statement is correct. The location is that of the "A" Core Spray injection valves vice RHR and the time allotment is another Emergency Exposure limitation intended to protect valuable property.

Technical Reference(s): EAP-15 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-10, EO 1.11.c.3
EP-12.5.4.2, EO 3.06; EP-12.5.3, EO 1.20

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 3) 295016 Control Room Abandonment G2.1.30
Ability to locate and operate components / including local controls.

Level	RO	SRO
Tier #	1	-----
Group #	1	-----
K/A #	295016 G2.1.30	
Importance Rating	3.9	-----

Proposed Question: # 27

The Shift Manager has just ordered a control room evacuation in accordance with AOP-43, "Plant Shutdown From Outside the Control Room." When you arrive at the Auxiliary Shutdown Panel 25 RSP you place the isolation switch for LPCI INBOARD INJECTION VALVE (10MOV-25B) in LOCAL. Reactor water level is 50 inches and reactor pressure is 700 psig. Reactor water level and reactor pressure are dropping. With the isolation switch in LOCAL which statement below describes the operation of the LPCI INBOARD INJECTION VALVE (10MOV-25B) valve as reactor pressure and reactor water level drop.

- Must be manually opened at valve (10MOV-25B) location
- Will automatically open when the "Bravo" RHR pump is started
- Will automatically open when reactor pressure is less than 450 psig
- Must be manually opened from the Auxiliary Shutdown Panel 25 RSP

Proposed Answer: d.

Explanation
(Optional):

- CORRECT – When the isolation switch for the 10MOV-25B is placed in LOCAL this disables all interlocks and will only allow operation of this valve from the Auxiliary Shutdown Panel. In addition, the valve will not open when the pump is started, the interlock is based on an ECCS signal and pressure.
- Incorrect – See above
- Incorrect – See above
- Incorrect – See above.

Technical Reference(s): AOP-43 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-10, EO 1.05.a.8.d & 1.11.b.9/23.a (As available)

Question Source:

Bank # 21353

Modified Bank #	
New	

(Note changes or attach parent)

Question History:

Last NRC Exam LOI-01-01 (11/5/01)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content:

55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 19) 219000 RHR/LPCI: Torus/Pool Cooling Mode K6.06

Knowledge of the effect that a loss or malfunction of the following will have on the RHR/LPCI TORUS/SUPPRESSION POOL COOLING MODE:

- Suppression pool

Level

RO

SR0

Tier #

2

Group #

2

K/A #

219000 K6.06

Importance Rating

3.7

Proposed Question: # 28

PLACE OP-13A, ATTACHMENT 1 INTO EXAM FORMAT OR PROVIDE AS EXAM ATT.

During accident conditions, the "Alpha" Loop of RHR is operating in Torus cooling with two (2) RHR pumps and the following indications:

- ◆ "A" RHR Loop Flow is 10,000 gpm.
- ◆ Torus Water Temperature is 193°F.
- ◆ Torus Pressure is 0 psig.
- ◆ Torus Water Level is 7.0 feet.

Continued operation of the "A" loop of RHR under these conditions....

- may result in pump damage. The 0 psig overpressure curve is violated by 35 °F.
- may result in pump damage. The 0 psig overpressure curve is violated by ~ 10°F.
- will not damage the pumps. The 5 psig overpressure curve has a 1° F margin.
- will not damage the pumps. The 5 psig overpressure curve has an ~ 20°F margin.

Proposed Answer: **b.**Explanation
(Optional):

- CORRECT:** Proper application of the curve will find an operating point at 5000 gpm and 193° torus temperature which is approximately 10° in violation of the 2 pump curve. 10° is chosen to provide validity to candidate curve interpolation at the computed overpressure value of 2 psig.
- Incorrect:** Incorrect application at the 10000 gpm line will find a 0 psig overpressure violation of the 2 pump curve by ~35°.
- Incorrect:** The 5 psig overpressure curve is incorrect but may be used if the candidate does not use the .4 multiplier in determining the value of overpressure. On the 10000 gpm line, the 5 psig overpressure for 2 pump operation is safe by ~1°.
- Incorrect:** The 5 psig overpressure curve is incorrect but may be used if the candidate does not use the .4 multiplier in determining the value of overpressure. On the 5000 gpm line, the 5 psig overpressure for 2 pump operation is safe by 20°.

Technical Reference(s): OP-13A, Attachment 1 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: OP-13A, Attachment 1

Learning Objective: MIT-301.11B EO-1.01 (As available)

Question Source:

Bank #	
Modified Bank #	

 (Note changes or attach parent)

New

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 10) 209001 LPCS K6.03

Knowledge of the effect that a loss or malfunction of the following will have on the LOW PRESSURE CORE SPRAY SYSTEM:

- Torus/suppression pool water level

Level	RO	SRO
Tier #	2	---
Group #	1	---
K/A #	209001 K6.03	---
Importance Rating	3.3	---

Proposed Question: # 29

The Core Spray System Pumps (14P-1A /1B) are normally aligned to take suction on the _____; and during pump operation, if level is continuously lost from the normal suction path, then _____.

- Torus; the Core Spray Pumps would continue to run until they overheat and trip.
- Torus; the Core Spray Pump Suction Valve(s) will automatically transfer to the CSTs.
- CSTs; the Core Spray Pump Suction Valve(s) will automatically transfer to the Torus.
- CSTs; the Core Spray Pumps will trip on low suction pressure if the suction source is not manually swapped.

Proposed Answer: a.

Explanation
(Optional):

- CORRECT:** Per OP-14 and supported by pump / suction valve circuitry drawings, the CS Pumps do not have Low Suction Pressure trips and there is no auto-swap on the Torus and CST suction in the case of Core Spray. Core Spray is normally aligned to the Torus, but can be manually aligned to the CSTs (requires declaring respective pump inop). A pump running until it loses suction would be a similar condition to a pump with a sheared shaft and would continue to operate until, in this case, friction builds up to a point where overheating occurs and the rotor may seize on bearing failure for example, which in turn would trip the pump on overcurrent conditions.
- Incorrect:** See above. First part correct, but there is no auto-swap feature on the suction valves.
- Incorrect:** See above. First part incorrect and there is no auto-swap feature on the suction valves.
- Incorrect:** See above. First part incorrect and there is no low suction pressure trip on the Core Spray Pumps.

Technical Reference(s): OP-14 (Attach if not previously provided)
ESK-5BF

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-14, EO 1.05.c.1 & 1.10.b (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input checked="" type="checkbox"/>
Comprehension or Analysis	<input type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 18) 202002 Recirculation Flow Control G2.2.14
Knowledge of the process for making configuration changes.
(10CFR 55.43.3)

Level	RO	SRO
Tier #	-----	2
Group #	-----	2
K/A #	202002	G2.2.14
Importance Rating	-----	3.0

Proposed Question: # 30

Prior to startup (in Mode 4), a special test is proposed. The test consists of starting a Recirculation Pump and then initially throttling open its discharge valve to 50%. The Recirculation Pump speed will then be raised to 50%. After 50% speed is achieved, the discharge valve will be throttled from 50% to 100% open over a period of 15 minutes while flow data is obtained at prescribed intervals.

The responsible engineer approaches you with technical questions on what specific method, and/or procedures, will allow the successful conduct of the test. You provide the appropriate response by indicating that the Shift Manager must...

- authorize jumpers to be installed around the Speed Limiter #1 (30% Runback) circuitry in accordance with ENN-DC-136, Temporary Alterations.
- authorize jumpers to be installed around the Speed Limiter #1 (30% Runback) circuitry in accordance with ENN-DC-102, Operating Plant Changes and Modifications.
- authorize jumpers to be installed around the Speed Limiter #2 (44% Runback) circuitry in accordance with ENN-DC-136, Temporary Alterations.
- authorize jumpers to be installed around the Speed Limiter #2 (44% Runback) circuitry in accordance with ENN-DC-102, Operating Plant Changes and Modifications.

Proposed Answer: a.

Explanation
(Optional):

- CORRECT:** First, the 30% Runback is generated by Speed Limiter #1 whenever the Recirc Pump is operating and the Recirc Pump Discharge Valve(s) are not full-open (<90%) or Total Feedwater Flow is less than 20%. Second, the controlling procedure for this type of non-permanent change is ENN-DC-136, Temporary Alterations.
- Incorrect:** First part correct. Second part incorrect in that the referenced procedure is a motherhood-style, high-level procedure which dictates that you will have processes/procedures in place to conduct design/configuration changes, whether temporary or permanent.
- Incorrect:** First part incorrect in that the #2 Speed Limiter does not receive input from Recirc Pump Discharge Valve position limit switches. Second part is correct.
- Incorrect:** First part – see "c" above. Second part incorrect in that the referenced procedure is a motherhood-style, high-level procedure which dictates that you will have processes/procedures in place to conduct design/configuration changes, whether temporary or permanent.

Technical Reference(s): ENN-DC-102 / ENN-DC-136 (Attach if not previously provided)
Dwgs. 1.60-150 / 151 / 152 / 156

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-02I, EO 1.05.a.4/5, c.1/2, 1.06.b/c, & 1.08.a/b (As available)
SDLP-02H, EO 1.13.b & 1.14.a

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input type="checkbox"/>
55.43	<input checked="" type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 2) 295005 Main Turbine Generator Trip G2.2.22
Knowledge of limiting conditions for operations and safety limits.
(10CFR 55.43.2)

Level	RO	SRO
Tier #	-----	1
Group #	-----	1
K/A #	295005	G2.2.22
Importance Rating	-----	4.1

Proposed Question: # 31

The plant is operating at normal 100% power, steady-state, when the GEMAC Master Feedwater Controller fails to maximum demand. All other plant equipment operates as designed and the following plant conditions result:

- Reactor Vessel Water Level rises rapidly to 224 inches on the Narrow Range GEMAC Indicators
- Turbine Bypass Valves and Safety Relief Valves function to limit the peak pressure at the bottom of the vessel to 1120 psig
- Reactor Engineering reports that the "Actual" Minimum Critical Power Ratio (MCPR) reached a value of 1.26 during the transient

Based on the above conditions, which of the following additional actions is warranted?

- Identify that the MCPR Safety Limit has been exceeded and respond to the automatic Reactor Scram.
- Identify that the MCPR Operating Limit has been exceeded and respond to the automatic Reactor Scram.
- Identify that the Reactor Coolant System Pressure Safety Limit has been exceeded and manually Scram the Reactor.
- Identify that the MCPR Safety Limit has been exceeded and manually Scram the Reactor.

Proposed Answer: b.

Explanation
(Optional):

- CORRECT:** Turbine Trip occurs at 222.5 inches and causes Rx scram above 29% power. Per COLR, Operating Limit MCPR ranges from 1.37 to 1.44, depending on fuel and cycle time.
- Incorrect: Per T.S., Safety Limit MCPR is ≥ 1.09 (two-loop) and was not violated.
- Incorrect: Per T.S., Rx Coolant Pressure Safety Limit < 1325 psig was not violated.
- Incorrect: Per T.S., Safety Limit MCPR is ≥ 1.09 (two-loop) and was not violated.

Technical Reference(s): ITS / COLR / SRLR (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-94A, EO 1.05.c.1 & 1.08 (As available)
ITS-LP-005, EO 1.03

Question Source:

Bank #	
Modified Bank #	

 (Note changes or attach parent)

New

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 11) 212000 RPS K3.12

Knowledge of the effect that a loss or malfunction of the REACTOR PROTECTION SYSTEM will have on the following:

- Secondary containment integrity

Level	RO	SRO
Tier #	2	-----
Group #	1	-----
K/A #	212000 K3.12	-----
Importance Rating	3.2	-----

Proposed Question: # 32

The plant is operating in a normal, full-power lineup when a loss of RPS Bus "Alpha" occurs. In accordance with the Prompt Actions of AOP-59, "Loss of RPS Bus A Power", you are directed by the CRS to isolate Reactor Building Ventilation per Section G of OP-51A, "Reactor Building Ventilation and Cooling System".

As you approach Control Room Panel 09-75 to perform the directed action, you discover which of the following Reactor Building Ventilation lineups?

	Intake / Exhaust Isolation Valves (66AOV-100A/B) (66AOV-101A/B)	Recirculation Dampers (66AOD-105) (66AOD-108)	Rx Bldg Vent. Supply Fans (66FN-5A/B/C)	Exhaust Fans Above Refuel Floor (66FN-13A/B) / Below Refuel Floor (66FN-12A/B)
a.	All Valves Closed	Both Closed	No Fans Running	No Fans Running
b.	100A/101A Failed Open 100B/101B Closed	Both Open	No Fans Running	1 "Above Refuel Floor" Fan Running
<input checked="" type="radio"/>	100A/101A Closed 100B/101B Open	Both Open	2 of 3 Running	1 "Below Refuel Floor" Fan Running
d.	All Valves Open	Both Closed	2 of 3 Running	1 Fan in Each Set Running

Proposed Answer: c.

Explanation (Optional):

- c. CORRECT: OP-51A, Page 20. Action directed by AOP-59 to "isolate" is to complete the isolation. Rx Bldg Ventilation will already be in an "isolate"/recirculation mode as 66AOV-100A/101A will have received a valid signal to "isolate". Remaining damper/fan configurations are those expected for the "isolate" mode.
- a. Incorrect: 66AOV-100B/101B would be **Open**. Recirc Dampers would be **Open**. **Two (2)** Supply Fans would be running, versus none; and one "Below Refuel Floor Exhaust Fan, versus **None**, would be running.
- b. Incorrect: 66AOV-100A/101A do **not** Fail Open. Recirc Damper position correct. **Two (2)** Supply Fans would be running, versus none; and a "Below Refuel Floor Exhaust Fan, versus **Above** Refuel Floor, would be running.
- d. Incorrect: 66AOV-100A/101A would be **Closed**. Recirc Dampers would be **Open**. Supply Fan lineup correct; and **only** one "Below Refuel Floor Exhaust Fan, versus **One in Each Set**, would be running.

Technical Reference(s): OP-51A (Attach if not previously provided)
AOP-59

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-05, EO 1.09.a (As available)
SDLP-17, EO 1.05.c.1 & 1.10.e
SDLP-66A, EO 1.05.c.1/2, 1.06.b, & 1.10.d

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 2) 295004 Partial or Total Loss of DC Pwr AA2.02
Ability to determine and/or interpret the following as they apply to
PARTIAL OR COMPLETE LOSS OF D.C. POWER:
Extent of partial or complete loss of D.C. power
(10CFR 55.43.5)

Level	RO	SRO
Tier #	-----	1
Group #	-----	1
K/A #	295004	AA2 02
Importance Rating	-----	3.9

Proposed Question: # 33

The plant is operating in a normal full-power lineup when a loss of a single DC Power System occurs. All other plant equipment operates as designed and the following plant conditions result:

- RPV water level rapidly rises to the Main Turbine, HPCI, and RFPT High Level Trip Setpoint
- A reactor scram occurs on Main Turbine Stop Valve Closure

Based on the above indications, which of the following series of Abnormal Operating Procedures (AOPs) would have the highest potential to be executed concurrently?

- AOP-16, Loss of 10300 Bus / AOP-18, Loss of 10500 Bus / AOP-21, Loss of UPS
- AOP-17, Loss of 10400 Bus / AOP-19, Loss of 10600 Bus / AOP-21, Loss of UPS
- AOP-16, Loss of 10300 Bus / AOP-18, Loss of 10500 Bus / AOP-11, Loss of RB Closed Loop Cooling
- AOP-17, Loss of 10400 Bus / AOP-19, Loss of 10600 Bus / AOP-6, Malfunction of EHC Pressure Regulator

Proposed Answer: b.

Explanation
(Optional):

- CORRECT: By indications, "Bravo" DC has been lost. AOP-46 requires execution, as necessary, of AOP-17, 19, and 21
- Incorrect: "Alpha" DC has not been lost. With the exception of AOP-21, these AOPs would be potentially necessary only if "Alpha" DC Power had been lost.
- Incorrect: "Alpha" DC has not been lost. These AOPs would be potentially necessary only if "Alpha" DC Power had been lost.
- Incorrect: By indications, "Bravo" DC has been lost. AOP-46 requires execution, as necessary, of AOP-17 and 19. "Alpha" DC does power EHC Trip Logic, and would cause a turbine trip but not a pressure regulator malfunction.

Examination Outline Cross-reference:

(Page 12) 215004 Source Range Monitor A4.05

Ability to manually operate and/or monitor in the control room:

- SRM back panel switches, meters, and indicating lights

Level	RO	SRO
Tier #	2	
Group #	1	
K/A #	215004 A4.05	
Importance Rating	3.1	

Proposed Question: # 34

The following plant conditions exist:

- Reactor Mode Switch is in "STARTUP/HOT STBY"
- All Intermediate Range Monitors (IRM's) are on Range 3 or 4
- Source Range Monitor (SRM) "Alpha" is reading 0.5 cps
- SRMs "Bravo" and "Charlie" are reading 8.3×10^4 cps
- SRM "Delta" mode switch is in "STANDBY"

A rod block signal has been generated. Based on the above indications, which one of the following has caused the rod block?

- SRM Inoperable
- SRM Downscale
- SRM Upscale
- SRM Not Full-In

Proposed Answer: a.Explanation
(Optional):

- CORRECT** – SRM "D" Mode Switch being placed in "Standby", on back Panel 09-12, will result in a SRM Inop alarm with a concurrent rod block. This function is not bypassed until IRM Range 8 or Reactor Mode Switch in "RUN".
- Incorrect** – Although SRM "A" is downscale, this rod block function is bypassed with associated IRMs on Range 3 or above.
- Incorrect** – Although SRMs "B" and "C" are approaching the Hi Flux (Upscale) Alarm setpoint of 1×10^5 cps, they are not yet there.
- Incorrect** – this rod block function is bypassed with > 100 cps on the respective SRM, associated IRMs on Range 3 or above, or Reactor Mode Switch in "RUN".

Technical Reference(s): ARP 09-5-2-21 / 31 / 51 (Attach if not previously provided)
OP-16

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-07B, EO 1.05.a.5.a, 1.12, 1.14.a/b/c & 1.15.b/c/d (As available)

Question Source: Bank # 25643
Modified Bank # [Redacted] (Note changes or attach parent)
New [Redacted]

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 22) G2.2.30

Knowledge of RO duties in the control room during fuel handling such as alarms from fuel handling area / communication with fuel storage facility / systems operated from the control room in support of fueling operations / and supporting instrumentation.

Level	RO	SRO
Tier #	3	---
Group #	---	---
K/A #	Cat 2 G2.2.30	---
Importance Rating	3.5	---

Proposed Question: # 35

The plant is in a refueling outage. The spent fuel pool gates are removed. Control Rod Drive stroke time testing is in progress. Thirty, (30) minutes after a complete loss of Instrument Air occurs, you note (on Panel 09-4) that Refuel Water Level (02-3LI-86) indicates that RPV Level has risen several inches over the last hour.

Which of the below is the probable cause?

- In-Service Fuel Pool Filter/ Demineralizer has Isolated
- In-Service CRD Flow Control Valve (03FCV-19A/B) failed open
- RWCU Blowdown Flow Control Valve (12FCV-55) failed closed
- Feedwater Low Flow Control Valve, (34FCV-137), loss of air signal

Proposed Answer: c.

Explanation
(Optional):

- CORRECT** – Question forces conclusion that CRD is in service and the RWCU Blowdown Mode is being used for level control. With the fail position of 12FCV-55 being closed, RPV Water Level will begin to rise.
- Incorrect – See above. FPC filter demin status has no effect on level.
- Incorrect – See above. CRD FCV's fail closed on loss of air yet are pinned to prevent full closure.
- Incorrect – See above. FW Low Flow Control Valve fails as-is.

Technical Reference(s): AOP-12 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-39, EO 1.09.f/j (As available)
LPAOP, EO 1.02 & 1.10

Question Source: Bank # 25605
 Modified Bank # (Note changes or attach parent)
 New

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 19) 214000 RPIS G2.4.7 **PLANT OE**

Knowledge of event based EOP mitigation strategies.

(10CFR 55.43.5)

Level	RO	SRO
Tier #	-----	2
Group #	-----	2
K/A #	214000	G2.4.7
Importance Rating	-----	3.8

Proposed Question: # 36

With the plant operating normally at 100% CTP, an electrical short in the East Electric Bay UPS Cabinet has resulted in an unrecoverable loss of UPS. As directed by AOP-21, Loss of UPS, a manual scram has been inserted.

Which of the below provides confirmation of the reactor scram and appropriate subsequent procedural guidance for Power, Pressure, and Level Control?

- 09-5 blue scram lamps on; EOP-2, RPV Control.
- 09-5 blue scram lamps on; EOP-3, Failure To Scram.
- 09-5 green full in lamps on, EOP-2, RPV Control
- 09-5 green full in lamps on, EOP-3, Failure To Scram.

Proposed Answer: b.

Explanation
(Optional):

- CORRECT:** Plant OE from a past event in which EOP-3 was not entered. UPS powers the full core display green full in lamps and the RPIS system. Per AOP-21, Step C.1.4.b, the reactor scram is confirmed by verification of 09-5 blue scram and yellow accumulator lamps. Since rod positions cannot be determined, it cannot be assured that the reactor will remain shutdown under all conditions without boron requiring EOP-2 exit to EOP-3.
- Incorrect: See Above. EOP-2 is immediately exited.
- Incorrect: See Above.
- Incorrect: See Above.

Technical Reference(s): AOP-21 (Attach if not previously provided)
EOP-2,3

Proposed references to be provided to applicants during examination: EOP-2,3

Learning Objective: LP-AOP EO-1.03, 2.12, MIT-301.11C EO-1.02 and 1.03 (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

(Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 3) 295018 Partial or Total Loss of CCW AA2.05Ability to determine and/or interpret the following as they apply to
PARTIAL OR COMPLETE LOSS OF COMPONENT COOLING WATER:

- System pressure

Level	RO	SRO
Tier #	1	-----
Group #	1	-----
K/A #	295018 AA2.05	-----
Importance Rating	2.9	-----

Proposed Question: # 37

At 0915, ALARM 09-6-2-31 "RBC HDR PRESS LO" is received in the Control Room. RBC header pressure continues to trend downward at 5 psig/minute. If all components and instrumentation function as designed, which of the following events would be expected to occur at 0922?

- The standby RBCLC Pump will start automatically and assume load to ensure cooling of all RBCLC Safe-Shutdown components
- Alarm 09-6-2-32 "RBC HDR PRES LO-LO" will actuate and ESW Lockout Matrix will actuate to inject ESW into the RBCLC System
- Alarm 09-6-2-22 "RBC MAKEUP TK LVL HI OR LO" will actuate and ESW will automatically align to pick up all RBCLC Safe-Shutdown loads
- ESW Pump 46-P2A will start automatically and align to pick up the load on the Reactor Water Cleanup (RWCU) Non-Regenerative Heat Exchanger

Proposed Answer: **b.**Explanation
(Optional):

- CORRECT:** At 0915, the first alarm is received at a system pressure of 75 psig. As pressure trends down at 5 psig/min over 7 minutes, the resulting pressure of 40 psig would bring in the LO-LO alarm and energize the ESW Lockout Matrix to inject ESW to RBCLC.
- Incorrect:** In that the standby RBCLC pump would have started at time 0915 on the first alarm (75 psig), not 40 psig. Additionally, none of the RBCLC loads are required for safe shutdown of the facility.
- Incorrect:** Although the RBCLC Makeup Tank Low Level Alarm could feasibly be received at time 0922, there exists no information to lead the candidate down the path of deducing a linear relationship between a leak size and a pressure/level decrease. Additionally, ESW does not automatically align to supply any RBCLC load; as none are required for safe shutdown of the facility.
- Incorrect:** Although ESW Pump 46-P2A will have started (both ESW Pumps start on Lockout Matrix), ESW cannot be aligned to the RWCU NRHX, manually or automatically, and it will isolate on high outlet temperature.

Technical Reference(s): ARP 09-6-2-31/32 (Attach if not previously provided)
AOP-11

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-15, EO 1.05.a.1/c.5, 1.06.b, 1.09.d, & 1.14.b/c (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:
Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content:
55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 3) 295006 SCRAM AK2.01

Knowledge of the interrelations between SCRAM and the following:

- RPS

Level	RO	SRO
Tier #	1	-----
Group #	1	-----
K/A #	295006 AK2.01	-----
Importance Rating	4.3	-----

Proposed Question: # 38

The reactor is operating at 25% power with recirculation flow at minimum.

If a turbine trip occurs and the bypass valves fail to open, which of the following would be the appropriate procedure(s) to respond to the event?

- AOP-2, "Main Turbine Trip Without Scram" and AOP-6, "Malfunction of EHC Pressure Regulator"
- AOP-1, "Reactor Scram" and AOP-6, "Malfunction of EHC Pressure Regulator"
- AOP-2, "Main Turbine Trip Without Scram" and EOP-2, "RPV Control"
- AOP-1, "Reactor Scram" and EOP-2, "RPV Control"

Proposed Answer: d.

Explanation
(Optional):

- CORRECT** – Conditions would cause a high pressure Scram and entry into EOP-2 on high pressure and/or < 177-inches reactor water level.
- Incorrect – Due to initial power level of 25%, if Bypass Valves were to function correctly, AOP-2 would be entered. As a result of the failure of Bypass Valves, the resultant high pressure condition will Scram the plant. There is no stem indication of an EHC malfunction.
- Incorrect – Conditions would cause a high pressure Scram, and thus entry into AOP-1. But, there is no stem indication of an EHC Pressure Regulator malfunction; and thus, no entry into AOP-6.
- Incorrect – Following the Scram, EOP-2 would be entered on high pressure and/or < 177-inches reactor water level. As discussed above, AOP-2 would have been entered if Bypass Valves had functioned.

Technical Reference(s): AOP-1 (Attach if not previously provided)
EOP-2

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-05, EO 1.07.a.10 (As available)
SDLP-94A, EO 1.09.f

Question Source: Bank # 25654
 Modified Bank #
 New (Note changes or attach parent)

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
 Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments: *This was an SRO Only question on the last NRC Exam, but is being utilized as an RO Question on this exam.*

Examination Outline Cross-reference:

(Page 3) 295021 Loss of Shutdown Cooling AA1.06Ability to operate and/or monitor the following as they apply to
LOSS OF SHUTDOWN COOLING:

- Containment / drywell temperature

Level	RO	SRO
Tier #	1	-----
Group #	1	-----
K/A #	295021 AA1.06	-----
Importance Rating	2.8	-----

Proposed Question: # 39

The plant was scrammed 8 hours ago and is currently in a normal shutdown cooling lineup. The Drywell is still inerted and over a period of 30 minutes, the following indications are observed:

- Reactor coolant temperature is trending upward
- RPV metal temperatures are trending upward
- Reactor Water Level, as read on the Refueling Level Instrument, is trending upward
- Reactor Water Level, as read on the Fuel Zone Level Instrument, trended slightly downward and then appears to have stabilized at approximately 2 inches below the previous value

Which of the following events has occurred and what is the cause of the Reactor Water Level indication mismatch?

- A Recirculation Pump was started and flow through the Jet Pumps has introduced error into the Reactor Water Level instrumentation.
- A Loss of Shutdown Cooling has occurred and a rising Drywell temperature has introduced error into the Reactor Water Level instrumentation.
- A Recirculation Pump was secured and Natural Circulation through the core has introduced error into the Reactor Water Level instrumentation.
- A Loss of Shutdown Cooling has occurred and the resulting core Natural Circulation has introduced error into the Reactor Water Level instrumentation.

Proposed Answer: b.

Explanation
(Optional):

- CORRECT:** The first two indications are primary symptoms of a Loss of Shutdown Cooling, as detailed in AOP-30. IF shutdown cooling is lost, Drywell Temperature will trend upward steadily based on core decay heat one day after shutdown. With a rising Drywell Temperature, as the result of having the largest reference leg vertical drop in the Drywell, the Refueling Level Instrument will experience the worst case rise in indicated level. The Fuel Zone instrumentation has a very small reference leg drop and a slight reduction in indicated level will be introduced by a rising Drywell Temperature.
- Incorrect:** While Jet Pump flows will introduce an error in the Fuel Zone instrumentation, it causes a rise in indicated level versus the slight lowering as indicated above in the stem indications.
- Incorrect:** While natural circulation through the core will introduce an error in the Fuel Zone instrumentation, it also causes a rise in indicated level versus the slight lowering as indicated above in the stem indications.
- Incorrect:** Different precursor leading to the same result of natural circulation. While natural circulation through the core will introduce an error in the Fuel Zone instrumentation, it also causes a rise in indicated level versus the slight lowering as indicated above in the stem indications.

Technical Reference(s): AOP-30 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-02B, EO 1.10.e (As available)
SDLP-10, EO 1.09.c/e/g

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 4) 295024 High Drywell Pressure / 5 G2.4.44
Knowledge of emergency plan protective action recommendations.
(10CFR 55.43.5)

Level	RO	SRO
Tier #	-----	1
Group #	-----	1
K/A #	295024 G2 4.44	
Importance Rating	-----	4.0

Proposed Question: # 40

An accident has resulted in the following conditions:

Drywell Hydrogen 6%, Steady

Torus Hydrogen 6%, Steady

Drywell Radiation 3100 R/Hr, Steady

RPV Pressure 600 psig, Lowering at 20 psig/min

Torus Water Temperature 180° F, Rising 0.5° F/min

Drywell Oxygen 2%, Steady

Torus Oxygen 3%, Steady

Reactor Coolant Activity 250 uci/gm, Steady

Torus Pressure 55 psig, Rising at 1 psig/min

Torus Water Level 14 Feet, Rising 1"/min

Fifteen minutes from now, the expected Control Room actions will be to:

- Declare a Site Area Emergency. Vent and Purge the Torus and Drywell.
- Declare a Site Area Emergency. Emergency Depressurize the Reactor Pressure Vessel.
- Declare a General Emergency. Evacuate a 5 mile radius and 10 miles downwind.
- Declare a General Emergency. Evacuate a 2 mile radius and 5 miles downwind.

Proposed Answer: **d.**

Explanation
(Optional):

- CORRECT:** The given conditions are 7 psig and 7 minutes from violating the PCPL Curve. IAW EOP-4, venting of primary containment is required prior to exceeding PCPL. General Emergency EAL 3.1.3 is applicable when primary containment venting is required due to PCPL. Whenever a General Emergency is declared, EAP-4 directs a Protective Action Recommendation to evacuate a 2 mile radius and 5 miles downwind.
- Incorrect:** The hydrogen values given warrants a Site Area Declaration on EAL 3.3.1. Using this rationale, the hydrogen and oxygen values given only result in vent and purge of the drywell and torus if the resultant off-site release rate will remain below the off-site release rate LCO. The values of Rx Coolant Activity and Containment Radiation, if vented, will clearly violate the release rate LCO. Additionally, IAP-2 directs EAL entry at the highest level indicated by the conditions.

- b. Incorrect: A Site Area Emergency 3.2.1 is declared if conditions cannot be maintained below HCTL. Although the values of RPV Pressure and Torus Temperature are in the GREY area of the HCTL curve, they are below that of 14 feet and trending parallel to the curve. An emergency depressurization is also required for the violation of PSP. Additionally, IAP-2 directs EAL entry at the highest level indicated by the conditions.
- c. Incorrect: Correct classification level. No E-plan guidance directs a radius evacuation beyond 2 miles.

Technical Reference(s): IAP-2, EAP-4 (and Bases) (Attach if not previously provided)
EOP-4, EOP-4A, EOP-11

Proposed references to be provided to applicants during examination: IAP-2 Attachment IAP-2.1, EOP-4, 4A, and 11

Learning Objective: EP-12.5.4 EO 2.04, 10.02 (As available)
MIT-301.11.B EO 1.01, MIT-301.11.E EO 4.07

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
 Comprehension or Analysis

10 CFR Part 55 Content: 55.41
 55.43

Comments:

Examination Outline Cross-reference:

(Page 13) 217000 RCIC K6.04

Knowledge of the effect that a loss or malfunction of the following will have on the REACTOR CORE ISOLATION COOLING SYSTEM (RCIC):

- Condensate storage and transfer system

Level	RO	SRO
Tier #	2	—
Group #	1	—
K/A #	217000 K6.04	—
Importance Rating	3.5	—

Proposed Question: # 41

The loss of Condensate Storage Tank (CST) level can impact Reactor Core Isolation Cooling in two distinctly different ways. First, with RCIC in standby, the loss of CST level could result in _____; and second, during RCIC operation, a lowering of CST level _____.

- severe water hammer when RCIC injection is initiated; to 59.5 inches will result in annunciator 09-6-2-10 "CST A OR B LVL HI OR LO" and a RCIC Turbine Trip on low suction pressure.
- severe water hammer when RCIC injection is initiated; to 59.5 inches will result in annunciator 09-4-0-28 "RCIC CST A LVL LO" and automatic closure of 13MOV-18 (RCIC Pump CST Suction Isolation Valve).
- having to manually swap RCIC suction over to the Torus; to 138.9 inches will result in annunciator 09-6-2-10 "CST A OR B LVL HI OR LO" and having to manually isolate all non-ECCS suction from the CST.
- having to manually swap RCIC suction over to the Torus; to 138.9 inches will result in annunciator 09-4-0-28 "RCIC CST A LVL LO" and automatic transfer of RCIC suction from the CSTs to the Torus.

Proposed Answer: b.

Explanation
(Optional):

- CORRECT:** RCIC normally aligned to CSTs in standby. Height of water in CSTs is sufficient to maintain RCIC piping full of water up to first isolation valve – in effect, a "keep-full" system which prevents water hammer on RCIC startup. Per ARP 09-4-0-28 (29), if CSTs drop to 59.5 inches, auto swap of RCIC suction to Torus occurs, which yields opening of Torus Suction Isolation Valves and Closure of 13MOV-18.
- Incorrect:** See above (first part correct). Wrong value for alarm and auto-swap feature would prevent low suction pressure RCIC Turbine Trip as it is "make before break."
- Incorrect:** Per OP-19, auto-swap will occur whether RCIC in operation or not. Per ARP 09-6-2-10, alarm actually at 238.9 inches, and this alarm has no impact on RCIC operation / alignment whatsoever.
- Incorrect:** See above. Also, wrong CST level value corresponding to alarm.

Technical Reference(s): OP-19 / OP-5 (Attach if not previously provided)
ARPs 09-4-0-28(29) / 09-6-2-10

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-13, EO 1.05.a.13/b.3, 1.06.d. & 1.10.f (As available)
SDLP-33, EO 1.05.a.1.a & 1.09.c

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
 Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 18) 201002 RMCS A1.01

Ability to predict and/or monitor changes in parameters associated with operating the REACTOR MANUAL CONTROL SYSTEM controls including:

- CRD drive water flow

Level	RO	SRO
Tier #	2	-----
Group #	2	-----
K/A #	201002 A1.01	-----
Importance Rating	2.8	-----

Proposed Question: # 42

A control rod is being continuously withdrawn from position 36 to position 48 during a reactor startup. During withdrawal, Control Rod Drive (CRD) water flow should be approximately _____ and during performance of the subsequent control rod coupling check, CRD water flow should _____.

- 2 gpm; stabilize at a value lower than 2 gpm.
- 2 gpm; stabilize at a value higher than 2 gpm.
- 4 gpm; stabilize at a value lower than 4 gpm.
- 4 gpm; stabilize at a value higher than 4 gpm.

Proposed Answer: a.

Explanation
(Optional):

- CORRECT:** OP-25, "CRD Hydraulic System" indicates a flow rate of approximately 2 gpm is required to withdraw a control rod, versus a flow rate requirement of 4 gpm to insert a control rod. With no noted seal deficiencies, etc., stall flows achieved during the rod coupling check will be lower than drive flows.
- Incorrect:** 2 gpm correct (see above). CRD Water **pressure** lowers during the withdraw sequence and would rise at stall flows. If candidate makes an erroneous direct correlation between pressure and flow, the higher value will be chosen.
- Incorrect:** 4 gpm is for **insert** sequence, versus withdraw. The secondary part of the answer, in theory, is correct.
- Incorrect:** 4 gpm is for **insert** sequence, versus withdraw. CRD Water **pressure** lowers during the withdraw sequence and would rise at stall flows. If candidate makes an erroneous direct correlation between pressure and flow, the higher value will be chosen.

Technical Reference(s): OP-25 (Attach if not previously provided)
ST-23B

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-03C, EO 1.05.a.6/c.4, 1.08.d/i, & 1.13.k (As available)
SDLP-03F, EO 1.08.c & 1.13.d

Question Source:

Bank #	
Modified Bank #	
New	<input checked="" type="checkbox"/>

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
 Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 10) 206000 HPCI A1.07

Ability to predict and/or monitor changes in parameters associated with operating the HIGH PRESSURE COOLANT INJECTION SYSTEM controls including:

- System discharge pressure: BWR-2,3,4

Level	RO	SRO
Tier #	2	---
Group #	1	---
K/A #	206000 A1.07	---
Importance Rating	3.7	---

Proposed Question: # 43

To support Post-Maintenance Testing, HPCI has been manually started in the Full Flow Test (CST-CST) mode with HPCI flow control in automatic. The system is stable at 3500 rpm and 2000 gpm.

To establish the prescribed pressure band, the operator throttles open 23MOV-21, TEST VLV TO CST.

Which of the following CORRECTLY describes the response of HPCI Discharge Pressure and TURBINE GOVERNOR CONTROL VALVE (HOV-2) position to this valve manipulation?

- a. HPCI Discharge Pressure lowers (decreases)
HOV-2 Position - Throttles CLOSED
- b. HPCI Discharge Pressure rises (increases)
HOV-2 Position - Throttles OPEN
- c. HPCI Discharge Pressure lowers (decreases)
HOV-2 Position - Remains the Same
- d. HPCI Discharge Pressure rises (increases)
HOV-2 Position - Remains the Same

Proposed Answer: a.

Explanation
(Optional):

- a. CORRECT – Per Fundamental Pump Laws, if you throttle open on a control valve in the discharge line of a centrifugal pump, discharge pressure (pump head) will decrease and flowrate will increase. With flow control in automatic, the sensed speed/flowrate increase will result in HOV-2 throttling closed to restore the dialed-in, desired flowrate.
- b. Incorrect – See above. Discharge Pressure **decreases** and HOV-2 will throttle **closed** in response to an increasing flowrate.
- c. Incorrect – See above. HOV-2 **will** change position.
- d. Incorrect – See above. Discharge Pressure **decreases** and HOV-2 **will** change position.

Technical Reference(s): OP-15 (Attach if not previously provided)
ST-4N

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-23_EO 1.05.a.23.e (As available)
JLP-LOI-Comp02_EO 1.12

Question Source: Bank #
Modified Bank # 681 (attached) (Note changes or attach parent)
New
Last NRC Exam

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Plant Duane Arnold 1
Exam Date 5/25/1999

Question Id 091
Exam Type ILD

Question The plant is at power and operators are performing post maintenance testing on the HPCI turbine in order to exit the HPCI LCO.

HPCI has been manually started in the CST-CST mode using the TEST POT for control. The system is stable at 3500 rpm and 2000 gpm.

At this point, the operator throttles open CV-2315, TEST BY-PASS, to achieve 3000 GPM.

Which of the following CORRECTLY describes the response of HPCI Discharge Pressure and HV-2200, TURBINE CONTROL VALVE, position to this valve manipulation?

- Answer** HPCI Discharge Pressure **DECREASES**
HV-2200 position **REMAINS THE SAME**
- Distractor 1** HPCI Discharge Pressure **INCREASES**
HV-2200 position **REMAINS THE SAME**
- Distractor 2** HPCI Discharge Pressure **INCREASES**
HV-2200 position **THROTTLES OPEN**
- Distractor 3** HPCI Discharge Pressure **DECREASES**
HV-2200 position **THROTTLES OPEN**

Ref Material

- Question Comment** RO must know that the test pot controls HPCI speed, not flow, so HV-2200 will not change position. Pump laws dictate that a pump at constant speed will have a decreased discharge pressure at higher flow.
- Distractor 1 Comment** Discharge pressure will decrease.
- Distractor 2 Comment** Discharge pressure will decrease. HV-2200 will not change position.
- Distractor 3 Comment** HV-2200 will not change position.

Cognitive Level	Exam Level	Ka Number			
3	R	30900A102			
Ka Segment 1	Ka Segment 2	Ka Segment 3	Ka Segment 4	Ka Segment 5	Ka Revision
		2600	A1	07	

Examination Outline Cross-reference:

(Page 11) 215003 IRM K5.01

Knowledge of the operational implications of the following concepts as they apply to INTERMEDIATE RANGE MONITOR (IRM) SYSTEM:

- Detector operation

Level	RO	SRO
Tier #	2	---
Group #	1	---
K/A #	215003 K5.01	---
Importance Rating	2.6	---

Proposed Question: # 44

A reactor startup is in progress. You are in the process of ranging up on all IRMs. You inadvertently range down on IRM "Charlie", which was indicating a value of 10 on Range 9.

Which of the following will result from the erroneous switch manipulation?

- IRM "C" reading within OP-65, Startup and Shutdown Procedure" range limits without resulting in a half-scam or rod block.
- IRM "C" reading outside OP-65, Startup and Shutdown Procedure" range limits without resulting in a half-scam or rod block.
- IRM "C" reading within OP-65, Startup and Shutdown Procedure" range limits which results in a rod block but no half-scam.
- IRM "C" reading outside OP-65, Startup and Shutdown Procedure" range limits which results in a half-scam and a rod block.

Proposed Answer: b.

Explanation
(Optional):

- CORRECT:** OP-65 specifies that IRMs should be changed to maintain between 5 and 75 on the 125 scale. Ranging down from a value of 10 on Range 9 would result in a value of 100 on Range 8. This value would be outside the specified range limits of OP-65, but would not yet have attained the values corresponding to the half-scam or rod block setpoints (120 and 108 respectively)
- Incorrect:** OP-65 specifies IRM range between 5 and 75 on the 125 scale. Ranging down from a value of 10 on Range 9 would result in a value of 100 on Range 8. This value would be **outside** the specified range limits of OP-65, but would not yet have attained the values corresponding to the half-scam or rod block setpoints (120 and 108 respectively)
- Incorrect:** Ranging down from a value of 10 on Range 9 would result in a value of 100 on Range 8. This value would be outside the specified range limits of OP-65, but would not yet have attained the values corresponding to the half-scam or rod block setpoints (120 and 108 respectively)
- Incorrect:** Ranging down from a value of 10 on Range 9 would result in a value of 100 on Range 8. This value would be outside the specified range limits of OP-65, but would not yet have attained the values corresponding to the half-scam or rod block setpoints (120 and 108 respectively)

Technical Reference(s): OP-65 (Attach if not previously provided)
SDLP-07B

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-07D, EO 1.05.a.4.f & 1.07.d (As available)
LP-OP-65, EO 1.12

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 2) 295005 Main Turbine Generator Trip AK1.03

Knowledge of the operational implications of the following concepts as they apply to MAIN TURBINE GENERATOR TRIP:

- Pressure effects on reactor level

Level	RO	SRO
Tier #	1	-----
Group #	1	-----
K/A #	295005 AK1.03	-----
Importance Rating	3.5	-----

Proposed Question: # 45

When comparing the various transient analyses contained in the Updated Facility Safety Analysis Report (UFSAR), the _____ transient is the most likely to limit plant operations. This is due to the resulting _____.

- Inadvertent High Pressure Coolant Injection Startup at 100% Power;** excess of coolant inventory which may result in severe damage from substantial carryover.
- Recirculation Flow Master Controller Failure (Maximum Speed Demand);** excess of coolant inventory which may result in severe damage from substantial carryover.
- Turbine Trip at 100% Power With Failure of the Bypass Valves to Operate;** collapse of voids in the moderator which may result in exceeding fuel cladding safety limits.
- Electro-Hydraulic Control (EHC) Pressure Regulator Failure (Rising RPV Pressure);** collapse of voids in the moderator which may result in exceeding fuel cladding safety limits.

Proposed Answer: c.

Explanation
(Optional):

- CORRECT:** The only transients discussed as "limiting" in the UFSAR are defined as such due to potential impacts on MCP. Turbine Trip Without Bypass results in a significant "pressure increase" and analyzing it in that category invokes the remainder of the answer (detailed in Ch 14.5).
- Incorrect:** Although a UFSAR "limiting" transient, it is not a transient that is analyzed in the category of "excess coolant inventory", but is analyzed as "coolant temperature decrease". Thus, carryover is not the concern; increasing density adding positive reactivity is the challenge to clad integrity.
- Incorrect:** Not a "limiting" transient. This is not a transient that is analyzed in the category of "excess coolant inventory", but is analyzed as "coolant flow increase". Thus, carryover is not the concern; reduction of void content and positive reactivity addition is the challenge to clad integrity.
- Incorrect:** Not a "limiting" transient and AOP-6 indicates that this failure will raise RPV Pressure by only approximately 3 psi. In the UFSAR analyses, this transient is considered "mild" with no significant thermal margin reductions.

Technical Reference(s): UFSAR, Chapter 14.5 (Attach if not previously provided)
AOP-6

Proposed references to be provided to applicants during examination: None

Learning Objective: NET-238.07, EO 1.01.b (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 4) 295025 High Reactor Pressure/3 G2.2.12
Knowledge of surveillance procedures.

Level	RO	SRO
Tier #	1	-----
Group #	1	-----
K/A #	295025 G2.2.12	-----
Importance Rating	3.0	-----

Proposed Question: # 46

During performance of Surveillance Test ST-1I, "Main Steam Isolation Valves Limit Switch Channel Functional Test", if the slow close pushbutton on MSIV 29AOV-86C is depressed too long, ...

- the MSIV could fully close resulting in a half-scam signal generated from RPS Subchannel "Alpha" One (A1).
- the MSIV could fully close due to steam forces acting on the valve, resulting in a reactor scram on high reactor pressure.
- annunciator 09-5-1-2, "MSIVs NOT FULL OPEN TRIP" will alarm and a reactor scram on MSIV closure will occur if > 29% reactor power.
- annunciator 09-5-1-2, "MSIVs NOT FULL OPEN TRIP" will alarm and a half-scam will be generated from RPS Subchannel "Bravo" Two (B2).

Proposed Answer: **b.**Explanation
(Optional):

- CORRECT:** Test of Caution in ST-1I in addition to a cause-effect relationship. Caution itself states that if pushbutton held too long, that the steam forces acting on the MSIV could cause it to go full-closed. UFSAR Ch. 14 Transient analyses discuss the impact of closure of one up to and including all MSIV's in the section on transients that cause reactor pressure increases.
- Incorrect:** Although the first portion of the answer is true, the Subchannel A1 reference is incorrect. 29AOV-86C Limit Switches provide input to **A2** and **B1** RPS Trip Logic circuits.
- Incorrect:** Although first portion of the answer is true, the associated RPS logic will allow the full closure of one MSIV without a full scram. In fact, the ST criteria for success, after pulling fuses for the other input to a particular subchannel, is a half-scam. A full scram would not occur on single MSIV position alone.
- Incorrect:** Although the first portion of the answer is true, the Subchannel B2 reference is incorrect. 29AOV-86C Limit Switches provide input to **A2** and **B1** RPS Trip Logic circuits.

Technical Reference(s): ST-11 (Attach if not previously provided)
ARPs 09-5-1-2

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-29, EO 1.05.b.1, 1.09.f, & 1.13.c (As available)
NET-238.07, EO1.01.c

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 2) 295003 Partial or Complete Loss of AC / 6 G2.1.8
Ability to coordinate personnel activities outside the control room.
(10CFR 55.43.5)

Level	RO	SRO
Tier #	-----	1
Group #	-----	1
K/A #	295003 G2.1.8	
Importance Rating	-----	3.6

Proposed Question: # 47

The plant is shutdown for a refueling outage with site electrical power being provided by the 115KV system. The only deviation from the normal alignment is that Disconnect 10017, North-South Bus Disconnect, is currently open. A 115KV Line Fault results in the tripping of the 10312 Breaker.

Which of the following describes the expected procedural response?

- AOP-16, Loss of 10300 Bus and AOP-18, Loss of 10500 Bus. Dispatch a NPO to monitor EDG A and C for normal operation.
- AOP-17, Loss of 10400 Bus and AOP-19, Loss of 10600 Bus. Dispatch a NPO to monitor EDG B and D for normal operation.
- AOP-16, Loss of 10300 Bus and AOP-18, Loss of 10500 Bus. Dispatch a NPO to secure EDG A and C due to the loss of ESW cooling.
- AOP-17, Loss of 10400 Bus and AOP-19, Loss of 10600 Bus. Dispatch a NPO to secure EDG B and D due to the loss of ESW cooling.

Proposed Answer: a.

Explanation
(Optional):

- CORRECT: The trip of the 10312 breaker with the 10017 disconnect open, divorces power from T-3 which de-energizes the 10300 Bus and the 10500 Bus resulting in EDG startup to re-energize the 10500. AOP-16 and 18 are the applicable procedures and direct the verification of proper operation of the A and C EDG's.
- Incorrect: The 10400 bus and 10600 bus would be lost if the 10022 breaker trips with the 10017 open.
- Incorrect: Correct procedures but incorrect action. Because the EDG's automatically start and re-energize the 10500 bus, the ESW pump will also start (powered from 10500) providing for EDG cooling. This is the correct action if the bus does not re-energize.
- Incorrect: Incorrect procedures and incorrect action.

Technical Reference(s): OP-44 (Attach if not previously provided)
AOP-16 and 18

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-71D, EO 1.23
LPAOP-EO 1.02, 1.03

Question Source:

Bank #	
Modified Bank #	25597 (attached)
New	
Last NRC Exam	

 (Note changes or attach parent)

Question History:

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

PLANT
FitzPatrick 1

ExamDate
7/1/2003

ExamType
ILO

QuestionId
25597

NSSSType
BWR

Question The plant is shutdown for a Refueling outage. Site electrical power is being provided from the 115 KV system. The only deviation from the normal alignment is that disconnect 10017, North-South Bus Disconnect, is currently OPEN. From this condition, circuit breaker 10022, (LHH-FITZ 115 KV LINE 3 BKR), trips. Which one of the following identifies the expected procedural response?

Answer AOP-17, Loss of 10400 Bus and AOP-19, Loss of 10600 Bus

Distractor 1 AOP-16, Loss of 10300 Bus and AOP-18, Loss of 10500 Bus

Distractor 2 AOP-57, Recovery from Residual Bus Transfer

Distractor 3 AOP-49A, Station Blackout In Cold Condition

RefMaterial

QuestionComment

Distract1Comment

Distract2Comment

Distract3Comment

<i>KaNumber</i>	<i>KaSegment1</i>	<i>KaSegment2</i>	<i>KaSegment3</i>	<i>KaSegment4</i>	<i>KaSegment5</i>
295003 AA2 05			295003	AA2	05
<i>KaRevision</i>				<i>CognitiveLevel</i>	<i>ExamLevel</i>
				2	S

Examination Outline Cross-reference:

(Page 10) 206000 HPCI K5.05

Knowledge of the operational implications of the following concepts as they apply to HIGH PRESSURE COOLANT INJECTION SYSTEM:

- Turbine speed control: BWR-2,3,4

Level	RO	SRO
Tier #	2	-----
Group #	1	-----
K/A #	206000 K5.05	-----
Importance Rating	3.3	-----

Proposed Question: # 48

Operating the High Pressure Coolant Injection (HPCI) Turbine at less than _____ could potentially cause improper oil system operation, overheating of the shaft driven oil pump, and/or _____.

- a. 1800 rpm; insufficient exhaust flow resulting in check valve banging
- b. 1800 rpm; inadvertent HPCI Turbine Trip on low lube oil pressure
- c. 2100 rpm; insufficient exhaust flow resulting in check valve banging
- d. 2100 rpm; inadvertent HPCI Turbine Trip on low lube oil pressure

Proposed Answer: c.

Explanation
(Optional):

- c. CORRECT: OP-15, procedural precaution C.2.3
- a. Incorrect: Incorrect rpm but related to other turbines, correct operational implication
- b. Incorrect: Incorrect rpm but related to other turbines, incorrect operational implication – HPCI does not trip on oil pressures.
- d. Incorrect: Correct rpm, incorrect operational implication – HPCI does not trip on oil pressures.

Technical Reference(s): OP-15 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-23, EO 1.13.a (As available)

Question Source:

Bank #	
Modified Bank #	

 (Note changes or attach parent)

New

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 12) 215005 APRM / LPRM A3.05

Ability to monitor automatic operations of the AVERAGE POWER RANGE MONITOR/LOCAL POWER RANGE MONITOR SYSTEM including:

- Flow converter/comparator alarms

Level

RO

SRO

Tier #

2

Group #

1

K/A #

215005 A3.05

Importance Rating

3.3

Proposed Question: # 49

Given the following initial conditions:

- Recirculation Flow Unit "Alpha" has a signal output equal to 92% flow
- Recirculation Flow Unit "Bravo" has a signal output equal to 93% flow
- Recirculation Flow Unit "Charlie" has a signal output equal to 94% flow
- Recirculation Flow Unit "Delta" has a signal output equal to 95% flow

THEN, Flow Unit "Alpha" falls UPSCALE and annunciator 09-5-2-25 "FLOW REF OFF NORM" alarms.As a result of this condition, APRM _____ will have a _____ trip setpoint (*as compared to the initial setpoint*).

- Alpha ; Lower
- Bravo ; Lower
- Charlie ; Higher
- Delta ; Higher

Proposed Answer: c.

Explanation
(Optional):

- CORRECT:** Recirc Flow Units provide a reference core flow signal for APRM and RBM flow-biased trip setpoints via Low-Value Gates (LVG). A failure of Flow Unit "A" upscale will default to the other associated Flow Unit "C" via the auctioneering circuit. APRMs A, C, and E are supplied from Flow Units A & C. Because the Flow Unit "C" signal is higher than the initial Flow Unit "A" signal, the trip setpoints for APRMs A, C, and E will all **rise**.
- Incorrect:** See above.
- Incorrect:** APRMs, B, D, and F are supplied through LVG from Flow Units B & D, and thus would be unaffected.
- Incorrect:** APRMs, B, D, and F are supplied through LVG from Flow Units B & D, and thus would be unaffected.

Technical Reference(s): ARP-09-5-2-25 (Attach if not previously provided)
OP-16 / SDLP-07C

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-07C, EO 1.09.a (As available)

Question Source: Bank #
Modified Bank # JEX-LOI-SYST02
#48 (attached) (Note changes or attach parent)

New
Question History: Last NRC Exam

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 21) 290002 Reactor Vessel Internals K4.02Knowledge of REACTOR VESSEL INTERNALS design feature(s)
and/or interlocks which provide for the following:

- * Separation of fluid flow paths within the vessel

Level	RO	SRO
Tier #	2	-----
Group #	2	-----
K/A #	290002 K4.02	-----
Importance Rating	3.1	-----

Proposed Question: # 50

During power operations, a large through-wall crack in the Reactor Core Shroud has developed. Which of the following would be a primary indicator in diagnosing the event?

- A rapid rise in indicated Core Flow with a resulting slight rise in Reactor Power level.
- The lowering of Jet Pump Differential Pressures on Jet Pumps in the vicinity of the shroud crack.
- An initial rapid lowering of indicated Reactor Water Level until stabilized by Feedwater Level Control.
- The cavitation of Recirculation Pumps and/or Jet Pumps due to the heat added by the mixing of fluids.

Proposed Answer: d.

Explanation
(Optional):

- CORRECT:** GE indicates that a large, through-wall shroud crack will provide indications similar to those experienced at VY (Loose Shroud Head). With a large crack or break in the shroud, enough heat may be added to the downcomer to cause cavitation of the Recirc Pumps, the Jet Pumps, or both.
- Incorrect:** See above. Although indicated core flow would rise due to a lower discharge head pressure on Recirc, reactor power would **lower** due to a higher inlet subcooling temperature.
- Incorrect:** See above. Differential Pressures would **rise** on **all** Jet Pumps with corresponding core flow rise.
- Incorrect:** See above. Shroud failures, depending upon magnitude, may have a corresponding initial **increase** in indicated reactor water level due to the sudden outrush of water; until such time as FWLC reacts to stabilize level.

Technical Reference(s): AOP-32 (Attach if not previously provided)
SDLP-02A/ GE SIL 462

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-02A, EO 1.09.a/b/d/e (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:
Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content:
55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 9) 500000 EA2.02Ability to determine and/or interpret the following as they apply to
HIGH PRIMARY CONTAINMENT HYDROGEN CONCENTRATIONS:

- Oxygen monitoring system availability

(10CFR 55.43.5)

Level	RO	SRO
Tier #	-----	1
Group #	-----	2
K/A #	500000 EA2.02	
Importance Rating	-----	3.5

Proposed Question: # 51

A small-break Loss of Coolant Accident (LOCA) has occurred resulting in the following conditions:

- RPV Level is currently +15 inches
- Drywell Pressure is currently 3.5 psig

You, as the Control Room Supervisor (CRS), direct an operator to go to the Relay Room and perform actions necessary to obtain accurate Hydrogen / Oxygen concentrations on the Drywell atmosphere utilizing the normally-aligned Exosensor. The operator calls you one (1) minute later and reports that "Bravo" Exosensor is reading 1.8 % Hydrogen and 1.5 % Oxygen. Which of the following is an appropriate response to the operator?

- "Bravo" Exosensor is reading 1.8% Hydrogen and 1.5% Oxygen – Thanks."
- "Wrong component – Please give me the Hydrogen/Oxygen concentration readings directly from "ALPHA" Exosensor."
- "Wrong component – re-initialize "ALPHA" Exosensor in accordance with AOP-15, *Isolation Verification and Recovery*, and then wait for readings to stabilize."
- "Wrong – You must first re-initialize "Bravo" Exosensor in accordance with OP-37, *Containment Atmosphere Dilution System*, and then wait for readings to stabilize."

Proposed Answer: d.

Explanation
(Optional):

- d. CORRECT:** Per OP-37, "Bravo" is normally aligned to Drywell mid-level with "Alpha" aligned to the Torus. Given the High Drywell Group 2 Isolation, all sample Isolation valves would be closed. I stayed away from the overrides, but this would have to be performed at the 27MAP Panel; and the valves would have to be opened, and the "Bravo" Exosensor re-initialized per OP-37 (directed from AOP-15). Exosensors can also yield inaccurate measurements (high) for about 5 minutes after restoration from Isolation.
- a. Incorrect:** Under "current" stem conditions, both Exosensors would be isolated and any readings they had would be invalid. Additionally, report is made 1 minute later, which would not yield accurate results either way.
- b. Incorrect:** See above. Wrong component – wrong timeframe.
- c. Incorrect:** See above. Wrong component – AOP-15 could be possibly correct, as it directs you to OP-37 – 15 minutes is longer than necessary, but would be functional readings.

Technical Reference(s): OP-37 (Attach if not previously provided)
AOP-15

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-16B, EO 1.05.a.3/c.9, 1.07.a, 1.13.e (As available)
SDLP-16C, EO 1.07.b, 1.14.c, 1.15.c

Question Source:

Bank #	
Modified Bank #	20097 (attached)
New	

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

PLANT
Dresden 2

ExamDate
2/15/2001

ExamType
ILO

QuestionId
20097

NSSS Type
BWR

Question A small LOCA occurred on Unit 2 resulting in the following conditions:
 -Drywell pressure 3.5 psig.
 -RPV level +15 inches.
 The NSO was asked to obtain primary containment oxygen concentration. He proceeded to the 923-5A panel and reported that concentration was 1.5%. Which of the following describes why this IS /IS NOT a valid report?

Answer This IS NOT a valid report because the containment atmospheric sampling system (CAS) isolates on a Group 2 signal.

Distractor 1 This IS a valid report because this panel monitors the containment in post accident conditions.

Distractor 2 This IS NOT a valid report because this panel only monitors hydrogen in post accident conditions.

Distractor 3 This IS NOT a valid report because the only way to get an oxygen concentration of the primary containment in a LOCA condition is from HRSS.

RefMaterial

QuestionComment

Distract1 Comment

Distract2 Comment

Distract3 Comment

<i>KaNumber</i>	<i>KaSegment1</i>	<i>KaSegment2</i>	<i>KaSegment3</i>	<i>KaSegment4</i>	<i>KaSegment5</i>
500000 a2 01			500000	a2	01
<i>KaRevision</i>				<i>CognitiveLevel</i>	<i>ExamLevel</i>
					S

Examination Outline Cross-reference:

(Page 22) G2.1.20

Ability to execute procedure steps.

(10CFR 55.43.5)

Level

RO

SRO

Tier #

3

Group #

K/A #

Cat 1 G2.1.20

Importance Rating

4.2

Proposed Question: # 52

A startup is in progress at 20% CTP when a Reactor Protection System (RPS) electrical malfunction results in the following:

- HPCI / RCIC & MSIV Isolation on High Temperature
- Full Reactor SCRAM
- One (1) rod remains at position 40 and one (1) other rod is at position 02. All other rods are "Full-In".
- Reactor Pressure Vessel (RPV) water level is 150 inches, and slowly trending down
- RPV pressure is 1000 psig, and slowly trending up

The correct course of action is to:

- a. Enter EOP-2, Emergency Depressurize the RPV, and maintain RPV level with SLC and CRD
- b. Enter EOP-3, stabilize RPV pressure, and maintain RPV level with Feed and Condensate
- c. Enter EOP-3, commence a normal cooldown, and attempt to maintain RPV level with SLC and CRD
- d. Enter EOP-2, commence a normal cooldown, and maintain RPV level with Feed and Condensate

Proposed Answer: d.


Explanation
(Optional):

- d. CORRECT: EOP-2 entered on low RPV level, reactor will remain shutdown with the one rod out; and therefore no EOP-3 entry conditions exist. There are also no "IF-THEN" EOP-2 conditions. So you step right through.
- a. Incorrect: See above.
- b. Incorrect: See above.
- c. Incorrect: See above.

Technical Reference(s): EOP-2 (Attach if not previously provided)
EOP-3

Proposed references to be provided to applicants during examination: EOP-2 and EOP-3

Learning Objective: MIT-301.11C, EO 1.02 & 1.06 (As available)

Question Source: Bank # 25632
Modified Bank #  (Note changes or attach parent)
New 

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 7) 295012 High Drywell Temperature G2.1.20

Ability to execute procedure steps.

(10CFR 55.43.5)

Level	RO	SRO
Tier #	-----	1
Group #	-----	2
K/A #	295012 G2.1.20	
Importance Rating	-----	4.2

Proposed Question: # 53

A major transient has just occurred; no operator actions have been taken. The following plant conditions exist:

- Torus pressure28 psig
- Torus water level16 feet
- Torus water temperature155°F
- DW Pressure30 psig
- DW Temperature290F
- RPV water level100 inches
- Reactor pressure500 psig

Considering the above conditions, the correct course of action would be to _____
_____ to prevent the _____ from being exceeded.

- a. Emergency Depressurize ; SRV Tail Pipe Level Limit
- b. Start Drywell Sprays ; Drywell Design Temperature
- c. Start Torus Venting through SGBT ; Pressure Suppression Pressure Limit
- d. Start Drywell Venting through SGBT ; Primary Containment Pressure Limit

Proposed Answer: b.

Explanation
(Optional):

- b. CORRECT: As required by the Drywell Temperature leg of EOP-4, Drywell Sprays are required to be placed in service PRIOR to Drywell Temperature reaching 309 degrees F.
- a. Incorrect: Torus Water Level and RPV Pressure are currently within the safe region of the SRV Tail Pipe Level Limit curve by ~2 feet of Torus Level. Additionally, the Emergency Depressurization is not required until a determination that neither can be restored and maintained on the safe side.

- c. Incorrect: Torus Water Level and Torus Pressure are currently within the safe region of the Pressure Suppression Pressure Limit curve by ~6 psig. Additionally, a determination that the safe side cannot be maintained requires an Emergency Depressurization vice Torus Venting.
- d. Incorrect: Torus Water Level and Containment Water Level are well within (at least 30 psig) the safe region of the Primary Containment Pressure Limit curve and no stem information indicates an immediate challenge. Additionally, the action to Emergency Depressurize based upon the Pressure Suppression Pressure precedes this requirement.

Technical Reference(s): EOP-2, 4 and 11 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: EOP-2, 4 and 11

Learning Objective: MIT- 301.11E, EO-4.07 and 3.0

Question Source:

Bank #	21342
Modified Bank #	
New	

 (Note changes or attach parent)

Question History: Last NRC Exam LOI-01-01 (11/5/01)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

**(Page 8) 295034 Secondary Containment Vent Hi Rad
EK2.01**Knowledge of the interrelations between SECONDARY
CONTAINMENT VENTILATION HIGH RADIATION and the following:

- Process radiation monitoring system

Level

RO

SRO

Tier #

1

Group #

2

K/A #

295034 EK2.01

Importance Rating

3.9

Proposed Question: # 54

The Reactor Vessel Head has been lifted approximately one (1)-inch in preparation for subsequent removal to support vessel refueling. The Auxiliary Gas Treatment System (AGT) has been discharging to Reactor Building Ventilation for approximately 6 hours when dilution air to the filtration unit is inadvertently reduced. Over the next 15 minutes, Reactor Building Ventilation airborne radioactivity levels climb to 1.5×10^4 cpm in the discharge plenum.

Which of the following actions will occur?

- EOP-5, Secondary Containment Control will be entered as the result of a Safety Parameter Display System (SPDS) Alarm on EPIC
- Operators will verify automatic isolation of Reactor Building Ventilation and the automatic initiation of the Standby Gas Treatment System (SGT)
- Refuel Floor personnel will direct the immediate lowering of the vessel head to avoid exceeding the setpoint for 09-3-2-40 "RX BLDG VENT MON HI-HI"
- Alarm 09-3-2-40 "RX BLDG VENT MON HI-HI" is received and AGT will automatically trip until discharge effluent can be manually re-routed to SGT

Proposed Answer: b.

Explanation
(Optional):

- CORRECT:** At the alarm setpoint for "RX BLDG VENT MONITOR HI-HI" (1.0×10^4 cpm, **automatic** actions occur to isolate Reactor Building Ventilation, start Standby Gas Treatment, and auto-swap AGT from Rx Bldg Ventilation to SGT.
- Incorrect: JAF is in cold shutdown, Mode 5. EP-1, "EOP Entry and Use" indicates that the "procedure applies during all operating modes, except when reactor coolant temperature is less than 212° F and a reactor startup or shutdown is **not** in progress."
- Incorrect: This action may, in fact, occur; but, the distracter indicates that action will be taken "prior" to exceeding the setpoint, when the setpoint has been exceeded.
- Incorrect: Although the alarm will be received, the fact of stating that the "AGT **automatically** trips until discharge effluent can be **manually** re-routed to SGT" makes the statement incorrect as AGT has **no** automatic trip on radiation levels and **automatic** action will occur to swap AGT discharge effluent from Rx Bldg Ventilation to SGT.

Technical Reference(s): OP-31 (Attach if not previously provided)
ARP 09-3-2-40

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-63, EO 1.05.c.1 & 1.14 (As available)
SDLP-17, EO 1.05.c & 1.14.d.11

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 22) G2.2.1

Ability to perform pre-startup procedures for the facility / including operating those controls associated with plant equipment that could affect reactivity.

Level

RO

SRO

Tier #

3

Group #

K/A #

Cat 2 G2.2.1

Importance Rating

3.7

Proposed Question: # 55

A plant startup is in progress with the Mode Selector Switch in "Startup". Control rods are being withdrawn. The Rod Worth Minimizer (RWM) has just failed with 25% of the control rods withdrawn.

What actions are required?

- Bypass the RWM, verify all further control rod movements are in compliance using a qualified person, and continue the reactor startup.
- Suspend withdrawal of the control rods, manually SCRAM the reactor, and verify operability of the RWM before commencing a reactor startup.
- Bypass the RWM, fully insert all control rods, and verify operability of the RWM before commencing a reactor startup.
- Suspend withdrawal of the control rods, verify operability of the Rod Block Monitor, and continue the reactor startup.

Proposed Answer: a.

Explanation
(Optional):

- CORRECT – Per T.S. 3.3.2.1 and OP-64, Section E.1, if the RWM becomes inoperable below the Low Power Setpoint (LPSP) – reference 25% rods withdrawn in stem. These are the required actions specified in the procedure.
- Incorrect – Per T.S. Required Action C.1, continued rod movement is suspended except by Scram.
- Incorrect – Correct only in the "Bypass RWM" portion of the distracter. Per OP-64 and T.S. 3.3.2.1, Control Rod insertion is not required.
- Incorrect – Although both the RBM and RWM appear in T.S. 3.3.2.1, they serve distinctly different functions and are not backups to each other.

Technical Reference(s): OP-64, Section E.1 / OP-65 (Attach if not previously provided)
T.S. 3.3.2.1

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-3D, EO 1.15.a & 1.19 (As available)

Question Source: Bank # 25683
Modified Bank # [Redacted] (Note changes or attach parent)
New [Redacted]

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 15) 261000 SGTS A1.01

Ability to predict and/or monitor changes in parameters associated with operating the STANDBY GAS TREATMENT SYSTEM controls including:

- System flow

Level	RO	SRO
Tier #	2	—
Group #	1	—
K/A #	261000 A1.01	—
Importance Rating	2.9	—

Proposed Question: # 56

Following a significant I-131 release in the Reactor Building, Standby Gas Treatment System (SGT) Train "Alpha" has been in service, on an isolated Reactor Building, for several hours and is in the process of being swapped to SGT Train "Bravo". During the swap, the NPO notes Train "B" flow at 5650 scfm. In an attempt to raise flow, the NPO closes valves 01-125SGT-3A/B "SGT Train A/B Fan 1A/B Suction Cross-Tie Isolation Valves". Resulting SGT Train "B" flow is now 5800 scfm.

Which of the following are the potential consequences of the NPO's actions?

- No consequences; the system will still function as designed
- Commence drawing a vacuum on the Standby Gas Treatment Room
- Exceeding the charcoal auto-ignition temperature on SGT Train "Alpha"
- Excessive SGT Train "Bravo" flows will reduce it's Iodine removal capability

Proposed Answer: c.

Explanation
(Optional):

- CORRECT:** Closing the 01-125SGT-3A/B Cross-connect valves will secure all decay heat cooling flow from the off-service Train A. With the decay heat buildup, the auto-ignition temperature of the charcoal may be exceeded.
- Incorrect:** There is a potential consequence, as stated above and the "Alpha" train has a high potential for overheating in this case.
- Incorrect:** Closing the 01-125SGT-3A/B Cross-connect valves will secure all decay heat cooling flow from the off-service Train A. Drawing a vacuum on the SGT Room is prevented by the orifice in the decay heat suction line. Without decay heat flow, there is no potential for drawing a vacuum on the SGT Room.
- Incorrect:** The highest flow noted in the stem is 5800 scfm. The maximum flow, by OP-20, is allowed to be as high as 6000 scfm.

Technical Reference(s): OP-20 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: FM-48A

Learning Objective: SDLP-01B, EO 1.05.b.6 & 1.13 (As available)

Question Source:	Bank #	<input type="checkbox"/>	(Note changes or attach parent)
	Modified Bank #	<input type="checkbox"/>	

New

Question History:	Last NRC Exam	<input type="checkbox"/>
-------------------	----------------------	--------------------------

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: **Memory or Fundamental Knowledge**

Comprehension or Analysis

10 CFR Part 55 Content: **55.41**

55.43

Comments:

Examination Outline Cross-reference:

(Page 6) 600000 Plant Fire On Site / 8 AA2.09Ability to determine and interpret the following as they apply to
PLANT FIRE ON SITE:

- That a failed fire alarm detector exists

(10CFR 55.43.5)

Level

PO

SRO

Tier #

1

Group #

1

K/A #

600000 AA2.09

Importance Rating

2.8

Proposed Question: # 57

While operating normally at full power, an unexpected half scram occurs. At the same moment, a NPO calls the control room to report a major fire in the Cable Spreading Room.

_____ detection has failed to indicate the fire on the Fire Protection Panel (FPP) in the Control Room and initiate the fire suppression system. A reactor shutdown and cooldown is required and will be accomplished by _____.

- Heat; AOP-43, Plant Shutdown From Outside The Control Room
- Heat; AOP-28, Operation During Plant Fires
- Ionization; AOP-43, Plant Shutdown From Outside The Control Room
- Ionization; AOP-28, Operation During Plant Fires

Proposed Answer: a.Explanation
(Optional):

- CORRECT:** Only heat or flame detectors actuate fire suppression systems. Ionization detectors provide alarm function only. AOP-28 does not accomplish a plant cooldown and if referenced will force exit to AOP-43. AOP-43 will place the plant in a cold shutdown condition.
- Incorrect: See Above.
- Incorrect: See Above.
- Incorrect: See Above.

Technical Reference(s): AOP-43 (Attach if not previously provided)
OP-33

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-76, EO 1.05.a.14, 1.14
LP-AOP, EO 1.03, 2.29 (As available)

Question Source:

Bank #	
Modified Bank #	
New	<input checked="" type="checkbox"/>

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 13) 217000 RCIC A2.01

Ability to (a) predict the impacts of the following on the REACTOR CORE ISOLATION COOLING SYSTEM (RCIC); and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:

- System initiation signal

Level

RO

SRO

Tier #

2

Group #

1

K/A #

217000 A2.01

Importance Rating

3.8

Proposed Question: # 58

The Reactor Core Isolation Cooling System (RCIC) steam supply line is in the process of being tagged out to support corrective maintenance on the Turbine Building Equipment Drain Sump. The following has occurred: (All other components are in their normal positions)

- Air has been isolated to both Steam Line Drain Isolation Valves (13AOV-34/35) and the Drain Trap Bypass Valve (13AOV-32). All are "CLOSED" and tagged in this position.
- Valve Switches for the RCIC Inboard and Outboard Steam Supply Isolation Valves (13MOV-15/16) have just been taken to "CLOSE" by an operator, in preparation for hanging tags. Both valves are "CLOSED"; still have electrical power, and tags have not yet been hung.

Just as 13MOV-15/16 indicate "CLOSED", a feedwater transient results in reactor water level dropping to 126 inches. Without operator action(s), RCIC will...

- start automatically with the only subsequent operator action being to start up RHR Torus Cooling as soon as practicable, per Section "Delta" of OP-13B "RHR - Containment Control".
- NOT start until all tags are cleared per EN-OP-102 "Protective and Caution Tagging" and all MOVs and AOVs are returned to their "Normal" positions per OP-19 "RCIC" Valve lineup (Attachment 1).
- attempt to start automatically, but will NOT be able to get steam to the turbine until Inboard / Outboard Steam Supply Isolation Valves (13MOV-15/16) are manually opened per Section "Golf" of OP-19 "RCIC".
- attempt to start automatically, but will NOT start until an operator takes the 13MOV-16 AUTO CONTROL BYPASS keylock switch (13S-2A) to "BYPASS" per AOP-15 "Isolation Verification and Recovery".

Proposed Answer: a.Explanation
(Optional):

- CORRECT:** Per OP-19, Even though 13MOV-15/16 are "normally open", they both still receive an "open" signal on RCIC initiation signal. The only operator action specified on auto-initiation (G.7) is to start RHR Torus Cooling as soon as practicable. Both the Drain Trap Isolation AOV's would close on RCIC initiation directly from the opening of 13MOV-131.
- Incorrect:** See above. RCIC auto-initiation is **not** dependent upon performing any of these actions.

- c. Incorrect: See above. Manual opening of 13MOV-15/16 would not be required as they receive an "open" signal upon RCIC initiation signal.
- d. Incorrect: See above. By taking the 13MOV-16 AUTO CONTROL BYPASS switch to "BYPASS" it would remove the auto-opening feature and the valve would stay closed; and no steam would reach the turbine.

Technical Reference(s): OP-19 / OP-13B (Attach if not previously provided)
SDLP-13

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-13, EO 1.05.a.11/a.17/c.3 (As available)

Question Source:

Bank #	
Modified Bank #	

 (Note changes or attach parent)

New

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 8) 295029 High Suppression Pool Wtr Lvl / 5 G2.4.8
 Knowledge of how the event-based emergency/abnormal operating procedures are used in conjunction with the symptom-based EOPs.
(10CFR 55.43.5)

Level	RO	SRO
Tier #	-----	1
Group #	-----	2
K/A #	295029 G2.4.8	
Importance Rating	-----	3.7

Proposed Question: # 59

With the plant operating normally at 100% CTP, an event occurs resulting in the following indications over several minutes:

- Total Feed Flow step rises by .5 Mlbm/hr then slowly returns to the previous value.
- RPV Water Level rises by ~3 inches and stabilizes.
- Drywell Pressure rises from 1.85 to 1.95 psig and is still slowly trending up.
- Torus Water Level rises from 13.98 to 14.03 feet and is slowly trending up.
- The "A" MSL Flow Indicator is found hard upscale.
- The "B", "C", and "D" MSL Flow Indicators are steady at 2.6 Mlbm/hr.

As a result of the current indications, which of the below procedure groups are required to be performed concurrently.

- a. EOP-2, RPV Control, AOP-9, Loss of Primary Containment Integrity, and AOP-39, Loss of Coolant.
- b. EOP-2, RPV Control, AOP-40, Main Steam Line Break, and AOP-41, Feedwater Malfunction (High RPV Water Level).
- c. EOP-4, Primary Containment Control, AOP-39, Loss of Coolant, and AOP-41, Feedwater Malfunction (High RPV Water Level).
- d. EOP-4, Primary Containment Control, AOP-9, Loss of Primary Containment Integrity, and AOP-40, Main Steam Line Break.

Proposed Answer: c.

Explanation
(Optional):

- c. CORRECT: The indications presented represent a small pipe break on the low pressure side of the "A" MSL Flow Transmitter located in the Drywell. Torus Water Level is above the EOP-4 entry condition of 14.0 feet. AOP-39 is specific to a loss of coolant inside the drywell. AOP-41 results from the feedwater transient introduced by the pipe failure.
- a. Incorrect: Although stem conditions indicate an EOP-2 entry condition will soon occur, it is not yet in. AOP-9 is not applicable as it directs exit if an EOP-4 or 5 entry condition is present. AOP-39 is applicable.
- b. Incorrect: Although stem conditions indicate an EOP-2 entry condition will soon occur, it is not yet in. AOP-40 is specific to a main steam line break outside the drywell and directs exit if the break is inside the drywell. AOP-41 is applicable.

- d. Incorrect: EOP-4 is applicable. AOP-9 is not applicable as it directs exit if an EOP-4 or 5 entry condition is present. AOP-40 is specific to a main steam line break outside the drywell and directs exit if the break is inside the drywell.

Technical Reference(s): OP-43A (Attach if not previously provided)
AOP-58

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-72B, EO 1.04 a/b/c & 1.09 a/b/c (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:
 Memory or Fundamental Knowledge
 Comprehension or Analysis

10 CFR Part 55 Content:
 55.41
 55.43

Comments:

Examination Outline Cross-reference:

(Page 15) 262001 AC Electrical Distribution A2.01

Ability to (a) predict the impacts of the following on the A.C. ELECTRICAL DISTRIBUTION; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:

- * Turbine/generator trip

(10CFR 55.43.5)

Level

PO

SRO

Tier #

2

Group #

1

K/A #

262001 A2.01

Importance Rating

3.6

Proposed Question: # 60

The plant is operating in a normal, full-power lineup when a Transformer T-4 Protection Relay actuates on overcurrent and trips the Main Generator. All components function as designed.

Which one of the following would be the correct course of action to respond to the event?

- Enter into and perform the actions of AOP-49, Station Blackout as all vital and non-vital AC electrical busses have been lost on a failure to fast and/or residual transfer.
- Enter into and perform the actions of AOP-57, Recovery from Residual Bus Transfers to expedite restoration of power to the 10300, 10400, 10500, and 10600 Busses.
- Direct Control Room operator to verify that the 10100, 10200, 10300, and 10400 Busses have fast transferred to 115 KV System per Section "Golf" of OP-44, 115 KV System.
- Dispatch operators to the EDGs, which are supplying the only operable AC busses, to verify proper operation per Section "Echo" of OP-22, Diesel Generator Emergency Power.

Proposed Answer: d.

Explanation
(Optional):

- CORRECT:** Any Transformer T-4 protection package that actuates results in no transfer, versus fast or residual, to 115 KV System power. As the 10100 through 10400 busses fail to transfer, the EDG circuitry will sense sustained undervoltage conditions, start, and force parallel to re-power the 10500 and 10600 busses.
- Incorrect:** Symptoms that warrant entry into AOP-49 include the loss of voltage and phase current to **all** 4160 VAC busses, along with loss of power to Normal and Reserve Station Service Transformers.
- Incorrect:** See above. As there would be no "Residual" transfer upon actuation of a T-4 protection package, there would be no need to recover from a residual transfer.
- Incorrect:** See above. As there would be no "Fast" transfer upon actuation of a T-4 protection package, there would be no need to verify the success of said transfer.

Technical Reference(s): ESK-5 (series) / ESK-8 (series) (Attach if not previously provided)
SDLP-71C

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-71C, EO 1.05 b.4/c.1 & 1.09 a/c/d/e (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:
Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content:
55.41
55.43

Comments:

Examination Outline Cross-reference:

**(Page 14) 223002 PCIS/Nuclear Steam Supply Shutoff
G2.3.9**

Knowledge of the process for performing a containment purge.

Level	RO	SRO
Tier #	2	-----
Group #	1	-----
K/A #	223002 G2.3.9	
Importance Rating	2.5	-----

Proposed Question: # 61

An unisolable Main Steam Line Rupture inside Primary Containment has resulted in:

- Emergency Depressurization of the Reactor Pressure Vessel (RPV) with RPV level currently at -5 inches
- Torus Pressure is swiftly approaching the Primary Containment Pressure Limit
- Current radiation levels inside the Drywell are noted on Panel 09-10 as being 190 Rem/Hour.

If all equipment functioned as designed, to initiate a containment Vent and Purge utilizing the "preferred" method, operators will have to...

- a. take the Div I and Div II Isolate Switches to "RESET" on the 09-4 / 09-3 respectively, open Torus Exhaust Inner and Outer Isolation Valves (27AOVs), and line up one Containment Atmosphere Dilution (CAD) Train to the Drywell.
- b. use at least nine (9) keylock switches on the 27PCP or 27CAD panels to override Group II isolations, open Drywell Exhaust Inner and Outer Isolation Valves (27AOVs), and line up one Containment Atmosphere Dilution (CAD) Train to the Torus.
- c. take the Div I and Div II Isolate Switches to "RESET" on the 09-4 / 09-3 respectively, open Drywell Exhaust Inner and Outer Bypass Valves (27MOVs), and line up one Containment Atmosphere Dilution (CAD) Train to the Torus.
- d. use at least nine (9) keylock switches on the 27PCP or 27CAD panels to override Group II isolations, open Torus Exhaust Inner and Outer Bypass Valves (27MOVs), and line up one Containment Atmosphere Dilution (CAD) Train to the Drywell.

Proposed Answer: d.Explanation
(Optional):

- d. CORRECT: Stem conditions have at least two Div II signals present (RPV level, DW Press). EP-6 Directs overriding all eight channel inputs on the 27PCP and either A or B Train on the 27CAD to vent from the Torus, using MOVs initially, and Purge through the Drywell (preferred paths).
- a. Incorrect: See above. Unless manual isolation directed, which is not a given, these switches are in "RESET" always; AOVs versus MOVs
- b. Incorrect: See above. Opposite paths and AOVs versus MOVs
- c. Incorrect: See above. Opposite paths.

Technical Reference(s): EOP-4 / EP-6 (Attach if not previously provided)
SDLP-16B/16C

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-16B, EO 1.05.a.2.c/e & 1.05.b.3 (As available)
SDLP-16C, EO 1.05.a.7/8 & 1.11.b.2/3

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 16) 263000 DC Electrical Distribution A2.02

Ability to (a) predict the impacts of the following on the D.C. ELECTRICAL DISTRIBUTION; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:

- Loss of ventilation during charging

(10CFR 55.43.5)

Level	RO	SRO
Tier #	-----	2
Group #	-----	1
K/A #	263000 A2.02	
Importance Rating	-----	2.9

Proposed Question: # 62

An Equalizing Charge is in progress on "Alpha" Station Battery. MCC-253 is lost mid-way through the charging cycle, resulting in the loss of:

- "Alpha" Air Handling Unit 72 AHU-30A
- "Alpha" Exhaust Fan 72FAN-46C
- "Alpha" Recirculation Fan 72FAN-31A

The correct course of action, relative to "Alpha" Station Battery / Ventilation, is to:

- Initiate actions to begin lining up emergency ventilation to "Alpha" Battery Room in accordance with AOP-58 "Station Battery Room Emergency Ventilation"
- Open Fire Dampers 72FD-3 and 72FD-6 to cross-connect "Alpha" and "Bravo" Supply and Exhaust Fans in accordance with OP-33 "Fire Protection"
- Dispatch an operator to secure the Equalizing Charge on "Alpha" Station Battery in accordance with OP-43A "125 VDC Power System"
- Ensure standby Exhaust Fan (72FAN-46A) for "Alpha" Battery Room starts in accordance with OP-59A "Battery Room Ventilation"

Proposed Answer: c.

Explanation
(Optional):

- CORRECT:** OP-43A Precaution states "Equalizing charges shall only be applied to batteries while battery room ventilation is operating to prevent hydrogen buildup." Therefore, the charge must be secured.
- Incorrect:** AOP-58 actions are only warranted when a fire in one of several possible locations causes the loss of Battery Room Ventilation.
- Incorrect:** Both Fire Dampers are, in fact, located in the supply and exhaust lines. 72FD-6 does cross-connect the supply line, but is normally open. 72FD-3 is located in the Alpha-side exhaust, but does not cross-connect and is normally open. Additionally, OP-33 does not address Fire Damper positioning for the aforementioned dampers.
- Incorrect:** Although there are two Exhaust Fans for Alpha-side, they are both powered from MCC-253. Therefore, in this case, the standby fan would not start upon trip of the running fan.

Technical Reference(s): OP-43A (Attach if not previously provided)
AOP-58

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-72B, EO 1.04.a/b/c & 1.09.a/b/c (As available)

Question Source:

Bank #	
Modified Bank #	
New	<input checked="" type="checkbox"/>

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input type="checkbox"/>
55.43	<input checked="" type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 16) 263000 DC Electrical Distribution K1.04

Knowledge of the physical connections and/or cause-effect relationships between D.C. ELECTRICAL DISTRIBUTION and the following:

- Ground detection

Level	RO	SRO
Tier #	1	-----
Group #	1	-----
K/A #	263000 K1.04	
Importance Rating	2.6	-----

Proposed Question: # 63

The plant is operating at 100% with operators performing AOP-22, "DC Power System A Ground Isolation," due to a ground on the "Alpha" station battery. The next breaker to be opened is the supply for the 10700 bus breaker Control Power. When this breaker is OPENED, which one of the following statements correctly describes the effect that this will have on the 10700 bus?

- All 10700 bus breakers will open if originally closed due to a loss of "A" 125 VDC control power.
- All 10700 bus breaker protection trips will operate normally because bus logic power has automatically swapped to "B" 125 VDC.
- All 10700 bus breakers will lose red / green position indicating lights because the breakers have lost "A" 125 VDC control power.
- All 10700 bus breaker red / green position indicating lights will still indicate breaker positions because the logic power has automatically swapped to "B" 125 VDC.

Proposed Answer: c.

Explanation
(Optional):

- CORRECT** – Per AOP-45/46, a loss of DC power will result in a loss of control power to the affected bus breaker(s) and electrical load indicating lamps.
- Incorrect** – The breakers will not automatically open on loss of DC control power; they fail as-is on a loss of control power.
- Incorrect** – There is no automatic swap of 125 VDC control power on bus 10700.
- Incorrect** – There is no automatic swap of 125 VDC control power on bus 10700, and the red and green lights will be lost when 125 VDC is lost.

Technical Reference(s): AOP-22 / 45 / 46 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-71B, EO 1.09.a.18 & 1.14a/b/c/d (As available)

Question Source:

Bank # 21357

Modified Bank #	
New	

(Note changes or attach parent)

Question History: Last NRC Exam LOI-01-01 (11/5/01)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 13) 217000 RCIC G2.4.16

Knowledge of EOP implementation hierarchy and coordination with other support procedures.

(10CFR 55.43.5)

Level

RO

SRO

Tier #

2

Group #

1

K/A #

217000 G2.4.16

Importance Rating

4.0

Proposed Question: # 64

You are the Control Room Supervisor when a MSIV closure scram occurs. The Turbine Generator Trip resulted in a residual transfer of the 10300 and 10400 busses. Upon startup of the HPCI system, a large rupture of the HPCI steam supply line occurred in the drywell entrance area. Automatic isolation stopped the HPCI steam line leak.

Which of the below is your required, procedurally-driven order to support the restoration of RPV water level control?

- Use EP-2 to override the RCIC area temperature isolation signal and startup RCIC.
- Use EOP-2 to emergency depressurize the RPV and start up RHR and Core Spray.
- Use EP-9 to reopen the MSIV's and startup the Feed and Condensate Systems.
- Use EP-8 to lineup the SLC system to the SLC test tank and start SLC.

Proposed Answer: a.

Explanation
(Optional):

- CORRECT:** The key word is immediate. Starting RCIC will obtain a 400 gpm injection source in short order. The stem conditions model the RCIC design basis in preventing core uncover.
- Incorrect:** Provided expeditious actions place the RCIC system in service, level will not drop below TAF and a required emergency depressurization will not occur.
- Incorrect:** EP-9 will get the MSIV's reopened once the cause of closure is corrected. This activity is time consuming as is the completion of AOP-57, Residual Transfer, which is required to restart the condensate and booster pumps.
- Incorrect:** Doubly incorrect. Requires time consuming field operations to change the suction lineup to the test tank. Just starting the pump from the control room is quicker but still only provides a 50 gpm injection source.

Technical Reference(s): EOP-2, AOP-57 (Attach if not previously provided)
EP-2, 8 and 9

Proposed references to be provided to applicants during examination: EOP-2

Learning Objective: MIT-301.11.C EO 1.04

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input type="checkbox"/>
55.43	<input checked="" type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 16) 264000 EDGs K3.03Knowledge of the effect that a loss or malfunction of the
EMERGENCY GENERATORS (DIESEL/JET) will have on the following:

- Major loads powered from electrical buses fed by the emergency generator(s)

Level	RO	SRO
Tier #	2	---
Group #	1	---
K/A #	264000 K3.03	---
Importance Rating	4.1	---

Proposed Question: # 65

Emergency Diesel Generator (EDG) start signals resulted from a Loss of Coolant Accident concurrent with Degraded 10500/10600 Bus Voltage conditions. The "Alpha" EDG failed to start. All other equipment operates as designed.

Without any operator action, which of the following combinations of Residual Heat Removal (RHR) and Core Spray (CSP) Pumps will be operating 45 seconds after the initial EDG start signals?

- ONLY "Delta" RHR Pump is running and "Bravo" Core Spray Pump is about to start.
- "Alpha, Charlie, and Delta" RHR Pumps along with "Alpha and Bravo" Core Spray Pumps are running.
- "Alpha, Bravo, and Delta" RHR Pumps are running with "Alpha and Bravo" Core Spray Pumps about to start.
- ONLY "Delta" RHR Pump and "Bravo" Core Spray Pump are currently running.

Proposed Answer: b.

Explanation
(Optional):

- CORRECT:** Upon failure to start of one EDG (in a pair), the 2nd RHR Pump on that side will not auto-start. The rest is just a timing sequence with "A and D" RHR Pumps starting at 11 seconds; "B and C" RHR Pumps at 16 sec ("B" won't start – one EDG); and "A and B" Core Spray Pumps at 21 seconds.
- Incorrect:** See above. Assumes neither "A or C" EDGs started and either "B or D" EDG failed to start also. Also, plays on the 45 second sequence associated with a Degraded Voltage signal without a LOCA signal present.
- Incorrect:** See above. Plays on the power supply oddity of RHR and the 45 second sequence.
- Incorrect:** See above. Assumes neither "A or C" EDGs started and either "B or D" EDG failed to start also.

Technical Reference(s): OP-13A / OP-22 (Attach if not previously provided)
SDLP-10, Att. III

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-10, EO 1.03 a, 1.05 a.1 a, 1.06 a & 1.10 a (As available)
SDLP-93, EO 1.03 a/b, 1.05 b.1/2/3, 1.06 c, & 1.09 b/c

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 20) 272000 Radiation Monitoring A2.16

Ability to (a) predict the impacts of the following on the RADIATION MONITORING SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:

- Instrument malfunctions

Level

RO

SRO

Tier #

2

Group #

2

K/A #

272000 A2.16

Importance Rating

2.7

Proposed Question: # 66

At 1500, the OPER-INOP keylock switch for 17RM-150A ("Alpha" Off Gas Radiation Monitor) is placed in "INOP" due to a bug source malfunction.

At 1510, 17RM-150B ("Bravo" Off Gas Radiation Monitor) fails downscale.

When will Off Gas Rad Timer (17RM-157) "time out" and which of the subsequent event sequences will occur?

- At 1515, 17RM-157 times out and AOP-31, "Loss of Condenser Vacuum" is entered to combat the degrading main condenser vacuum
- At 1515, 17RM-157 times out and AOP-3, "High Activity in Reactor Coolant or Off-Gas" is entered upon closure of 01-107AOV-100 "Off Gas Disch to Stack"
- At 1525, 17RM-157 times out and AOP-15, "Isolation Verification and Recovery" is entered to recover the Off Gas discharge flowpath
- At 1525, 17RM-157 times out and AOP-1, "Reactor Scram" is entered upon manual scram due to closure of 01-107AOV-100 "Off Gas Disch to Stack"

Proposed Answer: d.

Explanation
(Optional):

- CORRECT:** Per ARP 09-3-2-17, *both* rad monitors must fail downscale/inop to start the 15-minute timer. Thus, the timer will not start until time 1510 and will not time out until 1525. At time 1525, 01-107AOV-100 will close on the timer timing out, and ARP 09-3-2-17 directs a manual scram on valve closure.
- Incorrect:** See above, which invalidates time of valve closure on 01-107AOV-100; and, thus, any degrading vacuum condition. AOP-31 could potentially be entered for, or in anticipation of, a degrading condenser vacuum; but, the distracter indicates that degradation is in progress.
- Incorrect:** With no "upscale failure", Off Gas Hi Rad, or Off Gas Hi-Hi Rad condition present, AOP-3 would not be entered. Additionally, the above justification invalidates time of valve closure on 01-107AOV-100
- Incorrect:** Time out reference time is accurate from the perspective of 15 minutes after second downscale. AOP-15 deals with several radiation-related plant isolations, but **not** the one in question.

Technical Reference(s): ARP 09-3-2-17 (Attach if not previously provided)
AOP-1

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-01A, EO 1.05.c.1 & 1.10.b (As available)
SDLP-17, EO 1.05.a.4/c.4

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

Level

RO

SRO

(Page 8) 295035 Secondary Containment High Differential Pressure/5 G2.1.21

Tier #

1

Ability to obtain and verify controlled procedure copy.

Group #

2

K/A #

295035 G2.1.21

Importance Rating

3.1

Proposed Question: # 67

A Reactor Water Cleanup System (RWCU) high energy line break has occurred. Given the following resulting conditions, you have determined the Standby Gas Treatment (SGT) system has failed to automatically initiate:

- The highest RWCU Pump Room general area dose rate is 26 mrem/hr
- "Bravo" RWCU Pump Room Local Area Temperatures are 130°F and 132°F
- Reactor Building Ventilation Exhaust Radiation Levels are 1020 cpm
- Reactor Building Differential Pressure is 1.25 inches Water Gage

The control room hardcopies of procedures conflict with your determination. Which of the below choices would be correct in resolving the conflict?

- a. Review the most current revision of AOP-15, "Isolation Verification and Recovery", located in the Technical Reference Center Master Files.
- b. Review the most current revision of OP-20, "Standby Gas Treatment System" located on the Merlin Reference Library Website.
- c. Initiate a Procedure Change Request (PCR) per AP-02.04, "Control of Procedures", to correct the errant procedure(s).
- d. Submit a Work Order Request (WOR) per AP-10.01, "Problem Identification and Work Control" to repair the SGT Initiation logic.

Proposed Answer: **b.**Explanation
(Optional):

- b. **CORRECT:** The Master Copy of all Operating Procedures is the Merlin Reference Library Website per EN-AD-103 Step 7. This copy of OP-20 will also conflict with the INCORRECT assessment that SGT failed to automatically start.
- a. **Incorrect:** Although AOP-15 will also conflict with the INCORRECT assessment, the Master Copy is NOT located in the Technical Reference Center
- c. **Incorrect:** The procedure is not in error and therefore a Procedure Change Request will not resolve the conflict.
- d. **Incorrect:** The Standby Gas Treatment System is not malfunctioning; and therefore, there is no need to initiate a WOR.

Technical Reference(s): OP-20 (Attach if not previously provided)
AP-12.03

Proposed references to be provided to applicants during examination: None

Learning Objective: LPAP, EO 6.08, 46.04, (As available)
SDLP-01B, EO 1.05.c

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 19) 226001 RHR/LRCI: CTMT Spray Mode K5.06

Knowledge of the operational implications of the following concepts as they apply to RHR/LPCI CONTAINMENT SPRAY SYSTEM MODE:

- Vacuum breaker operation

Level

RO

SRO

Tier #

2

Group #

2

K/A #

226001 K5.06

Importance Rating

2.6

Proposed Question: # 68

If a small-break Loss of Coolant Accident were to occur in the Drywell, what affect would stuck-open Torus-to-Drywell Vacuum Breaker(s) have on the use of the Drywell and Torus Sprays as compared to the same event with functional Torus-to-Drywell Vacuum Breakers?

With one or more Torus-to-Drywell Vacuum Breakers stuck open, _____ would have to be initiated earlier in the event timeline.

- ONLY the Torus Spray
- ONLY the Drywell Spray
- NEITHER the Drywell nor the Torus Sprays
- BOTH the Drywell and the Torus Sprays

Proposed Answer: d.

Explanation
(Optional):

- CORRECT – During a small-break LOCA, if the aforementioned vacuum breaker(s) were stuck open, the pressure suppression function of the Torus itself would be degraded or bypassed entirely. Thus, pressures in both the Drywell and Torus air space would rise faster when compared to the same event with fully functional vacuum breakers; requiring initiation of Drywell and Torus Sprays earlier in the progression of events.
- Incorrect – See above.
- Incorrect – See above.
- Incorrect – See above.

Technical Reference(s): SDLP-16A (Attach if not previously provided)
UFSAR, Sections 6.5 and 14

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-16A, EO 1.05.c.1 & 1.06.b/c (As available)

Question Source: Bank # 25183 (LaSalle 1 – 5/23/2003)
 Modified Bank # (Note changes or attach parent)

Question History: New
 Last NRC Exam

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments: *This question was an SRO-Level question on the previous exam and is being used as an RO-Level question on this exam.*

Examination Outline Cross-reference:

(Page 23) G2.3.2

Knowledge of facility ALARA program.

(10CFR 55.43.4)

Level

RO

SRO

Tier #

3

Group #

K/A #

Cat 3 G2.3.2

Importance Rating

2.9

Proposed Question: # 69

A work activity inside the Condensate Pump Pit Area has resulted in local dose rates of 1200 to 1500 mr/hour.

Which of the following describe the minimum actions required?

- Post as a Very High Radiation Area and access is barricaded or guarded.
- Post as a Very High Radiation Area and access is locked or guarded.
- Post as a High Radiation Area and access is barricaded or guarded.
- Post as a High Radiation Area and access is locked or guarded.

Proposed Answer: d.

Explanation
(Optional):

- CORRECT: Technical Specification 5.7.2 (Admin Controls) supported by AP-07.06 definition of a Locked High Radiation Area.
- Incorrect: AP-07.06 defines a Very High Radiation Area as >500 Rads/hr
- Incorrect: AP-07.06 defines a Very High Radiation Area as >500 Rads/hr
- Incorrect: Tech Specs and AP-07.06 require the stem described area access(es) to be locked vice just barricaded.

Technical Reference(s): AP-07.06 (Attach if not previously provided)
TS 5.7

Proposed references to be provided to applicants during examination: None

Learning Objective: LPAP EO-31.02 (As available)

Question Source:

Bank #	
Modified Bank #	
New	<input checked="" type="checkbox"/>

--

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input checked="" type="checkbox"/>
Comprehension or Analysis	<input type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input type="checkbox"/>
55.43	<input checked="" type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 23) G2.3.7Knowledge of the process for preparing a radiation work permit.
(10CFR 55.43.4/5)

Level

RO

SRO

Tier #

3

Group #

K/A #

Cat 3 G2.3.7

Importance Rating

3.3

Proposed Question: **# 70**

During normal full power, steady-state operation a 55-gallon drum of Diesel Fuel is inadvertently spilled in the Ventilation Equipment Room just west of the Control Room. In a short time the Control Room Operators sense a strong concentration of gaseous fumes, which are becoming progressively more irritating to them.

As the CRS, you should direct entry into _____; and any in-plant actions that are warranted under this procedure will require _____.

- AOP-43, Plant Shutdown From Outside Control Room; that you contact Radiation Protection to activate the Standing RWP for Abnormal Plant Operations.
- AOP-73, Loss of Main Control Room Boundary; that you contact Radiation Protection to activate the Standing RWP for Abnormal Plant Operations.
- AOP-43, Plant Shutdown From Outside Control Room; you to inform operators, if asked, that all RWP requirements are waived for performance of those actions.
- AOP-73, Loss of Main Control Room Boundary; you to inform operators, if asked, that all RWP requirements are waived for performance of those actions.

Proposed Answer: **c.**Explanation
(Optional):

- CORRECT:** AOP-43 contains a specific Note just prior to the Procedure section that details the fact that "RWP requirements are waived to accomplish this procedure". Additionally, AP-07.01, Radiation Work Permit Program, Step 8.3.1 states that an RWP is not required for initial response to emergency situations.
- Incorrect:** See above. Correct procedure; incorrect action.
- Incorrect:** Although not a symptom that warrants entry into AOP-73, with infiltration of toxic fumes into the Control Room from an adjacent space, it is plausible to assume that the integrity of a Control Room boundary could be called into question. Although, a Standing RWP could feasibly be created if RP and Plant Management decided.
- Incorrect:** See Above. Also, the procedural note detailed above is not present in AOP-73.

Technical Reference(s): AP-07.01 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: LP-AP EO 26.03 and 26.04 (As available)

Question Source:

Bank #	
Modified Bank #	25603 (attached)
New	
Last NRC Exam	

(Note changes or attach parent)

Question History:

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

PLANT
FitzPatrick 1

ExamDate
7/1/2003

ExamType
ILO

QuestionId
25803

NSSSType
BWR

Question During normal full power steady-state operation, a 55-gallon drum of diesel fuel is inadvertently spilled in the Ventilation Equipment Room just west of the Control Room. In a short time the Control Room Operators sense a strong concentration of gaseous fumes, which are becoming progressively more irritating to them.

Which of the following sequences would be expected by the Crew?

Place the Control Room Ventilation ISOL & Purge CNTRL switch in _____; if conditions continue to worsen, consider entry into _____.

Answer PURGE; AOP-43, Plant Shutdown From Outside the Control Room

Distractor 1 ISOLATE; AOP-43, Plant Shutdown From Outside the Control Room

Distractor 2 ISOLATE; AOP-28, Operation during Plant Fires

Distractor 3 PURGE; AOP-28, Operation during Plant Fires

RefrMaterial

QuestionComment Although a flammable liquid, AOP-28 is only entered for a confirmed fire. As a Toxic Gas is entering the Control Room environment, AOP-43 entry is warranted. Operating Control Room Ventilation in the ISOLATE Mode will trap the toxic gas in the Control Room while the PURGE Mode will turnover the Control Room atmosphere volume to outside air.

Distract1Comment

Distract2Comment

Distract3Comment

<i>KaNumber</i>	<i>KaSegment1</i>	<i>KaSegment2</i>	<i>KaSegment3</i>	<i>KaSegment4</i>	<i>KaSegment5</i>
.295018.AK2.03			295018	AK2	03
<i>KaRevision</i>				<i>CognitiveLevel</i>	<i>ExamLevel</i>
				2	R

Examination Outline Cross-reference:

(Page 21) 290003 Control Room HVAC A2.03

Ability to (a) predict the impacts of the following on the CONTROL ROOM HVAC; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:

- Initiation/reconfiguration failure

Level

RO

SRO

Tier #

2

Group #

2

K/A #

290003 A2.03

Importance Rating

3.4

Proposed Question: # 71

Control Room and Relay Room Air Handling Units (AHUs) are in the process of being swapped to equalize run times on the units. The current configuration is as follows:

- Control Room 70AHU-3A was swapped to 70AHU-3B approximately thirty (30) minutes ago
- An NPO has just started the "Bravo" Relay Room AHU (70AHU-12B) in completing the swap over from "Alpha"

Shortly thereafter, the NPO calls you in the Control Room and reports that 70AHU-12B has tripped. The NPO further reports that 70AHU-12A started from standby and appears to be functioning normally. After acknowledging the NPO, you should direct the NPO to...

- verify that the running Relay Room Exhaust Fan flow is at least 600 – 900 scfm higher than 70AHU-12A flow in accordance with OP-56 "Relay Room Ventilation and Cooling."
- swap the Control Room AHUs back to their previous configuration in accordance with OP-55B "Control Room Ventilation and Cooling" to limit partial loading of the chillers.
- reset the High Vibration Trip (commonly received on startup), re-start the "Bravo" Relay Room AHU (70AHU-12B), and secure the "Alpha" AHU in accordance with OP-56 "Relay Room Ventilation and Cooling."
- start the standby Control Room AHU (70AHU-3A), so that both Control Room AHUs are running; to expeditiously restore the positive pressure to the Control and Relay Rooms in accordance with AOP-73 "Loss of Main Control Room Boundary."

Proposed Answer: b.Explanation
(Optional):

- CORRECT:** A distinct NOTE is provided in both the Control and Relay Room HVAC procedures to run "Alpha" Control and Relay Room AHUs together and "Bravo" Control and Relay Room AHUs together to limit partial loading on the chill water refrigeration units, which could cause spurious trips of the chillers.
- Incorrect:** In the case of the Control and Relay Room Ventilation System lineups, the Exhaust Fans are set to run approximately 600 – 900 scfm **less** than the Supply Fans to maintain a positive pressure in these spaces. Other building ventilation systems do maintain higher exhaust flows.
- Incorrect:** A high vibration condition will not trip the AHUs. It is alarm and white indicating lamp only on ventilation fans.

- d. Incorrect: AOP-73 focuses on starting CREVAS and does not support the proposed corrective action detailed in this distracter.

Technical Reference(s): OP-55B (Attach if not previously provided)
OP-56

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-70, EO 1.06.a. & 1.13.b/c (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:
 Memory or Fundamental Knowledge
 Comprehension or Analysis

10 CFR Part 55 Content:
 55.41
 55.43

Comments:

Examination Outline Cross-reference:

(Page 23) G2.4.26

Knowledge of facility protection requirements including fire brigade and portable fire fighting equipment usage.

Level	RO	SRO
Tier #	3	---
Group #	---	---
K/A #	Cat 4 G2.4.26	
Importance Rating	2.9	---

Proposed Question: # 72

Given the following conditions:

- You are responding to an electrical fire as a member of the plant's fire brigade team.
- You have brought a Class B/C fire extinguisher to the scene.
- Other members have rigged a fire hose with a solid-stream nozzle.

Which one of the following actions should be taken?

- Do **NOT** use the Class B/C fire extinguisher. Put the fire out with the fire hose.
- Do **NOT** use the fire hose. Put the fire out with the Class B/C fire extinguisher.
- Use the fire hose first. If it does not put out the fire, use the Class B/C fire extinguisher.
- Wait for the fire brigade member assigned to bring a Class D fire extinguisher; then use the Class D fire extinguisher.

Proposed Answer: **b.**Explanation
(Optional):

- CORRECT** – SDLP-76 discusses the use of portable fire extinguishers and what types of fires that they are used on. It also discusses the fact that solid streams are not to be used to fight electrical fires.
- Incorrect – See above.
- Incorrect – See above.
- Incorrect – See above.

Technical Reference(s): SDLP-76 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-76, EO 1.05.a.13 (As available)

Question Source: Bank # 25691

Modified Bank #	
New	

(Note changes or attach parent)

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 8) 295029 High Suppression Pool Wtr Lvl EA1.01Ability to operate and/or monitor the following as they apply to
HIGH SUPPRESSION POOL WATER LEVEL:

- HPCI: Plant-Specific

Level

RO

SRO

Tier #

1

Group #

2

K/A #

295029 EA1.01

Importance Rating

3.4

Proposed Question: # 73

**** Attach copy of Tech Spec 3.6.2.2(NO BASES) ****

The plant is operating at 100% power. This morning, multiple runs of HPCI have been required to establish operability following maintenance on the turbine. The following plant conditions have existed during this time period:

- At 0745, Torus Water Level was monitored at 13.96 feet
- At 0800, Torus Water Level was monitored at 14.01 feet
- At 0830, Torus Water Level was monitored at 14.19 feet
- At 0900, Torus Water Level was monitored at 14.30 feet
- At 0930, Torus Water Level was monitored at 14.42 feet
- At 1000, Torus Water Level was monitored at 14.51 feet

At 1000, a report of which of the following is expected?

- That HPCI suction valves have automatically swapped to the Torus
- That the plant has to be in Mode 3, Hot Shutdown, by 2200 (10PM) tonight
- That RCIC and HPCI suction valves have automatically swapped to the Torus
- That we now must start physically logging Torus Water Level every 5 minutes

Proposed Answer: a.

Explanation
(Optional):

- CORRECT: HPCI suction valves automatically transfer from the CSTs to the Torus on High Torus Level of 14.5 feet per the ARP 09-3-3-5.
- Incorrect: Tech Spec LCO 3.6.2.2 has a Note that allows Torus Water Level to be outside the LCO for up to 4 hours
- Incorrect: HPCI suction valves automatically transfer from the CSTs to the Torus on High Torus Level of 14.5 feet per the ARP 09-3-3-5. RCIC suction valves do NOT have a High Torus Water Level auto-swap design feature.
- Incorrect: Tech Spec and AOP-36 requirements to monitor / log (respectively) Torus Water TEMPERATURE every 5 minutes, when Torus Water Temperature Recording is inoperable during evolutions which add heat to the Torus.

Technical Reference(s): OP-15 (Attach if not previously provided)
TS 3.6.2.2

Proposed references to be provided to applicants during examination: TS 3.6.2.2 (No Bases Necessary)

Learning Objective: SDLP-23, EO 1.05.a.2/b.1 & 1.06.e (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input checked="" type="checkbox"/>
Comprehension or Analysis	<input type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 5) 295031 Reactor Low Water Level EA2.02

Ability to determine and/or interpret the following as they apply to REACTOR LOW WATER LEVEL:

- Reactor power

Level	RO	SRO
Tier #	1	---
Group #	1	---
K/A #	295031 EA2.02	---
Importance Rating	4.0	---

Proposed Question: # 74

Following the trip of one (1) Recirculation Pump from 100% steady-state reactor power conditions, which of the following sets of indications would be expected without operator action?

	Reactor Power	INDICATED Reactor Vessel Water Level	Vessel Water Level INSIDE SHROUD
a.	Approximately 52%	Upward surge followed by return to normal band	Downward surge and stabilizes at lower level
b.	Approximately 52%	Upward surge with sustained high level	Upward surge with sustained high level
c.	Approximately 65%	Upward surge followed by return to normal band	Downward surge and stabilizes at lower level
d.	Approximately 65%	Upward surge with sustained high level	Upward surge with sustained high level

Proposed Answer: c

Explanation (Optional):

- c. CORRECT: Per AOP-8, trip of one Recirc Pump yields a power value of approximately 65%. Symptoms further dictate an upward surge in indicated level. Further tests theory of level effects inside shroud and the impact on power level. Increased core voiding displaces water inside shroud and drives power down.
- a. Incorrect: See above. 52% is the value for trip of both Recirc Pumps. Remainder is correct for conditions.
- b. Incorrect: See above. 52% wrong. Also, FWLC would act to restore indicated level. Water level inside shroud would not go up. Tests misconception on inside versus indicated level.
- d. Incorrect: Correct power, but FWLC would act to restore indicated level and water level inside shroud would not go up.

Examination Outline Cross-reference:

(Page 6) 600000 Plant Fire On Site G2.1.22

Ability to determine Mode of Operation.

Level	RO	SRO
Tier #	1	-----
Group #	1	-----
K/A #	600000 G2.1.22	-----
Importance Rating	2.8	-----

Proposed Question: # 75

A reactor startup is in progress, following a refuel outage, with the following plant conditions:

- IRMs on mid-scale on Range 7
- Average Reactor Coolant Temperature is currently 200° F and rising slowly

A Zone RB-1W (Reactor Building West Crescent) Fire Alarm is received. An NPO is quickly dispatched to the location and reports significant heat, smoke, and flames. All AOP-28, "Operation During Plant Fires" prompt operator actions are completed satisfactorily. Which of the following accurately reflects the plant's current "Mode of Operation"?

- Mode 2: Startup / Hot Standby
- Mode 3: Hot Shutdown
- Mode 4: Cold Shutdown
- Mode 5: Refueling

Proposed Answer: c.

Explanation
(Optional):

- CORRECT:** Initial conditions place the plant in Mode 2. With a confirmed fire in Zone RB-1W, a Reactor Scram would be inserted and AOP-1 will direct taking the Mode Switch to "Shutdown"; resulting in either Mode 3 or 4 operation. With resulting Average Reactor Coolant Temperature below 212° F, Mode 4 operation would result.
- Incorrect:** Plant in Mode 2 currently. If candidate fails to recognize AOP-28 Prompt Action Reactor Scram, this would be the resulting mode.
- Incorrect:** See above. With resulting Average Reactor Coolant Temperature below 212° F, Mode 3 operation would **NOT** result.
- Incorrect:** See above. Mode switch can be in "Shutdown" for Mode 5 if vessel head not fully tensioned. If candidate fails to recognize dependency on tensioning, this could be the resulting mode.

Technical Reference(s): AOP-28 (Attach if not previously provided)
ITS (Mode Definitions)

Proposed references to be provided to applicants during examination: None

Learning Objective: JLP-OPS-ITS02, EO 1.03 (As available)
LPAOP, EO 1.03

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

**(Page 4) 295026 Suppression Pool High Water Temp. / 5
G2.1.18**Ability to make accurate / clear and concise logs / records / status
boards / and reports.

Level

RO

SRO

Tier #

1

Group #

2

K/A #

295026 G2.1.18

Importance Rating

2.9

Proposed Question: # 76

During the performance of ST-22B, MANUAL SAFETY RELIEF VALVE OPERATION AND VALVE MONITORING SYSTEM FUNCTIONAL TEST, Torus water temperature has steadily risen to a value of 92°F when it is determined that the 16-1TR-131A (09-4 Torus Water Temperature Recorder) has become inoperable.

Which of the below is the required operator action?

- Secure the test until Torus water temperature is reduced to <85°F.
- Log Torus water temperature at 15 minute intervals.
- Secure the test if Torus temperature exceeds 95°F.
- Observe Torus water temperature at 5 minute intervals.

Proposed Answer: d.Explanation
(Optional):

- CORRECT:** Per T/S 3.6.2.1, Torus water temperature is limited to 105° during testing that adds heat to the Torus. SR 3.6.2.1.1 requires a 5 minute interval verification of Torus temperature within limitation during this testing
- Incorrect:** See Above.
- Incorrect:** Logging Torus water temperature at 5 minute intervals is an AOP-36 requirement if both 09-4 temperature recorders are inoperable. The conditions do not warrant entry to AOP-36 and 16-1TR-131B is still available.
- Incorrect:** 95° Torus water temperature is the EOP-4 entry condition and the T/S 3.6.2.1 limitation during normal operations which are not adding heat to the Torus. ST-22B and T/S 3.6.2.1 allow operation to 105° in the stem conditions provided.

Technical Reference(s): T/S 3.6.2.1 (Attach if not previously provided)
ST-22B

Proposed references to be provided to applicants during examination: None

Learning Objective: (As available)

Question Source:

Bank #	
Modified Bank #	

(Note changes or attach parent)

New

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 15) 262001 AC Electrical Distribution G2.4.27

Knowledge of fire in the plant procedure.

Level	RO	SRO
Tier #	2	-----
Group #	1	-----
K/A #	262001 G2.4.27	
Importance Rating	3.0	-----

Proposed Question: **# 77**

Which of the following operator actions would be consistent with AOP-28, Operation During Plant Fires actions for preventing a Multiple High Impedance Fault (MHIF) from occurring during a plant fire in a given area?

- Place individual component control switches for loads in the affected area in "Pull-To-Lock"
- Transfer safe shutdown loads to alternate components not located in the affected area
- Trip the individual load breakers for components / panels in the affected area
- Trip the L-Gear feeder breaker associated with loads in the affected area

Proposed Answer: **c.**Explanation
(Optional):

- CORRECT:** MHIF, per AOP-28 definition, is a low probability phenomenon whereby several fire induced faulted circuits cause sufficient amperage to trip the panel or MCC feeder breaker before any of the individual load breakers trip. This could result in a loss of power to the entire panel or MCC unless operator action is taken to shed the affected loads.
- Incorrect:** See above. Although this action would secure loads, it does not meet the prescribed manner of AOP-28.
- Incorrect:** See above. Although this action would secure loads, it does not meet the prescribed manner of AOP-28.
- Incorrect:** See above. Overly conservative approach that may de-energize necessary loads needlessly.

Technical Reference(s): AOP-28 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: LPAOP, EO 1.08 (As available)

Question Source:	Bank #	<input type="checkbox"/>	(Note changes or attach parent)
	Modified Bank #	<input type="checkbox"/>	

New

Question History:	Last NRC Exam	<input type="checkbox"/>
-------------------	----------------------	--------------------------

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: **Memory or Fundamental Knowledge**

Comprehension or Analysis

10 CFR Part 55 Content: **55.41**

55.43

Comments:

Examination Outline Cross-reference:

(Page 22) G2.2.29

Knowledge of SRO fuel handling responsibilities.

(10CFR 55.43.2/6)

Level

RO

SRO

Tier #

3

Group #

K/A #

Cat 2 G2.2.29

Importance Rating

3.8

Proposed Question: # 78

With the plant in Mode 5, a non-spiral, routine fuel shuffle is in progress and the following plant conditions exist:

- Source Range Monitor (SRM) "Bravo" is inoperable
- The next fuel bundle to be moved is designated for reactor cavity position 09-42. (A core map is provided for reference)
- The fuel bundle to be moved is currently located in the Spent Fuel Pool.
- As the fuel bundle in question is grappled, SRM "Delta" fails downscale and is declared inoperable
- All other SRMs are OPERABLE

As the Refuel Floor Senior Reactor Operator (SRO), which of the following actions regarding the next fuel bundle move should you perform, including the bases for this action?

- a. Suspend the fuel bundle move; it cannot be completed since the SRM in the adjacent core quadrant is inoperable.
- b. Continue the fuel bundle move; it can be completed since the SRM in the adjacent core quadrant is OPERABLE.
- c. Suspend the fuel bundle move; it cannot be completed since the SRM in the affected core quadrant is inoperable.
- d. Continue the fuel bundle move; it can be completed since the SRM in the affected core quadrant is OPERABLE.

Proposed Answer: a.

Explanation
(Optional):

- a. CORRECT: Per TS Table 3.3.1.2 (and Bases), in non-spiral routine operations, two SRMs are required to be operable; one in the quadrant where the CORE ALTERATION is taking place and one in an adjacent quadrant containing fuel. SRM "B" and "D" are the adjacent quadrants to the stem designated cavity position. Once SRM "D" fails, CORE ALTERATIONS must be suspended immediately.
- b. Incorrect: See above. Can't continue with both adjacent SRMs inop
- c. Incorrect: See above. SRM not inop in "affected" core quadrant
- d. Incorrect: See above.

Technical Reference(s): TS 3.3.1.2 (and Bases) (Attach if not previously provided)
RAP-7.1.04B

Proposed references to be provided to applicants during examination: SDLP-07B, Figure 2

Learning Objective: SDLP-08A, EO 1.10.a (As available)
SDLP-07B, EO 1.16, 1.17, 1.18, and Figure 2

Question Source:

Bank #	
Modified Bank #	22024 (attached)

 (Note changes or attach parent)

Question History:

New	
Last NRC Exam	

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input type="checkbox"/>
55.43	<input checked="" type="checkbox"/>

Comments:

PLANT
Perry 1

ExamDate
3/1/2002

ExamType
ILO

QuestionId
22024

NSSSType
BWR

Question The following plant conditions exist:

CORE ALTERATIONS are in progress.
The next fuel bundle move is designated for reactor cavity position 09-42.
The fuel bundle is currently in the Containment Fuel Pool Storage area.
Source Range Monitor (SRM) Channel 'A' fails and is declared inoperable.
All other SRMs are OPERABLE.

A reactor core map is provided for reference.

As the Refueling Supervisor, which one of the following actions regarding the next fuel bundle move should you perform, including the bases for this action?

Answer Suspend the fuel bundle move; it cannot be completed since the SRM in the affected core quadrant is inoperable.

Distractor 1 Continue the fuel bundle move; it can be completed since the SRM in the adjacent core quadrant is OPERABLE.

Distractor 2 Suspend the fuel bundle move; it cannot be completed since the SRM in the adjacent core quadrant is inoperable.

Distractor 3 Continue the fuel bundle move; it can be completed since the SRM in the affected core quadrant is OPERABLE.

RefMaterial

QuestionComment

Distract1 Comment

Distract2 Comment

Distract3 Comment

<i>KaNumber</i>	<i>KaSegment1</i>	<i>KaSegment2</i>	<i>KaSegment3</i>	<i>KaSegment4</i>	<i>KaSegment5</i>
2229			2	2	29
<i>KaRevision</i>				<i>CognitiveLevel</i>	<i>ExamLevel</i>
				3	5

Examination Outline Cross-reference:

(Page 5) 295030 Low Suppression Pool Wtr Lvl / 5 EA1.06

Ability to operate and/or monitor the following as they apply to LOW SUPPRESSION POOL WATER LEVEL:

- Condensate storage and transfer (make-up to the suppression pool): Plant-Specific

Level

RO

SRO

Tier #

1

Group #

1

K/A #

295030 EA 1.06

Importance Rating

3.4

Proposed Question: # 79

While operating the RCIC system in the Full Flow Test Mode per ST-24J, RCIC FLOW RATE AND IN-SERVICE TEST, an I/C test results in simultaneous full opening of both RCIC Torus Suction Valves, 13MOV-39 and 41.

Which of the below describes the expected system response?

- The RCIC CST Suction valve (13MOV-18) and Full Flow Test valve (13MOV-30) will both close. RCIC will continue to operate on minimum flow only.
- The HPCI Full Flow Test CST Return valve (23MOV-24) opens. RCIC continues to operate with return to the CST via HPCI.
- The RCIC CST Suction valve (13MOV-18) closes. RCIC continues to operate in Full Flow Test.
- No additional changes. RCIC continues to operate in Full Flow Test.

Proposed Answer: a.

Explanation
(Optional):

- CORRECT: Either torus suction valve opening will close the full flow test valve to prevent pumping the torus water volume to the CST. When both torus suction are full open, the CST suction will close thus maintaining RCIC suction during the transfer. The net result is RCIC continues to operate with the full flow test path isolated resulting in min flow valve opening.
- Incorrect: Although this flowpath is used for RCIC testing, there are no automatic openings to the HPCI full flow test return to the CST and this valve is in series with the RCIC full flow test valve which closes.
- Incorrect: See Above.
- Incorrect: See Above.

Technical Reference(s): ST-24J (Attach if not previously provided)
ARP 09-4-0-28

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-13, EO-1.06.b, d, 1.12.d, and 1.14.b (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 22) G2.2.24

Ability to analyze the affect of maintenance activities on LCO status.

Level

RO

SRO

Tier #

3

Group #

K/A #

Cat 2 G2.2.24

Importance Rating

2.8

Proposed Question: # 80

The Plant is operating at 100% power steady state with HPCI tagged out for maintenance. You are currently in day three (3) of the Technical Specification Required Actions / Completion Times associated with the HPCI LCO. The SNO is performing a surveillance test to demonstrate RCIC operability and reports that the Barometric Compressor Vacuum Pump, (13P-3), will not start.

Which of the below describes appropriate action and the impact on Technical Specifications?

- Dispatch NPO to check breaker status on BMCC-1/3. No change in LCO.
- Dispatch NPO to check breaker status on BMCC-2/4. No change in LCO.
- Dispatch NPO to check breaker status on BMCC-2/4. LCO is more restrictive.
- Dispatch NPO to check breaker status on BMCC-1/3. LCO is more restrictive.

Proposed Answer: d.

Explanation
(Optional):

- CORRECT – Tests the recognition of "Alpha" DC to RCIC, whereas "Bravo" DC powers HPCI. Additionally, with HPCI inop, RCIC must be operable. With the operability of RCIC called into question on the failure to start of the vacuum pump, action must be taken immediately to determine / verify RCIC status.
- Incorrect – See above.
- Incorrect – See above.
- Incorrect – See above.

Technical Reference(s): OP-19 (Attach if not previously provided)
OP-43A

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-13, EO 1.04.a & 1.16 (As available)
SDLP-23, EO 1.16

Question Source: Bank # 25649
Modified Bank # [REDACTED] (Note changes or attach parent)
New [REDACTED]

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments: *This question was an SRO-Level question on the previous exam and is being used as an RO-Level question on this exam.*

Examination Outline Cross-reference:

(Page 14) 239002 SRVs G2.1.11

Knowledge of less than one hour technical specification action statements for systems.

(10CFR 55.43.2)

Level

RO

SRO

Tier #

2

Group #

1

K/A #

239002 G2.1.11

Importance Rating

3.8

Proposed Question: # 81

The plant is currently operating steady state at 20% CTP after startup from a refueling outage. During the performance of ST-22B, Safety Relief Valve Testing, the following events occur:

- At 1945: SRV "Foxtrot" fails to open
- At 2030: SRV "Golf" fails to open
- At 2200: SRV "Hotel" fails to open
- At 2205: SRV Testing is secured to troubleshoot
- At 2240: Annunciator 09-3-3-36, HPCI VLV OR MTR OVERLOAD OR CNTRL POWER LOSS, is received. Investigation reveals that the power supply breaker to 23MOV-16, HPCI Outboard Steam Supply Isolation, is tripped and charred.

Which of the following Technical Specification actions are required for the above conditions?

- a. Enter LCO 3.4.3 Condition "Alpha" at 2030

Enter LCO 3.5.1 Condition "Charlie" at 2240 and immediately direct that ST-24A RCIC Monthly Operability Test be performed

- b. Enter LCO 3.5.1 Condition "Echo" at 2030

Enter LCO 3.4.3 Condition "Alpha" at 2200 and immediately exit LCO 3.5.1 Condition "Echo" upon entry into LCO 3.5.1 Condition "Golf" at 2200

- c. Enter LCO 3.5.1 Condition "Echo" at 2200

Enter LCO 3.4.3 Condition "Alpha" at 2200

Enter LCO 3.5.1 Condition "Hotel" at 2240 and immediately direct the Reactor Operator to insert cram groups to reduce power below 5% and take the Mode Switch to "Startup/Hot Standby"

- d. Enter LCO 3.4.3 Condition "Alpha" at 2200

Enter LCO 3.5.1 Condition "Echo" at 2200

Enter LCO 3.5.1 Conditions "Charlie" and "Hotel" at 2240, and immediately verify RCIC operability by administrative means in addition to initiating actions for a reactor shutdown

Proposed Answer: d.

Explanation
(Optional):

- d. CORRECT: ADS SRVs are A, B, C, D, E, G, and H. Non-ADS SRVs are F, K, L, J. Candidate must first know this to answer the question. 9 of 11 SRVs required by LCO 3.4.3 and 6 of 7 ADS SRVs required by LCO 3.5.1. By 2030, two SRVs (one ADS) are inop. No T.S. entry required until the third SRV (second ADS) is inop. At 2200, both LCO 3.4.3 and 3.5.1 respective conditions (A & E) would be entered. With the subsequent HPCI inop at 2240, both conditions (C & H) would be entered, which entail two separate "Immediate" actions, including LCO 3.03. Both would need to be accomplished. Per LCO-3.0.3 bases, immediate entry results in actions commenced within 1 hour to prepare for an orderly shutdown to meet the applicable mode requirement(s).
- a. Incorrect: At time 2030, conditions are such that the minimum number of SRV and ADS (6 and 9 respectively) valve remain operable so no LCO yet applies. At 2040, 3.5.1 condition "C" is applicable but actual run to demonstrate RCIC operable is not required.
- b. Incorrect: At time 2030, conditions are such that the minimum number of SRV and ADS (6 and 9 respectively) valve remain operable so no LCO yet applies. Additionally, per LCO 3.0.2, all applicable LCO's are entered and the required actions accomplished until the LCO is met or no longer applicable. LCO 3.5.1 condition E remains applicable and is not exited.
- c. Incorrect: The 2200 LCO entries are correct. Per LCO-3.0.3 bases, immediate entry results in actions commenced within 1 hour to prepare for an orderly shutdown to meet the applicable mode requirement(s).

Technical Reference(s): T.S. 3.4.3 and 3.5.1 (and Bases) (Attach if not previously provided)

Proposed references to be provided to applicants during examination: T.S. 3.4.3 / 3.5.1

Learning Objective: SDLP-29, EO 1.16, 1.17.d. & 1.18.d (As available)
SDLP-23, EO 1.16, 1.17.a. & 1.18.a

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:
 Memory or Fundamental Knowledge
 Comprehension or Analysis

10 CFR Part 55 Content:
 55.41
 55.43

Comments:

Examination Outline Cross-reference:

(Page 5) 295037 SCRAM Condition Present and Power Above APRM Downscale or Unknown EK3.01

Knowledge of the reasons for the following responses as they apply to SCRAM CONDITION PRESENT AND REACTOR POWER ABOVE APRM DOWNSCALE OR UNKNOWN:

- Recirculation pump trip/runback: Plant-Specific

Level

RO

SRO

Tier #

1

Group #

1

K/A #

295037 EK3.01

Importance Rating

4.1

Proposed Question: # 82

Which of the following is the basis for the ATWS Trip of the Recirculation Pumps?

Tripping the Recirculation Pumps...

- causes indicated reactor level to go down resulting in a rapid power reduction.
- adds negative reactivity quickly by increasing core inlet subcooling.
- minimizes the potential of experiencing thermal-hydraulic instabilities.
- adds negative reactivity quickly due to a large rise in core void fraction.

Proposed Answer: d.

Explanation
(Optional):

- CORRECT – Per TS Bases 3.3.4.1, on ATWS RPT Instrumentation, tripping of the Recirculation Pumps adds negative reactivity from the increase in steam voiding in the core area as the core flow decreases.
- Incorrect – not the basis.
- Incorrect – not the basis.
- Incorrect – not the basis.

Technical Reference(s): TS Bases 3.3.4.1 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-02H, EO 1.07.a & 1.17.c (As available)

Question Source: Bank # 23563 (Columbia Generating Station 2 3/27/03)

Modified Bank #		(Note changes or attach parent)
New		
Last NRC Exam		

Question History:

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 14) 223002 PCIS/Nuclear Steam Supply Shutoff A2.04

Ability to (a) predict the impacts of the following on the PRIMARY CONTAINMENT ISOLATION SYSTEM /NUCLEAR STEAM SUPPLY SHUT-OFF; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:

- Process radiation monitoring system failures

(10CFR 55.43.2/5)

Level	RO	SRO
Tier #	---	2
Group #	---	1
K/A #	223002	A2.04
Importance Rating	---	3.2

Proposed Question: # 83

The plant is operating normally at 100% CTP when the following annunciators are received simultaneously:

- 09-4-0-4, CONT HI RANGE RAD MON B FAIL OR POWER LOSS
- 09-4-0-5, CONT HI RANGE RAD MON B ALERT
- 09-4-0-6, CONT HI RANGE RAD MON B HI-HI

At the 09-10 Panel:

- 17RM-104A, Containment Hi Range Rad Monitor "Alpha", reads 9R/HR
- 17RM-104B, Containment Hi Range Rad Monitor "Bravo", indicates UPSCALE.

Which of the following describe the appropriate operator action?

- Swap the "A" H2/O2 (Exosensor) analyzer to drywell sampling per OP-37, Containment Atmosphere Dilution System. A daily swap to Torus is required to obtain Torus values.
- Due to the inability to maintain drywell to Torus d/p, primary containment must be immediately declared inoperable. Perform AOP-9, Loss of Primary Containment Integrity.
- A Containment Vent and Purge partial isolation requires swapping containment vent and purge control to the "A" CAD Train per OP-37, Containment Atmosphere Dilution System.
- Due to the inability to maintain drywell to Torus d/p, 27RM-104B must be returned to service and the isolation reset per AOP-15, Isolation Verification and Recovery.

Proposed Answer: d.

Explanation (Optional):

- CORRECT:** This instrument only effects the containment vent and purge functions and will isolate one valve in each penetration pathway. Eventually, drywell to torus d/p will drift to <1.7 psid unless the instrument is restored and the Isolation reset to allow d/p maintenance.
- Incorrect:** The PCIS arrangement of the exosensors will result in a single analyzer fully isolated on appropriate rad monitor isolation signals resulting in the need to swap the remaining analyzer between sample points. The Containment Hi Range Rad Monitors DO NOT isolate the exosensors.

- b. Incorrect: TS 3.6.2.4 does not require declaring primary containment inoperable much less immediately nor will d/p be lost very rapidly. The spec provides 8 hours to restore.
- c. Incorrect: As described above, the vent and purge function is fully isolated. Unlike the exosensors, this function does not remain on the "A" division after an isolation of the "B" division.

Technical Reference(s): ARP-09-4-0-4/6 (Attach if not previously provided)
AOP-15

Proposed references to be provided to applicants during examination: TS 3.6.2.4

Learning Objective: SDLP-17 EO-1.05.c.2 (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: **Memory or Fundamental Knowledge**
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 7) 295007 High Reactor Pressure AK1.01

Knowledge of the operational implications of the following concepts as they apply to HIGH REACTOR PRESSURE:

- Pump shutoff head

Level	RO	SRO
Tier #	1	_____
Group #	2	_____
K/A #	295007 AK1.01	_____
Importance Rating	2.9	_____

Proposed Question: # 84

The Core Spray System has automatically initiated on Low Reactor Vessel Water Level.

The Core Spray Injection Valve opens when reactor pressure drops below _____.

When the injection valve opens, RPV Injection _____ immediately.

- 310 psig ; occurs
- 310 psig ; does **NOT** occur
- 450 psig ; occurs
- 450 psig ; does **NOT** occur

Proposed Answer: **d.**Explanation
(Optional):

- CORRECT** – Per TS 3.3.5.1.c, Core Spray Injection Permissive Allowable value is between 410 psig and 490 psig. Actual RPV injection occurs at approximately 200 psig (RPV). Until such time as this pressure is reached (lowering), the pump will run at shutoff head in relation to injecting to the RPV.
- Incorrect – See above, incorrect pressure. Teamed with additional incorrect response.
- Incorrect – See above, incorrect pressure. Teamed with correct response if that were correct permissive.
- Incorrect – See above, correct pressure. Reactor pressure still too high to actually inject and will not actually inject until well below 300 psig.

Technical Reference(s): OP-14 (Attach if not previously provided)
TS 3.3.5.1.c (and Bases)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-14, EO 1.05.a.6/b.1/c.4 & 1.07.b (As available)

Question Source: Bank # 25620
Modified Bank # [Redacted] (Note changes or attach parent)
New [Redacted]

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 21) 290001 Secondary CTMT A2.01

Ability to (a) predict the impacts of the following on the SECONDARY CONTAINMENT; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations:

- Personnel airlock failure

Level	RO	SRO
Tier #	2	-----
Group #	2	-----
K/A #	290001 A2.01	-----
Importance Rating	3.3	-----

Proposed Question: # 85

The plant is operating normally at full power. A Spent Fuel Cask is being moved out of the reactor building. While the reactor building track bay outer doors were open, a power supply failure de-energized the track bay door control system.

Which one of the below describes the required operator action(s).

- Declare Secondary Containment inoperable. Per TS 3.6.4.1, restore secondary containment within 4 hours.
- Restrict track bay access via the inner doors. Per OP-73, Miscellaneous Plant Equipment, dispatch a NPO to manually close the outer doors.
- Consider Secondary Containment degraded. Per OP-51A, Reactor Building Ventilation and Cooling System, isolate reactor building ventilation.
- Declare the Secondary Containment Penetration inoperable. Per TS 3.6.4.2, deactivate the inner doors in the closed condition within 8 hours.

Proposed Answer: b.

Explanation
(Optional):

- CORRECT:** As long as the inner set or the outer set is closed and sealed, Secondary Containment continues to be operable. The pneumatic seal solenoid is fail safe to maintain the seal pressurized. OP-73 contains actions to operate the doors in the stem described condition.
- Incorrect: See Above.
- Incorrect: Although secondary containment is degraded, it is still intact and operable. Isolating reactor building ventilation is not a required action for this condition.
- Incorrect: See Above. This penetration is not inoperable. The referenced T/S is for Secondary Containment Isolation Valves, not penetrations.

Technical Reference(s): OP-73 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: TS 3.6.4.1, 3.6.4.2

Learning Objective: SDLP-16A EO-1.05.a.9 (As available)

Question Source:

Bank #	
Modified Bank #	

 (Note changes or attach parent)

New

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 22) G2.2.13 **Plant OE**

Knowledge of tagging and clearance procedures.

(10CFR 55.43.5)

Level

RO

SRO

Tier #

3

Group #

K/A #

Cat 2 G2.2.13

Importance Rating

3.8

Proposed Question: # 86

A maintenance activity to adjust belt tension on a ventilation fan will require several starts and stops with adjustments while the fan is off. Which of the below personnel protection measures is intended to support this type of activity?

- Per AP-12.06, Equipment Status Control, Caution Tags will be hung on the fan control switch and breaker stating that the fan will be started and stopped as directed by the responsible maintenance individual only.
- Per EN-OP-102, Protective and Caution Tagging, during adjustment, the fan breaker will be Danger Tagged in the off position. The tag will be cleared to support fan running and a new tag hung if further adjustment is needed.
- Per EN-OP-102, Protective and Caution Tagging, during adjustment, the fan breaker will be locked open with a Test and Maintenance Tag in place. Without tag removal, it may be unlocked for fan running and relocked if further adjustment is needed.
- Per AP-12.06, Equipment Status Control, No tagging is required if a Safety Observer is stationed at the fan breaker. This individual's sole responsibility is to operate the breaker as instructed by the responsible maintenance individual.

Proposed Answer: c.

Explanation
(Optional):

- CORRECT:** The Test and Maintenance tag was developed exclusively for this type of situation as described in EN-OP-102, Attachment 9.1 and General Requirement 5.2 [1] with additional support provided in AP-12.06 Section 8.16
- Incorrect:** EN-OP-102 specifically states that Caution Tags will not be used in place of Danger Tags (Caution Tags shall not be used for personnel protection).
- Incorrect:** Although Danger Tags are an acceptable method of providing personnel protection in this event, they are not the intended method.
- Incorrect:** ENN and JAF have no provision for the use of human danger tags.

Technical Reference(s): EN-OP-102 (Attach if not previously provided)
AP-12.06

Proposed references to be provided to applicants during examination: None

Learning Objective: LP-AP EO-44.03, 44.11 (As available)

Question Source:

Bank #	
Modified Bank #	

(Note changes or attach parent)

New

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content:

55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 15) 262002 UPS (AC/DC) A4.01

Ability to manually operate and/or monitor in the control room:

- Transfer from alternative source to preferred source

Level	RO	SRO
Tier #	2	---
Group #	1	---
K/A #	262002 A4.01	---
Importance Rating	2.8	---

Proposed Question: # 87

SEE ATTACHED...

Given the above **"BEFORE"** and **"AFTER"** Alarm Panel indications, determine which of the following events could result in the above change in alarm conditions:

- A loss of UPS AC Drive has occurred resulting in a UPS auto-swap to DC Drive
- UPS is in the process of being returned to AC Drive and is currently on DC Drive for synchronization
- A loss of AC Drive to UPS has occurred and operator action has been taken to swap to backup DC power
- A fault has occurred in the Alternate AC feed to UPS resulting in a UPS auto-swap to its DC power supply

Proposed Answer: **b.**Explanation
(Optional):

- Correct: In the "Before" picture above, UPS is already on the Alternate AC Feed due to a low voltage condition on the DC Drive. In the "After" sequence, and minus additional alarms, the "UPS ON DC DRIVE" indicates that the MG Set is in the process of being restored and is on the DC Drive solely for the purpose of synchronization prior to swapping back to the normal AC Drive.
- Incorrect: Taking the "Before" alarm sequence into account, the MG set AC and DC Drives had been lost and the Alternate AC Feed was supplying loads.
- Incorrect: Taking the "Before" alarm sequence into account, the MG set AC and DC Drives had been lost and the Alternate AC Feed was supplying loads. Additionally, if AC Drive had been lost, no operator action would be necessary, as there is an auto-swap to DC Drive.
- Incorrect: There is no auto-swap feature from Alternate AC Feed to DC Drive.

Technical Reference(s): OP-46B (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-71F, EO 1.05.c & 1.13 (As available)

Question Source:	Bank #	<input type="checkbox"/>	(Note changes or attach parent)
	Modified Bank #	<input type="checkbox"/>	

New

Question History:	Last NRC Exam	<input type="checkbox"/>
-------------------	----------------------	--------------------------

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: **Memory or Fundamental Knowledge**

Comprehension or Analysis

10 CFR Part 55 Content: **55.41**

55.43

Comments:

Examination Outline Cross-reference:

(Page 14) 259002 Reactor Water Level Control A4.02
****Recent Plant Modification****

Ability to manually operate and/or monitor in the control room:

- All individual component controllers in the automatic mode

Level

RO

SRO

Tier #

2

Group #

1

K/A #

259002 A4.02

Importance Rating

3.7

Proposed Question: # 88

The reactor is operating steady-state 100% power when Annunciator 09-5-1-28 "RX WATER LVL ALARM HI OR LO" alarms. As you observe, reactor water level continues to trend downward until level steadies out at +189 inches. Which of the following impacts on Feedwater Level Control is the probable cause?

- Input from one steam flow signal transmitter has been lost
- Inadvertent sustained opening of one Safety Relief Valve (SRV)
- Input from a single feedwater flow signal transmitter has been lost
- Inadvertent High Pressure Coolant Injection System (HPCI) initiation

Proposed Answer: a.

Explanation
(Optional):

- CORRECT:** Loss of one steam flow transmitter causes indicated steam flow to drop below feed flow. Actual feed flow decrease to compensate. Since actual steam flow remains at the original rate, an actual mismatch occurs and level drops. A developed level error signal slows the transient, and steady-state is restored when level error exactly compensates for the reduction in indicated steam flow. This requires 12 – 15 inches and final actual level ends up at approximately 190 inches.
- Incorrect:** One SRV yields approximately 8% steam flow and therefore, an 8% mismatch. System anticipates a level transient and biases sensed level to appear 5 inches high (8% of 60). System stabilizes with level 5 inches lower than level set. You would get alarm, but not additional level drop.
- Incorrect:** System sees a 50% mismatch, anticipates transient, and biases level to appear 24-30 inches low. RFP's speed up and level increases to the RFPT and Main Turbine/Reactor Scram setpoints before stabilized.
- Incorrect:** Approximate 3% Steam Flow and 20% Feed Flow. Result is approximate 16% mismatch. System anticipates and biases level to appear 10 inches low. System stabilizes with level 10 inches higher than level set.

Technical Reference(s): AOP-41/42 (Attach if not previously provided)
SDLP-06

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-06, EO 1.08.b & 1.10.e (As available)

Question Source:

Bank #	
Modified Bank #	
New	<input checked="" type="checkbox"/>

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 16) 263000 DC Electrical Distribution A3.01

Ability to monitor automatic operations of the D.C. ELECTRICAL DISTRIBUTION including:

- * Meters, dials, recorders, alarms, and indicating lights

Level	RO	SRO
Tier #	2	---
Group #	1	---
K/A #	263000 A3.01	---
Importance Rating	3.2	---

Proposed Question: # 89

With normal full-power loading on the system, 125 VDC Battery Bus Voltage (as read on the 09-8 Panel) should be approximately _____; and, in the event that AC input is lost to the "Alpha" 125 VDC Battery Charger, the same 125 VDC BATT BUS A meter would

- 132 VDC; steadily lower to approximately 118 VDC resulting in annunciator 09-8-1-20 "125 VDC BATT A VOLT LO" several minutes later.
- 132 VDC; promptly lower slightly to approximately 128 VDC resulting in annunciator 09-8-1-19 "125 VDC BATT CHGR A AC SUPP TROUBLE" immediately.
- 125 VDC; remain constant at approximately 125 VDC resulting in annunciator 09-8-1-19 "125 VDC BATT CHGR A AC SUPP TROUBLE" several minutes later.
- 125 VDC; promptly lower slightly to approximately 122 VDC resulting in annunciator 09-8-1-20 "125 VDC BATT A VOLT LO" immediately.

Proposed Answer: a.

Explanation
(Optional):

- CORRECT:** Per OP-43A, Section E, normal float voltage verified by operators shiftly to be 131 – 133 VDC. SDLP-71B specifically mentions the 118 VDC value on loss of charger. ARP 09-8-1-19/20 discuss the two alarms noted above with a specific note in 19 (AC SUPP TROUBLE), which does come in immediately; to expect 20 (BATT A VOLT LO) in approximately 3 minutes on loss of AC input.
- Incorrect:** See above. Correct initial VDC; Wrong Drop; Correct alarm but wrong input.
- Incorrect:** See above. Wrong initial VDC; Wrong response; Wrong alarm in response to timeframe.
- Incorrect:** See above. Wrong initial VDC; Wrong Drop; Wrong alarm in response to timeframe.

Technical Reference(s): OP-43A (Attach if not previously provided)
ARP 09-8-1-19/20

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-71B, EO 1.05 a.1, 1.06 a, & 1.10 a.1 (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:
Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content:
55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 16) 300000 Instrument Air K2.01

Knowledge of electrical power supplies to the following:

- Instrument air compressor

Level

RO

SRO

Tier #

2

Group #

1

K/A #

300000 K2.01

Importance Rating

2.8

Proposed Question: # 90

The 10300 Bus has been lost. L-13 and L-23 have been re-energized. How many Air Compressors are available?

- None
- One
- Two
- Three

Proposed Answer: c.Explanation
(Optional):

- CORRECT:** Per OP-39, Air compressor power supplies as follows: 39AC-2A / L-23; 39AC-2B / L-24; 39AC-2C / L-33. L-33 has been lost and is yet to be cross-connected; therefore 39AC-2C is unavailable, leaving two (2) available compressors.
- Incorrect: see above.
- Incorrect: see above.
- Incorrect: see above.

Technical Reference(s): OP-39 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-39, EO 1.03.a (As available)

Question Source:	<u>Bank #</u>	<u>[Redacted]</u>	(Note changes or attach parent)
	<u>Modified Bank #</u>	<u>[Redacted]</u>	

New

Question History:	<u>Last NRC Exam</u>	<u>[Redacted]</u>
-------------------	----------------------	-------------------

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 7) 295012 High Drywell Temperature AK2.02

Knowledge of the interrelations between HIGH DRYWELL TEMPERATURE and the following:

- Drywell cooling

Level	RO	SRO
Tier #	1	---
Group #	2	---
K/A #	295012 AK2.02	---
Importance Rating	3.6	---

Proposed Question: # 91

Two hours into your shift, you notice that Torus Water Level has risen from 13.91 feet to 13.94 feet while Drywell to Torus Differential Pressure has risen from 1.75 psid to 1.80 psid and Torus pressure has remained constant at 0.0 psig. You have confirmed the indications on EPIC LOG 1.

Which of the following is an appropriate action for these conditions?

- Per OP-37 "Containment Atmosphere Dilution System", vent the Drywell to return differential pressure to normal band.
- Per OP-40 "Reactor Building Closed Loop Cooling", raise Service Water flow(s) to in-service RBCLC Heat Exchangers.
- Enter AOP-9 "Loss of Primary Containment Integrity" and dispatch Operators to search for Primary Containment leakage.
- Enter EOP-4 "Primary Containment Control" and immediately dispatch Operators to drain water from the Torus to restore level to normal band.

Proposed Answer: b.

Explanation
(Optional):

- CORRECT:** Stem conditions are symptomatic of a rise in RBCLC temperature. A leak in Primary Containment would cause the reverse of provided stem indications based on a leak from the Torus.
- Incorrect:** See above. Per OP-37, the stem indications of parameters on Drywell to Torus D/P are within the normal band. Additionally, any venting would be from the Torus versus the Drywell.
- Incorrect:** See above. Related symptoms do not exist for entry into AOP-9. For example, Drywell to Torus D/P **lowering** is a symptom for AOP-9 entry and stem conditions have it rising.
- Incorrect:** See above. EOP-4 entry conditions of 13.88 feet or 2.7 psig Drywell Pressure do not exist. Therefore, EOP-4 entry is not warranted.

Technical Reference(s): OP-40 (Attach if not previously provided)

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-15, EO 1.05.a.2, 1.09.b, 1.10.a, & 1.13.c (As available)

Question Source:	<u>Bank #</u>	<u>[Redacted]</u>	
	<u>Modified Bank #</u>	<u>25628 (attached)</u>	(Note changes or attach parent)

	<u>New</u>	<u>[Redacted]</u>	
Question History:	<u>Last NRC Exam</u>	<u>[Redacted]</u>	

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

PLANT
FitzPatrick 1

ExamDate
7/1/2003

ExamType
ILO

QuestionId
25628

NSSSType
BWR

Question Two hours into the shift, the SNO reports that Torus water level has dropped from 14.0 ft to 13.91 ft while Drywell to Torus ?P has dropped from 1.8 psid to 1.6 psid and Torus pressure has remained constant at 0.0 psig. You have confirmed the indications on EPIC-LOG1.
Your required actions are.

Answer Enter AOP-9, Loss of Primary Containment Integrity, and dispatch Operators to search for Primary Containment leakage.

Distractor 1 Enter EOP-4, Primary Containment Control, and immediately makeup nitrogen to the Drywell restore ?P.

Distractor 2 Enter EOP-4, Primary Containment Control, and immediately makeup water to the Torus to restore Torus level.

Distractor 3 Enter AOP-9, Loss of Primary Containment Integrity, and dispatch Operators to determine why RBCLC temperature has risen.

RefMaterial

QuestionComment *EOP-4 Entry conditions of 13.88 ft or 2.7 psig DW pressure do not exist, therefore EOP-4 Entry is not required.
*Adequate AOP-9 symptoms do exist warranting entry.
*The stem conditions are symptomatic of Primary Containment leakage. A RBCLC temperature rise will cause the reverse of the indications based on higher DW temperatures caused by less heat removal by the DW cooling units.

Distract1Comment

Distract2Comment

Distract3Comment

<i>KaNumber</i>	<i>KaSegment1</i>	<i>KaSegment2</i>	<i>KaSegment3</i>	<i>KaSegment4</i>	<i>KaSegment5</i>
295030 EA2 D4			295030	EA2	D4
<i>KaRevision</i>				<i>CognitiveLevel</i>	<i>ExamLevel</i>
				2	S

Examination Outline Cross-reference:

(Page 8) 295015 Incomplete SCRAM/1 G2.4.20

Knowledge of operational implications of EOP warnings / cautions / and notes.

Level

RO

SRO

Tier #

1

Group #

2

K/A #

295015 G2.4.20

Importance Rating

3.3

Proposed Question: # 92

A Feedwater transient has resulted in a Reactor Scram on Low Reactor Water Level. The following plant conditions result:

- RPV Water Level is currently stable at 140 inches
- Rod 26-27 remains at position 06 in the core
- Rod 34-35 stops at position 04 in the core
- Rod 18-35 position indication is lost during the scram
- All Intermediate Range Monitors (IRMs) are on Range 6 and trending down slowly

Which of the following must be accomplished?

- a. Use AOP-1 to insert Control Rods and *rapidly* restore Reactor Water Level to 177 – 222.5 inches.
- b. Use AOP-1 to insert Control Rods and *slowly* restore Reactor Water Level to 177 - 222.5 inches.
- c. Use EP-3 to insert Control Rods and *rapidly* restore Reactor Water Level to 177 – 222.5 inches.
- d. Use EP-3 to insert Control Rods and *slowly* restore Reactor Water Level to 177 – 222.5 inches.

Proposed Answer: d.

Explanation
(Optional):

- d. CORRECT: Scram gets you into AOP-1. Reactor Water Level less than scram setpoint is EOP-2 entry. With rods out and shutdown not assured without Boron, EOP-3 entry, and thus EP-3, is warranted. Further tests EOP-3 Caution on rapid level changes to prevent subsequent power excursions.
- a. Incorrect: See above. **EOP-2 entry** condition would take precedence and drive you to EOP-3 actions. Also, "**rapidly**" would be wrong.
- b. Incorrect: See above. Other than "**AOP-1**" portion of distracter, the remainder is correct.
- c. Incorrect: See above. Correct with exception of "**rapidly**".

Technical Reference(s): AOP-1 (Attach if not previously provided)
EOP-2 / EOP-3

Proposed references to be provided to applicants during examination: None

Learning Objective: MIT-301.11C, EO 1.02 & 1.03 (As available)
MIT-301.11D, EO 1.02 & 1.05

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 5) 295028 High Drywell Temperature /5 EK3.04

Knowledge of the reasons for the following responses as they apply to HIGH DRYWELL TEMPERATURE:

- Increased drywell cooling

Level

RO

SRO

Tier #

1

Group #

1

K/A #

295028 EK3.04

Importance Rating

3.6

Proposed Question: # 93

A Design Basis Loss of Coolant Accident has occurred. In focusing on the Drywell Temperature leg of EOP-4 "Primary Containment Control", which of the following must be accomplished, and why?

- In accordance with "Operate all available drywell cooling", start the fourth fan for each Drywell Unit Cooler to maximize the convective cooling provided by the operating unit coolers.
- In accordance with "Operate all available drywell cooling", start the fourth fan for each Drywell Unit Cooler to maximize the evaporative and convective cooling provided by the operating unit coolers.
- In accordance with "BEFORE Drywell temperature reaches 309° F", initiate Drywell Sprays because convective cooling far surpasses evaporative cooling in providing rapid pressure / temperature reductions.
- In accordance with "BEFORE Drywell temperature reaches 309° F", initiate Drywell Sprays because evaporative cooling far surpasses convective cooling in providing rapid pressure / temperature reductions.

Proposed Answer: d.

Explanation
(Optional):

- CORRECT:** Per Emergency Procedure Guidelines (EPGs), Evaporative cooling results when the sprayed water droplets flash to steam; absorbing the latent heat of vaporization from the surrounding atmosphere. This process can result in a relatively large drop in Drywell pressure and may occur at a rate faster than can be compensated for by operator action. Alternatively, Convective cooling results when the sprayed water droplets absorb sensible heat from the surrounding atmosphere resulting in a pressure/temperature reduction until equilibrium conditions are established. This process occurs at a rate much slower than evaporative cooling and can be controlled by terminating sprays.
- Incorrect:** See above. The operation of four Drywell Unit Cooler Fans is strictly prohibited, except for short periods to alternate fans, by OP-53 Precautions. Additionally, during a DBA LOCA, all Drywell Fans would trip on high vibration.
- Incorrect:** See above. Also, Unit Coolers do not provide evaporative cooling.
- Incorrect:** See above. Reverses effectiveness of "Convective" versus "Evaporative" cooling effect.

Technical Reference(s): EPGs (Attach if not previously provided)
EOP-4

Proposed references to be provided to applicants during examination: None

Learning Objective: MIT-301.11E, EO 4.05 (As available)

Question Source: Bank # [Redacted] Modified Bank # [Redacted] (Note changes or attach parent)

New X

Question History: Last NRC Exam [Redacted]

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 5) 295038 High Off-Site Release Rate EK2.03
Knowledge of the interrelations between HIGH OFF-SITE RELEASE RATE and the following:

- Plant ventilation systems

Level	RO	SRO
Tier #	1	-----
Group #	1	-----
K/A #	295038 EK2.03	
Importance Rating	3.6	-----

Proposed Question: # 94

A Loss of Coolant Accident (LOCA) has occurred. The following conditions are present:

- Reactor Building Ventilation.....ISOLATED
- Reactor Building Ventilation Exhaust Radiation..... 1×10^5 cpm
- "A" Standby Gas Train.....OPERATING
- Reactor Building to Atmosphere Differential Pressure.....negative (-)1.1 inches water
- Turbine Building VentilationISOLATED
- Turbine Building Exhaust Radiation..... 3×10^4 cpm
- Offsite ReleaseAbove the ALERT Level

As directed by the EOPs, re-establish the...

- a. Turbine Building Ventilation to filter the ventilation exhaust from the turbine building.
- b. Reactor Building Ventilation to prevent an unmonitored ground level release of radioactivity.
- c. Turbine Building Ventilation to prevent an unmonitored ground level release of radioactivity.**
- d. Reactor Building Ventilation to reduce the reactor building area and equipment temperatures.

Proposed Answer: c.

Explanation
(Optional):

- c. **CORRECT** – The turbine building is not a leak tight building. Restarting the turbine building vent will result in monitored ground releases vice unmonitored ground releases for any radioactivity in the building.
- a. Incorrect – There is no filtration on turbine building exhaust.
- b. Incorrect – EOP-4 states that if reactor building exhaust radiation is greater than 1×10^4 cpm, then isolate reactor building vents.
- d. Incorrect – EOP-4 states that if reactor building exhaust radiation is greater than 1×10^4 cpm, then isolate reactor building vents.

Technical Reference(s): EOP-6 EPG (Attach if not previously provided)
EOP-4

Proposed references to be provided to applicants during examination: EOP-5/6

Learning Objective: MIT-301.11G, EO 6.04 (As available)

Question Source: Bank # 21340
Modified Bank # [Redacted]
New [Redacted] (Note changes or attach parent)

Question History: Last NRC Exam LOI-01-01 (11/5/01)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 14) 239002 SRVs K5.05

Knowledge of the operational implications of the following concepts as they apply to RELIEF/SAFETY VALVES:

- Discharge line quencher operation

Level	RO	SRO
Tier #	2	-----
Group #	1	-----
K/A #	239002 K5.05	-----
Importance Rating	2.6	-----

Proposed Question: # 95

While experiencing Torus water level control problems, an operator opens a Safety Relief Valve (SRV) with Torus water level at 5.2 ft.

Opening the SRV under these conditions will result in...

- drawing water up into the SRV Tailpipe.
- direct Suppression Chamber pressurization.
- A HPCI Isolation on high exhaust backpressure.
- excessive hydrodynamic loading on the SRV Tailpipe.

Proposed Answer: b.

Explanation
(Optional):

- CORRECT** – EOP EPG Bases indicates that SRV Tailpipe T-Quenchers become uncovered at 5.5 feet and discuss the resulting direct Torus pressurization. Tech Spec Bases 3.6.2.2 mirror this discussion.
- Incorrect – associated with failure of vacuum breaker(s).
- Incorrect – check valves in the exhaust discharge to the Torus would prevent backflow of sufficient magnitude to cause bursting of a rupture disc and subsequent HPCI isolation logic actuation.
- Incorrect – associated with Torus water level too **high**, versus low.

Technical Reference(s): EOP-2/3, and EPG Bases (Attach if not previously provided)
TS Bases 3.6.2.2

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-16A, EO 1.05.a.7.e, 1.09.f, & 1.10.c (As available)

Question Source: Bank # 25614
Modified Bank # [Redacted] (Note changes or attach parent)
New [Redacted]

Question History: Last NRC Exam LOI-03-01 (7/1/03)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 17) 400000 Component Cooling Water K4.01

Knowledge of CCWS design feature(s) and/or interlocks which provide for the following:

- Automatic start of the standby pump

Level

RO

SRO

Tier #

2

Group #

1

K/A #

400000 K4.01

Importance Rating

3.4

Proposed Question: # 96

The Service Water System is in a normal lineup with 46P-1A and 46P-1C running and 46P-1B in standby. Alarm 09-6-2-3 "SERV WTR PMP 46P-1A OVERLOAD OR TRIP" annunciates. The lowest NSW header pressure was 85 psig.

Which of the following is expected?

- Service Water Pump 46P-1B has auto-started on the trip of 46P-1A
- Service Water Pump 46P-1B must be manually started at 09-6 Panel
- Manually scram the reactor and manually trip both Recirculation Pumps
- Service Water Pump 46P-1B has auto-started on low NSW header pressure

Proposed Answer: a.

Explanation
(Optional):

- CORRECT:** Per ARP 09-6-2-3, if 46P-1A trips, the standby pump will start. With 46P-1B in standby, it will auto-start on trip of 46P-1A.
- Incorrect:** Per ARP 09-6-2-3, if 46P-1A trips, the standby pump will start **automatically**. With 46P-1B in standby, it will **auto-start** on trip of 46P-1A.
- Incorrect:** The scram and tripping of the Recirc pumps is a Prompt Action of AOP-10, "Loss of Service Water" during a **complete** loss of Service Water. The stem conditions do not support a **complete** loss.
- Incorrect:** Per ARP 09-6-2-3, if Service Water header pressure lowers to less than **75** psig, the standby pump will start. Stem conditions indicate that the lowest resultant pressure is **85** psig (which is the auto-start for TBCLC versus NSW).

Technical Reference(s): OP-42, AOP-10 (Attach if not previously provided)
ARP 09-6-2-3

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-46A, EO 1.05.c.2 & 1.14.a/b.1 (As available)

Question Source:

Bank #	
Modified Bank #	
New	X

 (Note changes or attach parent)

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level:

Memory or Fundamental Knowledge	<input type="checkbox"/>
Comprehension or Analysis	<input checked="" type="checkbox"/>

10 CFR Part 55 Content:

55.41	<input checked="" type="checkbox"/>
55.43	<input type="checkbox"/>

Comments:

Examination Outline Cross-reference:

(Page 13) 218000 ADS A4.02

Ability to manually operate and/or monitor in the control room:

- ADS logic initiation

Level

RO

SRO

Tier #

2

Group #

1

K/A #

218000 A4.02

Importance Rating

4.2

Proposed Question: # 97

A small break LOCA has occurred and no operator action has been taken. HPCI is out of service, RCIC is injecting into the reactor vessel and all low pressure ECCS pumps have started from High Drywell Pressure except the "B" Core Spray Pump which failed to automatically start.

- At Time 0: Reactor water level was 177 inches
- Currently (Time 0 plus one hundred (100) seconds): Reactor water level is 75 inches and dropping.

Which statement correctly describes the operation of the Automatic Depressurization System (ADS)?

- All 7 ADS valves will open as soon as an additional 34 seconds have elapsed
- All 7 ADS valves will open 134 seconds after reactor water level drops to 59.5 inches
- All 7 ADS valves will open 134 seconds after the "B" Core Spray Pump is manually started
- All 7 ADS valves will open immediately after the "B" Core Spray Pump is manually started

Proposed Answer: **b.**Explanation
(Optional):

- CORRECT** – Explanation: The following conditions are required for ADS to automatically open 7 valves. Any low pressure ECCS pump running, reactor low 177 and low-low level 59.5 after 134 second timer times out.
- Incorrect – Have not reached the triple-low setpoint for timer initiation as of the current time.
- Incorrect – Criteria is **any** low-pressure ECCS Pump running, which has already been met, but still have not reached the triple-low setpoint for timer initiation as of the current time.
- Incorrect – See above.

Technical Reference(s): ARP 09-4-1-28 (Attach if not previously provided)
TS Table 3.3.5.1-1

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-02J, EO 1.05.c.1, 1.10.b, & 1.14.c (As available)

Question Source: Bank # 21344
Modified Bank # (Note changes or attach parent)
New

Question History: Last NRC Exam LOI-01-01 (11/5/01)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
Comprehension or Analysis

10 CFR Part 55 Content: 55.41
55.43

Comments:

Examination Outline Cross-reference:

(Page 4) 295026 Suppression Pool High Water Temp. / 5 EA2.01Ability to determine and/or interpret the following as they apply to
SUPPRESSION POOL HIGH WATER TEMPERATURE:

- Suppression pool water temperature

(10CFR 55.43.5)

Level

RO

SRO

Tier #

1

Group #

1

K/A #

295026 EA 2.01

Importance Rating

4.2

Proposed Question: # 98

During extended HPCI surveillance testing, annunciator 09-3-1-14, TORUS BULK TEMP HI OR RTD FAILURE, is received and temperature is confirmed to be slowly rising with panel indications. All other plant systems are functioning normally.

Which of the below describes the expected operator action?

- Enter EOP-4, Primary Containment Control. Then, exit based upon a determination that an emergency does not exist.
- Enter EOP-4 and Start Torus Cooling. EOP-4 may not be exited until the 09-3-1-14 annunciator clears.
- EOP-4 entry is not required when the annunciator results from surveillance testing.
- An EOP-4 entry condition does not exist, no action is required.

Proposed Answer: a.

Explanation
(Optional):

- CORRECT:** The annunciator setpoint is 95° and is confirmed with panel indication. This is an EOP-4 entry condition. EP-1, EOP Entry and Use, step 4.2.1 directs that EOP's be entered if an entry condition exists and may be exited if it is determined that an emergency no longer exists.
- Incorrect:** EOP-4 entry is correct. Per the surveillance procedure torus cooling is already in service. As described above, EOP-4 may be exited upon determination that an emergency does not exist
- Incorrect:** EP-1 requires entry.
- Incorrect:** The high torus water temperature entry condition does exist.

Technical Reference(s): EP-1 (Attach if not previously provided)
ARP-09-3-1-14

Proposed references to be provided to applicants during examination: None

Learning Objective: MIT-301.11A EO 1.03f
MIT-301.11E EO4.02

Question Source: Bank # 8797 (Note changes or attach parent)

Modified Bank #	
New	
Last NRC Exam	

Question History:

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge

Comprehension or Analysis

10 CFR Part 55 Content: 55.41

55.43

Comments:

Examination Outline Cross-reference:

(Page 7) 295010 High Drywell Pressure AA1.02Ability to operate and/or monitor the following as they apply to
HIGH DRYWELL PRESSURE:

- Drywell floor and equipment drain sumps

Level

RO

SRO

Tier #

1

Group #

2

K/A #

295010 AA1.02

Importance Rating

3.6

Proposed Question: # 99

The plant is operating at 90% power during a startup, when the following occurs:

At Time 0. Annunciator 09-4-2-23 "RX VESSEL FLANGE SEAL LEAKAGE" alarms.*At Plus Three (3) Minutes:*

- CRS notices that Drywell Pressure is 2.6 psig and steadily rising, and
- SNO reports Drywell Floor Drain Sump (FDS) Pump 20P-1B running on a steady, high FDS level

At Plus Eight (8) Minutes:

- SNO reports receipt of annunciator 09-4-1-10 "DW FLOOR SUMP HI-HI OR LO-LO" with neither FDS Pump running, and
- SNO observes Drywell Equipment Drain Sump (EDS) Pump 20P-5A running with EDS level trending up slowly.

Which of the following events is the probable cause of the final operating configuration?

- The "Alpha" Floor Drain Pump has failed to auto-start on its alternating cycle with "Bravo", and now the FDS overflow to the EDS is exceeding the capacity of the running Equipment Drain Pump.
- A High Drywell Pressure PCIS Group 2 isolation was generated, but only the "Bravo" side isolation actually occurred, and now the Equipment Drain Pump is running at shut-off head.
- A High Drywell Pressure PCIS Group 2 isolation was generated, and a successful isolation resulted in the trip of both Floor Drain Pumps and NO trip of the Equipment Drain Pump.
- The "Bravo" Floor Drain Pump has tripped and a logic failure of the associated Drywell Floor Drain Sump Fill Timer has failed to auto-start the "Alpha" Floor Drain Pump.

Proposed Answer: c.

Explanation
(Optional):

- CORRECT:** Stem conditions of fairly rapid and significant rise in Drywell pressure; still climbing. A PCIS Group 2 Isolation, at 2.7 psig, would auto-close both sump's inboard & outboard isolation valves. On the FDS, either valve closure trips the pump(s). On the EDS, there are no pump trips on valve closure, as the valve cycles versus the pump (always running on recirc).
- Incorrect:** See above. Pumps do alternate, but not in this manner and FDS would not overflow to EDS.

- b. Incorrect: See above. Signal generation correct, each sump has an isolation valve on A and B PCIS, EDS Pump on recirc.
- d. Incorrect: See above. No pump auto-start logic associated with Fill Timer whatsoever – level alarms only.

Technical Reference(s): OP-50 (Attach if not previously provided)
AOP-15 / ARP-09-4-2-23

Proposed references to be provided to applicants during examination: None

Learning Objective: SDLP-16C, EO 1.09.c (As available)
SDLP-20D, EO 1.05.c.1

Question Source:

Bank #	
Modified Bank #	23829 (attached)
New	
Last NRC Exam	

 (Note changes or attach parent)

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: Memory or Fundamental Knowledge
 Comprehension or Analysis

10 CFR Part 55 Content: 55.41
 55.43

Comments:

PLANT
Susquehanna 1

ExamDate
8/1/2002

ExamType
ILO

QuestionId
29529

NSSS Type
BWR

Question A scram has occurred on Unit 1 with drywell pressure above the trip setpoint due to a small leak in the containment. An operator is directed to pump down the Drywell floor drain sump for sampling to determine the leak source. The following events are observed during the evolution:

"Drywell Floor Drain pump (1P402A) control switch was taken to RUN
"Inboard (HV-16108A1) and Outboard (HV-16108A2) Drywell floor drain sump isolation valves were noted to be closed
"Drywell Floor Drain pump tripped after 45 seconds

Which one of the following describes the response of the system under these conditions?

Answer Response was as expected, isolation valves did not auto open due to a high drywell pressure signal.

Distractor 1 Response was unexpected, isolation valves should have been open due to a high drywell pressure signal.

Distractor 2 Response was as expected, isolation valves must be opened manually prior to starting sump pump.

Distractor 3 Response was unexpected, isolation valves should have auto opened after pump start.

RefMaterial

QuestionComment d. correct - >1.72 psig isolates valves preventing pump operation for >45 sec. From start signal

Distract1Comment a. incorrect - valves will not auto open with isolation signal in

- b. incorrect - valves are normally closed and will not auto open with isolation signal in
- c. incorrect - valve auto open if isolation signal is not in

Distract3Comment a. incorrect - valves will not auto open with isolation signal in

- b. incorrect - valves are normally closed and will not auto open with isolation signal in
- c. incorrect - valve auto open if isolation signal is not in

Distract3Comment a. incorrect - valves will not auto open with isolation signal in

- b. incorrect - valves are normally closed and will not auto open with isolation signal in
- c. incorrect - valve auto open if isolation signal is not in

<i>KaNumber</i>	<i>KaSegment1</i>	<i>KaSegment2</i>	<i>KaSegment3</i>	<i>KaSegment4</i>	<i>KaSegment5</i>
295010 AA1 02			295010	AA1	02
<i>KaRevision</i>				<i>CognitiveLevel</i>	<i>ExamLevel</i>
				2	R

Examination Outline Cross-reference:

(Page 23) G2.4.2

Knowledge of system setpoints / interlocks and automatic actions associated with EOP entry conditions.

Level	RO	SRO
Tier #	3	-----
Group #	-----	-----
K/A #	Cat 4 G2.4.2	
Importance Rating	3.9	-----

Proposed Question: # 100

A single plant parameter trend has resulted in a transient in which all systems responded as expected. You observe that HPCI has initiated. RCIC remains in standby. Your SNO reports that Reactor Building Ventilation has isolated.

As a result of this information you.....

- enter EOP-2, RPV Control only.
- enter EOP-2, RPV Control, and EOP-4, Primary Containment Control.
- enter EOP-5, Secondary Containment Control only.
- enter EOP-2, RPV Control, and EOP-5, Secondary Containment Control.

Proposed Answer: b.

Explanation
(Optional):

- CORRECT:** HPCI initiated with RCIC in standby can only result from High Drywell Pressure. High Drywell pressure requires entry into EOP-2 and 4.
- Incorrect: See above. A low RPV Water Level will result in both HPCI and RCIC initiation and is only an EOP-2 entry.
- Incorrect: RBV isolates on high drywell pressure but this is not an EOP-5 entry condition. EOP-5 is entered on RBV isolation on high radiation yet this does not result in a HPCI start.
- Incorrect: See Above. There is no single parameter that will result in both EOP-2 and EOP-5 entry.

Technical Reference(s): EOP-2, 4 and 5 (Attach if not previously provided)
AP-12.03, Step 8.9.3.I

Proposed references to be provided to applicants during examination: None

Learning Objective: MIT-301.11C EO-1.02, MIT-301.11 EO-4.02

Question Source:

Bank #	
Modified Bank #	

 (Note changes or attach parent)

New

Question History:

Last NRC Exam	
---------------	--

(Optional - Questions validated at the facility since 10/95 will generally undergo less rigorous review by the NRC; failure to provide the information will necessitate a detailed review of every question.)

Question Cognitive Level: **Memory or Fundamental Knowledge**

Comprehension or Analysis

10 CFR Part 55 Content: **55.41**

55.43

Comments: